

Docket Nos.: 50-445
and 50-446

SEP 20 1984

Mr. M. D. Spence
President
Texas Utilities Generating Company
400 N. Olive Street
Lock Box 81
Dallas, Texas 75201

Dear Mr. Spence:

Subject: Request for Additional Information Pertaining to the Safe
Shutdown and Alternate Safe Shutdown of the Comanche Peak
Steam Electric Station (Units 1 and 2)

The enclosed additional information is required by the staff in order to complete its review of a recent revision to the fire hazards analysis document, submitted by TUGCO letter dated August 16, 1984. The questions were discussed informally with your staff during the week of September 10, 1984. This letter serves to formally document the staff's request.

We understand that your staff is in the process of preparing a response to the enclosed questions and that we should be receiving their responses the week of September 24, 1984. Responses should be identified as noted in the enclosure for eventual documentation in the Comanche Peak FSAR.

Sincerely,

LS
B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

Enclosure:
As stated

cc: See next page

CONCURRENCES:
DL:LB#1 DL:LB#1
JStefano:es BJYoungblood
9/18/84 9/18/84

DIST:

Docket File	JStefano	P. Hearn, ASB/DSI
NRC PDR	O.D. Attorney	A. Singh, ASB/DSI
Local PDR	ACRS (16)	V. Benaroya, CHEB/DE
PRC System	EJordan	J. Stang, CHEB/DE
NSIC	NGrace	R. Ferguson, CHEB/DE
LB#1 Rdg	O. D. Parr, ASP/DSI	T. Ippolito
MRushbrook	J. S. Wermiel, ASB/DSI	S. Burwell

8409280513 840920
PDR ADDCK 05000445
F PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SEP 20 1984

Docket Nos.: 50-445
and 50-446

Mr. M. D. Spence
President
Texas Utilities Generating Company
400 N. Olive Street
Lock Box 81
Dallas, Texas 75201


Dear Mr. Spence:

Subject: Request for Additional Information Pertaining to the Safe
Shutdown and Alternate Safe Shutdown of the Comanche Peak
Steam Electric Station (Units 1 and 2)

The enclosed additional information is required by the staff in order to complete its review of a recent revision to the fire hazards analysis document, submitted by TUGCO letter dated August 16, 1984. The questions were discussed informally with your staff during the week of September 10, 1984. This letter serves to formally document the staff's request.

We understand that your staff is in the process of preparing a response to the enclosed questions and that we should be receiving their responses the week of September 24, 1984. Responses should be identified as noted in the enclosure for eventual documentation in the Comanche Peak FSAR.

Sincerely,


B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

Enclosure:
As stated

cc: See next page

COMANCHE PEAK

Mr. M. D. Spence
President
Texas Utilities Generating Company
400 N. Olive St., L.B. 81
Dallas, Texas 75201

cc: Nicholas S. Reynolds, Esq.
Bishop, Liberman, Cook,
Purcell & Reynolds
1200 Seventeenth Street, N. W.
Washington, D. C. 20036

Robert A. Wooldridge, Esq.
Worsham, Forsythe, Sampels &
Wooldridge
2001 Bryan Tower, Suite 2500
Dallas, Texas 75201

Mr. Homer C. Schmidt
Manager - Nuclear Services
Texas Utilities Generating Company
Skyway Tower
400 North Olive Street
L. B. 81
Dallas, Texas 75201

Mr. H. R. Rock
Gibbs and Hill, Inc.
393 Seventh Avenue
New York, New York 10001

Mr. A. T. Parker
Westinghouse Electric Corporation
P. O. Box 355
Pittsburgh, Pennsylvania 15230

Renea Hicks, Esq.
Assistant Attorney General
Environmental Protection Division
P. O. Box 12548, Capitol Station
Austin, Texas 78711

Mrs. Juanita Ellis, President
Citizens Association for Sound
Energy
1426 South Polk
Dallas, Texas 75224

Ms. Nancy H. Williams
CYGNA
101 California Street
San Francisco, California 94111

Mr. James E. Cummins
Resident Inspector/Comanche Peak
Nuclear Power Station
c/o U. S. Nuclear Regulatory
Commission
P. O. Box 38
Glen Rose, Texas 76043

Mr. John T. Collins
U. S. NRC, Region IV
611 Ryan Plaza Drive
Suite 1000
Arlington, Texas 76011

Mr. Lanny Alan Sinkir
114 W. 7th, Suite 220
Austin, Texas 78701

B. R. Clements
Vice President Nuclear
Texas Utilities Generating Company
Skyway Tower
400 North Olive Street
L. B. 81
Dallas, Texas 75201

William A. Burchette, Esq.
1200 New Hampshire Avenue, N. W.
Suite 420
Washington, D. C. 20036

Ms. Billie Pirner Garde
Citizens Clinic Director
Government Accountability Project
1901 Que Street, N. W.
Washington, D. C. 20009

David R. Pigott, Esq.
Orrick, Herrington & Sutcliffe
600 Montgomery Street
San Francisco, California 94111

Anthony Z. Roisman, Esq.
Trial Lawyers for Public Justice
2000 P. Street, N. W.
Suite 611
Washington, D. C. 20036

AUXILIARY SYSTEMS BRANCH
REQUEST FOR ADDITIONAL INFORMATION
COMANCHE PEAK NUCLEAR PLANT, UNITS 1 AND 2

Question 010.24 A recent plant inspection at another facility revealed that in order for some systems necessary for hot shutdown to be isolated from control room fire damage and maintain operability without fuse replacement, isolation must take place prior to fire damage. Although the present isolation switches at Comanche Peak do isolate the required equipment or components from the control room, it has not been demonstrated that it is unnecessary to replace fuses in order to place the equipment/component in the desired mode of operation or position. In order for the staff to conduct a review to determine if fuse replacement is necessary for the operation of safety systems after a control room fire, provide a description including schemation drawings of the different isolation switch designs used at Comanche Peak. If the Comanche Peak design necessitates the changing of fuses to achieve and maintain hot shutdown after a control room fire, modify your design to eliminate the need for fuse replacement and provide a description of the design modifications.

Question 010.25 Provide the details of your proposed design to demonstrate that you satisfy the criteria of Section C.5.b and C.5.c of Branch Technical Positions CMEB 9.5.1. In your response, provide the following information: (9.5.1)

- a. Describe the methodology used to verify that proper separation is provided for the safe shutdown capability in accordance with the requirements of C.5.b of Branch Technical Position CMEB 9.5.1. Provide the area arrangement drawings showing the safe shutdown system including the cable routing.
- b. Address the means you will provide for assuring the proper functioning of your safe shutdown capability, assuming fire induced failures in the associated circuits. Attachment 1 provides our concerns with associated circuits. This attachment also provides guidance for reviewing the associated circuits of concern and the additional information we need. Your response should specifically address Part II.C of this attachment.
- c. Confirm that your proposed design will have the capability to achieve cold shutdown conditions within 72 hours and maintain cold shutdown thereafter, as defined in Section III.L of Appendix R to 10 CFR Part 50 and Section C.5.c of Branch Technical Position CMEB 9.5-1, assuming that offsite power is not available.

ATTACHMENT 1

ASSOCIATED CIRCUIT GUIDANCE

1. INTRODUCTION

The following discusses the requirements for protecting redundant and/or alternative equipment needed for safe shutdown in the event of a fire. The requirements of Appendix R address hot shutdown equipment which must be free of fire damage. The following requirements also apply to cold shutdown equipment if the applicant/licensee elects to demonstrate that the equipment is to be free of fire damage. Appendix R does allow repairable damage to cold shutdown equipment.

Using the requirements of Sections III.G and III.L of Appendix R, the capability to achieve hot shutdown must exist given a fire in any area of the plant in conjunction with a loss of offsite power for 72 hours. Section III.G of Appendix R provides four methods for ensuring that the hot shutdown capability is protected from fires. The first three options as defined in Section III.G.2 provides methods for protection from fires of equipment needed for hot shutdown:

1. Redundant systems including cables, equipment, and associated circuits may be separated by a three-hour fire rated barrier; or,
2. Redundant systems including cables, equipment and associated circuits may be separated by a horizontal distance of more than 20 feet with no intervening combustibles. In addition, fire detection and an automatic fire suppression system are required; or,
3. Redundant systems including cables, equipment and associated circuits may be enclosed by a one-hour fire rated barrier. In addition, fire detectors and an automatic fire suppression system are required.

The last option as defined by Section III.G.3 provides an alternative shutdown capability to the redundant trains damaged by a fire.

4. Alternative shutdown equipment must be independent of the cables, equipment and associated circuits of the redundant systems damaged by the fire.

II. Associated Circuits of Concern

The following discussion provides A) a definition of associated circuits for Appendix R consideration, B) the guidelines for protecting the safe shutdown capability from the fire-induced failures of associated circuits and C) the information required by the staff to review associated circuits. It is important to note that our interest is only with those circuits (cables) whose fire-induced failure could affect shutdown. Guidelines for protecting the safe shutdown capability from the fire-induced failures of associated circuits are provided. These guidelines do not limit the alternatives available to the licensee for protecting the shutdown capability. All proposed methods for protection of the shutdown capability from fire-induced failures will be evaluated by the staff for acceptability.

- A. Our concern is that circuits within the fire area will receive fire damage which can affect shutdown capability and thereby prevent post-fire safe shutdown. Associated Circuits* of Concern are defined as those ^{*The definition} for associated circuits, is not exactly the same as the definition presented in IEEE-384-1977.

cables (safety related, non-safety related Class 1E, and non-Class 1E) that:

1. Have a physical separation less than that required by Section III.G.2 of Appendix R, and;
2. Have one of the following:
 - a. a common power source with the shutdown equipment (redundant or alternative) and the power source is not electrically protected from the circuit of concern by coordinated breakers, fuses, or similar devices (see diagram 2a), or
 - b. a connection to circuits of equipment whose spurious operation would adversely affect the shutdown capability (e.g., RHR/RCS isolation valves, ADS valves, PORVs, steam generator atmospheric dump valves, instrumentation, steam bypass, etc.) (see diagram 2b), or
 - c. a common enclosure (e.g., raceway, panel, junction) with the shutdown cables (redundant and alternative) and,
 - (1) are not electrically protected by circuit breakers, fuses or similar devices, or
 - (2) will allow propagation of the fire into the common enclosure (see diagram 2c).

EXAMPLES OF ASSOCIATED CIRCUITS OF CONCERN




Diagram 2A




Diagram 2B

Equipment whose spurious operation could affect Shutdown




Diagram 2C

The area barriers shown above meet the appropriate sub-paragraphs (a-f) of section III.G-2 of Appendix R.

B. The following guidelines are for protecting the shutdown capability from fire induced failures of circuits (cables) in the fire area. The shutdown capability may be protected from the adverse effect of damage to associated circuits of concern by the following methods:

1. Provide protection between the associated circuits of concern and the shutdown circuits as per Section III.6.2 of Appendix R, or

2. a. For a common power source case of associated circuits:

Provide load fuse/breaker (interrupting devices) to feeder with fuse/breaker coordination to prevent loss of the redundant or alternative shutdown power source. To ensure that the coordination criteria are met the following should apply:

(1) The associated circuits of concern interrupting devices (breakers or fuses) time-overcurrent trip characteristic for all circuit faults should cause the interrupting device to interrupt the fault current prior to initiation of a trip of any upstream interrupting device which will cause a loss of the common power source.

(2) The power source shall supply the necessary fault current for sufficient time to ensure the proper interruption without loss of function of the shutdown loads.

The acceptability of a particular interrupting device is considered demonstrated if the following criteria are met:

- (i) The interrupting device design shall be factory tested to verify overcurrent protection as designed in accordance with the applicable UL, ANSI, or NEMA standards.
 - (ii) For low and medium voltage switchgear (480 V and above) circuit breaker/protective relay periodic testing shall demonstrate that the overall coordination scheme remains within the limits specified in the design criteria. This testing may be performed as a series of overlapping tests.
 - (iii) Molded case circuit breakers shall periodically be manually exercised and inspected to insure ease of operation. On a rotating refueling outage basis a sample of these breakers shall be tested to determine that breaker drift is within that allowed by the design criteria. Breakers should be tested in accordance with an accepted QC testing methodology such as MIL STD 10 5 D.
 - (iv) Fuses when used as interrupting devices do not require periodic testing. Administrative controls must insure that replacement fuses with ratings other than those selected for proper coordination are not accidentally used.
- b. For circuits of equipment and/or components whose spurious operation would affect the capability to safely shutdown:

- (1) provide a means to isolate the equipment and/or components from the fire area prior to the fire (i.e., remove power cables open circuit breakers); or
 - (2) provide electrical isolation that prevents spurious operation. Potential isolation devices include breakers, fuses, amplifiers, control switches, current XFRS, fiber optic couplers, relays and transducers; or
 - (3) provide a means to detect spurious operations and then procedures to defeat the maloperation of equipment (i.e., closure of the block valve if PORV spuriously operates, opening of the breakers to stop spurious operation of safety injection);
- c. For common enclosure cases of associated circuits:
- (1) provide appropriate measures to prevent propagation of the fire and
 - (2) provide electrical protection (i.e., breakers, fuses or similar devices)

c. INFORMATION REQUIRED

The following information is required to demonstrate that associated circuits will not prevent operation or cause maloperation of the shutdown method:

- a. Describe the methodology used to assess the potential of associated circuits adversely affecting the shutdown capability. The description of the methodology should include the methods used to identify the

circuits which share a common power supply or a common enclosure with the shutdown system and the circuits whose spurious operation would affect shutdown. Additionally, the description should include the methods used to identify if these circuits are associated circuits of concern due to their location in the fire area.

- b. Show that fire-induced failures (hot shorts, open circuits or shorts to ground) of each of the associated circuits of concern will not prevent operation or cause maloperation of the shutdown method.
2. The residual heat removal system is generally a low pressure system that interfaces with the high pressure primary coolant system. To preclude a LOCA through this interface, we require compliance with the recommendations of Branch Technical Position RSB 5-1. Thus, the interface most likely consists of two redundant and independent motor operated valves. These two motor operated valves and their associated cables may be subject to a single fire hazard. It is our concern that this single fire could cause the two valves to open resulting in a fire initiated LOCA through the high-low pressure system interface. To assure that this interface and other high-low pressure interfaces are adequately protected from the effects of a single fire, we require the following information:
 - a. Identify each high-low pressure interface that uses redundant electrically controlled devices (such as two series motor operated valves) to isolate or preclude rupture of any primary coolant.
 - b. For each set of redundant valves identified in a., verify the redundant cabling (power and control) have adequate physical separation as required by Section III.G.2 of Appendix R.

- c. For each case where adequate separation is not provided show that
- fire induced failures (hot short, open circuits or short to ground)
 - of the cables will not cause maloperation and result in a LOCA.