

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) LaSalle County Station Unit 2	DOCKET NUMBER (2) 0 5 0 0 0 3 7 4	PAGE (3) 1 OF 02
--	--------------------------------------	---------------------

TITLE (4)
Reactor Water Cleanup High Ambient Temperature Isolation

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAME		DOCKET NUMBER (8)
08	23	84	84	051	00	09	13	84			0 5 0 0 0
THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)											

OPERATING MODE (9) 4	POWER LEVEL (10) 0.00	20.402(b)	20.408(a)	<input checked="" type="checkbox"/>	80.73(a)(2)(iv)	73.71(b)
		20.408(a)(1)(U)	80.35(a)(1)		80.73(a)(2)(v)	73.71(a)
		20.408(a)(1)(R)	80.36(a)(2)		80.73(a)(2)(vii)	OTHER (Specify in Abstract below and in Text, NRC Form 385A)
		20.408(a)(1)(H)	80.73(a)(2)(i)		80.73(a)(2)(viii)(A)	
		20.408(a)(1)(N)	80.73(a)(2)(ii)		80.73(a)(2)(viii)(B)	
		20.408(a)(1)(W)	80.73(a)(2)(iii)		80.73(a)(2)(ix)	

LICENSEE CONTACT FOR THIS LER (17)

NAME Kermit C. Wittenburg, extension 772	TELEPHONE NUMBER 8 1 5 3 5 7 1 - 6 7 1 6 1
---	---

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS
X	JM	TIS	R281	N					

SUPPLEMENTAL REPORT EXPECTED (14)

<input checked="" type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)	<input type="checkbox"/> NO	EXPECTED SUBMISSION DATE (15)
		1 2 0 1 8 4

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (18)

On August 23, 1984 at 0944 hours with Unit 2 in Cold Shutdown, the Reactor Water Cleanup (RWC) Inboard Isolation valve 2G33-F001 closed and the Reactor Water Cleanup pumps tripped. The Control Room panel alarms indicated that the system had isolated on a spurious high ambient temperature from the Riley Leak Detection Isolation system. After verifying that no abnormal condition existed the RWC system was restarted.

8410020029 840913
PDR ADOCK 05000374
S PDR

IE2 a
11

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1): LaSalle County Station Unit 2	DOCKET NUMBER (2) 0 5 0 0 0 3 7 4	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		84	051	00	02	OF 02

TEXT (if more space is required, use additional NRC Form 305A's) (17)

I. EVENT DESCRIPTION

On August 23, 1984, at 0944 hours, with Unit 2 in Cold Shutdown, the Reactor Water Cleanup (CE) Inboard Isolation valve 2G33-F001 closed and the Reactor Water Cleanup pumps tripped. The Control Room panel alarms indicated that the system had isolated on a spurious high ambient temperature from the Riley Leak Detection Isolation system (JM).

II. CAUSE

The exact cause of the spurious trip is not known. No significant plant changes were occurring at the time of the event.

III. PROBABLE CONSEQUENCES OF THE OCCURRENCE

The system was placed in a safe condition by the isolation signal. No abnormal temperatures or leaks were found in the various RWCU equipment areas. The health and safety of plant and public personnel were maintained at all times.

IV. CORRECTIVE ACTION

Upon determining that no abnormal conditions existed in the RWCU areas, the system was restarted. Members of the Technical Staff are investigating potentially related spurious isolations of the RWCU system from the Leak Detection system. The results of this action are being tracked by AIR 01-84-67089.

V. PREVIOUS OCCURRENCES

This exact event has occurred previously as documented in LER's 374/84-028-00 and 84-046-00. Similar events were described in LER's 84-016-00, 84-023-00, 84-026-00, 84-031-00, 84-32-00 (050-374) and LER 84-028-00 (050-373).

VI. NAME AND TELEPHONE NUMBER OF PREPARER

Kermit C. Wittenburg, 817/357-6761, extension 772.




Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

September 13, 1984

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Dear Sir:

Reportable Occurrence Report #84-051-00, Docket #050-374 is being submitted to your office in accordance with 10CFR 50.73


G. J. Diederich
Superintendent
LaSalle County Station

GJD/MLD/kg

Enclosure

xc: NRC, Regional Director
INPO - Records Center
File/NRC

IE22
/1