

~~SAFEGUARDS INFORMATION~~

Iowa Electric Light and Power
Company

2

SEP 26 1984

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

W. L. Axelson, Chief
Nuclear Materials Safety and
Safeguards Branch

Enclosure: Inspection Report
No. 50-331/84-13(DRSS)
(UNCLASSIFIED SAFEGUARDS INFORMATION)

cc w/encl:
D. Mineck, Plant Superintendent
Nuclear
IE File
IE/DQASIP/ORPB
IE/ES
NMSS/SGPL
NRR/DL/SSPB
ACRS

cc w/encl, w/o UNCLASSIFIED
SAFEGUARDS INFORMATION:
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
Thomas Houvenagle, Iowa
Commerce Commission

Enclosure contains
SAFEGUARDS INFORMATION
Upon separation this
page is Decontrolled

8410020238 840926
PDR ADOCK 05000331
Q PDR

RIII

Te/jp
09/25/84

RIII

Meed

RIII

Boyd

RIII

Axelson

~~SAFEGUARDS INFORMATION~~

U. S. NUCLEAR REGULATORY COMMISSION

REGION III

Report No. 50-331/84-13(DRSS)

Docket No. 50-331

License No. DPR-49

Safeguards Group IV

Licensee: Iowa Electric Light and Power Company
P. O. Box 351
Cedar Rapids, IA 52406

Facility Name: Duane Arnold Energy Center

Inspection At: Duane Arnold Energy Center, Palo, IA

Inspection Conducted: September 4-6, 1984

Type of Inspection: Announced Special Physical Security

Date of Last Physical Security Inspection: May 7-10, 1984

Inspector:

J. R. Creed
G. L. Pirtle
Physical Security Inspection

9/26/84
Date

Approved By:

J. R. Creed
J. R. Creed, Chief
Physical Security Section

9/26/84
Date

Inspection Summary

Inspection on September 4-6, 1984 (Report No. 50-331/84-13(DRSS))

Areas Inspected: Included a review of the licensee's Physical Security Event Reporting Program (10 CFR 73.71(c)). The inspection involved a total of 13 inspector-hours by one NRC inspector. One of the 13 inspector-hours was conducted during back-shift periods. The inspection began during the day shift.

Results: The licensee was found to be in compliance within the areas examined. Two unresolved items were identified. One issue pertained to compensatory measures for partial degradation of Protected Area lighting the other item pertained to false/nuisance alarm criteria for the perimeter intrusion detection system. The unresolved items will be sent to NRC, HQ for resolution.

(Details: UNCLASSIFIED SAFEGUARDS INFORMATION)

Enclosure contains
SAFEGUARDS INFORMATION
Upon separation this
page is Decontrolled