

Arizona Public Service Company

September 17, 1984
ANPP-30536-TDS/TRB

U. S. Nuclear Regulatory Commission
Region V
Creekside Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, CA 94596-5368

Attention: Mr. T. W. Bishop, Director
Division of Resident
Reactor Projects and Engineering Programs

Subject: Interim Report - DER 84-55
A 50.55(e) Potentially Reportable Deficiency Relating To
Unqualified Foxboro Modules.
File: 84-019-026; D.4.33.2

Reference: Telephone Conversation between P. Narbut and T. Bradish on
August 17, 1984

Dear Sir:

The NRC was notified of a potentially reportable deficiency in the referenced telephone conversation. At that time, it was estimated that a determination of reportability would be made within thirty (30) days.

Due to the extensive investigation and evaluation required, an Interim Report is attached. It is now expected that this information will be finalized by October 19, 1984, at which time a complete report will be submitted.

Very truly yours,

E. E. Van Brunt ASK

E. E. Van Brunt, Jr.
APS Vice President
Nuclear Production
ANPP Project Director

EEVB/TRB/nj
Attachment

cc: See Page Two

REGION V ISE

1984 SEP 20 AM 10:56

RECEIVED
NRC

8410020288 840917
PDR ADOCK 05000528
S PDR

11
IE-27

Mr. T. W. Bishop
DER 84-55
Page Two

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
D. B. Karner
W. E. Ide
D. B. Fasnacht
A. C. Rogers
L. A. Souza
D. E. Fowler
T. D. Shriver
C. N. Russo
J. Vorees
J. R. Bynum
J. M. Allen
J. A. Brand
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
H. D. Foster
D. R. Hawkinson
L. E. Vorderbrueggen
R. P. Zimmerman
S. R. Frost
L. Clyde
M. Woods
T. J. Bloom

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, GA 30339

INTERIM REPORT - DER 84-55
POTENTIAL REPORTABLE DEFICIENCY
ARIZONA PUBLIC SERVICE COMPANY (APS)
PVNGS UNIT 1

I. Potential Problem

NCR SJ-4607

Unqualified Foxboro Modules have been installed in the following QIE instrumentation cabinets: (R Class Material)

<u>Plant Tag No.</u>	<u>Description</u>	<u>PO Spec.</u>
1JSBAC02A	Process Protective Cabinet A1	NM-001
1JSBBC02A	Process Protective Cabinet B1	NM-001
1JSBBC02B	Process Protective Cabinet B2	NM-001
1JSBAC02B	Process Protective Cabinet A2	NM-001
1JSBDC02A	Process Protective Cabinet D	NM-001

NCR SM-4778

- a. In accordance with Combustion Engineering (C-E) serial number list, IEC-84-675, there appears to be four Foxboro modules, serial numbers 3647589, 3647581, 4712336, and 4712337, installed in Unit 2 instead of Unit 1.
- b. A total of six Foxboro modules are installed in Unit 2 which are not on the C-E serial number list.

Note: This condition is similar to that identified in DER 83-73.

II. Approach To and Status Of Proposed Resolution

Bechtel Engineering is currently studying this problem to determine reportability and technical justification for corrective action.

III. Projected Completion of Corrective Action and Submittal of the Final Report

The complete evaluation and final report are forecast to be completed by October 19, 1984.