



Georgia Institute of Technology

SCHOOL OF NUCLEAR ENGINEERING AND HEALTH PHYSICS

ATLANTA, GEORGIA 30332

NEELY NUCLEAR RESEARCH
CENTER

(404) 894-3600

September 26, 1984

Dr. Cecil O. Thomas, Chief
Standardization and Special Projects Branch
Division of Licensing
Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Dr. Thomas:

Re: Document #50-276

On behalf of the Georgia Institute of Technology and in accordance with 10 CFR 50.82(a), I hereby apply for authorization to dismantle the AGN 201 and for eventual termination of License #R-111. As mentioned in my letter to you of May 25, 1984, the continued use of this reactor in the Institute programs is no longer justified, so the decision has been made to decommission and dispose of it.

Pending NRC approval, we plan to remove all components of the reactor which contain special nuclear materials, and to initially store this fuel in the GTRR vault. Ultimately, this fuel will be returned to its owner, the U.S. Department of Energy. The purpose of this letter is to inform NRC of our plan.

Please advise us with regard to whether or not we can store the AGN fuel (~700 g of U-235 contained in $\leq 20\%$ enriched fuel) in the GTRR vault. Our license for the GTRR (License R-97) allows us to receive, possess and use 13.5 kg of contained U-235. However, a letter from Mr. Robert Kirkland, dated September 25, 1979 to NRC, (appended) stipulates that the maximum amount of contained U-235 that can be in unirradiated fuel storage shall be 4.99 kg. Currently we have 4.888 kg of unirradiated U-235 in the GTRR vault. In accordance with 10 CFR 73.60, we interpret that the 700 grams of U-235 in the AGN fuel do not affect the 4.99 kg limit because the enrichment is 20% or less. Please confirm. At any rate we will not do anything in this regard until we receive NRC approval.

8410020400 840926
PDR ADOCK 05000276
P PDR

A020
11

The reactor may still be in operable condition, but has not been operated since 1979. It contains all of the U-235 fuel of the core, and the fueled control rods. All control instrumentation is connected.

Available records show that the AGN-201 was operated at Georgia Tech for a total of 683.75 hours. Assuming that all operations were performed at a power level of 100 milliwatts the total energy generated is 68.4 watt-hours. The total radioactivity of fission products in the fuel is estimated to be 0.03 μ Ci per gram which is about two orders of magnitude less than the natural radioactivity in U-235.


We plan to remove the fuel from the reactor following the procedures outlined in the Dismantling Plan, originally submitted 25 May 1984, and appended to this request, and storing it in our GTRR vault. Ultimately, this fuel will be shipped to ORNL in approved containers and in accordance with NRC and DOT requirements. Mr. William Pryor of ORNL stated to me that approved containers will be sent to us from ORNL. All transportation requirements will also be specified by Mr. Pryor.

After the fuel has been removed, the Institute will perform a comprehensive radiation survey, will transmit the results to NRC, and will ultimately request termination of License #R-111 and residual reactor hardware and facilities. The Ra-Be neutron source will be retained.

The Dismantling Plan which was submitted to you on May 25, 1984 discusses in detail the procedures to be used, and the precautions to be employed to protect the general public. During the defueling of the reactor, the Institute will utilize the services of a re-licensed AGN-201 senior operator, Dr. J. Narl Davidson of Georgia Tech. His examination for re-licensing is now scheduled for October 4, 1984. Nothing will be done however until and unless Dr. Davidson is re-licensed.

If you have any questions please let me know (404) 894-3620).


Sincerely yours,



R.A. Karam
Interim Director
Nuclear Research Center

RAK/jlr

Notary Public, Georgia State at Large
My Commission Expires March 19, 1988



pc: Mr. James O'Reilly, NRC Atlanta
Dr. J. Pettit, President
Dr. T.E. Stelson, Vice President, Research

file

GEORGIA INSTITUTE OF TECHNOLOGY
SCHOOL OF NUCLEAR ENGINEERING
ATLANTA, GEORGIA 30332

September 25, 1979

FRANK H. NEELY
NUCLEAR RESEARCH CENTER
TELEPHONE: (404) 894-3600

U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Mr. Robert W. Reid, Chief
Operating Reactors Branch #4
Division of Operating Reactors

REFERENCE: Georgia Tech Research Reactor License R-97

Gentlemen:

This is in response to your letter dated July 30, 1979 requesting information from us regarding quantities of SNM material. Under the above referenced license, Georgia Tech is currently able to receive, possess and use at any one time up to 13.5 kilograms of contained uranium 235.

Based upon your letter and our analysis of our needs, this quantity can be adjusted as follows:


1. Total amount of SNM Georgia Tech can receive, possess and use at any one time shall be 11.09 kilograms of contained uranium 235.
2. Maximum amount of contained uranium 235 that can be in the reactor core shall be 3.60 kilograms. All of this material will be classed exempt because of a self protection radiation level of ≥ 100 rem per hour at three feet. 19 elements
3. Maximum amount of contained uranium 235 that can be in irradiated fuel storage shall be 2.50 kilograms. All of this material will be classed exempt. 22 elements
@ 113 gm
= 40%
4. Maximum amount of contained uranium 235 that can be in un-irradiated fuel storage shall be 4.99 kilograms. All of this material will be classed non-exempt.

3.60
2.50
4.99

11.09

Should you need any further information on this matter please contact me.

Sincerely yours,



Robert S. Kirkland
Associate Director

RSK:lrm

~~7910030328~~

DISMANTLING AND DISPOSAL PLAN

I. Introduction

The Georgia Institute of Technology currently possesses an AGN-201 Training Nuclear Reactor under License No. R-111 (Docket No. 50-276). This facility is being defueled in preparation for ultimate disposal of the entire reactor. However, only the fuel will be removed and relocated at this time. To permit the transfer of the fuel, this document provides for the dismantling of the component parts and disposal of the fuel as prescribed by the NRC Regulatory Guide 1.86, "Termination of Operating Licenses of Nuclear Reactors."

The procedure for disassembly will be to remove the reactor control rods, the Ra-Be startup source and then the separate sections of the core assembly. The Ra-Be source will be placed in the source container (a Pb pig). The fission plate, fuel sections of the control rods and fuel assemblies (polyethylene discs) will be separated into two, approximately equal amounts (according to U-235 content), wrapped in polyethylene bags, and placed in NRC and DOT approved shipping containers for storage. After all fuel and the startup neutron source are removed, the electrical connections for the control rod drives and other instrumentation will be disconnected. All components and areas will be checked for contamination and decontaminated where required.

The fuel will be temporarily stored in the GTRR vault. When all approvals are received the fuel will be shipped off-site to DOE, Oak Ridge, Tennessee in accordance with all Federal and State Regulations. All used filter papers, wiping papers and rags, and gloves will be disposed of as rad-waste, according to the Georgia Tech and other applicable regulations. All protective clothing will be handled according to Georgia Tech procedures. No effluents will be disposed of through cold-drains or normal waste procedures until shown to be within applicable limits. During the entire operation, great care will be taken to protect both the operations personnel and the general public from exposure to ionizing radiations, and to keep any necessary exposure as low as reasonably practicable.

II. Dismantling Procedure

A. General Procedures

For the accomplishment of the defueling operations, Dr. R.A. Karam will be present at all times. A licensed operator will be present as a consultant. In addition the Institute Radiation Safety Officer, Mr. Robert Boyd, will monitor the operations for radiological safety aspects. All personnel involved in the operation will receive instructions of the operation at a pre-defueling meeting. A radiation work permit

will be issued for the job.

B. Hazard Evaluation

1. Nuclear Safety. A nuclear excursion would be the most serious type of accident that could occur during the disassembly and removal of the reactor core. However, it is one of the least likely of all credible accidents. To obtain criticality, the complete core assembly, including all fuel discs, the two fueled safety rods and the fueled coarse control rod must be assembled within a nearly optimum reflector.

Nuclear Safety will be maintained by first removing the fuel from safety and control rods and storing it in the shipping container. The combined fuel content of the rods is approximately 45 grams of U-235.

The core itself contains approximately 620 grams of U-235 and, with the rods removed, has a negative reactivity in excess of three percent (3%) in k/k .

The core disassembly will be done in the reactor room area. As the fuel discs are removed, they will be placed on a workbench covered with clean protective paper. Discs from the two halves of the core will be stored in separate shipping containers, approximately 350g U-235 per container.

A portable fast neutron survey meter will be in continuous operation during the disassembly of the core as an indicator of neutron multiplication. However, a detailed critical mass determination by neutron multiplication measurements will not be performed since the maximum reactivity increase that can be achieved by repositioning the fuel discs is less than the worth of the control rods.

As a further precaution, a temporary cadmium safety rod will be inserted into the core tank glory hole tube prior to disassembly of the core. This cadmium rod will remain in place during the disassembly of the top half of the core. The rod will be removed then by pushing it out as the glory hole liner tube is removed.

The removal and disassembly of the reactor core will be performed under the supervision of Dr. R.A. Karam. Whenever left unattended, the reactor facility will be locked, with access controlled by Dr. R.A. Karam.

2. Radiation Safety. Radioactive contamination could arise from three sources: the reactor core, activation products outside the core and the Ra-Be startup source. Fixed surface contamination produces external radiation exposures; airborne contamination adds an inhalation hazard. Thorough surveys of the reactor and core components and comprehensive monitoring of air and personnel during disassembly will prevent accidental and/or excessive exposures to contamination hazards. Such monitoring

will be supervised by the Institute's Radiation Safety Officer, and/or the health physics technologist.

Respiratory protective equipment and coveralls will be worn by all persons in the reactor room when the core tank is initially opened, and until the absence of airborne contamination has been definitely established.

The 10 mCi Ra-Be startup source will be removed from the reactor after the removal of the safety and control rods. The source will be wipe-tested immediately after removal and stored in a shielded container.

Personal monitoring devices are worn by all individuals entering the AGN reactor room under any condition. This regulation will continue to be strictly enforced during all of the procedures contained in this Dismantling Plan.

3. Mechanical Safety. The most probable type of accident is that which might be called mechanical and may result from either human error or mechanical failure. The probability of human error will be minimized by making adequate preparation for the work (see Section C) and by following a predetermined plan of action (see Section D). The probability of mechanical failure will be minimized by thorough inspection of all equipment in advance.

C. Preparation (Check List)

1. Radiation Protection

a. The following instruments will be checked for proper operation, then placed in the reactor room for use.

1. Air sampler
2. Fast neutron survey meter
3. Gamma dose rate survey meter (Cutie Pie or Radector)
4. Contamination survey meter (End-window Geiger Counter)

b. The following supplies will be collected and placed in the reactor room:

1. Glass fiber filters and filter holders for air sampling.
2. Whatman filters or Nucon smears for wipe tests.
3. Individual containers for air sample and wipe test filters.
4. Shielded storage container for storing the Ra-Be startup source.
5. Appropriate breathing apparatus (face

mask) will be worn as required by the Radiation Safety Officer.

- 6. Coveralls, lab coats and gloves.
- 7. Radioactive waste container.
- 8. Cadmium safety rod.

2. Work Area and Tools

- a. Clear reactor room of extraneous large items and clean the work area with vacuum cleaner.
- b. Collect the following tools and place in reactor room:
 - 1. Hand tools (socket and allen wrenches) required for disassembly.
 - 2. Handling tool for removing the Ra-Be source.
 - 3. Fuel storage and shipping containers.
 - 4. Operating crane for lifting the thermal column, core tank and upper graphite reflector.
- c. The following items will also be placed in the reactor room:
 - 1. Plastic bags or sheeting on which to place control rods and fuel components, and for packaging such components.
 - 2. Labels for dismantled core components.

D. Procedures

Disassembly

- 1. Removal of the Thermal Tank, Part No. 2-000139.
 - a. Remove bolts that secure the thermal tank assembly to the water tank.
 - b. Attach lifting frame, T-000458, to the flange of the thermal tank with the bolts provided, and hoist carefully from the water tank.
- 2. Removal of control and safety rod capsules (part No. 2-000104).
 - a. Insert temporary cadmium safety rod into glory hole.
 - b. Remove the bottom cover plate (2-000169) by loosening and turning

the latching dogs, Part No. 2-000358. (Note: Gasket Part No. 2-000593, should come off with the cover.)

- c. Remove Dash Pot assembly (Part No. 2-000510 shown on 2-000184) by grasping the knurled surface and unscrew by hand (right-hand thread), then lower carefully out of the main frame assembly.
- d. Remove the rod capsule-and-tube assembly by unscrewing (right-hand thread) cap 2-000195, using a 1/2" socket wrench, until detached, and lower carefully out of the control rod main frame assembly.
- e. Remove rod capsule from rod tube by gripping the two tubes by hand and unscrewing. This thread is LEFT HAND; if the other direction is used, the capsule O-ring seal will be opened and the active material will be exposed.
- f. Remove U-fuel from control rods, wipe-test for removable radioactivity wrap in plastic and place in shipping container.
- g. Remove and wipe-test the Ra-Be start-up source. Place it in the portable storage container.

3. Core Disassembly

The entire disassembly of the reactor core will be performed in the presence of Professor R.A. Karam with a minimum of two persons present during each step of the operation. However, the total number of people present will be minimized. The following procedure will be followed in the sequence indicated:

- a. Start membrane filter air sampler operating in close proximity to reactor core.
- b. The two individuals to be in the reactor room as the core is opened will wear the appropriate face masks and gloves.

- y
- 6
- c. The upper end plate of the core tank will be removed, with special care being taken of the O-ring gasket.
 - d. After the air sampler has been allowed to run several minutes, the filter will be removed and counted on the low background gamma ray detector. Another filter will be placed in the air sampler and collection of a second sample will started. As soon as the absence of an airborne contamination hazard is established, the face masks will be dispensed with.
 - e. Lifting lugs will be screwed into the threaded sockets in the upper main reflector and this reflector will then be lifted out of the core tank.
 - f. As each piece of the core assembly is removed, a representative area of approximately 100 cm will be wiped with a filter paper or Nucon smear. The smears will be retained for later analysis to determine quantities of removable contamination throughout the core. Each core component will then be completely wiped with "wiping tissues" and these wipings will be disposed of as radioactive wastes.
 - g. The fuel discs will be removed one at a time, beginning with the tip of the core and working downward through disc No. 4. Each disc must be removed carefully to avoid jostling, and thereby shifting, the remaining discs. NOTE: Fuel from the top half of the core will be placed in one of the two shipping casks provided.
 - h. After removal of all fuel discs in the upper half of the core, the peripheral reflector sections will be inspected for possible removal.
 - i. The temporary Cd control rod will be removed, followed by removal of the Glory Hole tube.
 - j. The core tank will now be removed from the reactor and lowered to floor

7

level.

- k. The lower main reflector, together with fuel discs 1, 2, and 3 and the thermal fuse assembly will now be removed.
- l. The lower half of the core will be disassembled by compressing the support spring recessed in the base of the lower main reflector. The thermal fuse assembly will then be exposed above fuel disc No. 2 and may be released by removing the clip ring. The fuel discs from the lower half of the core, and the thermal fuse will be wrapped for placement in the second shipping container.
- m. All parts, components, etc., will be decontaminated to acceptable levels before the shipping containers are finally closed and secured.
- n. Following removal of all of the fuel, the reactor reflector components will be reinserted, and the tank system reassembled for future disposition. Based on prior experience, it is expected that the tank system will contain no measurable radioactivity.
- o. The Ra-Be startup source will be retained and will be stored according to applicable regulations by Georgia Tech.

III. Criticality and Security Safeguards During Storage of Fuel Awaiting Shipment

A. Storage Location of Fuel and Control Rods

As indicated above, the fuel and fuel portions of the control and safety rods will be wrapped in polyethylene and placed in the two NRC, and DOT approved shipping containers which will ultimately be used to transport the Special Nuclear Material to Oak Ridge, Tennessee. The containers will be sealed and properly labeled. The containers will be stored in the vault of the GTRR until shipment.

B. Criticality Monitoring

With half of the fuel stored in each of the two shipping containers, inadvertent criticality is impossible. A remote

radiation monitoring instrument exists in the vault.