Docket Nos. 50-352/353

Mr. Edward G. Bauer, Jr. Vice President & General Counsel Philadelphia Electric Company 2301 Market Street Philadelphia, Pennsylvania 19101

Dear Mr. Bauer:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - LIMERICK

The NRC staff has completed a review of amendments to the FSAR effecting the Limerick Initial Plant Test Program through FSAR Amendment 35. During this review, the staff noted that changes have been made to the previously evaluated Chapter 14 without sufficient justification. Therefore, it is requested that you respond to enclosed request for additional information at the earliest possible date.

Sincerely,

A. Schwencer, Chief Licensing Branch No. 2 Division of Licensing

Enclosure: As stated

cc: See next page

LB#2/DL/PM LB#2/DL/BC RMartin/1b ASchwencer 9/20/84 9/20/84 Distribution:
Docket File D. Ziernann
NRC PDR
Local PDR
PRC System
NSIC
LB#2 Reading
EHylton
RMartin
EJordan
NGrace
Vogler, OELD
ACRS (16)

8410030379 840920 PDR ADDCK 05000352 A PDR

LIMERICK

Mr. Edward G. Bauer, Jr Vice President & General Counsel Philadelphia Electric Company Philadelphia, Pennsylvania 19101

Troy B. Conner, Jr., Esquire Conner and Wetterhahn 1747 Pennsylvania Ave, N.W. Washington, D. C. 20006

Zori G. Ferkin Assistant Counsel Governor's Energy Council 1625 N. Front Street Harrisburg, Pennsylvania 17105

Federic M. Wentz County Solicitor County of Montgomery Courthouse Norristown, Pennsylvania 19404

Eugene J. Bradley Philadelphia Electric Company Associate General Counsel 2301 Market Street Philadelphia, Pennsylvania 19101

Mr. Vincent Boyer Senior Vice President Nuclear Operations Philadelphia Electric Company 2301 Market Street Philadelphia, Pennsylvania 19101

Mr. Suresh Chaudhary Resident Inspector U.S. Nuclear Regulatory Commission P. O. Box 47 Sanatoga, PA 19464

James Wiggins, SR. R.I. U. S. Nuclear Regulatory Commission P. O. Box 47 Sanatoga, Pennsylvania 19464 Mr. Marvin I. Lewis 6504 Bradford Terrace Philadelphia, Pennsylvania 19149

Frank R. Romano, Chairman Air & Water Pollution Patrol 61 Forest Avenue Ambler, Pennsylvania 19002

Charles W. Elliott, Esquire Brose & Poswistilo, 1101 Bldg. 11th & Northampton Streets Easton, Pennsylvania 18402

Ms. M. Mulligan Limerick Ecology Action 762 Queen St. Pottstown, Pennsylvania 19464

Mr. Karl Abraham Public Affairs Officer Region I U.S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, PA 19806

Joseph H. White, III 8 North Warner Avenue Bryn Mawr, PA 19010

Thomas Gerusky, Director
Bureau of Radiation Protection
Dept. of Environmental Resources
5th Floor, Fulton Bank Bldg.
Third and Locust Streets
Harrisburg, Pennsylvania 17120

Sugarman, Denworth & Hellegers 16th Floor Center Plaza 101 North Broad Street Philadelphia, Pennsylvania 19106

Robert L. Anthony Friends of the Earth of the Delaware Valley Harrisburg, Pennsylvania 17120

Martha W. Bush
Deputy City Solicitor
Municipal Services Bldg.
15th and JFK Blvd.
Phildelphia, Pennsylvania 19107

David Wersan, Esq. Assistant Consumer Advocate Office of Consumer Advocate 1425 Strawberry Square Harrisburg, Pennsylvania 17120

Steven P. Hershey, Esq.
Community Legal Services, Inc.
Law Center North Central - Bevry Bldg.
3701 North Board Street
Philadelphia, Pennsylvania 19140

Mr. J. T. Robb, NS-1 Philadelphia Electric Company 2301 Market Street Philadelphia, Pennylsvania 19101

Timothy R. S. Campbell, Director Department of Emergency Services 14 East Biddle Street West Chester, Pennsylvania 19380 Director, Pennsylvania Emergency Management Agency Basement, Transportation & Safety Building Harrisburg, Pennsylvania 17120

Angus Love, Esq. 107 East Main Street Norristown, Pennsylvania 19401

Lawrence Brenner, Esq Administrative Judge Atomic Safety & Licensing Board U.S. Nuclear Regulatory Commission Washington, D. C. 20555

Dr. Peter A. Morris Administrative Judge Atomic Safety & Licensing Board U.S. Nuclear Regulatory Commission Washington, D. C. 20555

Dr. Richard F. Cole Administrative Judge Atomic Safety & Licensing Board U.S. Nuclear Regulatory Commission Washington, D. C. 20555

Mr. Spence W. Perry, Esq. Associate General Counsel Federal Emergency Management Agency Room 840 500 C St., S.W. Washington, D. C. 20472

REQUEST FOR ADDITIONAL INFORMATION AND STAFF POSITIONS LIMERICK GENERATING STATION, UNITS 1/2

- 640.8 Modify the following test abstracts contained in FSAR Table 14.2-4 to clearly indicate the source of acceptance criteria to be used in determining test adequacy.
 - (P-2.1)
 125 V (Div III, IV) dc Safeguard Power System
 (P-2.2)
 125/250 V (Div I, II) dc Safeguard Power System

(P-11.1) Service Water System

4. (P-15.1) Turbine Enclosure Cooling Water System

5. (P-53.1) Standby Liquid Control System
6. (P-65.1) Radwaste Enclosure HVAC System

- 7. (P-70.1) Standby Gas Treatment, Reactor Enclosure Air Recirculation, Secondary Containment Isolation
- 8. (P-76.2) Post-Accident Sampling System

Items 1, 2, and 5-7 are tests which had appropriate acceptance criteria that was deleted by Amendment 28. Items 3, 4 and 8 are test abstracts added by Amendment 28 which do not contain appropriate acceptance criteria.

- 640.13 a. Modify the dc Power System tests (P-2.1), P-2.2) to reinstate testing of all dc loads necessary to safe shutdown at minimum terminal voltage or to demonstrate that the voltage drop at load to these components is acceptable.
 - b. Provide justification for deleting the reference to system bus voltages in the acceptance criteria of the 13.2 kV Unit Auxiliary and 4 kV Safeguard Power System test abstracts (P-3.1, P-4.1).
 - c. The Unit Scope section for the dc Power System tests (P-2.1, P-2.2) states that testing will be performed on Unit 1, Unit 2, and common systems. FSAR Subsection 8.3.2.1 states there are no common or shared dc power systems. Modify the Unit Scope of these two test abstracts accordingly.
- 640.14 The Loss of Instrument Air test (P-100.2) has been revised to meet the requirements of Regulatory Guide 1.68.3, "Preoperational Testing of Instrument and Control Air Systems." This modification is acceptable to the NRC staff; however, the following modifications should be made:
 - FSAR Subsections 1.8 and 14.2.7.2 should delete reference to Regulatory Guide 1.80 as it is superseded by Regulatory Guide 1.68.3.

- FSAR Subsection 1.8 should either state that Limerick will be in conformance with this guide or provide technical justification for any exceptions.
- 640.21 The MSIV Leakage Control System Test (STP-38) has been deleted. The deletion is acceptable if preoperational testing of the system is accomplished at rated temperature.
- 640.23 The Main Steam Relief Valves (MSRVs) Performance test (STP-26) should reinstate measurement of the capacity of each MSRV and provide acceptance criteria consistent with accident analysis assumptions.