

SEP 1 1 1984

Docket/License: 50-219/DPR-16

GPU Nuclear Corporation
ATTN: Mr. P. B. Fiedler
Vice President and Director
Oyster Creek Nuclear Generating Station
P. O. Box 388
Forked River, New Jersey 08731

Gentlemen:

Subject: Inspection 50-219/84-11

This refers to the routine resident safety inspection by Mr. J. Wechselberger on May 1 - 31, 1984 at the Oyster Creek Nuclear Generating Station, Forked River, New Jersey. The inspection consisted of document reviews, interviews, and observation of activities. The findings were discussed with you and other members of your staff at the conclusion of the inspection.


Within the scope of this inspection, no violations were identified. However, during our review of LER 84-7 involving failure to test a standby gas treatment system (SGTS) train within the required time, it became apparent that the Technical Specifications for this particular situation were unclear in regards to surveillance requirements and backup power supply. Mr. M. Laggart of your staff has committed to request by November 15, 1984, a revision to clarify the requirements for the SGTS during refueling.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosure will be placed in the NRC Public Document Room unless you notify this office, by telephone, within 10 days of the date of this letter and submit written application to withhold information contained therein within 30 days of the date of this letter. Such application must be consistent with the requirements of 2.790(1). The telephone notification of your intent to request withholding, or any request for an extension of the 10 day period which you believe necessary, should be made to the Supervisor, Files, Mail and Records, USNRC, Region 1, at (215) 337-5223.

No reply to this letter is required. Your cooperation with us in this matter is appreciated.

Sincerely,

Original Signed By:



Richard W. Starostecki, Director
Division of Project and Resident
Programs

8410030658 840911
PDR ADOCK 05000219
Q PDR

Enclosure: NRC Region 1 Report 50-219/84-11

OFFICIAL RECORD COPY

50-219/84-11 - 0001.0.0
07/02/84

1E01 1/1

cc w/encl:

BWR Licensing Manager
Licensing Manager, Oyster Creek
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety information Center (NSIC)
NRC Resident Inspector
State of New Jersey

bcc w/encl:

Region 1 Docket Room (with concurrences)
Senior Operations Officer (w/o encl)
DPRP Section Chief
Director, DETP

S. GREENMAN

9/8/84

RI:DPRP

Wechselberger/meo
8/9/84

RI:DPRP

Conner
8/16/84

RI:DPRP

Starostocki
9/8

RI DETP

TY
BELLAMY
1/27/84

WS
8/21/84

OFFICIAL RECORD COPY

50-219/84-11 - 0002.0.0
07/02/84