

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 2	DOCKET NUMBER (2) 05000361	PAGE (3) 1 OF 01
--------------------------------------------------------------------	-------------------------------	---------------------

TITLE (4)
DIESEL GENERATOR LOAD VERIFICATION DELINQUENT SURVEILLANCE

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQ. NUMBER	REV. NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		
08	22	84	84	048	000	09	20	84			
									DOCKET NUMBER(S) 050000		

OPERATING MODE (9) 1

POWER LEVEL (10) 100

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)

20.402(b)	20.405(c)	50.73(a)(2)(iv)	73.71(b)
20.405(a)(1)(i)	50.36(c)(1)	50.73(a)(2)(v)	73.71(c)
20.405(a)(1)(ii)	50.36(c)(2)	50.73(a)(2)(vii)	OTHER (Specify in Abstract below and in Text, NRC Form 366A)
20.405(a)(1)(iii)	X 50.73(a)(2)(i)	50.73(a)(2)(viii)(A)	
20.405(a)(1)(iv)	50.73(a)(2)(ii)	50.73(a)(2)(viii)(B)	
20.405(a)(1)(v)	50.73(a)(2)(iii)	50.73(a)(2)(x)	

LICENSEE CONTACT FOR THIS LER (12)

NAME J. G. HAYNES, STATION MANAGER	TELEPHONE NUMBER AREA CODE: 714, NUMBER: 492-7700
---------------------------------------	------------------------------------------------------

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)

MONTH	DAY	YEAR

Abstract (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On 8/22/84, it was determined from audit records that the Unit 2 Electrical Power Systems 18-month surveillance was delinquent, in that it was not performed in accordance with Technical Specification Surveillance Requirement 4.8.1.1.2.d.9, which requires verifying every 18 months by calculation that the auto-connected loads to each diesel generator do not exceed 4700 kilowatts. The two surveillances that have been performed were on 2/7/82 and 3/10/84, respectively. Based on these surveillances and the 25% extension limit of Technical Specification 4.0.2, the 18-month requirement was delinquent by approximately two and one-half months.

The delinquency was caused by lack of procedural control. As corrective actions, this requirement will be proceduralized and incorporated in the Technical Specification Surveillance Program Implementation Procedure S023-XV-3.0.


The remaining Electrical Power Systems surveillances were reviewed and no further delinquencies were found.

Since the surveillance performed on 3/10/84 established that the auto-connected loads to each diesel generator did not exceed 4700 kilowatts, there is no safety significance to this occurrence.

8410050416 840920
PDR ADOCK 05000361
S PDR

IE 22
1/1

Southern California Edison Company



SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

J. G. HAYNES
STATION MANAGER

TELEPHONE
(714) 492-7700

September 20, 1984

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Docket No. 50-361
Licensee Event Report No. 84-048
San Onofre Nuclear Generating Station, Unit 2

Pursuant to 10 CFR 50.73(a)(2)(i)(B), this submittal provides the required 30-day written Licensee Event Report (LER) for an occurrence involving the Electrical Power Systems. Neither the health and safety of plant personnel nor the public were affected by this event.

If you require any additional information, please so advise.

Sincerely,

Enclosure: LER No. 84-048

cc: A. E. Chaffee (USNRC Senior Resident Inspector, Units 1, 2 and 3)
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

J. B. Martin (Regional Administrator, USNRC Region V)

Institute of Nuclear Power Operations (INPO)

IE22
1/1