

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 3		DOCKET NUMBER (2) 0 5 0 0 0 3 6 2	PAGE (3) 1 OF 0 6
--	--	--------------------------------------	----------------------

TITLE (4)  
DOSE EQUIVALENT IODINE LIMITS EXCEEDED

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)																																																		
MONTH	DAY	YEAR	YEAR	SEQ. NUMBER	REV. NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)																																																
0 8	2 3	8 4	8 4	0 3	7	0 9	1 8	8 4			0 5 0 0 0																																																
<table border="1"> <tr> <td>OPERATING MODE (9)</td> <td colspan="11">THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)</td> </tr> <tr> <td>POWER LEVEL (10)</td> <td>3</td> <td><input type="checkbox"/> 20.402(b)</td> <td><input type="checkbox"/> 20.405(c)</td> <td><input type="checkbox"/> 50.73(a)(2)(iv)</td> <td><input type="checkbox"/> 73.71(b)</td> </tr> <tr> <td></td> <td>0 0 0</td> <td><input type="checkbox"/> 20.405(a)(1)(i)</td> <td><input type="checkbox"/> 50.36(c)(1)</td> <td><input type="checkbox"/> 50.73(a)(2)(v)</td> <td><input type="checkbox"/> 73.71(c)</td> </tr> <tr> <td></td> <td></td> <td><input type="checkbox"/> 20.405(a)(1)(ii)</td> <td><input type="checkbox"/> 50.36(c)(2)</td> <td><input type="checkbox"/> 50.73(a)(2)(vii)</td> <td><input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 366A)</td> </tr> <tr> <td></td> <td></td> <td><input type="checkbox"/> 20.405(a)(1)(iii)</td> <td><input type="checkbox"/> 50.73(a)(2)(i)</td> <td><input type="checkbox"/> 50.73(a)(2)(viii)(A)</td> <td></td> </tr> <tr> <td></td> <td></td> <td><input type="checkbox"/> 20.405(a)(1)(iv)</td> <td><input type="checkbox"/> 50.73(a)(2)(ii)</td> <td><input type="checkbox"/> 50.73(a)(2)(viii)(B)</td> <td></td> </tr> <tr> <td></td> <td></td> <td><input type="checkbox"/> 20.405(a)(1)(v)</td> <td><input type="checkbox"/> 50.73(a)(2)(iii)</td> <td><input type="checkbox"/> 50.73(a)(2)(x)</td> <td></td> </tr> </table>												OPERATING MODE (9)	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)											POWER LEVEL (10)	3	<input type="checkbox"/> 20.402(b)	<input type="checkbox"/> 20.405(c)	<input type="checkbox"/> 50.73(a)(2)(iv)	<input type="checkbox"/> 73.71(b)		0 0 0	<input type="checkbox"/> 20.405(a)(1)(i)	<input type="checkbox"/> 50.36(c)(1)	<input type="checkbox"/> 50.73(a)(2)(v)	<input type="checkbox"/> 73.71(c)			<input type="checkbox"/> 20.405(a)(1)(ii)	<input type="checkbox"/> 50.36(c)(2)	<input type="checkbox"/> 50.73(a)(2)(vii)	<input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 366A)			<input type="checkbox"/> 20.405(a)(1)(iii)	<input type="checkbox"/> 50.73(a)(2)(i)	<input type="checkbox"/> 50.73(a)(2)(viii)(A)				<input type="checkbox"/> 20.405(a)(1)(iv)	<input type="checkbox"/> 50.73(a)(2)(ii)	<input type="checkbox"/> 50.73(a)(2)(viii)(B)				<input type="checkbox"/> 20.405(a)(1)(v)	<input type="checkbox"/> 50.73(a)(2)(iii)	<input type="checkbox"/> 50.73(a)(2)(x)	
OPERATING MODE (9)	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)																																																										
POWER LEVEL (10)	3	<input type="checkbox"/> 20.402(b)	<input type="checkbox"/> 20.405(c)	<input type="checkbox"/> 50.73(a)(2)(iv)	<input type="checkbox"/> 73.71(b)																																																						
	0 0 0	<input type="checkbox"/> 20.405(a)(1)(i)	<input type="checkbox"/> 50.36(c)(1)	<input type="checkbox"/> 50.73(a)(2)(v)	<input type="checkbox"/> 73.71(c)																																																						
		<input type="checkbox"/> 20.405(a)(1)(ii)	<input type="checkbox"/> 50.36(c)(2)	<input type="checkbox"/> 50.73(a)(2)(vii)	<input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 366A)																																																						
		<input type="checkbox"/> 20.405(a)(1)(iii)	<input type="checkbox"/> 50.73(a)(2)(i)	<input type="checkbox"/> 50.73(a)(2)(viii)(A)																																																							
		<input type="checkbox"/> 20.405(a)(1)(iv)	<input type="checkbox"/> 50.73(a)(2)(ii)	<input type="checkbox"/> 50.73(a)(2)(viii)(B)																																																							
		<input type="checkbox"/> 20.405(a)(1)(v)	<input type="checkbox"/> 50.73(a)(2)(iii)	<input type="checkbox"/> 50.73(a)(2)(x)																																																							

LICENSEE CONTACT FOR THIS LER (12)

NAME	TELEPHONE NUMBER
J. G. HAYNES, STATION MANAGER	7 1 4 4 9 2 1 - 7 7 0 0

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NFRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NFRDS

SUPPLEMENTAL REPORT EXPECTED (14)

<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)	<input checked="" type="checkbox"/> NO	EXPECTED SUBMISSION DATE (15)	MONTH	DAY	YEAR

Abstract (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

Pursuant to Limiting Condition for Operation (LCO) 3.4.7, Action Statement 'd' of Appendix A, Technical Specifications to Facility Operating License NPF-15 for San Onofre Unit 3, this submittal provides the required 30-day written Licensee Event Report (LER) for an occurrence involving the Reactor Coolant System specific activity.

On August 23, 1984, at 1035, Unit 3 was shut down due to high chloride conductivity in the hot wells and condensate system. Following the shutdown, at 1400, analysis of a Reactor Coolant System (RCS) sample indicated that RCS specific activity exceeded 1.0 microcurie/gram Dose Equivalent (DE) I-131. RCS specific activity was reduced to less than 1.0 microcurie/gram DE I-131 by purification flow at 1100 on August 25, 1984.

The event was an indication of iodine spiking. We will continue to monitor and evaluate primary coolant activity. No further corrective action is planned.

8410050456 840918  
PDR ADDCK 05000362  
S PDR

IE22  
|||

LICENSEE EVENT REPORT (LER)  
TEXT CONTINUATION

FACILITY NAME (1)  SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 3	DOCKET NUMBER (2)  0 5 0 0 0 3 6 2	LER NUMBER (6)			PAGE (3)	
		YEAR	SEQ. NUMBER	REV. NUMBER		
		8 4	- 0 3 1 7	- 0 1 0	0 2	OF 0 6

TEXT (If more space is required, use additional NRC Form 366A's) (17)

Pursuant to Limiting Condition for Operation (LCO) 3.4.7, Action Statement 'd' of Appendix A, Technical Specifications to Facility Operating License NPF-15 for San Onofre Unit 3, this submittal provides the required 30-day written Licensee Event Report (LER) for an occurrence involving the Reactor Coolant System (RCS) specific activity.

On August 23, 1984, at 1035, Unit 3 was shut down due to high chloride conductivity in the hot wells and condensate system. Following the shutdown, at 1400, RCS sample analysis indicated that RCS specific activity exceeded 1.0 microcurie/gram Dose Equivalent (DE) I-131. RCS specific activity was reduced to less than 1.0 microcurie/gram DE I-131 by purification flow at 1100 on August 25, 1984.

The event was an indication of iodine spiking. Similar occurrences were previously reported in LER 83-111, LER 84-005, LER 84-013, LER 84-015, and LER 84-023. We will continue to monitor and evaluate primary coolant activity. No further corrective action is planned. Neither the health and safety of plant personnel nor the public were affected by this event.

Additional information, required by LCO 3.4.7, Action Statement 'd', is provided on the following pages. Although the unit has a degasification path which operates continuously and takes pressurizer steam, condenses it and directs it to Liquid Radwaste, degassing operation history is not applicable, because this system reduces the noble gas content of the RCS but has no effect on iodine.

LICENSEE EVENT REPORT (LER)  
TEXT CONTINUATION

FACILITY NAME (1)  SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 3	DOCKET NUMBER (2)  0   5   0   0   0   3   6   2	LER NUMBER (6)			PAGE (3)		
		YEAR 8   4	SEQ. NUMBER -   0   3   7	REV. NUMBER -   0   0			

TEXT (If more space is required, use additional NRC Form 366A's) (17)

CLEANUP FLOW HISTORY

<u>PERIOD</u>	<u>AVERAGE CLEANUP FLOW (GPM)</u>
8/21/84, 1400 to 8/23/84, 1400	80.0
8/23/84, 1400 to 8/24/84, 1700	85.4
8/24/84, 1700 to 8/24/84, 2100	85.0 *
8/24/84, 2100 to 8/24/84, 2400	88.6
8/24/84, 2400 to 8/25/84, 0400	85.0 *
8/25/84, 0400 to 8/25/84, 1100	83.7

\* Hourly cleanup flow data not available. Figure used is taken from average flow with two charging pumps in operation.

REACTOR POWER HISTORY

<u>PERIOD</u>	<u>REACTOR POWER</u>
8/21/84, 1400 to 8/23/84, 0935	100% Rated Power
8/23/84, 0935 to 8/23/84, 1035	100% to 10%
8/23/84, 1035 to 8/23/84, 1045	10% to 0%
8/23/84, 1045 to 8/24/84, 0601	0%
8/24/84, 0501 to 8/24/84, 1400	0% to 10%
8/24/84, 1400 to 8/25/85, 1104	10% to 18%

LICENSEE EVENT REPORT (LER)  
TEXT CONTINUATION

FACILITY NAME (1)  SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 3	DOCKET NUMBER (2)  0 5 0 0 0 3 6 2	LER NUMBER (6)			PAGE (3)		
		YEAR 8 4	SEQ. NUMBER - 0 3 7	REV. NUMBER - 0 0			

TEXT (If more space is required, use additional NRC Form 366A's) (17)

REACTOR COOLANT SYSTEM SPECIFIC ACTIVITY ANALYSIS

<u>DATE</u>	<u>TIME</u>	<u>DE I-131 MICROCURIES/GRAM</u>
8/23/84	1400	3.63
8/23/84	1800	3.85
8/23/84	2200	3.09
8/24/84	0200	2.29
8/24/84	0600	1.84
8/24/84	0750	1.81
8/24/84	1150	1.51
8/24/84	1545	3.03
8/24/84	1755	2.51
8/25/84	2155	1.92
8/25/84	0200	1.52
8/25/84	0600	1.14
8/25/84	0850	1.05
8/25/84	1100	0.94

The total time with the DE I-131 above 1.0 microcuries/gram for this event was 45.0 hours.



AXIALLY INTEGRATED AND PEAK OUTPUT ASSEMBLY EXPOSURE EDITS  
 FORMAT OF ASSEMBLY IN CORE MAP  
 ASSEMBLY NUMBER - BATCH NUMBER  
 INTEGRATED BOX EXPOSURE IN 10\*\*00:MM/D/T  
 MAXIMUM BOX EXPOSURE IN 10\*\*00:MM/D/T  
 LOCATION OF MAX. ASS. EXP. IN O/O HEIGHT

				1-05	2-05	3-05	4-05																			
				31.055	40.619	40.567	30.930																			
				40.315	52.536	57.376	40.003																			
				36.000	36.000	36.000	34.000																			
				5-05	6-05	7-07	8-07	9-04	10-07	11-07	12-05	13-05														
				30.323	40.702	47.524	55.307	48.545	55.220	47.145	40.175	29.511														
				39.001	52.945	62.258	72.518	63.721	72.070	61.345	51.685	38.167														
				36.000	36.000	34.000	36.000	35.000	36.000	34.000	36.000	40.000														
				14-05	15-06	16-04	17-02	18-04	19-02	20-04	21-02	22-04	23-06	24-05												
				32.998	48.781	48.869	50.580	53.936	52.090	53.833	50.302	48.376	48.050	32.551												
				42.676	63.685	63.748	65.656	70.372	67.632	70.090	65.075	62.613	61.991	41.666												
				36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000												
				25-05	26-02	27-04	28-02	29-04	30-02	31-04	32-02	33-04	34-02	35-04	36-02	37-05										
				33.696	41.904	49.081	51.033	55.139	54.145	56.471	54.122	55.238	50.674	48.430	41.371	33.328										
				43.822	54.200	64.053	66.028	71.314	69.930	73.155	69.876	71.343	65.195	62.519	53.103	42.874										
				36.000	36.000	36.000	36.000	38.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	34.000										
				38-05	39-06	40-04	41-02	42-04	43-02	44-04	45-02	46-04	47-02	48-04	49-02	50-04	51-06	52-05								
				29.175	48.573	49.661	51.217	56.176	55.152	58.503	55.696	58.407	54.939	55.650	50.539	48.008	47.938	28.701								
				37.430	62.815	64.335	66.035	72.508	70.256	75.675	72.205	75.506	70.532	71.689	64.872	63.128	61.655	36.747								
				36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000								
				53-05	54-04	55-02	56-04	57-02	58-03	59-01	60-03	61-01	62-03	63-02	64-04	65-02	66-04	67-05								
				40.502	48.055	51.127	56.054	55.565	59.093	57.258	59.818	57.134	58.648	55.042	55.011	50.409	47.376	39.945								
				51.900	61.907	65.744	72.069	71.237	75.729	73.460	77.318	73.261	75.353	70.490	70.838	64.671	61.070	50.901								
				36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000								
				68-07	69-02	70-04	71-02	72-03	73-01	74-03	75-01	76-03	77-01	78-03	79-02	80-04	81-02	82-07								
				49.076	50.895	55.838	55.381	59.472	57.526	61.851	58.465	61.048	57.556	59.203	54.899	55.234	50.266	48.312								
				63.528	65.543	72.142	71.210	76.711	73.809	78.464	74.654	78.194	73.397	75.905	70.352	70.453	64.195	61.705								
				83-05	34.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	38.000	38.000	38.000	38.000	38.000	36.000	36.000	84-05						
				32.630													32.047									
				42.157	85-07	86-04	87-02	88-04	89-01	90-03	91-01	92-03	93-01	94-03	95-01	96-04	97-02	98-04	99-07	40.389						
				32.000	57.427	53.769	54.454	58.470	57.237	60.319	58.663	61.468	58.805	60.892	57.273	58.345	54.632	53.164	56.594	36.000						
				74.630	69.677	70.263	75.829	73.798	78.278	75.019	78.287	74.742	77.540	73.197	75.317	69.138	67.844	72.353								
				100-05	34.000	36.000	36.000	36.000	36.000	36.000	36.000	38.000	38.000	38.000	38.000	38.000	36.000	36.000	36.000	101-05						
				42.563													41.891									
				54.742	102-04	103-02	104-04	105-02	106-03	107-01	108-03	109-01	110-03	111-01	112-03	113-02	114-04	115-02	116-04	53.053						
				34.000	51.628	52.957	57.273	55.643	60.171	58.335	61.868	59.174	61.900	58.410	60.091	55.533	56.826	52.277	50.792	36.000						
				67.278	68.568	74.305	72.168	77.815	75.019	79.386	75.235	79.073	74.513	77.221	71.586	73.154	66.979	65.359								
				117-05	34.000	34.000	36.000	36.000	36.000	36.000	38.000	35.000	38.000	38.000	36.000	36.000	36.000	36.000	36.000	118-05						
				42.694													41.973									
				55.040	119-07	120-04	121-02	122-04	123-01	124-03	125-01	126-03	127-01	128-03	129-01	130-04	131-02	132-04	133-07	53.516						
				34.000	57.721	54.183	54.262	57.456	57.173	60.935	56.923	61.695	58.877	60.675	57.812	57.612	53.836	53.116	56.695	34.000						
				75.322	76.428	69.982	74.026	73.468	78.905	75.270	78.551	74.955	78.193	72.967	73.914	69.017	68.667	73.277								
				134-05	34.000	34.000	36.000	36.000	38.000	38.000	38.000	36.000	36.000	36.000	36.000	36.000	36.000	36.000	34.000	135-05						
				33.855													32.353									
				43.105	136-07	137-02	138-04	139-02	140-03	141-01	142-03	143-01	144-03	145-01	146-03	147-02	148-04	149-02	150-07	41.865						

UNIT 3  
 SAN ONDRE NUCLEAR GENERATING STATION

0	1	5	0	0	0	1	6	2	8	4	-	0	3	7	-	0	0	0	1	5	0	1	6
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1)		DOCKET NUMBER (2)		LER NUMBER (3)			PAGE (4)	
SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 3		0 5 0 0 0 3 6 2		8 4 - 0 3 7 - 0 0			0 6 U P 0 6	
TITLE OF THIS REPORT (5) Required, see instructions NRC Form 884a (1/77)								

34.000 49.240 50.000 55.630 59.307 57.796 61.323 58.730 61.139 57.462 59.040 54.720 55.192 50.376 40.556 34.000  
 64.209 65.947 72.031 70.700 76.527 74.104 78.563 74.633 76.220 73.995 75.719 80.202 76.870 64.703 62.603  
 34.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000

151-05 152-04 153-02 154-04 155-02 156-03 157-03 158-03 159-01 160-03 161-02 162-04 163-02 164-04 165-05  
 40.612 47.690 50.893 55.076 55.505 59.189 57.525 60.391 57.268 58.551 54.997 55.140 50.513 47.739 40.122  
 52.259 62.304 63.719 71.928 71.218 76.189 73.428 76.722 73.866 75.389 70.207 70.736 64.528 61.513 51.307  
 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000

166-05 167-06 168-04 169-02 170-04 171-02 172-04 173-02 174-04 175-02 176-04 177-02 178-04 179-06 180-05  
 29.004 40.379 49.430 51.000 56.040 55.269 50.699 55.927 58.432 54.760 55.555 50.563 40.929 47.790 58.002  
 37.528 62.748 64.814 65.502 72.225 70.070 75.576 71.996 75.199 70.174 71.341 64.611 62.772 61.247 36.744  
 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000

181-05 182-02 183-04 184-02 185-04 186-02 187-04 188-02 189-04 190-02 191-04 192-02 193-05  
 33.725 41.699 46.659 50.603 55.348 54.260 56.670 54.831 54.658 50.570 40.506 41.163 32.574  
 43.440 53.621 62.631 65.425 71.345 69.791 73.226 69.464 70.471 64.069 62.635 52.504 41.107  
 36.700 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000

194-05 195-06 196-04 197-02 198-04 199-02 200-04 201-02 202-04 203-06 204-05  
 32.782 46.374 40.565 50.429 53.902 52.146 53.795 50.232 48.346 48.104 32.994  
 41.972 62.336 62.722 64.912 69.780 67.250 69.672 64.605 62.365 61.056 41.434  
 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000

205-05 206-05 207-07 208-07 209-04 210-07 211-07 212-05 213-05  
 28.912 40.312 46.977 55.217 48.675 55.262 47.166 40.239 29.714  
 38.437 51.700 60.740 71.504 63.078 71.630 61.176 51.605 38.092  
 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000 36.000


214-05 215-05 216-05 217-05  
 30.097 40.579 40.590 30.954  
 39.662 51.931 51.977 39.708  
 36.000 36.000 36.000 36.000

MAXIMUM INTEGRATED ASSEMBLY EXPOSURE IS 0.616960+04 RAD/T IM ASSEMBLY 110  
 MAXIMUM PEAK AXIAL EXPOSURE IS 0.793660+04 RAD/T, OCCURRING AT 38.00 0.0 OF THE CORE HEIGHT IN ASSEMBLY 100  
 CORE AVERAGE EXPOSURE IS 0.504620+04 RAD/T  
 Equal to 133.47 EFPD

----- BATCH AVERAGE EXPOSURES -----

BATCH NUMBER	BATCH NAME	AVERAGE EXPOSURE (RAD/T)
1	A1	5.793
2	A2	5.204
3	B1	6.031
4	B2	5.334
5	C	3.619
6	C+	6.625
7	C+	5.210

*Southern California Edison Company*



SAN ONOFRE NUCLEAR GENERATING STATION  
P.O. BOX 128  
SAN CLEMENTE, CALIFORNIA 92672

J. G. HAYNES  
STATION MANAGER

TELEPHONE  
(714) 492-7700

September 18, 1984

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Subject: Docket No. 50-362  
30-Day Report  
Licensee Event Report No. 84-037  
San Onofre Nuclear Generating Station, Unit 3

Pursuant to Limiting Condition for Operation (LCO) 3.4.7, Action Statement 'd' of Appendix A, Technical Specifications to Facility Operating License NPF-15 for San Onofre Unit 3, this submittal provides the required 30-day written Licensee Event Report (LER) for an occurrence involving the Reactor Coolant System specific activity. Neither the health and safety of plant personnel nor the public were affected by this event.

If you require any additional information, please so advise.

Sincerely,

Enclosures: LER No. 84-037

cc: A. E. Chaffee (USNRC Senior Resident Inspector, Units 1, 2 and 3)  
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)  
J. B. Martin (Regional Administrator, NRC Region V)  
Institute of Nuclear Power Operations (INPO)

IE22  
11