



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

NUCLEAR LICENSING & SAFETY DEPARTMENT

September 8, 1984

U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D. C. 20555

Attention: Mr. Harold R. Denton, Director

Dear Mr. Denton:

SUBJECT: Grand Gulf Nuclear Station
Units 1 and 2
Docket Nos. 50-416 and 50-417
License No. NPF-13
File: 0260/15180/L-860.0
Revision 1 to Amendment 13 of the
Technical Specifications
AECM-84/0446

MP&L was notified by your office on September 4, 1984, that seven of the technical specification pages included in your transmittal to us of Amendment 13 to the Operating License on August 31, 1984, contained uncorrected typographical errors. The subject pages were then transmitted to us by telecopy.

Pursuant to our request for documentation of the corrections, MP&L received Ms. Adensam's letter of September 6, 1984, which included two attachments. One attachment enclosed eight corrected technical specification pages, while the other enclosed ten pages. The attachment of ten pages included the eight pages of the other attachment, and both attachments included the seven pages received on September 4. MP&L confirmed with your staff by telephone on September 7, 1984, that the attachment of ten corrected pages was the correct package for implementation into the technical specifications.

The letter stated that the corrections were of typographical errors. However, MP&L's review of the pages revealed that one of the changes (on two different pages) was of technical significance, rather than a typographical error. This was the change of the required flow rate for surveillance of the containment spray system from 5650 to 7450 gpm on page 3/4 6-24. Current surveillances are adequate to meet the requirements of the revised specifications and no additional action on our part in that area is required.

8409120166 840908
PDR ADOCK 05000416
P PDR

Member Middle South Utilities System

8021
1/0


MISSISSIPPI POWER & LIGHT COMPANY

AECM-84/0446

Page 2

MP&L has completed the review of these corrected pages.

Yours truly,



L. F. Dale

Director

JOE/SHH:rg

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. N. S. Reynolds
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. J. P. O'Reilly, Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30323