

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4504

JOHN S. KEMPER
VICE-PRESIDENT
ENGINEERING AND RESEARCH

SEP 06 1984

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Docket Nos.: 50-352
50-353

Subject: Limerick Generating Station, Units 1 and 2
Information for Materials Engineering Branch (MTEB)
Regarding SER Confirmatory Issue No. 22 (Fracture
Toughness of Containment Pressure Boundary).

Reference: (1) Letter, J. S. Kemper (PECO) to A. Schwencer
(NRC), dated May 25, 1984.

Attachments: (1) Compliance with General Design Criterion
(GDC) 51.
(2) Certified Material Test Reports (CMTR).
(3) Stress Intensity Factor KI Calculation for
Assumed Flaws in 24-inch Feedwater Check Valve
Body Castings.

File: GOVT 1-1 (NRC)

Dear Mr. Schwencer:

Attachment (1) is submitted to confirm compliance of Limerick Generating Station Units 1 and 2 with the requirements of GDC 51, "Fracture Prevention of Containment Pressure Boundary". Attachment (2) provides the CMTRs for the containment pressure boundary components evaluated in Attachment (1). Attachment (3) is a fracture mechanics calculation summary which provides, in part, the results of the fracture mechanics evaluations performed at the 1180 psi maximum pressure during the 40°F lowest temperature operation experienced by the feedwater check valves when acting as a containment pressure boundary. This summary also includes information on the size and location of the assumed flaw, the stress direction, and a description of how the fracture mechanics analysis was performed. Reference (1) previously documented the fracture toughness capability of the Limerick Class 1 feedwater isolation check valves.

Sincerely,

Jw Ballyhen
for
J.S. Kemper

B001

8409130133 840906
PDR ADOCK 05000352
F PDR

JHA/gra/08318401

cc: See Attached Service List

cc: Judge Lawrence Brenner (w/o enclosure)
Judge Peter A. Morris (w/o enclosure)
Judge Richard F. Cole (w/o enclosure)
Judge Christine N. Kohl (w/o enclosure)
Judge Gary J. Edles (w/o enclosure)
Judge Reginald L. Gotchy (w/o enclosure)
Troy B. Conner, Jr., Esq. (w/o enclosure)
Ann P. Hodgdon, Esq. (w/o enclosure)
Mr. Frank R. Romano (w/o enclosure)
Mr. Robert L. Anthony (w/o enclosure)
Ms. Maureen Mulligan (w/o enclosure)
Charles W. Elliot, Esq. (w/o enclosure)
Zori G. Ferkin, Esq. (w/o enclosure)
Mr. Thomas Gerusky (w/o enclosure)
Director, Penna. Emergency (w/o enclosure)
Management Agency
Angus R. Love, Esq. (w/o enclosure)
David Wersan, Esq. (w/o enclosure)
Robert J. Sugarman, Esq. (w/o enclosure)
Martha W. Bush, Esq. (w/o enclosure)
Spence W. Perry, Esq. (w/o enclosure)
Jay M. Gutierrez, Esq. (w/o enclosure)
Atomic Safety & Licensing (w/o enclosure)
Appeal Board
Atomic Safety & Licensing (w/o enclosure)
Board Panel
Docket & Service Section (w/o enclosure)
Mr. James Wiggins (w/o enclosure)
Mr. Timothy R. S. Campbell (w/o enclosure)

Attachment (1)
Limerick Generating Station, Units 1 and 2
Compliance with General Design Criterion (GDC) 51

From June 21 to June 24, 1983, a compliance review was held at the offices of Bechtel and General Electric by Mr. J. Halapatz (NRC/MTEB) to assess compliance with GDC-51. The reviewer examined drawings, certified material test reports (Attachment 2), and heat treatment records of the reactor containment pressure boundary ferritic materials for compliance with GDC-51. The limiting components were identified. The metallurgical characterization of these materials, when correlated with the data presented in NUREG-0577 and the Summer 1977 Addenda of the ASME Code Section III, provides the technical basis for the staff's evaluation of the compliance with Code Class 2 requirements of these materials.

The following are the conclusions of the MTEB reviewer concerning permissible lowest service metal temperature (PLSMT).

1. Main Steam Isolation Valve (F028A typ., S/N 1-683 typ.)

- Body: SA 216 WCB by Quaker Alloy
Normalized: 4- $\frac{1}{4}$ " min design thk: NUREG-0577 Table 4.4 assigns a ($\overline{NDT} + 1.3\sigma$) TNDT of +57°F. NUREG-0577 Fig. B2 would infer (because material is normalized) a TNDT in the population at or below the \overline{NDT} of +35°F (Table 4.4). S'77 Addenda CL-2 rules, assuming a TNDT of +35°F, would assign a PLSMT of +85°F to the material.
- Cover: SA 105 Gr II: Heat treated by Cann & Saul:
Normalized: 4- $\frac{1}{4}$ " min design thk: NUREG-0577 Table 4.4 assigns a ($\overline{NDT} + 1.3\sigma$) TNDT of -5°F: S'77 Addenda CL-2 rules assign a PLSMT of +45°F.
- Poppet: SA 105 Gr II: Heat Treated by Cann & Saul:
Normalized: 5-7/8" min design thk: As with the cover, a ($\overline{NDT} + 1.3\sigma$) TNDT is assumed to be -5°F: S'77 Addenda CL-2 rules assign a PLSMT of +55°F.
- Bolting: 2"SA 193 Gr-B7 and SA 194 Gr-2H:
NUREG-0577 Table 4.6 categorizes these materials as having the least susceptibility to brittle fracture.

2. Main Steam Flued Head (Process pipe is integral within flued head)

SA 105 Gr II and SA 350 Gr. LF2: Quenched and tempered: 5 in. axial thickness: NUREG-0577 Table 4.4 assigns a TNDT of -28°F to normalized material. The materials are both categorized as C-MN, quenched and tempered, and, therefore, could be assumed to have a TNDT below -28°F . Assuming a TNDT of -28°F , S'77 Addenda CL-2 rules assign a PLSMT of $+27^{\circ}\text{F}$.

3. Feedwater Flued Head (Process pipe is integral within flued head)

SA 350 Gr. LF2: 8" Axial Thk: Normalized: NUREG-0577 Table 3.2 categorize material as C-MN comparable to SA-105. NUREG-0577 Table 4.4 assigns a $(\overline{\text{NDT}} + 1.3\sigma)$ TNDT of -5° to normalized SA 350 LF2: S'77 Addenda CL-2 rules assign a PLSMT of $+67^{\circ}\text{F}$.

4. Feedwater Isolation Valve (F074A typ.)

Body: SA 352 Gr LCB: Quaker Alloy: Normalized (interrupted quench): 6 hrs @1630/1650 $^{\circ}\text{F}$; Furnace Cool 1440/1460 $^{\circ}\text{F}$, for 2 hrs; 1420-1430 $^{\circ}\text{F}$, for 40 min; SA 352 Gr. LCB is categorized as similar to SA 216.

NUREG-0577 Table 4.4 assigns a $(\overline{\text{NDT}} + 1.3\sigma)$ TNDT of $+57^{\circ}\text{F}$. NUREG-0577 Fig. B-2, however, would assign a TNDT in the population below $\overline{\text{NDT}}$ of $+35^{\circ}\text{F}$ (Table 4.4). Based on assuming TNDT of $+35^{\circ}\text{F}$, S'77 Addenda CL-2 rules would assign a PLSMT of $+80^{\circ}\text{F}$.

Cover: SA 350 Gr LF2 (by Cann & Saul): Normalized and tempered: 5" min design thk: SA 350 Gr LF2 is categorized as C-MN (per NUREG-0577 Table 3.2) comparable to SA 105: NUREG-0577 Table 4.4 assigns a $(\overline{\text{NDT}} + 1.3\sigma)$ TNDT of -5°F ; S'77 Addenda CL-2 rules assign a PLSMT of $+50^{\circ}\text{F}$.

Disc: SA 352 Gr LCB: Quaker Alloy: 3.75" min Thk. Normalized: NUREG-0577 Table 4.4 assigns a $(\overline{\text{NDT}} + 1.3\sigma)$ TNDT of $+57^{\circ}\text{F}$. However, S'77 Addenda CL-2 rules based on Fig. B2 data for normalized material assign a PLSMT of $+85^{\circ}\text{F}$, assuming a TNDT $+35^{\circ}\text{F}$ (Table 4.4).

Bolting: SA 193 B7: SA 194 2H: NUREG-0577 Table 4.6 categorizes these materials as having the least susceptibility to brittle fracture.

5. Flued Heads - General

Flued heads identified are limiting materials, SA 105 (X-8 penetration) was specified but SA 350 Gr LF-2 was applied. Normalized, quenched and tempered: 3" max Thk: NUREG-0577 Table 4.4 would assume a TNDT of -28°F : S'77 Addenda CL-2 rules assign a PLSMT of $+2^{\circ}\text{F}$.

6. Penetrations

All penetration sleeves apply per Bechtel Spec. 8031-C-2 Rev. 10: SA 516 Gr 60 or Gr 70, Normalized; or SA 333 Gr 1: SA 537 Gr B is identified, but not applied.

PEN X. 9A/B: SA 516 Gr 60: 1- $\frac{1}{2}$ " Thk: S'77
(Limiting) Addenda CL-2 rules assign a TNDT of 0°F and a PLSMT of +30°F.

X-11: SA 333 Gr 6: 0.812" Thk: NUREG-0577
(Limiting) Table 4.4 assigns a (NDT +1.3σ) TNDT of 67°F; S'77 Addenda CL-2 rules assign a PLSMT of 97°F. However, the material was Cv tested at -50°F to criteria consistent with S'77 Addenda CL-2 rules given the design LMST of 65°F.

X-15 Typ: SA 420 WPL 1: Applying SA 516 Gr 70 and A350 LF1:
Pipe Caps Limiting Thk is 1.156" WL x 18": Cv tested at -50°F to Cv criteria consistent with S'77 Addenda CL-2 rules given the design LMST of 65°F.

7. Equipment Hatch/Personnel Airlocks

69-3 SA 516 Gr 60: 3" Thk: quenched and tempered.
(Typ. Door and barrel reinforcement is identified as
Limiting) limiting. S'77 Addenda CL-2 rules assign a TNDT
-10°F and a PLSMT of +30°F.

MK-70-7: SA 516 Gr 60: 1" thk door assembly.
(Limiting) Normalized: S'77 Addenda CL-2 rules assign a
TNDT of 0°F and a PLSMT of +30°F.

162-1 SA 516 Gr 70: 3" thk. Quenched and tempered.

The above data was compared by the applicant with system design data to determine if the lowest service metal temperature (LMST) for any system was below the PLSMT for the equipment in that system. The LMSTs are identified in Table 1.

The ambient air temperature was assumed to equal the LSMT for those identified components that are part of the primary containment. The ambient air temperature was conservatively calculated by postulating failure of the Reactor Enclosure Air Supply System and all heating under those conditions cited in GDC-51. The reactor enclosure was calculated to maintain ambient temperature above 65°F.

Fluid temperatures were assumed to equal the LMST for those identified components in intimate contact with the fluid. One mode of the feedwater system results in a LMST of 42°F due to HPCI injection from the condensate storage tank. For this mode, four items associated with the feedwater system appeared as potential problems because this LMST was below the NRC-calculated PLMST provided earlier. These four items are the feedwater flued head and the cover, disk, and body of the outboard feedwater isolation check valve.

Subsequent to the June 1983 review, the applicant reviewed these components with the following dispositions:

- . Feedwater Flued Head - the actual thickness of the flued head is 8". This is considerably larger than the minimum design thickness of less than 2.5" and yields a PLMST of 25°F.
- . Feedwater Valve Cover - the actual thickness of the valve cover is 5". This is considerably larger than the minimum design thickness of 2.75" and yields a PLMST of 30°F.
- . Feedwater Valve Disk - Under the limiting condition, HPCI is injecting into the vessel and, therefore, the disc does not have a pressure retaining function in this case.
- . Feedwater Valve Body - The evaluation of PLMST and a fracture mechanics analysis has been provided in a report transmitted by letter, J. S. Kamper to A. Schwencer, dated May 25, 1984. The report calculates a PLMST of 30°F.

The results of these evaluations are summarized in Table 1.

Conclusion

The materials of the reactor containment pressure boundary under the conditions of operation, maintenance testing, and a postulated accident will not fail in brittle fracture and the probability of a rapidly propagating fracture is minimized.

DEFINITIONS

General Design Criteria 51

The reactor containment pressure boundary shall be designed with sufficient margin to assure that under operating, maintenance, testing and postulated accident conditions (1), its ferritic materials behave in a non-brittle manner and (2) the probability of rapidly propagating fracture is minimized. The design shall reflect consideration of service temperatures and other conditions of the containment boundary material during operation, maintenance, testing and postulated accident conditions, and the uncertainties in determining (1) material properties, (2) residual, steady state and transient stresses, and (3) size of flaws.

Reactor Containment Pressure Boundary

The reactor containment pressure boundary as addressed in the NRC licensing review process, consists of those ferritic steel parts of the reactor containment system which sustain loading and provide a pressure boundary in the performance of the containment function under the operating, maintenance, testing and postulated accident conditions. These include equipment hatches, personnel airlocks, drywell head, containment penetration sleeves, process pipes, end closure caps, flued heads and penetrating-piping systems connecting penetration process pipes extending to and including the system outboard isolation valves.

Lowest Service Metal Temperature (LSMT)

The lowest service metal temperature (LSMT) is defined as the minimum temperature of the fluid or metal whenever the component must perform its pressure retaining function under operating, maintenance, testing, and postulated accident conditions.

Permissible Lowest Service Metal Temperature (PLSMT)

The permissible lowest service metal temperature (PLSMT) as defined by the ASME Code Section III NC-2311, is the sum of the temperature (T_{NDT}) and the value of A which is equal to or less than $(LSMT - T_{NDT})$ as shown in Figure NC-2311(A)-1 corresponding to the thickness of the material. To insure fracture toughness, the PLSMT of the limiting ferritic steel components of the reactor containment pressure boundary must be less than or equal to the LSMT under operating, maintenance, testing and postulated accident conditions.

SUMMARY
TABLE 1

Limiting Item*	Part	MTL	Thickness (in)		PLSMT* (°F)	Limiting Condition	LMST (°F)	Remarks
			Min. Req. Thk	Actual Thk				
Main Steam								
Flued Hd. MSIV	X-7A(Typ)	SA350 Gr. LF2		5.0 (Axial)	27°F	Maint. & Test	120°F	The reactor, MSIV's, flued head, and piping water hydrotested at 120°F.
Body	F028(Typ)	SA216WCB		4.25	85°F	"	"	
Cover		SA105 Gr II		4.25	45°F	"	"	
Poppet		SA105 Gr II		5.88	55°F	"	"	
Feedwater					(Using Min. Req. Thk)			PLSMT based upon material thickness required to perform its pressure retaining function.
Flued Hd. Isolation Valve	X-9A/B(Typ)	SA350 Gr LF2	<2.5	8.00 (Axial)	25°F	Postulated Accident	42°F	
Body#	F074A(Typ)	SA352 Gr LCB	1.18	2.31	30°F	"	"	
Cover		SA350 Gr LF2	2.75	5.00	30°F	"	"	
Disc****		SA352 Gr LCB	2.78	3.75	NA	NA	NA	
Flued Heads (Gen)	X-8(Typ)	SA350 Gr LF2		3.00	2°F	Postulated Accident	65°F	
Sleeves								
Feedwater** Steam to HPCI	X-9A/B(Typ)	SA516 Gr. 60		1.50 (wall)	30°F	"	"	
Spare Pen	Pen X-11	SA333 Gr. 6		0.81	**65°F	"	"	
& Pipe Caps	X-15(Typ)	SA420 WPL1		1.16	**65°F	"	"	
Equip. Hatch	69-3 Door/barrel Assy.	SA516 Gr 60		3.00	30°F	Maint. & Testing	65°F	Postulated loss of reactor enclosure air supply and heating system
	70-7 (Door Assy)	SA516 Gr 60		1.00	30°F	"	"	
Personnel Air Locks	162-1	SA516 Gr 70		3.00	30°F	"	"	

NOTES: * Defined by the NRC.

** Use Lowest Metal Service Temp. (LMST)

*** Categorized by the NRC as a Sleeve.

**** Disc does not have a pressure retaining function under limiting condition.

For evaluation of PLSMT see report submitted by letter, J. S. Kemper (PECo) to A. Schwencer (NRC), dated 5/25/84.

ATTACHMENT #2: Index for Attached CMTRs (Sh 1/2)

<u>Limiting Item - Part</u>		<u>MHI Heat No</u>
Main Steam Penetrations	X-7A 7B 7C 7D	44736 - 8 ↓ -6 -6 -8
		(FUELED HEAD (TYP.) HEAT NO.: 2L2574)
Feedwater Penetration	X-9A X-9B	B3596 ↓
		(fueled heads: Heat No: K-5073)
Penetration (Gen)	X-8 X-11 X-15	68328 (fueled head heat No. is 326N077) N31420 X5996
Equip Hatch	69-3 70-7	66B094 67A756
Airlock	162-1	C8676
Feedwater Isolation Valve	1F074A/B	
Body	↓	F6137/F6152
Cover		213643/213643
Disc		F6589/F6589

INDEX FOR ATTACHED CMTRS (SK 2/2)

LIMITING ITEM - PART

MATERIAL HEAT NO.

MAIN STEAM

ISOLATION VALVE - IF028A (TYP.)

BODY

8816

COVER

219222

POPPET

219727

PURCHASER: **08**
 Chicago Bridge & Iron Co.
 6 Pur. Dept.

LUKENS STEEL COMPANY
 COATESVILLE, PA. 19320
TEST CERTIFICATE

DATE: **6-3-71** FILE NO: **1540-03-05**
 CONSIGNEE:

MILL ORDER NO. **50018-3** CUSTOMER P.O. **70-7198U-23** RG **6171 LK**

SPECIFICATIONS: **SA-516 Gr. 60 CB & I MS-603B Rev. 0 DTD 3/9/70 Sect. 111 Winter 68 Addenda CB & I GP3 516**
O.K. MONOGENEITY TEST
 Rev. 4 DTD 2/25/70

CHEMICAL ANALYSIS

MELT NO.	C	Mn	P	S	Cu	Si	Ni	Cr	Mo	V	Ti	Al	B	Grain Size
U4736	14	1.02	012	028		29								7 - 8

LIMERICK GENERATING STATION, UNIT 1
 PHILADELPHIA ELECTRIC COMPANY
 SPEC. 8031-C-2
 CBI 70-7198

Affirmed and subscribed before me
 this day of **JUN 3 1971**
Phillip A. Romandino Jr.
 Notary Public

PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD PSI X100	TENSILE PSI X100	% ELONG IN	% R.A.	BHN	Long. IMPACTS V-Notch -30°F.	Fracture Appearance % Shear	DESCRIPTION
U4736	8	505	709	29			63 - 56 - 63	50-50-50	1-280 x 129-3/4 x 1"
							Lateral Expansion in Inches .054 .058 .056		
00007	7	477	713	28			66 - 58 - 55	50-50-50	1-322 x 129-3/4 x 1"
							Lateral Expansion in Inches .047 .050 .059		

My Commission Expires April 1, 1972

RAM 6-10-71


Plates and tests heated to 1625°F. ±25°F., held 1/2 hr. per inch min. and air cooled.

We hereby certify that the above material has been manufactured according to SA-516 Gr. 60 CB & I MS-603B Rev. 0 DTD 3/9/70 Sect. 111 Winter 68 Addenda CB & I GP3 516 Rev. 4 DTD 2/25/70 and that we have complied with all the requirements of these specifications.

We hereby certify the above figures are correct as contained in the records of Lukens Steel Company. *7-75*
 SUPERVISOR TESTING: *A. H. E. L...*

08

LUKENS STEEL COMPANY
COATESVILLE, PA.



Order # 50012-3 Contract _____ Furnace 200' Date 5-9-71

Heat No. 04736-7 Original Charts are available for customer verification

- 8

H. J. Allen 80

80000

MAIN STEAM PENETRATION X-7A

FLUED HEAD (TYP.)

HEAT NO. 2L2574



NATIONAL FORGE COMPANY

TEST CERTIFICATION

Limerick Flued Head

CUSTOMER: The M. W. Kellogg Company

NATIONAL FORGE CO. ORDER: 60-4875

CUSTOMER ORDER NO.: N-8774-11

SPECIFICATION: ASME-SA 350-LF2, ES-11 and ES-151, Addendum "A" G.E. Spec. 21-A-1556 & 21-A-9416 and ASME Code, Section III, NE2310 and NE2321

ITEM-SERIAL NO.

DESCRIPTION:

02-001
N42
MARK: Item 15

42" OD Flued Head Fittings
Drawing 131-C-7525-2, Rev. 2, Part No. 2-EE

ITEM-SERIAL	HEAT NO.	C.	Mn.	P.	S.	Si.	Ni.	Cr.	Mo.	V.
02-001	2L2574	.23	1.03	.014	.014	.23				.04

TEST	ULTIMATE TENSILE STRENGTH (P.S.I.)	YIELD PT (P.S.I.)	% ELONGATION	% REDUCTION OF AREA	XXXXXXXX % Shear	Charpy IMPACT (FT-LBS.) @ 0°F	Lat. Exp.
02-001	84,250	72,000	32.0	72.3	59% 57% 63%	109.0 95.0 113.0	.078 .070 .081
QUENCHED @ 1580°F for 6 hrs. in water TEMPERED @ 1220°F for 6 hrs. GRAIN SIZE 8-9 FREE OF MERCURY CONTAMINATION ROUND FLUTED INGOT MOLD TENSILE SPEC. 505 TESTED LONGITUDINAL GAGE LENGTH 2"							
						HEAT TREAT PROCEDURE HT-60-A-4875-OA 10/27/72 IMPACT PROCEDURE LT-60-A-4875-OA, Rev. A 1/22/73	

State of Pennsylvania }
Warren County } ss:


Before me, a Notary Public in and for above County, personally appeared N. C. Baxter, Jr.
of the National Forge Company, who being duly Sworn according to Law, deposes and says that the above Report is a true and correct copy of tests as contained in the records of the Company.

N. C. Baxter, Jr.

Subscribed and Sworn to
14th March 73
at its day of 19...

Kathleen J. Harvey
My Commission expires.....

Embossed Hereon is My
Irvine, Warren County, Pennsylvania, Notary Public
My Comm.....



FW Fired Head
Penetration X-9A/B

Heat No. B3596



- Material Types:
 1. Welded Assemblies
 2. Non-Welded Code Matl.
 3. Non Code Matl.

See Standard 607.3-7 for instructions for using this form.

MATERIAL HEAT NUMBER SHEET

SHIPMENT # 81 UNIT #1

C 2 F. 10-1

Piece-Mark	Serial No.	CTR REF. No.	Material Heat No.	Matl. Type	Piece-Mark	Serial No.	Material Heat No.	Matl. Type
(1)			335-A ~ INSERT					
			ASSY					
(1)	-1-		83611	1 1				
(9)	245-4	-	114,516C2540	A36 3				
(2)	336-1	-1-	163 83576	3 1				
(2)		-2-	163 83576	3 1				
(2)		-1-	23596	3 1				
(2)		-2-	23596	3 1				
(4)	336-3	-	49,748232	A36 3				
(5)	336-4	-	49,748232	A36 3				
(8)	336-5	-	49,748232	A36 3				
(2)		-	748232	A36 3				
(2)		-	748232	A36 3				
(2)		-	748232	A36 3				
(2)		-	748232	A36 3				
(2)		-	748232	A36 3				
(2)	336-11	-	49,748232	A36 3				
(2)	336-12	-	L2x2x3/16	A36 3				
(1)	145-2A	-	131,516C2431	A36 3				
(1)	245-3A	-	131,516C2431	A36 3				
(4)	307-2	-1-	85,728418	A36 3				
(16)	307-3	-1-	85,728418	A36 3				
(16)	307-4	-1-	85,728418	A36 3				
(4)	307-5	-1-	85,728418	A36 3				
(4)	307-6	-1-	122,658C819	A36 3				
(4)	307-7	-1-	122,658C819	A36 3				
(4)	307-8 ^R	-1-	119,661C579	A36 3				
(4)	307-9 ^R	-1-	119,661C579	A36 3				
(4)	307-10	-1-	85,728418	A36 3				

LIMERICK GENERATING STATION, UNIT 1
 PHILADELPHIA ELECTRIC COMPANY
 SPEC. 8031-C-2
 CBI 70-7198

J. J. McQuillan
Resident
 7-9-75

Data taken from applicable CBI records.
 CBI Shop QA *[Signature]*

Date 7-10-75

Revisions	By	
	Chkd	
	Date	

Reviewed (for material covered by code):
 Authorized Inspector *[Signature]*

Date 7/11/75

Contract No. 70-7193 U
 No. 81
 Sh 1 of 1
 G0830 REV DEC

BUYER:

E91

Chicago Bridge & Iron Co.
Pur. Dept.

LUKENS STEEL COMPANY

COATESVILLE, PA. 19320

TEST CERTIFICATE

(2-P-10-1)

DATE: 9-23-71

FILE NO 1540-03-06

CONSIGNEE:

MILL ORDER NO.

CUSTOMER P.O.

52474-2

71-7198U-40

RG 91571 DR

REFERENCES:

MS-603-B Rev. 0 DTD 3/9/70 SA-516-69 Gr. 60 Sect. III thru Winter 1968 Addenda

BEND TEST

O.K.

HOMOGENEITY TEST

CHEMICAL ANALYSIS

MELT NO.	C	Mn	P	S	Cu	Si	Ni	Cr	Mo	V	Ti	Al	B	Grain Size
596	12	95	006	020		22								7-8

LIMERICK GENERATING STATION, UNIT 1
PHILADELPHIA ELECTRIC COMPANY
SPEC. 8031-C-2
CBI 70-7198

PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD PSI X100	TENSILE PSI X100	% ELONG IN 8"	% R.A.	BHN	Long. IMPACTS V-Notch -30°F.	Fracture Appearance % Shear	DESCRIPTION
3596	9	436	668	33			58 87 49	60-60-60	1-256 x 128 x 1-1/2"
	8	441	643	34			97 98 67	70-70-70	1-

Lateral Expansion in inches
.074 .053 .056

Lateral Expansion in inches
.073 .075 .059

plates and tests heated 1550-1650°F., held 1/2 hr. per inch min. and air cooled.

10-5-71

Notary Public
My Commission Expires April 1, 1972

Shelby A. Romandino

SUPERVISOR TESTING

(Signature)

Feedwater
penetration X-9A

fluid head

heat No. K-5073

Cameron

IRON WORKS, INC.

P. O. BOX 1212 HOUSTON, TEXAS 77001

CIFICATE OF TESTS

Date 10 September 1975

S
O
L
D
T
O

SARGENT INDUSTRIES
AIRITE DIVISION
1700 East Grand Avenue
El Segundo, Ca 90245

S
H
I
P
T
O

Customer Order No. N5035
C.I.W. Sales Order No. F-12979
Specification Carbon Steel in accordance with ASME Sec. II SA-350
~~ASME Sec. III Class 1 Component, except as modified by P.O.~~

Description of Material
Flu@d Head Dwg.# 9256-13 N/C

C.I.W. Part Number	Heat No.	CHEMICAL ANALYSIS											
		C	MN	P	S	SI	CR	NI	MO	W	V	CU	
60607-1	2015	.20	1.23	.015	.012	.23							

C.I.W. Part No. or Size	Quantity	Heat No.	MECHANICAL PROPERTIES					Charpy Impact	Hardness
			Yield PSI	Tensile PSI	% Elong. in.	% Red. Area			
60607-1	4	K 5073	See attachment for mechanical properties.						

Code requirements for U.T. and P.T. not performed.

*Bechtel Corp.
M. Schlegel
9-22-75*

C.I.W. Heat No. Jominy Hardenability Grain Size
Heat treat performed in accordance with approved CIW procedure FH-414 Rev. B.
1550°F., held 6 hrs. at temp. AIR cooled.

VENDOR DOC. REVIEW GRP.
P 126A E 188 1

REVIEW
QUALITY CONTROL
AP 28 DC
9/15/75
STAMP

Subscribed and Sworn to before me this 10th Day of September 1975

MATERIAL CODE

No. 418

G. A. Touchton
Notary Public
G. A. TOUCHTON
Notary Public in and for Harris County, Texas
My Commission Expires June 1, 1976

H. O. Wright
H. O. WRIGHT, Metallurgist
197

MECHANICAL PROPERTIES:

Forging Ser.#	Heat#	.2% Offset Y.S. psi	Ult. T.S. psi	Elong. %	R.A. %
---------------	-------	---------------------	---------------	----------	--------

Impact test performed in accordance with approved CIW Inspection procedure FI-77 N/C
 Test Temp. ~~Transition Temperature~~ ~~Fracture Type~~

Forging Ser.#	Heat#	.2% Offset Y.S. psi	Ult. T.S. psi	Elong. %	R.A. %	Test Temp.	Impact Energy Ft.-Lbs.	Transition	Fracture	Tensile Test	
0001	K 5073					+32°F.	138.0	Ft.Lbs.	.084	100%	4
						32	92.0	.072	60		
						32	104.0	.072	80		
						32	140.0	.090	99		
						32	140.0	.084	100		
						32	136.0	.086	100		
0002	K 5073					+32°F.	147.0		.089	100%	4
						32	134.0	.085	100		
						32	101.0	.071	80		
						32	100.0	.071	80		
						32	114.0	.075	80		
						32	121.5	.079	80		
0003	K 5073					+32°F.	144.0		.090	100%	4
						32	143.0	.094	100		
						32	114.0	.081	70		
						32	97.0	.082	70		
						32	102.0	.085	80		
						32	126.0	.093	99		
0004	K 5073	52,400	76,100	30.8	70.4	+32°F.	102.0		.075	80	4
						32	154.0	.085	100		
						32	108.0	.076	80		
						32	146.0	.088	100		
						32	109.0	.080	80		
						32	138.0	.079	99		

MRR-8031-SF-1325

VENDOR DOC. REVIEW GRP. 126A F 188.1

MATERIAL CODE

No. 418

REVIEW QUALITY CONTROL
 AP 26 DC
 STAMP 9/15/75

Bechtel Corp.
 M. Z. Philippe
 9-22-75

FW penetration X-9B
fixed head

Heat No. K-5073

Casper

IRON WORKS, INC.

P. O. BOX 1212 HOUSTON, TEXAS 77001

CERTIFICATE OF TESTS

Date 10 September 1975

S
O
L
D
T
O

SARGENT INDUSTRIES
AIRITE DIVISION
1700 East Grand Avenue
El Segundo, Ca 90245

S
H
I
P
T
O

Customer Order No. 15035	C.I.W. Sales Order No. F-12979	Specification Carbon Steel in accordance with ASME Sec. II SA-312 LF 2, ASME Sec. III 1974 Class I Component, except as modified by P.O.
-----------------------------	-----------------------------------	---

Description of Material
Fluid Head Dwg. # 9256-13 N/C

C.I.W. Part Number	Heat No.	CHEMICAL ANALYSIS											
		C	MN	P	S	SI	CR	NI	MO	W	V	CU	
60607-1	K 5073	.20	1.23	.015	.012	.23							

C.I.W. Part No. or Size	Quantity	Heat No.	MECHANICAL PROPERTIES					Charpy Impact	Hardness
			Yield PSI	Tensile PSI	% Elong. In.	% Red. Area			
60607-1	4	K 5073	See attachment for mechanical properties.						

Code requirements for U.T. and P.T. not performed.

*Bechtel Corp.
M. J. Phillips
9-12-75*

C.I.W. Heat No.	Jominy Hardenability	Grain Size
Heat treat performed in accordance with approved CIW procedure FH-414 Rev. B. 1550°F., held 6 hrs. at temp. Air cooled.		

REVIEW
QUALITY CONTROL
AP 28 OC
9/15/75
STAMP

MATERIAL CODE

No. 418

Subscribed and Sworn to before me this 31st day of September 1975

[Signature]
Notary Public in and for Harris County, Texas
G. A. TOUCHTON
My Commission Expires June 1, 1977

H. O. WRIGLEY *[Signature]* 1975

MECHANICAL PROPERTIES:

Forging Ser.#	Heat#	.2% Offset Y.S. psi	Ult. T.S. psi	Elong. %	R.A. %	Impact test performed in accordance with approved CIW Inspection procedure FI-77 N/C				Tensile Test Lot#
						Test Temp.	Absorbed Energy	Lat. Expansion %	Shear Fracture %	
0001	K 5073					+32°F.	138.0 Ft.Lbs.	.084	100%	#4
						32	92.0	.072	60	
						32	104.0	.072	80	
						32	140.0	.090	99	
						32	140.0	.084	100	
						32	136.0	.086	100	
0002	K 5073					+32°F.	147.0	.089	100%	4
						32	134.0	.085	100	
						32	101.0	.071	80	
						32	100.0	.071	80	
						32	114.0	.075	80	
						32	121.5	.079	80	
0003	K 5073					+32°F.	144.0	.090	100%	4
						32	143.0	.094	100	
						32	114.0	.081	70	
						32	97.0	.082	70	
						32	102.0	.083	80	
						32	126.0	.093	99	
0004	K 5073	52,400	76,100	30.8	70.4	+32°F.	102.0	.075	80	4
						32	154.0	.085	100	
						32	108.0	.076	80	
						32	146.0	.088	100	
						32	109.0	.080	80	
						32	138.0	.079	99	

P 425 A F 175
 1
 34
 REVIEW DOC. REVIEW 10/2

MATERIAL CODE
 No. 418

REVIEW
 QUALITY CONTROL
 AP 26 OC
 STAMP 9/15/75

Bechtel Corp.
M. Z. Philippe
 9-27-75

Fluid Head (cen): X-8

heat No 326N077

CARLTON FORGE WORKS

7743 EAST ADAMS STREET
PARAMOUNT, CALIFORNIA

METALLURGICAL ANALYSIS REPORT

CUSTOMER: Sargent-Airite Div.
 CUSTOMER ORDER NO.: NS058 Item #
 C.F.W. S.O. NO.: 134463
 QUANTITY: 6 & T.S.
 DATE: 6-5-75
 PART NO.: 9256-11 N/C
 PART NAME OR DESCRIPTION:
 MATERIAL: 1029
 SPECIFICATIONS: ASME-SA-105-73, Sect. II, 1974 *
 CONDITION OF FORGINGS: Normalize 1650 F., 2hrs., air cool, Quench 1500 F., 2hrs., oil cool, Temper 1200 F., 6hrs., air cool per NP-AS-004 N/C ***
 HARDNESS OF FORGINGS BHN: 137/156
 Forgings fluorescent penetrant inspected per
 Forgings magnetic particle inspected per
 Forgings ultrasonic inspected per
 Forgings radiographically inspected per
 Not performed, to be performed by SI/AD
 Not performed, to be performed by SI/AD
 Mechanical property acceptance of listed forgings are based on results from:
 Sectioned forgings or rolled ring
 Separately forged test bar
 Integral test ring or slug
 Heat treat response test bar
 which conforms to material specifications listed above and are tabulated below:

MILL: Bethlehem Steel
 HEAT NO.: 325N077

CHEMICAL ANALYSIS

	C	Mn	P	S	Si	Ca	Ni	Fe	Al	Ti	Cb & Ta	Cu	B	Co	Mg	Zn	N	H	O	
												W	Sn	V	Zr	Mo				
MILL DATA	.29	.80	.026	.030	.20			Bal												

TENSILE

STRESS RUPTURE

SERIAL NO.	CODE	TEST		YIELD STRESS, KSI	ULTIMATE STRESS, KSI	% ELONG. IN 4D	% RED. OF AREA	TYPE BAR	STRESS, KSI	TEMP., °F	HRS. TO BREAK	% ELONG. IN 4D	INCREASED STRESS TO	GRAIN SIZE
		LOCATION & DIRECTION	TEMP.											
CFW DATA				46.6	75.2	32.0	69.5							
#001 thru #015		Heavy Thin	RT	45.1	75.7	33.0	71.3							

*Bechtel Corp.
M.P. Phillips
7-1-75*

MICROSTRUCTURE:

REMARKS: ***@Aircraft Heat Treat
 *ASME-Section III, Class I, 1974, Edition.
 Contract No. 8031-P-310

REVIEW QUALITY CONTROL
 STAMP 7/1/75

CODE	CLEANLINESS AND PREP.	JOM. HARD. IN 1/16 OF AN INCH - R "C" -												
		1	2	4	6	8	12	16	22	32				

I HEREBY CERTIFY THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF THIS MATERIAL ANALYSIS REPORT IS TRUE AND CORRECT.
 SWORN AND SUBSCRIBED TO BEFORE ME THIS 5TH DAY OF JUNE 1975

ASME MATERIAL CODE

COPIES OF THIS SPECIFICATION ARE AVAILABLE TO YOU OR YOUR CUSTOMER AT THE ASME HEADQUARTERS, 3300 MICHIGAN AVENUE, NEW YORK, N.Y. 10017. THIS SPECIFICATION IS SUBJECT TO PERIODIC REVISIONS AND ACCEPTED IN ACCORDANCE WITH THE APPLICABLE BLUEPRINTS AND SPECIFICATIONS.

*Bechtel Corp.
M.P. Phillips
METALLURGIST*

MY COMMISSION EXPIRES

0-126 AC-F-180-1

Penetration X-8

Heat No. 68328



ARMO ARMO STEEL CORPORATION
AMBRIDGE WORKS
Ambridge, Pennsylvania

12" Sch 100 Gr.

NUCLEAR

REPORT OF TESTS

8-2-F-1153.1

CUSTOMER Capital Pipe and Products, Inc.

DATE 10-24-69

SPECIFICATION ASTM A333 Gr. 1 - ASME SA333 Gr. 1

OUR ORDER NO CC13455-0148

MATERIAL Steel Pipe

CUSTOMER'S ORDER NO. 43933

100' CAR. PIPE #43719

IDENTIFICATION TEST	TENSILE TESTS			HYDRO TEST	HEAT NUMBER	ANALYSIS															
	YIELD PSI	CLIMATE PSI	% ELONG. IN 2 IN.			C	Mn	P	S	SI	HI	Cr	Mo								
None																					
12 1/2 x 84 1/2	49500	72100	44.0	2400 #	68328	22.81	0.17	0.14													
KEYHOLE CORRPY	50°F	32-34-31			32 Ave.	10-10000															
Material from 100' Steel Pipe																					
Charpy																					
Flattening																					
Sworn to and subscribed before me this 4th day of NOVEMBER A.D. 1969.																					
RM 6-7-71																					

Chicago Bridge & Iron Co.
P. O. #G-40295-2
Contract #70-7198U
ITEMS 12 & 13

PAULINE DISTRAMIS, NOTARY PUBLIC
AMBRIDGE BOROUGH, DEWAR COURT
MY COMMISSION EXPIRES MARCH 1, 1972

THE CHEMICAL ANALYSES AND PHYSICAL OR MECHANICAL TESTS REPORTED ABOVE ARE CORRECT AS CONTAINED IN THE RECORDS OF THE CORPORATION.
ARMO STEEL CORPORATION

1271 - D. D. C. 74

12" S/100 Gr-1

W. B. COLEMAN CO.
METALLURGISTS - CHEMISTS - ENGINEERS

9TH AND RIDING SUN AVENUE
PHILADELPHIA, PA. 19140

Physical Test of: Seamless Carbon Steel Pipe Date 10/7/69

Received from: Capitol Pipe & Steel Prods., Inc.

P. O. No. W 44047

Q. 1105-1
G-40295-2
70-71924
ITEMS 125

Laboratory Number	906604			
MARKING	12" Sch. 100	A-333	Gr. 1	
Ht. #68328-	1	2	3	
Size of Bar	10mm	0.394	0.394	0.394
Linear Inch	10mm x	0.394 x	0.394 x	0.394 x
Tensile Strength				
Linear Inch				
Transverse Load				
Lbs. Corrected (In. Centers)				
Deflection				
Inches - Corrected				
Impacts	Charpy			
Notch	Charpy V			
Broken at	Minus 50 ° F			
Resistance to Impact				Avg. impact value
In Ft. Lbs.				
Brinell Hardness	36.0	29.0	37.0	34.0
500 Kg. Load				
Rockwell Hardness	Minimum average impact value required of a set of three specimens-15.0ft. lb.			
Standard Superficial Scale	Minimum impact value permitted on one specimen only of a set-10.0ft. lb.			
Equivalent to Brinell Rockwell				
Witnessed by				
% Shear	30.0	30.0	30.0	
Lateral Expansion (in inches)	0.0345	0.026	0.033	

Remarks:

W. B. COLEMAN CO.

BY *J. B. Kempf*

FORM 2P REV. 5-57 P. P.

LIMERICK GENERATING STATION, UNIT 1
PHILADELPHIA ELECTRIC COMPANY
SPEC. 8031-C-2
CBI 70-7198

hl

R27M 6-7-71

26

Penetration K-11

MHI Heat No. N31420

SL-57

MATERIAL HEAT NUMBER SHEET

Material Types:

- 1. Welded Assemblies
- 2. Non-Welded Code Matl.
- 3. Non Code Matl.

SHIPMENT #56 UNIT #1

9-2-1975

Piece-Mark	Serial No.	Material Heat No.	Mat. Type	Piece-Mark	Serial No.	Material Heat No.	Mat. Type
(1)		DRYWELL INSERT ASSY 44-A		(1)		PENETRATION SUB ASSY 44-E	
		(1) PENETRATION SUB ASSY 44-B		(1) 44-9	1	348 29199 G53021	1
(1) 44-1	1	95 04716 748	1	(1) 44-10	-	46 66B204 A36	3
(1) 44-2	-	46 66B204 A36	3	(4) 43-3	-	311 516J0615 A36	3
(4) 43-3	-	311 516J0615 A36	3	(1) 24-20	-	- BNR TEMP A36	3
(4) 2432	-	153 526C0060 A36	3	(1) 24-21	-	- R. TEMP A36	3
		(2) PENETRATION SUB ASSY 44-C				(1) INS. RESTRAINT PR.77	
(2) 44-5	-	46 66B204 A36	3	(2) 94-1	1	87 68B414 A441	3
(2) 24-22	-	- P.W.C. CND TEMP ALN-MC	3	(2) 94-2	1	84 74B405 A441	3
(2) 44-4	-1	60 65358 G40295-1	1	(2) 94-3	1	87 69B414 A441	3
(2) 44-E	-	274 ALNR ^{MS-9028} G-70161	1	(4) 94-4	1	86 69B390 A441	3
		(1) PENETRATION SUB ASSY 44-D		(4) 94-5	1	89 67B431 A36	3
(1) 24-16	-	155 55B272 A36	3	(2) 94-6	1	89 ↓ ↓	3
(1) 24-17	-	63 69B298 A36	3	(2) 94-7	1	86 69B390 A441	3
(4) 43-7	-	53 74B232 A36	3			(1) 49-A ~ DRYWELL INSERT ASSY	
(1) 44-6	1	147 N31420 G40295-2	1	(1) 49-1	-1	160 B3596 2	1
(1) 44-7	-	52 74B232 A36	3			(1) ~ PENETRATION SUB-ASSY ~ 47-R	
(1) 40-72	1	179 A8640 - 1B	1	(1) 47-10	-1	321 131420 G-42199	1
				(4) 43-7	-	53 74B232 A36	3
				(1) 44-7	-	52 74B232 A36	3
				(1) 24-16	-	155 55B272 A36	3
				(1) 24-17	-	63 69B298 A36	3

LIMERICK GENERATING STATION, UNIT 1
 PHILADELPHIA ELECTRIC COMPANY
 SPEC. 5031-C-2
 CBI 70-7198

Handwritten:
 113 24-75

Data taken from applicable CBI records.

CBI Shop QA *Walter H. George*

Date 2-18-75

Revisions

By

Chkd

Date

00005

Reviewed (for material covered by code):

Authorized Inspector *[Signature]*

Date 2/19/75

Contract No.

70-7198U

No. 56

Sh. 1 of 1



United States Steel Corporation

20 Mr 00 Mr I

National WORKS
C-2-F-1117

STANDARD SWORN TEST REPORT TUBULAR PRODUCTS

8-16-71 DATE

ITEM: Seamless pressure pipe

REMARKS: Normalized at 1600°F for 105 min. & air cooled

NAME: Capital Pipe & Steel Products Inc.

CITY AND STATE:

GRADE: 12L

ASTM A-533

ASME SA-333

CUSTOMER'S ORDER NO.: 5725L

U.S. STEEL OFFICE NO.: KC 34675

INVOICE NO.: 356-03600

COIL OR LOT NO.	SIZE O.D.	WALL THICKNESS	HEAT NUMBER	HYDRO. TEST PRESSURE MIN. P.S.I.	MECHANICAL PROPERTIES			CHEMICAL ANALYSIS (%)						
					YIELD STRENGTH P.S.I.	TENSILE STRENGTH P.S.I.	ELONG. IN. IN. 2"	C	Mn	P	S	Si	Mo	
7455	20"	8/12	N31420	1800	42270	68670	51.0	20.82	0.16	0.21	18			CHECK
			N31420	1800	45730	68640	49.0	20.82	0.16	0.21	18			CHECK
			LIMERICK GENERATING STATION, UNIT 1 PHILADELPHIA ELECTRIC COMPANY SPEC. 8031-C-2 CBI-70-7198					21.25	0.12	0.24	17			TABLE
<u>Flattening test: Satisfactory</u>														
<u>FULL SIZE LONGITUDINAL KEYHOLE CHARPY SPECIMEN @ MINUS -50°F</u>														
			FT LBS		27	28	26							
			1/2 SHEAR		67	67	65							
			LAT. RIP		030	031	029							
<u>FULL SIZE LONGITUDINAL CHARPY V NOTCH IMPACTS @ MINUS -50°F</u>														
			FT LBS		26	28	24							
			1/2 SHEAR		36	38	30							
			LAT. RIP		022	027	020							

Chicago Bridge & Iron Company
PO# G-40293
Contract #70-7198U

STATE OF PENNSYLVANIA
COUNTY OF ALLEGHENY

Subscribed and sworn to before me this 16th day of August 19 71

R. Stanley NOTARY PUBLIC

COMMISSION EXPIRES

A. F. Reftson BEING DULY SWORN ACCORDING TO LAW, DEPOSES & SAYS THAT THE FIGURES SET FORTH ABOVE ARE CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY

A. F. Reftson C. J. ...

U0018

United States Steel Corporation, National Office, Pittsburgh, Pa.

Penetration X-15

Heat No. X5996

PURCHASER: **66**
 Chicago Bridge & Iron Co.
 Pur. Dept.
 Greenville, Pa. 16125

*3 Plates
 Located
 11-24-71*

LUKENS STEEL COMPANY
 COATESVILLE, PA. 19320
TEST CERTIFICATE

DATE: **6-7-71** FILE NO: **1540-03-05**
 CONSIGNEE:

MILL ORDER NO.	CUSTOMER P.O.	
50018-2	70-7198U-23	DP 6271 LX

C-2-F-609-1

SPECIFICATIONS: **SA-516 Gr. 60 CB & I MS-603B Rev. 0 DTD 3/9/60 Sect. 111 Winter 68 Addenda CB & I GPS 516 Rev. 4 DTD 2/25/70**

BEND TEST **C.R.** HOMOGENEITY TEST

CHEMICAL ANALYSIS

MELT NO.	C	Mn	P	S	Cu	Si	Ni	Cr	Mo	V	Ti	Al	B	Grain Size
U4736 X5996	14 12	1.02 1.11	012 010	028 028		29 23								7-8 6-7
LIMERICK GENERATING STATION, UNIT 1 PHILADELPHIA ELECTRIC COMPANY SPEC. 8031-C-2 CBI 70-7198														
Affirmed and subscribed before me this <u> </u> day of <u> </u> JUN 7 1971 <i>Phillip A. Romanick Jr.</i> Notary Public My Commission Expires April 1, 1972														

PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD STRENGTH KSI	TENSILE STRENGTH KSI	ELONGATION IN 8"	% R.A.	BHN	Long. IMPACTS V-Notch -30°F.	Fracture Appearance	DESCRIPTION
U4736	1	482	714	27			42 39 44 Lateral Expansion in Inches .042 .041 .044	% Shear 40-40-40	1-256 x 115 x 1-1/2" - ITEM 60 ITEM 60
U4736	10	487	718	25			57 69 49 Lateral Expansion in Inches .053 .062 .047	50-50-50	2-224 x 109-1/4 x 1-1/2" - ITEM 61
X5996	10	442	653	32			111 119 139 Lateral Expansion in Inches .094 .097 .091	80-80-80	2-240 x 54 x 1-1/4" - ITEM 61A

RAM 6-10-71

Plates and tests heated 1625°F. ±25°F., held 1/2 hr. per inch min. and air cooled.


We hereby certify that the above material has been manufactured according to SA-516 Gr. 60 CB & I MS-603B Rev. 0 DTD 3/9/70 Sect. 111 Winter 68 Addenda **XB** CB & I GPS 516 Rev. 4 DTD 2/25/70 and that we have complied with all the requirements of these specifications.

Phillip A. Romanick Jr.

66

LUKENS STEEL COMPANY
COATESVILLE, PA.

JFW: 4/2
C-2-F-69-1



Order # 50018-2 Contract _____ Furnace 200' Date 5-16-71

Heat No. X5996-10 Original Charts are available for customer verification

Handwritten signature

Equipment Hatch 69-3

Heat No. 66B094

Equipment Hatch 70-7

Heat No 67A756



Material Types:
 1. Welded Assemblies
 2. Non-Welded Code Matl.
 3. Non Code Matl.

See Standard 607 3-7 for instructions for using this form.

MATERIAL HEAT NUMBER SHEET

SHIPMENT # 75 UNIT # 1

Piece-Mark	Serial No.	CTR REF No.	Material Heat No.	Matl. Type	Piece-Mark	Serial No.	Material Heat No.	Matl. Type
(1)			69-A~EQUIPMENT DOOR NECK & HEAD ASSEMBLY ~ 1 1~EQUIPMENT DOOR PENETRATION NECK SUB- ASSEMBLY ~ 67-B					
(1) 67-4	-		275 655H111	A36	3			
(2) 67-5	-		275 655H111	A36	3			
(1) 67-9	-		275 P3576	5	1			
(1) 67-10	-		275 X6003	17A	1			
(1) 67-13	-		275 655H111	A36	3			
(1) 69-1	-		278 2272 ^{MS-572}	G-21166	3			
(1) 69-2	-		278 2272 ^{MS-572}	G-21166	3			
(1) 69-3	-1-		275 663094	46253	1			
(1) 69-3	-2-		275 668094	46253	1			
(1) 70-12	-		277 704541	210723	1			
(1) 70-14	-		277 704541	210723	1			
(2) 70-17	-		277 67A756	224703	1			
(3) 70-18	-		277 728392	139036	1			
(48) 70-19	-		277 70A541	210723	1			
(2) 70-5	-		277 70A541	210723	1			
(2) 70-9	-		277 70A541	210723	1			
(24) 70-11	-		277 70A541	210723	1			
(24) 70-1	-		274 ^{G-23 MS-800-2} 06A4523	G-112262	1			
(24) 70-10	-		^{G-51 MS-800-2} 266 73M351	G-112262	1			
(50) 70-15	-		^{STEEL} 263 1/32 CUTTER PINS	G-21164	3			
(24) 70-14	-		^{G-91 MS-801B} 265 78A691	G-112262	1			
(24) 70-13	-		^{G-55 AISI 4140} 267 3201655	G-112262	3			

LIMERICK GENERATING STATION, UNIT 1
 PHILADELPHIA ELECTRIC COMPANY
 SPEC. 8031-C-2
 CBI 70-7198

Handwritten signature: J. J. Pacitti
 4-25-75

a taken from applicable CBI records.
 CBI Shop QA *Steve H. ...*

Date 4-25-75

Revisions	By	▶	▶
	Chkd		
	Date		

Reviewed (for material covered by code):
 Authorized Inspector *[Signature]*

Date 4/25/75

Contract No. 70-7198U No. 75
 Sh. 1 of 1
 G0810 REV DEC

United States Steel Corporation

CORRECTED TEST REPORT

IRONSTEAD BOARD, ALLEGHENY COUNTY
 MY COMMISSION EXPIRES APRIL 30, 1973
 Member, Pennsylvania Association of Chartered Accountants

REPORT OF PLATES *C-2-F 1157-1*
 WORKS IRONSTEAD DISTRICT U.S. ORDER NO. LA34248 LOAD TALLY OR INVOICE NO. 163-17251
 CUSTOMER ORDER NO. 70-7198H 6/30/71
 CAR OR TRUCK NO. BLE 012288 SHIPPER NO. & DATE 51769 10/28/71 160

STATE OF PENNSYLVANIA
 COUNTY OF ALLEGHENY
 SUBSCRIBED AND SWORN TO BEFORE ME
 THIS 31st DAY OF Oct., 1971

CHICAGO BRIDGE & IRON CO
 P.O. BOX 610
 GREENVILLE PA 16125

SHIP TO
 CHICAGO BRIDGE & IRON CO
 GREENVILLE PA

E. J. ...
 BEING DULY SWORN ACCORDING
 TO LAW, DEPOSES AND SAYS
 THAT THE CHEMICAL ANALYSIS
 AND/OR TESTS SHOWN IN THIS
 REPORT ARE CORRECT AS CON-
 TAINED IN THE RECORDS OF
 THE COMPANY.

AS PER SA 516-89-70-71-70-PRESSURE VESSEL QUAL. REQUIREMENTS - TEMPER-LONG-
 CHURCH-V-NOTCH-IMPACT-PR-TEST-F-MILUS-30-DEG-F-STRESS-RELIEVE-TEST
 -PCS-15-HRS-100-PR-CB&I-SPEC-MS601H-DTD-2/25/70-R-GPS-516-REV4

008975

INSPECTION & TEST INSPECTION FOR HEAT TREATMENT ONLY NOT SUR
 TESTING NOTIFY MR SMITH 412-588-5500 PRIOR TO HEAT TREAT
 SHOWN T/R LADLE FULL ANAL ALSO COST SPEC GPS516 REV

0703

SIGNATURE E. J. ...
 DATE 10/28/71

ITEM NO.	HEAT NO.	TEST OR PIECE IDENTITY NO.	MATERIAL DESCRIPTION					YIELD ST. PSI	TENSILE ST. PSI	ELONGATION %		% RED. OF AREA
			NO. PCS.	THICKNESS OR SECTION	WIDTH, DIA. OR FT. WT.	LENGTH	WEIGHT			IN 8"	IN 2"	
105	668094	46253 BC TC	1	3.0000	57	233	11288	* 59500 * 52800 * 094.0	75800 79600 -070.0	30.0 32.0 67.0	35	
FULL SIZE LONG V NOTCH CHURCH IMPACT TEST 10 10MM MADE AT = 30 DEG. AND LATERAL EXPANSION .074-.060-058 MILS. AVERAGE IMPACT STRENGTH = 77												
105	668094	46254 BC TC	1	3.0000	57	233	11288	* 50400 * 51800 * 065.0	78800 80200 -095.0	29.0 32.0 63.0	35	
FULL SIZE LONG V NOTCH CHURCH IMPACT TEST 10 10MM MADE AT = 30 DEG. AND LATERAL EXPANSION .055-.076-056 MILS. AVERAGE IMPACT STRENGTH = 74 Above Test Specimens Stress Relieved at 1150 Deg. F., Maintained 15 hrs. Furnace cooled to below 600 Deg. F. Test Specimens Chilled Heating Rate 110 Deg. F. Per Hour. Cooling Rate 40 Deg. F. Per Hour. Test treated in accordance with heat treat reference Number C2.2 Above Plates Quenched at 1697 Deg. F., Tempered at 1185 Deg. F.												

ITEM SIZE TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE

* B OR H INDICATE COMPLIANCE OF BEND OR HOMO TESTS, RESPECTIVELY

HEAT NO.	TYPE	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	Al	N	V	B	Ti	Co
668094	LNPL	22	.12	.015	.015	.20											
LIMERICK GENERATING STATION, UNIT 1 PHILADELPHIA ELECTRIC COMPANY SPEC. 8031-C-2 CBI 70-7198 GRAIN SIZE # 8 ✓ AVG GR SIZE 11-15-71 2.35																	



PRODUCTION DEPARTMENT - METALLURGICAL

United States Steel Corporation

J. JAMES HENRY, Notary Public
HOMESTEAD TOWNSHIP, ALLEGHENY COUNTY
MY COMMISSION EXPIRES JULY 10, 1973
Member, Pennsylvania Association of Notaries

Sheet No. 1

TEST REPORT OF PLATES *C.F. 1171*

WORKS HOMESTEAD DISTRICT U.S.S. ORDER NO. LA34246 LOAD TALLY OR INVOICE NO. 163-17249

CUSTOMER ORDER NO. 70-7198U-46 8/30/71

TRUCK OR TRUCK NO. BLE 019288 SHIPPER NO. & DATE 51789 10/28/71 160

STATE OF PENNSYLVANIA
COUNTY OF ALLEGHENY

SUBSCRIBED AND SWORN TO BEFORE ME
THIS 31st DAY OF Oct., 1971

James Henry
E. J. ...

CHICAGO BRIDGE & IRON CO
PO BOX 610
GREENVILLE PA 16125

CHICAGO BRIDGE & IRON CO
GREENVILLE PA

BEING JULY SWORN ACCORDING
TO LAW, DEPOSES AND SAYS
THAT THE CHEMICAL ANALYSIS
AND/OR TESTS SHOWN IN THIS
REPORT ARE CORRECT AS CON-
TAINED IN THE RECORDS OF
THE COMPANY.

SIGNATURE M. W. MAXSON, CH. MET.

DATE 10/29/71

45 E-54-516-69-GRADE-70-PRESSURE-VESSEL-JUAL-NORMALIZED-LONG-CHAMP
Y-V-NOTCH-IMPACT-TESTS-W-HINUS-30-DEG-F-MOD-PER-CR1-SPEC-MS601B-R
1-DTD-2/25/70-8-GPS-516-REV-4-DTD-2/25/70-8-GPS-516-REV-4-

008974

CHICAGO BRIDGE & IRON INSPECTION FOR HEAT TREATMENT ONLY NOT SUB
FACE OR TESTING NOTIFY NK SMITH 412-588-5500 PRIOR TO HEAT TREAT
220020 ENT SWORN T/R LADLE FULL ANAL ALSO CUST SPEC GPS 516 RE

0703

ITEM NO	HEAT NO	TEST OR PIECE IDENTITY NO	MATERIAL DESCRIPTION					YIELD ST. PSI	TENSILE ST. PSI	ELONGATION %		% RED OF AREA
			NO. PCS	THICKNESS OR SECTION	WIDTH, DIA OR FT. WT	LENGTH	WEIGHT			IN 2	IN 4	
04	67A756	224703	50	1	1.0000	79	300	6714	* 47100	75800	35.0	
FULL SIZE LONG, V NOTCH CHAMPY IMPACT TEST 10X10MM MADE AT = 30 DEG. F. AND LATERAL EXPANSION .027-.020-.024 MILS.												
8 SHEAR RATE 029.0-027.0-027.0-000.0												
Avg. Impact Str. = 24												
04	75A924	272637	50	1	1.0000	79	300	6714	* 45200	76100	25.0	
FULL SIZE LONG, V NOTCH CHAMPY IMPACT TEST 10X10MM MADE AT = 30 DEG. F. AND LATERAL EXPANSION .020-.021-.027 MILS.												
8 SHEAR RATE 066.0-088.0-038.0-000.0												
AVERAGE IMPACT STRENGTH = 28												
Above Plates Normalized at 1660 Deg. F. for 40.0 Minutes												
Heat treated in accordance with heat treat reference Number: C2.1												
YIELD POINT 2.0050 EXT.												

LIMERICK GENERATING STATION, UNIT 1
PHILADELPHIA ELECTRIC COMPANY
SPEC. 8031-C-2
CBI 70-7198

11-3-71

OTHER SIZE TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE

* B OR H INDICATE COMPLIANCE OF BEND OR HOMO TESTS, RESPECTIVELY

HEAT NO	TYPE	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	Al	N	V	B	Ti	Cb	Co
67A756	PLATE	24	1.06	011	027	19												
75A924	PLATE	25	1.10	010	022	21												

Grain Size #7
Grain Size #8

11-3-71
11-3-71

227

Airlock 162-1

Heat No. C8076

C-2-F-1188-1

METAL MATERIAL VERIFICATION SUMMARY SHEET
CHICAGO BRIDGE & IRON COMPANY

C-2-F-78-1

Contract No. 70-7198
Sheet 1 of 4

Copy to Engineering - By _____ Date _____
No. of Ctrs For Customer _____

NO. OF PLS	ORDERED ITEM NO.	SUPPLIER'S HEAT, LOT OR OTHER IDENTIFICATION NUMBER	SUPPLIER'S SLAB NUMBER	MATERIAL SPEC. AND THICKNESS FOR PLATES	CAR OR TRUCK NUMBER AND SUPPLIER	CTR CHECKED DATE AND INITIAL	METAL INSPECTION REPORT CHECKED DATE AND INITIAL	DAILY FABR OR STORES RELEASE CHECKED DATE AND INITIAL	PIECES	SERIAL NUMBER	NO. OF FABRICATED	CHECKED FOR DEFECTS INITIAL	REMARKS
1	MI-5	80C01200	C31547	SAS10-70 MS60B T=3/4	M7198-3 Beth.	5-13-71 RCC	6-1-71 RCC	10-11-71 RCC	See	1	1	RCC	
1	MI-7(A)	879C02040	C31571	T=1	Beth.	5-13-71 RCC	6-1-71 RCC	10-11-71 RCC	See	7	7	RCC	
1	MI-22	60002	P41319	T=3/4	M7198-5 ADPCCO	5-13-71 RCC	6-1-71 RCC	10-11-71 RCC	See	8	8	RCC	
1	MI-9	X5998	5A	T=2	M7198-6 LUKENS	6-9-71 RCC	6-1-71 RCC	10-11-71 RCC	See	1	1	RCC	
1	MI-11	C8676	1B	T=1/2	M7198-7 G.O. CARLSON	7-15-71 RCC	7-15-71 RCC	10-11-71 RCC	See	11-2	11-2	RCC	
1	MI-13	X300403	2C	SAS20-70 MS60B T=3/4	M7198-8 G.O. CARLSON	7-15-71 RCC	7-15-71 RCC	10-11-71 RCC	See	1	1	RCC	
2	MI-15	X300403	2C	SAS20-70 MS60B T=3/4	M7198-9 G.O. CARLSON	7-15-71 RCC	7-15-71 RCC	10-11-71 RCC	See	1	1	RCC	
1	MI-6	S01809500	B32510	SAS20-70 MS60B T=3/4	M7198-10 Beth.	3-4-71 RCC	3-4-71 RCC	10-11-71 RCC	See	1	1	RCC	
1	MI-7(B)	802C04120	C31587	SAS16-70 MS60B T=1/2	M7199-2 Beth.	5-13-71 RCC	5-13-71 RCC	10-11-71 RCC	See	6	6	RCC	
1	MI-7(C)	801309500	B10553	SAS16-70 MS60B T=1/2	M7199-3 Beth.	5-13-71 RCC	5-13-71 RCC	10-11-71 RCC	See	12	12	RCC	
1	MI-7(D)	80181530	B32526	SAS16-70 MS60B T=1/2	M7199-4 Beth.	5-13-71 RCC	5-13-71 RCC	10-11-71 RCC	See	5	5	RCC	
1	MI-7(E)	801809500	C71586-1	SAS16-70 MS60B T=1/2	M7199-5 Beth.	5-13-71 RCC	5-13-71 RCC	10-11-71 RCC	See	39	39	RCC	
1	MI-7(F)	71A527	170008	SAS16-70 MS60B T=1/2	M7199-6 Beth.	5-13-71 RCC	5-13-71 RCC	10-11-71 RCC	See	7	7	RCC	
1	MI-7(G)	801C03400	10265-1	SAS16-70 MS60B T=1/2	M7199-7 Beth.	5-13-71 RCC	5-13-71 RCC	10-11-71 RCC	See	1-5	1-5	RCC	
1	MI-7(H)	23D169	T3763	AE10-70 T=1/2	M7199-8 Beth.	5-13-71 RCC	5-13-71 RCC	10-11-71 RCC	See	58	58	RCC	

ARTIFICIAL LT NO. SYSTEM	QUAL. C.	ENG. PC. AIR.	Serial No.	NO. PGS.
ML-11	2	[REDACTED]	11	2
76-18 ✓	1	[REDACTED]	11	1
MOS L3	1	[REDACTED]	11	1
G'ville	2	[REDACTED]	1-2	2
11-7.8)	2	[REDACTED] 5-5 ✓	4	2
1 2/3"	4	[REDACTED] 8-36	4	4
M104 LB	1	[REDACTED]	4 This pc. Ref. get	
302C 04120 ✓	1	[REDACTED]	4	1
C 31587	2	141-6	4	1
	1	150-12	4	1
				C2F-1188-1
11B11530-832526 ✓	1	[REDACTED] ✓	12	1
2"	1	[REDACTED] ✓	12	1
	2	[REDACTED] ✓	12	2
	2	[REDACTED]	12	2
	1	[REDACTED]	12	1
M101 L17	1	[REDACTED]	12	1
	1	[REDACTED]	12	1
	2	[REDACTED]	12	2
	2	[REDACTED]	12	2
	2	[REDACTED]	12	2
	2	[REDACTED]	12	2
	4	[REDACTED] 144-f	12	4
	1	[REDACTED]	12	1
	1	[REDACTED]	12	1
	1	[REDACTED]	12	1
	1	[REDACTED]	12	1
	2	[REDACTED]	12	2

C-2-F-1188-1

①
215

LUKENS STEEL COMPANY

COATESVILLE, PA. 19320

TEST CERTIFICATE

DATE: 7-9-71

FILE NO 1540-06199

PURCHASER:
 3 Chicago Bridge & Iron Co.
 Mr. Grant Wagner
 P.O. Box 13308
 Presidents Island
 Memphis, Tenn. 38101

MILL ORDER NO.

CUSTOMER P.O.

48174-2

M7198-6

RG 7771 DD

CONSIGNEE:

Chicago Bridge & Iron Co.
 Greenville, PA.

(51)

SPECIFICATIONS:

A-516-69 Gr. 70, A-300-68 Class 1 Mod. CB&I MS-601B Rev. 1 Sup. 5, 16 & GPS 516 Rev. 4 Sup. 18
 (ASME Sect. 11 & 111 Winter 1969 Addenda)
 Sheet 1 of 2

BEND TEST

O.K.

HOMOGENEITY TEST

CHEMICAL ANALYSIS

MELT NO.	C	Mn	P	S	Cu	Si	Ni	Ca	Mo	V	Ti	Al	Grain Size
CB676	27	1.01	010	019									6-7
CBI 70-7198 BECHTEL 8031-C-2 LGS 1													

Handwritten signature and date: 4-10-75

PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD PSI X100	TENSILE PSI X100	% ELONG. IN 2"	% R.A.	BHN	LONG. IMPACTS V-Notch -30°F.	Fracture Appearance	DESCRIPTION
CB676	1B	552	773	29			57 64 69	30-30-30	2-232 x 83-3/8 x 3"
							Lateral Expansion in inches		
							.060 .050 .049		
Pl #8 and tests heated 1650°F ±25°F., held 1/2 hr. per inch min. and water quenched to below 400°F., then tempered 1180°F., held 1/2 hr. per inch min. and air cooled. Tests stress relieved by heating to 1150°F., held 15 hrs. and furnace cooled to 600°F.									
We hereby certify that the above material has been manufactured according to A-516-69 Gr. 70 A-300-68 Class 1 Mod. CB&I MS-601B Rev. 1 Sup. 5, 16 & GPS 516 Rev. 4 Sup. 18 (ASME Sect. 11 & 111 Winter 1969 Addenda), and that we have complied with all the requirements of these specifications.									
<i>Handwritten: RC 7-15-71</i>									

Handwritten: H-111

Handwritten signature: H. J. Lyons

We hereby certify the above figures are correct as contained in the records of the company.

SUPERVISOR TESTING

PURCHASER:

Chicago Bridge & Iron Co.
Mr. Grant Wagner
P.O. Box 13308
Presidents Island
Memphis, Tenn. 38101

LUKENS STEEL COMPANY

COATESVILLE, PA. 19320

TEST CERTIFICATE

DATE: 7-9-71

FILE NO. 1540-06-99

CONSIGNEE:

Chicago Bridge & Iron Co.
Greenville, Pa.

MILL ORDER NO.

CUSTOMER P.O.

48174-2

M7198-6

RG 7771 DD

SPECIFICATIONS:

SA-516-69 Gr. 70, A-300-68 Class 1 Mod. CB&I MS-601B Rev. 1 Sup. 5, 16 & GPS 516 Rev. 4 Sup. 18
(ASME Sect. 11 & 111 Winter 1969 Addenda)
Sheet 1 of 2

BEND TEST

O.K.

HOMOGENEITY TEST

CHEMICAL ANALYSIS

MELT NO.	C	Mn	P	S	Cu	Si	Ni	Cr	Mo	V	Ti	Al	B	Grain Size
CB676	27	1.01	010	019		22								6-7

CBI 70-7198
BECHTEL 8031-C-2
LGS I

RECEIVED
MEMPHIS, TENN.

JUL 14 1971

M. J. Schmitt
Bechtel
4-10-75

PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD PSI X100	TENSILE PSI X100	ELONG. IN. 2"	R.A.	BHN	Long. IMPACTS V-Notch -30°F.	Fracture Appearance	DESCRIPTION
CB676	1B	552	773	29			57 64 69 .060 .050 .049	30-30-30 \$ Shear	2-232 x 83-3/8 x 3"

Lateral Expansion in inches

Plates and tests heated 1650°F ±25°F., held 1/2 hr. per inch min. and water quenched to below 400°F., then tempered 1180°F., held 1/2 hr. per inch min. and air cooled.

Tests stress relieved by heating to 1150°F., held 15 hrs. and furnace cooled to 600°F.

We hereby certify that the above material has been manufactured ~~HEREIN~~ according to A-516-69 Gr. 70 A-300-68 Class 1 Mod. CB&I MS-601B Rev. 1 Sup. 5, 16 & GPS 516 Rev. 4 Sup. 18 (ASME Sect. 11 & 111 Winter 1969 Addenda), and that we have complied with all the requirements of these specifications.

RCC
7-15-71

156-23
156-24
156-25
162-1

C-2-F-1188-1

We hereby certify the above figures are correct as contained in the records of the company.

SUPERVISOR TESTING

L. J. Kline

Feedwater Valve

Body

1 F074A

Heat No.

F6137

Body: 4-1-75

2-521



QUAKER ALLOY CASTING CO.
A DIVISION OF HARSCO CORP.
MYERSTOWN, PENNA. 17067

MATERIAL TEST REPORT

CUSTOMER ORDER NO.	PATTERN NO.	QUAKER ALLOY DESIGNATION	SPECIFICATION	SHOP ORDER NUMBER	DATE SHIPPED
2125171	16435-20223-505	C50-LCB	ALUE SA352 GR, LCB		7-29-75

CUSTOMER

Atwood and Morrill

SHEET NO.	C	Mn	Si	P	S	Cr	Ni	Mo	YIELD PSI	TENSILE PSI	ELONG. %	RED OF AREA %	C55		PS SHIPPED	
													SER.#	SER.#		
F6137	.20	.75	.45	.017	.013				42,500	71,500	30.0	53.3	F5137-1	N1127		
									Charpy Impact V Notch Plus 30°F							
									43-45-72 foot pounds							
									41-44-13 Lateral expansion							
									43-60-70 % Ductile Fracture							

Castings produced in accordance with ASME Boiler and Pressure Vessel Code Sect. III 1971
 and 1975 Winter Addenda, and with SA352. All special requirements of Art. NB2000 Sect. III
 of the 1972 Winter Addenda have been met.
 Castings produced in accordance with Decimals spec G031-2-350 and CC100-ND, CC102-Welding,
 and 9-71-101-Markings.

W. Miller
 Atwood & Morrill Co.
 9/11/75



I CERTIFY THE ABOVE INFORMATION IS CORRECT.
 QUAKER ALLOY CASTING CO.

John Paul Jones - Authorized Inspector

7-29-75 *Richard A. ...*

Followed by 8A

Feedwater Valve

Body

1F074 B

Heat No.

FG152



QUAKER ALLOY CASTING CO.
A DIVISION OF HARSICO CORP.
MYERSTOWN, PENNA. 17067

Kit: 12681-01-
BODY for 14-903#
MATERIAL TEST REPORT

CUSTOMER ORDER NO	PATTERN NO	QUAKER ALLOY DESIGNATION	SPECIFICATION	SHOP ORDER NUMBER	DATE SHIPPED
A124171	16435-30228-606	Q60-LCB	ASME SA352 GR.LCB		

CHEMICAL & PHYSICAL
REPORT CHECKED
BY L.T. Harris
DATE 8/5/75
ATWOOD & MORRILL CO. INC.

CUSTOMER

Atwood and Morrill

HEAT NO	C	Mn	Si	P	S	Cr	Ni	Mo	YIELD PSI	TENSILE PSI	ELONG %	RED OF AREA %	CSTG.		P/S SHIPPED
													SER.#	SEE.#	
F6152	.19	.32	.50	.021	.015				61,000	93,000	28.0	63.3	F6152-1	N1134	
										47-53-57		foot pounds			
										41-47-45		lateral expansion			
										40-40-40		% Ductile Fracture			

REMARKS
 Approved N. Atwood + Morrill
 9/2/75
 Castings produced in accordance with ASME Boiler and Pressure Vessel Code Sect. II, 1971 and 1972 Winter addenda and with Bechtel spec 8031-P-350 and QC100-Rad., QC102-Welding, QC103 Mag, and 90-71-101-Markings.
 Castings produced in accordance with ASME SA352. All requirements of Art. MD2000 Sect. III 1971 & 1972 Winter add. have been met.
 7-31-75
 S.C. Cline
 BECHTEL CO
 7/31/75

STATE OF PENNSYLVANIA COUNTY OF BERKLEY SS
 I, John Paul Jones Authorized Inspector
 DO hereby certify and subscribed before me
 this 9-23-75 day of September 1975
 "I CERTIFY THE ABOVE INFORMATION IS CORRECT"
 QUAKER ALLOY CASTING CO.
 BY John Paul Jones METALLURGIST

FW Valve IF074A

Cover

Heat No. 213643

CANN & SAUL STEEL CO.

ROYERSFORD, PA. 19408

Report of Physical Tests and/or Chemical Compositions

7/25/75

Customer's Order No.

Cann & Saul Order No.

Customer Atwood & Morrill Co., Inc.
285 Canal St.
Address Salem, Mass. 01970

Atm-21,522
Ref. 12521-01-014(4)
#12681-01-009(4)

32759

Attention Purchasing Dept.

CHEMICAL COMPOSITIONS

HEAT NO.	C	MN	P	S	SI	CR	NI	MO	CB
213643	.23	1.10	.011	.018	.21				

PHYSICAL TESTS

CUT FROM	TEST NUMBER	GAUGE	YIELD PT. LBS.	YIELD PER Square In Lbs.	BROKE AT LBS.	ULTIMATE TENSILE LBS.	ELONG %	REDUCED AREA	Reduction %	B.H.N.
Forging	32759 1	.505	8,500	42,500	14,000	70,000	35.0	.070	65.0	
Charpy Impact			20.0	20.0	22.0 Ft. Lbs. @ plus 30°F					
Notch			52	49	50 mils Lat. Exp.					
			15	15	15 percent shear					

APPROVED
BY *N. Sullivan*
DATE 9/23/75
ATWOOD & MORRILL CO. INC.

OTHER TESTS

See C&S Proc. #388, Rev. 16 Mod. 2 (4/25/75)
Attach. #1 (4/25/75) O.K.

We certify the material meets the requirements of the specification and/or P.O.

Customer's Specifications: ASME SA-350, Gr. LF-2
Charpy "V" impacts 40 mils Lat. exp. @ plus 30°F
0.30 Carbon
B.H.N.

Y. P. 36,000
T. 70,000
E. 22.0 CHEMICAL & PHYSICAL
B. 30.0 REPORT CHECKED

THE ABOVE TESTS COVER THE FOLLOWING MATERIAL:

Cover Forgings 23-1/4" dia. x 5-1/4" thick
Forgings serialized #1 thru 8

J.P. Jones 7-25-75
INSPECTION

J.P. Jones 7/24/75
INSPECTION

(P) A.I. 9-23-75 - original on an airplane

FORGED AND PEENED F.P.
P 116AC E 2 1

BY *W. Francis*
DATE 7-30-75
ATWOOD & MORRILL CO. INC.

CANN & SAUL STEEL CO.

M.E. Salsovich
M.P. of Tests

John Paul Jones
Authorized Inspector

FW Valve IF074B

Cover

Heat No. 213643

CANN & SAUL STEEL CO.

S/N 3-5213

ROVERS FORD, PA. 19080

Report of Physical Tests and/or Chemical Compositions

7/25/75

Customer Atwood & Morrill Co., Inc.
285 Canal St.
Salem, Mass. 01970

Customer's Order No. AM-21502

Cann & Saul Order No. 32759

Ref. 12521-01-014(4)
#12081-01-009(4)

Attention Purchasing Dept.

CHEMICAL COMPOSITIONS

HEAT NO.	C	MN	P	S	SI	CR	NI	MO	CB
213643	.23	1.10	.011	.018	.21				

Lab. No.

PHYSICAL TESTS

CUT FROM	TEST NUMBER	GAUGE	YIELD PT. LBS.	YIELD PER Square In Lbs.	BROKE AT LBS.	ULTIMATE TENSILE LBS.	ELONG %	REDUCED AREA	Reduction %	B.H.N.
Forging	32759 1	.505	8,500	42,500	14,000	70,000	35.0	.070	65.0	
Charpy Impact		20.0	20.0	22.0	Ft. Lbs. @ plus 30°F					
Notch		52	49	50	mils Lat. Exp.					
		15	15	15	percent shear					

APPROVED
 BY: *N. Sullivan*
 DATE: 9/23/75
 ATWOOD & MORRILL CO. INC.

OTHER TESTS

ionic C&S Proc. A388, Rev. 16 Mod. 2 (4/25/75)
Attach. #1 (4/25/75) O.K.

We certify the material meets the requirements of the specification and/or P.O.

Customer's Specifications: ASME SA-350, Gr. LF-2
Fpy "V" Impacts 40 mils Lat. Exp. @ plus 30°F
Lbs. and percent shear for Info.
1/30 Carbon B.H.N.

Y. P.	36,000
T.	70,000
E.	22% CHEMICAL & PHYSICAL
R.	30% REPORT CHECKED

THE ABOVE TESTS COVER THE FOLLOWING MATERIAL:

- Cover Forgings 23-1/4" dia. x 5-1/4" thick
Forgings serialized #1 thru 8

J.P. [Signature] 7-25-75
Inspection

[Signature] 7/25/75
Inspector

(P) A.I. 9-23-75 - [Signature]

W. Francis
DATE 7-30-75
ATWOOD & MORRILL CO. INC.

CANN & SAUL STEEL CO.

[Signature]
John Paul Jones
Authorized Inspector

123

FW Valve IF074A

Disc

Heat No. F6589



QUAKER ALLOY CASTING CO.
 A DIVISION OF HARSICO CORP.
 MYERSTOWN, PENNA. 17067

Disc: 12521-01
 12/14-521

MATERIAL TEST REPORT

CUSTOMER ORDER NO.	PATTERN NO.	QUAKER ALLOY DESIGNATION	SPECIFICATION	SHOP ORDER NUMBER	DATE SHIPPED
1194171	16619-20545-501	C50-LCB	ASME SA352 GR. LCB		8-14-75

CUSTOMER

Atwood and Merrill

CSTG. R.T.

TEST NO.	C	Mn	Si	P	S	Cr	Ni	Mo	YIELD PSI	TENSILE PSI	ELONG %	RED OF AREA %	SER.#	S ER.#	PCS SHIPPED
6589	.22	.25	.49	.020	.011				43,000	79,000	31.0	65.7	F6539-5	H1475	1

Charpy Impact V Notch Plus 30°

69-65-69

foot pounds

65-54-53

lateral expansion

69-30-50

% Ductile Fracture

REMARKS:

*d. Sullivan
 8/11/75
 Atwood + Merrill Co.*

Castings produced in accordance with ASME Boiler and Pressure Vessel Code Sect. III 1971 and Winter Addenda 72 and with Bechtel spec 8031-P-350 and CC100 - Rad, CC102 - Welding, CC103 - Mag, and 90-71-101 - Markings; and with SA352. All special requirements of Art. NB2000 Sect. III 1971 and 1972 Winter Addenda have been met.

P 1164 E 2

73 followed by 73A



8-13-75



9-22-75

STATE OF PENNSYLVANIA, COUNTY OF LEBANON, SS
 I, the undersigned, hereby certify that the above information is correct.

DAY OF

19

"I CERTIFY THE ABOVE INFORMATION IS CORRECT"
 QUAKER ALLOY CASTING CO.

BY

MATERIAL TEST

FW Valve 1F074B

Disc

Heat No

F6589



QUAKER ALLOY CASTING CO.
 A DIVISION OF HARSCO CORP.
 MYERSTOWN, PENNA. 17067

MATERIAL TEST REPORT

476-12521-01
 Disc 11/3

CUSTOMER ORDER NO.	PATTERN NO.	QUAKER ALLOY DESIGNATION	SPECIFICATION	SHOP ORDER NUMBER	DATE SHIPPED
N124171	16553-30545-601	Q50-LCB	ASME SA352 GR. LCB		814.75

RECEIVED

Atwood and Morrill

SAY NO.	C	Mn	Si	P	S	Cr	Ni	Mo	YIELD P.S.I.	TENSILE P.S.I.	ELONG. %	RED. OF AREA %	CSTD.	R.T.	PCS SHIPPED
													SER.#	SER.#	
F6589	.22	.95	.49	.022	.011				43,000	73,000	31.0	65.7	F6589-8	N1477	1

Charpy Impact V Notch Plus 30°

REMARKS: Castings produced in accordance with ASME Boiler and Pressure Vessel Code Sect. III 1971 and Winter addenda 72 and with Bechtel spec 9031-P-350 and QC100-Kad, QC102-Welding, QC103-Wag, QC 90-71-101-Markings and with SA352.... All special requirements of Art. NB2000 Sect. III 1971 and 1972 Winter Addenda have been met.

CHEMICAL & PHYSICAL REPORT CHECKED

3/3/75
 116911
 Q.C. 8
 -13.75

BY [Signature]

"I CERTIFY THE ABOVE INFORMATION IS CORRECT"

QUAKER ALLOY CASTING CO.

STATE OF PENNSYLVANIA COUNTY OF BERK...
 AUTHORITY AND QUALIFIED BEFORE ME

[Signature]
 Atwood & Morrill &
 19 7116175

DAY OF...
 A.P. (P) 9 23.75
 John Paul Jones
 Authorized Inspector

BY [Signature]

MSIV (IF028 A , TYP.)

• BODY

HEAT NO: 8816

MSIV (1F02BA, TYP.)

• COVER

HEAT NO: 219222

CANN & SAUL STEEL CO. All Pcs - 7168-3

ROVERSFOED, PA.

Report of Physical Tests and/or Chemical Compositions

Date 9-21-71

Customer Atwood & Morrill Co., Inc. Customer's Order No. AM-4075
285 Canal St.
Address Salem, Mass. 01970

Cann & Saul Order No. 7375

Attention Purch. Dept.

CHEMICAL COMPOSITIONS

HEAT NO.	C	MN	P	S	SI	CR	NI	MO	CB
219222	.30	.68	.009	.014	.19				

Lab. No.

PHYSICAL TESTS

CUT FROM	TEST NUMBER	GAUGE	YIELD PT. LBS.	YIELD PER Square In. Lbs.	BROKE AT LBS.	ULTIMATE TENSILE LBS.	ELONG %	REDUCED AREA	Reduction %	B.H.N.
Forging	7375 2	.505	9,400	47,000	15,100	75,500	30.0	.098	51.0	

OTHER TESTS

Ultrasonic to C&S Proc. A388, Rev. 4: O.K. 9-22-71
Mag. Part. C&S P&V #1.
Heat Treat Procedure C&S #1.

Customer's Specifications: ASTM A-105, Gr. 2

Y. P. 36,000
Y. 70,000
E. 22%
R. 30%

B.H.N.

THE ABOVE TESTS COVER THE FOLLOWING MATERIAL:

7 - Machined Cover Forgings, Dwg. 20884-D, Code 32113-012-2972.
Forgings serial numbered #9, 10, 11, 12, 13, 14 & 15

A&M & G.E.

Inspector

Inspector

CANN & SAUL STEEL CO.

Eng. of Tests

MSIV (IF028 A, TYP.)

• POPPET

HEAT No: 219727

CANN & SAUL STEEL CO.

POYERSFORD, PA.

Report of Physical Tests and/or Chemical Compositions

C+S # 15

11683-01-802

POPPET

1-12-72

Date 6-27-72

Customer's Order No.

AM-4075 Add'l.

Cann & Saul Order No.

8018

Customer Atwood & Morrill Co., Inc.
285 Canal St.

Address Salem, Mass. 01970

AM S.O. 11683-01 GE 205-AB319

S/14
5 THRU
8-683

Attention Purch. Dept.

CHEMICAL COMPOSITIONS

HEAT NO.	C	MN	P	S	SI	CR	NI	MO	CB
219727	.33	.72	.009	.016	.24				

Lab. No.

PHYSICAL TESTS

CUT FROM	TEST NUMBER	GAUGE	YIELD FT. LBS.	YIELD PER Square in Lbs.	BROKE AT LBS.	ULTIMATE TENSILE LBS.	ELONG %	REDUCED AREA	Reduction %	B.H.N.
Forging	8018 3	.505	9,500	47,500	15,000	75,000	30.0	.089	55.5	

OTHER TESTS

Ultrasonic to C&S Proc. A388, Rev. 4 dated 5-10-71 & Mod. 8-11-71:- O.K. Ref. D.D.R.
 Mag. Part to C&S Proc. P & V #1, Rev. 1 (7-14-71): O.K. #4377
 Heat Treat Procedure C&S #1.

Q477 # 7-683
C+S # 15

Customer's Specifications: ASTM A-105, Gr. 2

Y. P. 36,000
 T. 70,000
 E. 22%
 R. 30%

B.H.N.

THE ABOVE TESTS COVER THE FOLLOWING MATERIAL:

4 - Machined Poppet Forgings, Dwg. 30521-801D, Alt. 5, dated 1-17-72.

Forgings serial numbered #13 thru 16 inclusive

AM S/O. 5 THRU 8-683

AM & GE

Inspector

CHEMICAL & PHYSICAL REPORT CHECKED

CANN & SAUL STEEL CO.

BY

DATE

Eng. of Tests



Authorized Inspector

Stress Intensity Factor K_I Calculations for Assumed Flaws in 24-inch Feedwater Check Valve Body Castings

1. Bechtel prepared a report, Acceptability of 24-inch Feedwater Check Valves, Technical Report No. 1183-05EV, Revision 2, May 1984. It provided several justifications including a fracture mechanics evaluation to support the acceptability of the feedwater check valves. The fracture mechanics methodology used and actual step-by-step calculations are presented below in support of the use-as-is recommendation.
2. The Class II shrinkage criteria for X-ray examination of valve body castings were conservatively equated to a 3.50-inch long crack for the purpose of calculating K_I . This flaw was assumed to lie normal to the principal stress (membrane and bending stresses). For a mid-thickness flaw, the width (2a) was assumed to be 1.00-inch. For a surface flaw, the depth (a) was assumed to be 1.00-inch.
 - (a) The methodology of ASME Section XI, Appendix A, Analysis of Flaw Indications, was used to calculate K_I .

$$K_I = \sigma_m M_m \sqrt{\pi a/Q} + \sigma_b M_b \sqrt{\pi a/Q} \quad (1)$$

where

σ_m, σ_b = membrane and bending stresses, psi, in accordance with A-3200

a = minor half-diameter, in., of embedded flaw; flaw depth for surface flaw

Q = flaw shape parameter as determined from Fig. A-3300-1 using $(\sigma_m + \sigma_b)/\sigma_y$ and the flaw geometry

M_m = correction factor for membrane stress (see Fig. A-3300-2 for subsurface flaws; Fig. A-3300-3 for surface flaws)

M_b = correction factor for bending stress (see Fig. A-3300-4 for subsurface flaws; Fig. A-3300-5 for surface flaws)

- (b) The results of calculations in the attached sheets are summarized as follows.

	Stress Intensity Factor K_I ksi $\sqrt{\text{in}}$ (For flaws in flat plate)	
	Midthickness	Surface
For design stresses Membrane stress = 18.5 ksi Bending stress = 10.2 ksi	26	32
For conservatively assumed stresses Membrane stress = 20 ksi Bending stress = 20 ksi	30	36

- (c) The membrane stress correction factor M_m was compared with a correction factor F for surface flaws in an internally pressurized cylindrical body. See Sheet No. 6. Using an adjustment factor ($F/M_m = 1.27$), the following values were obtained to represent K_I for the assumed flaws in the valve body castings.

	Stress Intensity Factor K_I ksi/ $\sqrt{\text{in}}$ (For flaws in cylindrical bodies)	
	Midthickness	Surface
For design stresses Membrane stress = 18.5 ksi Bending stress = 10.2 ksi	26	40
For conservatively assumed stresses Membrane stress = 20 ksi Bending stress = 20 ksi	30	46

3. The maximum internal pressure during the 40°F lowest temperature operation is 1180 psi as compared to the 2100 psi standard calculation pressure for the above design stresses. The membrane stress corresponding to the 1180 psi internal pressure is 10.4 ksi. Using this value and the conservatively estimated 20 ksi bending stress, K_I calculations resulted in the following values.

	Stress Intensity Factor K_I ksi/ $\sqrt{\text{in}}$ (For flaws in cylindrical bodies)	
	Midthickness	Surface
Membrane stress = 10.4 ksi (corresponding to 40°F initial temperature) Bending stress = 20 ksi assumed	17	25

4. Estimated values for K_{Ic} from CVN energy absorption in certified material test reports are 110 to 190 ksi/ $\sqrt{\text{in}}$ (corresponding to 34 to 74 ft-lbs). These values give an ample margin against the above K_I values.
5. A surface flaw, 3.50-inch long x 1.00-inch deep, is a grossly exaggerated assumption for a valve body casting which was RT and MTed. This was done only to demonstrate the unlikelihood of brittle fracture.
6. Because of the solidification pattern of a casting, shrinkage will occur around the midthickness. Equating that to a flat crack-like flaw is still another conservative assumption.
7. The number of thermal transients and loading conditions are such that fatigue cracking will not develop from the above flaws. This is due to the low number of thermal cycles and low stress intensity factor ranges (ΔK).
8. A K_I value of 90 ksi/ $\sqrt{\text{in}}$ on page 9 of the Bechtel report (No. 1183-05EV) is a typographical error of 50 ksi/ $\sqrt{\text{in}}$, which was a value by rounding off 46 ksi/ $\sqrt{\text{in}}$ for the worst case.

DATE 8/22/84

DESIGN BY YUN CHUNG DATE _____ CHECKED BY RAW 8/30/84 SHEET NO 1


PROJECT Limerick JOB NO 8031-000

SUBJECT Fracture Mechanics Evaluation CALCULATION NO _____ FILE NO _____

of 24-inch Feedwater Check Valves

1. Flaw assumptions

- i) Midthickness flaw
- ii) Surface flaw



$l = 3.50 \text{ inches}$
 (assumed)
 $a = 2a = 1.00 \text{ inch}$
 (assumed)

2. Data from Design Report for 24" Feedwater Check Valve
 (Atwood & Merrill order No. 12521, Sept 28, 1972)

$R = 11.50 \text{ inches}$ $t = 2.313 \text{ inches}$

$P_m = 18.5 \text{ ksi}$ membrane stress


$P_{eb} = 10.2 \text{ ksi}$ Bending stress

DESIGN BY _____ DATE _____ CHECKED BY _____ SHEET NO. 2

PROJECT _____ JOB NO. _____

SUBJECT _____ CALCULATION NO. _____ FILE NO. _____

3. KI Calculation for a Midthickness Flaw



(Fig. A-3200-1 (b))

$t = 2.313$ inches
 $2a = 1.00$ (assumed)
 $\sigma_m = P_m = 18.5$ ksi
 $\sigma_{bo} = P_{eb} = 10.2$ ksi
 $\sigma_b = \sigma_{bo} \cdot \frac{0.5}{1.157}$
 $= (10.2) \left(\frac{0.5}{1.157} \right) = 4.41$ ksi
 $\sigma_{ys} = 40$ ksi

$\frac{\sigma_m + \sigma_b}{\sigma_{ys}} = \frac{18.5 + 4.4}{40} = 0.57$

$\frac{a}{l} = \frac{0.5}{3.5} = 0.143$

$Q = 1.13$ (From Fig. A-3300-1)

$\frac{2e}{t} = 0$ $\frac{2a}{t} = \frac{1}{2.313} = 0.43$

$M_m = 1.14$ (Fig. A-3300-2)

$M_b = 0.24$ (Fig. A-3300-4)

$K_I = \sigma_m M_m \sqrt{\pi} \sqrt{a/Q} + \sigma_b M_b \sqrt{\pi} \sqrt{a/Q}$
 $= \sqrt{314} \cdot \sqrt{\frac{0.5}{1.09}} \{ (18.5)(1.14) + (4.4)(0.24) \}$
 $= (1.77)(0.67)(21.1 + 1.1)$

$K_I = 26$ ksi $\sqrt{\text{in}}$

DATE _____

DESIGN BY _____ DATE _____ CHECKED BY _____ SHEET NO. 3

PROJECT _____ JOB NO. _____

SUBJECT _____ CALCULATION NO. _____ FILE NO. _____

$$\text{If } \sigma_m = P_m = 20 \text{ ksi}$$

$$\sigma_{b0} = 20 \text{ ksi}$$

$$\text{Then, } \sigma_b = \sigma_{b0} \cdot \frac{0.5}{1.157} = 8.64$$

$$\frac{\sigma_m + \sigma_b}{\sigma_{ys}} = \frac{20 + 8.64}{40} = 0.72$$

$$Q = 1.08$$

$$M_m = 1.14$$

$$M_b = 0.24$$

$$K_I = \sqrt{3.14} \sqrt{\frac{0.5}{1.08}} \left\{ (20)(1.14) + (8.64)(0.24) \right\}$$

$$= (1.77)(0.68)(22.8 + 2.1)$$


$$= 30 \text{ ksi } \sqrt{in}$$

DESIGN BY _____ DATE _____ CHECKED BY _____ SHEET NO. 4

PROJECT _____ JOB NO. _____

SUBJECT _____ CALCULATION NO. _____ FILE NO. _____

4. K_I Calculation for a Surface Flaw



$$t = 2.313 \text{ inches}$$

$$a = 1.00 \text{ inch (assumed)}$$

$$\sigma_m = P_m = 18.5 \text{ ksi}$$

$$\sigma_{bo} = P_{eb} = 10.2 \text{ ksi}$$

$$\sigma_b = (10.2) \left(\frac{t/2 - a}{t/2} \right) = (10.2) \left(\frac{1.157 - 1.00}{1.157} \right) = 1.4 \text{ ksi}$$

$$\frac{\sigma_m + \sigma_b}{\sigma_{ys}} = \frac{18.5 + 1.4}{40} = 0.5$$

$$\frac{a}{l} = \frac{1.00}{3.50} = 0.286$$

$$Q = 1.56 \text{ (From Fig. A-3300-1)}$$

$$a/t = 1/2.313 = 0.43$$

$$a/l = 1/3.50 = 0.29$$

$$M_m = 1.18 \text{ (From Fig. A-3300-3)}$$

$$M_b = 0.50 \text{ (From Fig. A-3300-5)}$$

$$K_I = \sigma_m M_m \sqrt{\pi} \sqrt{a/Q} + \sigma_b M_b \sqrt{\pi} \sqrt{a/Q}$$

$$= \sqrt{3.14} \sqrt{\frac{1}{1.56}} \{ (18.5)(1.18) + (1.4)(0.5) \}$$

$$= (1.77)(0.801)(21.8 + 0.7)$$

$$K_I = 32 \text{ ksi} \sqrt{\text{in}}$$

DATE _____

DESIGN BY _____ DATE _____ CHECKED BY _____ SHEET NO 5

PROJECT _____ JOB NO _____

SUBJECT _____ CALCULATION NO _____ FILE NO _____

$$\text{If } \sigma_m = 20 \text{ ksi}, \sigma_{b0} = 20 \text{ ksi}$$

$$\text{Then, } \sigma_b = (20) \left(\frac{1.157 - 1.00}{1.157} \right) = 2.7 \text{ ksi}$$

$$\frac{\sigma_m + \sigma_b}{\sigma_{ys}} = \frac{20 + 2.7}{40} = 0.57$$

$$Q = 1.54$$

$$M_m = 1.18$$

$$M_D = 0.50$$

$$\begin{aligned} K_I &= \sigma_m M_m \sqrt{\pi} \sqrt{\frac{a}{Q}} + \sigma_b M_D \sqrt{\pi} \sqrt{\frac{a}{Q}} \\ &= \sqrt{3.14} \sqrt{\frac{1.00}{1.54}} \{ (20)(1.18) + (2.7)(0.5) \} \\ &= (1.77)(0.81)(23.6 + 1.4) \\ &= 36 \text{ ksi} \sqrt{\text{in}} \end{aligned}$$

DESIGN BY _____ DATE _____ CHECKED BY _____ SHEET NO 6
 PROJECT _____ JOB NO _____
 SUBJECT _____ CALCULATION NO _____ FILE NO _____

5. Boundary-Correction Factor F for surface flaws

Raju and Newman, J_r^* gave the following equations for F for surface cracks in an internally pressurized cylinder.

* *J. of Pressure Vessel Technology*, V.104 (Nov. 1982) pp 293-298

For internal surface cracks

$$F_i = \frac{t}{R} \left(\frac{R_0^2}{R_0^2 - R^2} \right) \left[2G_0 - 2 \left(\frac{a}{R} \right) G_1 + 3 \left(\frac{a}{R} \right)^2 G_2 - 4 \left(\frac{a}{R} \right)^3 G_3 \right]$$

$$R_0 = R + t = 11.50 + 2.313 = 13.8 \quad a/R = 1/11.5 = 0.087$$

G_0, \dots, G_3 are given in Table 2* ($t/R = 0.25$, $a/c = 0.4$, $\frac{a}{t} = 0.5$, $\frac{2\phi}{\pi} = 1.0$)

$$= \frac{2.313}{11.5} \left(\frac{13.8^2}{13.8^2 - 11.5^2} \right) \left[(2)(1.193) - 2(0.087)(0.715) + 3(0.087)^2(0.545) - 4(0.087)^3(0.454) \right]$$

$$= (0.201)(3.27) (2.386 - 0.124 + 0.012 - 0.001)$$

$$= 1.5$$

For external surface cracks

$$F_e = \frac{t}{R} \left(\frac{R^2}{R_0^2 - R^2} \right) \left[2G_0 + 2 \left(\frac{a}{R_0} \right) G_1 + 3 \left(\frac{a}{R_0} \right)^2 G_2 + 4 \left(\frac{a}{R_0} \right)^3 G_3 \right]$$

$$a/R_0 = 1/13.8 = 0.072$$

For G_0, \dots, G_3 , see Table 4 of the reference (see the next page)

$$= \frac{2.313}{11.5} \left(\frac{11.5^2}{13.8^2 - 11.5^2} \right) \left[(2)(1.360) + 2(0.072)(0.773) + 3(0.072)^2(0.575) + 4(0.072)^3(0.472) \right]$$

$$= (0.201)(2.27) (2.72 + 0.111 + 0.009 + 0.001)$$

$$= 1.3$$

6. Ratio of F_i vs M_m

$$F_i/M_m = 1.5/1.18 = 1.27$$

7. Correction for KI surface flaw = $32 \text{ ksi}\sqrt{\text{in}} \times 1.27 = 40 \text{ ksi}\sqrt{\text{in}}$,
 of $P_m = 18.5 \text{ ksi}$, $P_{e2} = 10.2 \text{ ksi}$.

$$\text{or } = 36 \times 1.27 = 46 \text{ ksi}\sqrt{\text{in}},$$

$$\text{of } P_m = 20 \text{ ksi}, P_{e2} = 20 \text{ ksi}.$$

Table 4 Influence coefficients, G_j , for semi-elliptical surface crack on outside of a cylinder ($t/R = 0.25$)

Type of loading	$\frac{2\phi}{\pi} \backslash \frac{a}{t}$	0.2			0.4			1.0		
		0.2	0.5	0.8	0.2	0.5	0.8	0.2	0.5	0.8
Uniform (G_0)	0	0.612	0.786	1.160	0.793	0.994	1.400	1.163	1.286	1.498
	0.25	0.752	0.952	1.346	0.828	1.016	1.365	1.088	1.184	1.320
	0.5	0.972	1.278	1.860	0.967	1.175	1.513	1.049	1.123	1.183
	0.75	1.114	1.541	2.344	1.072	1.311	1.682	1.034	1.100	1.163
Linear (G_1)	0	0.080	0.134	0.242	0.130	0.195	0.318	0.204	0.243	0.302
	0.25	0.209	0.272	0.389	0.252	0.315	0.421	0.365	0.396	0.435
	0.5	0.430	0.532	0.713	0.451	0.521	0.626	0.546	0.570	0.583
	0.75	0.618	0.767	1.044	0.620	0.702	0.833	0.674	0.698	0.724
Quadratic (G_2)	0	0.023	0.049	0.097	0.045	0.078	0.134	0.077	0.096	0.122
	0.25	0.076	0.106	0.159	0.100	0.130	0.180	0.156	0.171	0.188
	0.5	0.241	0.291	0.376	0.261	0.295	0.345	0.336	0.347	0.350
	0.75	0.437	0.513	0.654	0.447	0.489	0.556	0.516	0.527	0.542
Cubic (G_3)	0	0.010	0.025	0.051	0.022	0.041	0.073	0.040	0.051	0.064
	0.25	0.032	0.050	0.079	0.046	0.064	0.093	0.077	0.086	0.095
	0.5	0.148	0.177	0.225	0.164	0.184	0.212	0.220	0.226	0.226
	0.75	0.337	0.383	0.468	0.350	0.375	0.416	0.418	0.424	0.435
	1.0	0.434	0.488	0.596	0.445	0.472	0.523	0.513	0.520	0.536




Fig. 3 Distribution of influence coefficients along crack front for semi-circular internal or external surface crack in cylindrical vessel ($t/R = 0.1$; $a/c = 1.0$; $a/t = 0.5$)

cylinder under the desired loading. The hoop stress distribution is then expanded or fitted into the form

$$\sigma_{\theta} = \sum_{j=0}^3 A_j z^j \quad (3)$$

where z is measured from the proposed crack mouth toward the crack front (see Fig. 2(c)). Rewriting equation (3) to agree with the form of equation (1) gives

$$\sigma_{\theta} = \sum_{j=0}^3 A_j a^j \left(\frac{z}{a}\right)^j \quad (4)$$

where the term $A_j a^j$ is the scale factor to be applied to equation (2) to obtain the corresponding stress-intensity factor. The stress-intensity factor for the σ_{θ} distribution is then given by

$$K_I = \sqrt{\pi} \frac{a}{Q} \sum_{j=0}^3 G_j A_j a^j \quad (5)$$

The G_j values for all crack configurations analyzed in this study are tabulated in Tables 1 through 4.

Application to Internal Pressure

The influence-coefficient procedure was applied to obtain the stress-intensity factors for internally pressurized cylinders with internal and external surface cracks.

Internal Surface Cracks. The stress-intensity factors for an internal surface crack in an internally pressurized cylinder were obtained from equations (3) through (5) using Lamé's solution [11] for the hoop stress (σ_{θ}) in an uncracked internally pressurized cylinder. For convenience, the stress-intensity factor was written as

$$K_I = \frac{pR}{t} \sqrt{\pi} \frac{a}{Q} F_i \left(\frac{a}{c}, \frac{a}{t}, \frac{t}{R}, \phi \right) \quad (6)$$

where pR/t is the "average" hoop stress and F_i is the boundary-correction factor for a surface crack on the inside of an internally pressurized cylinder. The expression for F_i , in terms of G_j , was obtained from the first four terms of a power-series expansion of Lamé's solution with the coordinate origin at the inside of the cylinder, plus the internal pressure applied to the crack surfaces. The result is

$$F_i = \frac{t}{R} \left(\frac{R_0^2}{R_0^2 - R^2} \right) \left[2G_0 - 2\left(\frac{a}{R}\right)G_1 + 3\left(\frac{a}{R}\right)^2 G_2 - 4\left(\frac{a}{R}\right)^3 G_3 \right] \quad (7)$$

where each G_j was obtained from the appropriate finite-element solution (Tables 1 and 2) for the particular values of t/R , a/c , a/t , and ϕ .

External Surface Crack. The stress-intensity factors for an external surface crack in an internally pressurized cylinder were also obtained from equations (3) through (5), again using Lamé's solution. The stress-intensity factor was written as

$$K_I = \frac{pR}{t} \sqrt{\pi} \frac{a}{Q} F_e \left(\frac{a}{c}, \frac{a}{t}, \frac{t}{R}, \phi \right) \quad (8)$$

where F_e is the boundary-correction factor for a surface crack located on the outside of an internally pressurized cylinder. The expression for F_e , in terms of G_j , was obtained from the first four terms of a power-series expansion of Lamé's solution with the coordinate origin at the outside of the cylinder. The result is