



GE Nuclear Energy

ABWR

Date 29 June 92

To BOB ALLA
NRC 10EY

Fax No. _____

This page plus 1 page(s)

From JAKE DUNCAN

Mail Code _____
175 Curtner Avenue
San Jose, CA 95125

Phone (408) 925- 6947

FAX (408) 925-1193
or (408) 925-1687

Subject ABWR PRA - CONSEQUENCE
ANALYSIS / SITE ACCEPTABILITY

Message The following modification

addresses the necessary
correctives for the site
acceptability appendices. This
is item CA-1 on the
punch list.

*cc JNFot
Hk Crowley*

Modification to ABWR paragraph 2.2.2, change next to last paragraph begining with "The basic reference..." to read as follows

The basic reference case used for determining individual and societal risk comparisons (see Table 2.2-1) uses a 95/5 evacuation model as is shown in Table 19E.3-3. For the determination of dose consequences for comparison to the dose goal shown in Table 2.2-1 no evacuation or shielding factors were assumed. If the results for a specific site using the above assumptions prove unacceptable, then site specific evacuation and shielding parameters may be substituted in lieu of the reference values in Subgroup Evacuation.

(d:\abwr\pra\revision\text1.doc)