



ENTERGY

ARKANSAS NUCLEAR ONE
CALCULATION COVER SHEET

Calc No.: 92-E-0065-01 Unit: 2 Category: Q

Calc Title: ANO Unit 2 Degraded

Voltage Study for Startup No. 2 System(s): A,B

Topic(s): DVEQ

Calc Type: EG

Plt Area: Bldg _____ Elev _____

Room _____ Wall _____

Coordinates: _____

Abstract (Include Purpose/Results): _____

PURPOSE:

Provide verification that the ANO Unit 2 safety bus voltages are acceptable when the unit is in accident conditions (MSLB) and Unit 1 is in LOOP by analyzing the system in steady state and transient conditions and applying Millstone voltage criteria.

RESULTS:

All voltages were deemed acceptable.

Rev No.: 0 Verification Method: _____ Design Review: X

Alternate Calculation: _____ Qualification Testing: _____

Pages Revised and/or Added: All new

Purpose of Revision: Initial Issue

Initiating Document(s)

Resulting Document(s)

Key Design Input Docs.

_____ 86-E-0002-01

_____ 85-S-0002-01

_____ 89-E-0144-01

_____ 92-D-8005-01

Amends Calc(s): _____

Supersedes Calc(s): _____

Computer Software (Version): DAPPER Version 3.5


By: Brian Williams BW 7/24/92 Rvw'd: _____
(Print Name) (Init) (Date) (Print Name) (Init) (Date)

Chk'd: John Hotz JH 7/24/92 Apv'd: J. G. Dobbs JGD 7-24-92
(Print Name) (Init) (Date) (Print Name) (Init) (Date)

Check if Additional Revisions: _____

CONTENTS

| | | |
|-------|---|----|
| 1.0 | PURPOSE | 3 |
| 2.0 | REFERENCES | 3 |
| 3.0 | ASSUMPTIONS AND GIVEN CONDITIONS | 4 |
| 4.0 | SYSTEM MODEL | 5 |
| 4.1 | TRANSFORMER IMPEDANCES | 5 |
| 4.1.1 | <u>UNIT 1</u> | 5 |
| | (1) Startup No. 2 Transformer (X-04) | 5 |
| | (2) B5 Load Center Transformer (X-5) | 7 |
| | (3) B6 Load Center Transformer (X-6) | 8 |
| 4.1.2 | <u>UNIT 2</u> | 9 |
| | (1) 2B5 Load Center Transformer (2X-25) | 9 |
| | (2) 2B6 Load Center Transformer (2X-26) | 10 |
| 4.2 | CURRENT LIMITING REACTORS | 11 |
| 4.3 | MOTORS | 14 |
| | (1) Service Water Pump 2P4A, 2P4B & 2P4C | 14 |
| | (2) Emergency Feedwater Pump 2P7B | 15 |
| | (3) Containment Spray Pump 2P35A & 2P35B | 15 |
| | (4) Low Pressure Safety Injection Pump 2P60A | 16 |
| | (5) Low Pressure Safety Injection Pump 2P60B | 16 |
| | (6) High Pressure Safety Injection 2P89A, 2P89B, & 2P89C | 17 |
| 4.4 | SYSTEM EQUIVALENT IMPEDANCE AND VOLTAGE | 17 |
| 4.5 | SYSTEM NETWORK DIAGRAM | 17 |
| 5.0 | RELAY DATA | 18 |
| | (1) Under Voltage Relays 27-1/B5, 27-2/B5, 27-1/B6, & 27-2/B6 | 18 |
| | (2) Under Voltage Relays 27-1/2B5, 27-2/2B5, 27-1/2B6, & 27-2/2B6 | 19 |
| 6.0 | DEGRADED VOLTAGE CASE RUNS | 19 |
| 6.1 | <u>CASE T=0 SECONDS, RED TRAIN STEADY STATE</u> | 21 |
| 6.2 | <u>CASE T=0 SECONDS, GREEN TRAIN STEADY STATE</u> | 22 |
| 6.3 | <u>CASE T=4.5 SECONDS, RED TRAIN STEADY STATE</u> | 23 |
| 6.4 | <u>CASE T=4.5 SECONDS, GREEN TRAIN STEADY STATE</u> | 24 |
| 6.5 | <u>CASE T=10 SECONDS, RED TRAIN STEADY STATE</u> | 25 |
| 6.6 | <u>CASE T=10 SECONDS, GREEN TRAIN STEADY STATE</u> | 26 |
| 6.7 | <u>CASE T=15 SECONDS, RED TRAIN STEADY STATE</u> | 27 |

| | | | | | | |
|-------------|-------------|-----------|--------------|--|---------------------------|---|
| 0 | 7/29/92 | BCW | GWH |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE | |
| REV. | DATE | BY | CHK'D | | NUMBER | 2 |


| | | |
|------|---|----|
| 6.8 | <u>CASE T=15 SECONDS, GREEN TRAIN STEADY STATE</u> | 28 |
| 6.9 | <u>CASE T=18.2 SECONDS, RED TRAIN STEADY STATE</u> | 29 |
| 6.10 | <u>CASE T=18.2 SECONDS, GREEN TRAIN STEADY STATE</u> | 30 |
| 6.11 | <u>CASE T=22.7 SECONDS, RED TRAIN STEADY STATE</u> | 31 |
| 6.12 | <u>CASE T=22.7 SECONDS, GREEN TRAIN STEADY STATE</u> | 32 |
| 6.13 | <u>CASE T=50 SECONDS, RED TRAIN STEADY STATE</u> | 33 |
| 6.14 | <u>CASE T=50 SECONDS, GREEN TRAIN STEADY STATE</u> | 34 |
| 6.15 | <u>CASE T=60 SECONDS, RED TRAIN STEADY STATE</u> | 35 |
| 6.16 | <u>CASE T=60 SECONDS, GREEN TRAIN STEADY STATE</u> | 36 |
| 6.17 | <u>CASE T=70 SECONDS, RED TRAIN STEADY STATE</u> | 37 |
| 6.18 | <u>CASE T=70 SECONDS, GREEN TRAIN STEADY STATE</u> | 38 |
| 6.19 | <u>CASE T=80 SECONDS, RED TRAIN STEADY STATE</u> | 39 |
| 6.20 | <u>CASE T=80 SECONDS, GREEN TRAIN STEADY STATE</u> | 40 |
| 6.21 | <u>CASE T=85 SECONDS, GREEN TRAIN STEADY STATE</u> | 41 |
| 6.22 | <u>CASE T=90 SECONDS, RED TRAIN STEADY STATE</u> | 42 |
| 6.23 | <u>CASE T=90 SECONDS, GREEN TRAIN STEADY STATE</u> | 43 |
| 6.24 | <u>CASE T=STEADY STATE BUS LOADS, WITH SWING LOADS ON BUS 2B5</u> | 45 |
| 6.25 | <u>CASE T=STEADY STATE BUS LOADS, WITH SWING LOADS</u> | 46 |
| 7.0 | MINIMUM LOAD CASE RUN | 47 |
| 7.1 | <u>CASE SYSTEM VOLTAGE=1.05 pu, Minimum Expected Loading</u> | 47 |
| 8.0 | CONCLUSION | 48 |
| 9.0 | ATTACHMENTS | 50 |

1.0 PURPOSE

Provide verification that the ANO Unit 2 safety bus voltages are acceptable when the unit is in accident conditions (MSLB) and Unit 1 is in LOOP by analyzing the system in steady state and transient conditions and applying the Millstone voltage criteria. The conditions analyzed are post trip when ANO Unit 2 and ANO Unit 1 auxiliary power to the safety loads is supplied through Startup Transformer No. 2, assuming Unit 2 with accident loads (ES loads sequencing) and Unit 1 safe shutdown loads (equivalent to LOOP loads). The system configuration represents the worst expected system voltage profile with respect to the Millstone undervoltage relays for Startup Transformer #2.

2.0 REFERENCES


- 2.1 Calculation 86-E-0002-01, Revision 5, *ANO-1 Diesel Generator #1 and #2 Load Study*
- 2.2 Calculation 85-S-0002-01, Revision 5, *ANO-2 Diesel Generator #1 (2K4A) and #2 (2K4B) Loading Calculation*

| | | | | | | |
|-------------|-------------|-----------|--------------|---|---------------------------|---------|
| 0 | 7/24/92 | BCU | gwh |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 3 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

- 2.3 Arkansas Nuclear One Unit 2 Emergency Operating Procedure 2202.010, *Standard Attachments*
- 2.4 IEEE Std. 399-1990, *IEEE Recommended Practice for Power System Analysis*, December 15, 1990
- 2.5 Calculation 92-D-8005-01, Revision 0, *ANO-2 Millstone Analysis Load Centers Tap Change*
- 2.6 EPRI Power Plant Electrical Reference Series, Volume 6, *Motors*, Reprint December 1991
- 2.7 IEEE Std. 141-1986, *IEEE Recommended Practice for Electric Power Distribution for Industrial Plants*, October 10, 1986
- 2.8 Calculation 89-E-0144-01, Revision 2, *ANO 2 Diesel Generator Loading for 2A3 and 2A4 Buses*
- 2.9 ANO Unit 2 SAR, Amendment No. 9A

3.0 ASSUMPTIONS AND GIVEN CONDITIONS

- (1) Unit 2 is in a MSLB accident condition 0-2 hours with ES loads sequencing and loading in accordance with Reference 2.9. And also Reference 2.2 except for MOV loads. The MOV's were not included in Reference 2.2, since they are momentary loads. The load for the MOV's was computed using a power factor of 0.70. The KW load for the MOV's is removed after time $T=22.7$ seconds, per Reference 2.9, Table 8.3-1.
- (2) Unit 1 is in safe shutdown (equivalent to LOOP loads, Maximum assumed, Short Time 0-2hrs).
- (3) Manually added loads are only considered at steady state. Starting of manually added loads is neglected, since these starting loads are small (<10 KW Running Load).
- (4) The auxiliaries for both units are supplied by Startup Transformer No. 2.
- (5) Starting KVA is 6.5 times running KVA for 480V motors. (Per Reference 2.4, page 220, plus a 0.5 for conservatism)
- (6) $HP=KVA$ for 480V motors. (Per Reference 2.4, page 219)
- (7) The starting power factor is 0.20 for 480V motors. (Per Reference 2.4, page 220)
- (8) Only one train will be sequenced at a time, per Reference 2.3, page 78. Therefore, the most conservative case will be for the loads of one train to be in steady state with the second train sequencing the normal loads plus the swing loads.
- (9) Running loads at time T are loads that have sequenced onto the bus prior to time T. Starting loads at time T are loads that are sequenced onto the bus at time T. Except at $T=0$ where non-motor loads sequenced on at $T=0$ are considered as running loads at $T=0$.

| | | | | | | |
|------|---------|-----|-------|---|--------------------|---------|
| 0 | 7/24/92 | BEL | QWH |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 4 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

- (10) Timers that sequence the motor starts are kept within 10% of their desired setpoint. Therefore, when checking the maximum expected voltage dip and/or the maximum duration of the voltage dip, motor starting times will be adjusted within the $\pm 10\%$ time band to overlap motors starts whenever possible.
- (11) The maximum voltage drop from the 4160V bus to the 4000V motors is 2%. And the maximum voltage drop from the 480V bus to the 460V motors is 6%.
- (12) The 460V motors are 200% torque machines.
- (13) All small loads (less than or equal to 60HP) are assumed to accelerate in less than 3 seconds due to the small size of the motors.

4.0 SYSTEM MODEL

4.1 TRANSFORMER IMPEDANCES

Calculation Methodology

1. The Load Loss values given on the transformer test sheets will be used to calculate the transformer resistance in accordance with Attachment 1 equation 3.1.
2. The impedance of 3 winding transformers will be converted to the system voltage base.
3. When the transformer load losses are not available, the X and R values will be calculated in accordance with Attachment 1 equations 4.3 and 4.4. The X/R ratio will be taken from Reference 2.4, Fig 153, page 316.

4.1.1 UNIT 1

(1) Startup No. 2 Transformer (X-04)

Given: (From Attachment 3)

Serial No. H-409010

$$Z_{PS}\% = 5.03 @ 15MVA, 157kV \text{ to } 6.9kV$$

$$Z_{PT}\% = 4.84 @ 12.6MVA, 157kV \text{ to } 4.16kV$$

$$Z_{ST}\% = 8.91 @ 12.6MVA, 6.9kV \text{ to } 4.16kV$$


Transformer Tap = 157kV (From Attachment 5)

Calculate X/R (Ref. 2.4, Fig 153, pg 316, Using 27MVA)

$$\frac{X}{R} = 24$$

Convert Voltages to Nominal (Attachment 1, eq. 1.3)

$$Z_{PS}\% = 5.03 \times \left(\frac{157kV}{161kV} \right)^2$$

| | | | | | | |
|------|---------|------|-------|---|--------------------|---------|
| C | 7/24/92 | BCEJ | QWH |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 5 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

$$Z_{PS} \% = 4.78$$

$$Z_{PT} \% = 4.84 \times \left(\frac{157\text{kV}}{161\text{kV}} \right)^2$$

$$Z_{PT} \% = 4.60$$

$$Z_{ST} \% = 8.91$$

Calculate X (Attachment 1, eq 1.3)

$$X_{PS} \% = 4.78 \sqrt{\frac{24^2}{24^2+1}}$$

$$X_{PS} \% = \underline{4.78}$$

$$X_{PT} \% = 4.60 \sqrt{\frac{24^2}{24^2+1}}$$

$$X_{PT} \% = \underline{4.60}$$

$$X_{ST} \% = 8.91 \sqrt{\frac{24^2}{24^2+1}}$$

$$X_{ST} \% = \underline{8.90}$$

Calculate Resistances (Attachment 1, eq 3.4)


$$R_{PS} \% = \frac{4.78}{24}$$

$$R_{PS} \% = \underline{0.20}$$

$$R_{PT} \% = \frac{4.60}{24}$$

$$R_{PT} \% = \underline{0.19}$$

$$R_{FS} \% = \frac{8.90}{24}$$

| | | | | | | |
|------|---------|-----|-------|---|--------------------|---------|
| 0 | 7/24/92 | BCW | QWH |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 6 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

$$R_{ST} \% = 0.37$$

Calculate % Primary Tap (Per Attachment 1, eq. 3.5)

$$\%Tap = \left(\frac{157kV}{161kV} - 1 \right) \times 100$$

$$\%Tap = -2.5$$

Dapper Input

| | | | |
|-------------------------------------|----------|------------|-----------|
| 3 Winding Xfmr Transf in Service | | | |
| Pri. Bus | 200 | Name | 161kV APL |
| Voltage | 161000 | Conn | YG |
| Sec. Bus | 1200 | Name | H BUSES |
| Bus Volts | 6900 | Conn | YG |
| Ter. Bus | 2901 | Name | ST2-CLR |
| Voltage | 4160 | Conn | YG |
| Ground Impedance (OHMS) Primary Tap | | | |
| R: | X: | -2.5 ± 10% | |
| | Base KVA | %R | %X |
| Pri-Sec | 15000.0 | 0.20 | 4.78 |
| Pri-Ter | 12600.0 | 0.19 | 4.60 |
| Sec-Ter | 12600.0 | 0.37 | 8.90 |

(2) B5 Load Center Transformer (X-5)

Given: (From Attachment 4)


Serial No. 18880

Z% = 8.10 @ 1000KVA, 4160V to 480V, Load Loss = 12.396kW

Transformer Tap = 4055V (From Attachment 6)

Calc' Resistance (Per Attachment 1, eq. 3.1)

$$R\% = \frac{(12.396kW)}{(1000kVA)} \times 100$$

| | | | | | | |
|------|---------|-----|-------|---|--------------------|---------|
| 0 | 7/24/92 | BCW | gwh |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 7 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

$$R\% = \underline{1.2396}$$

Calculate X (Per Attachment 1, eq. 3.2)

$$X\% = \sqrt{8.10^2 - 1.2396^2}$$

$$X\% = \underline{8.0046}$$

Dapper Input

| TRANSFORMER | | Input Name Plate Data | |
|-----------------|----------|-----------------------|--------|
| Primary | | Secondary | |
| Bus | 2008 A3 | 3105 B5 | |
| Bus Voltage | 4160 | | 480 |
| Xfmr Voltage | 4055 | | 480 |
| Xfmr Connection | D | | YG |
| Nom KVA | 1000.0 | FL kVA | 1000.0 |
| Type Code | DT | Loading | DESIGN |
| Primary Tap(%) | | Status | EX |
| % +/- Seq. | % 0 Seq. | Percent Ohms | |
| R 1.2396 | R 1.2396 | R | |
| X 8.0046 | X 8.0046 | X | |

(3) B6 Load Center Transformer (X-6)

Given: (From Attachment 4)

Serial No. 18881

Z% = 8.11 @ 1000KVA, 4160V to 480V, Load Loss = 12.532kW

Transformer Tap = 4055V (From Attachment 6)


Calculate Resistance (Per Attachment 1, eq. 3.1)

$$R\% = \frac{(12.532\text{kW})}{(1000\text{kVA})} \times 100$$

$$R\% = \underline{1.2532}$$

Calculate X

$$X\% = \sqrt{8.11^2 - 1.2532^2} \quad (\text{Per Attachment 1, eq. 3.2})$$

| | | | | | | |
|------|---------|-----|-------|---|--------------------|---------|
| 0 | 7/24/92 | BCL | gwt |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 8 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

$$X\% = \underline{8.0126}$$

Dapper Input

| TRANSFORMER | | Input Name Plate Data | |
|-----------------|---------|-----------------------|------------|
| Primary | | Secondary | |
| Bus | 2009 A4 | 3106 | B6 |
| Bus Voltage | 4160 | | 480 |
| Xfmr Voltage | 4055 | | 480 |
| Xfmr Connection | D | | YG |
| Nom KVA | 1000.0 | FL kVA | 1000.0 |
| Type Code | DT | Loading | DESIGN |
| Primary Tap(%) | | Status | EX |
| % +/- Seq. | | % 0 Seq. | Neut. Ohms |
| R | 1.2532 | R | 1.2532 R |
| X | 8.0126 | X | 8.0126 X |

4.1.2 UNIT 2

(1) 2B5 Load Center Transformer (2X-25)

Given: (From Attachment 7)

Serial No. 21288-B03

$Z\% = 7.71 @ 1000\text{KVA}, 4160\text{V to } 480\text{V}, \text{ Load Loss} = 12.315\text{kW}$

Transformer Tap = 4055V (From Attachment 6)

Calculate Resistance (Per Attachment 1, eq. 3.1)


$$R\% = \frac{(12.315\text{kW})}{(1000\text{kVA})} \times 100$$

$$R\% = \underline{1.2315}$$

Calculate X (Per Attachment 1, eq. 3.2)

$$X\% = \sqrt{7.71^2 - 1.2315^2}$$

$$X\% = \underline{7.6110}$$

| | | | | | | |
|------|---------|-----|-------|---|--------------------|---------|
| 0 | 7/24/92 | BCE | QWH |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 9 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

Dapper Input

| TRANSFORMER | | Input Name Plate Data | |
|-----------------|----------|-----------------------|------------|
| Primary | | Secondary | |
| Bus | 2003 2A3 | 3005 | 2B5 |
| Bus Voltage | 4160 | | 480 |
| Xfmr Voltage | 4055 | | 480 |
| Xfmr Connection | D | | YG |
| Nom KVA | 1000.0 | FL kVA | 1000.0 |
| Type Code | DT | Loading | DESIGN |
| Primary Tap(%) | | Status | EX |
| % +/- Seq. | | % 0 Seq. | Neut. Ohms |
| R | 1.2315 | R | 1.2315 R |
| X | 7.6110 | X | 7.6110 X |

(2) 2B6 Load Center Transformer (2X-26)

Given: (From Attachment 8)

Serial No. 18883

Z% = 8.04 @ 1000KVA, 4160V to 480V, Load Loss = 12.438kW

Transformer Tap = 4055V (From Attachment 6)

Calculate Resistance (Per Attachment 1, eq. 3.1)


$$R\% = \frac{(12.438\text{kW})}{(1000\text{kVA})} \times 100$$

$$R\% = \underline{1.2438}$$

Calculate X (Per Attachment 1, eq. 3.2)

$$X\% = \sqrt{8.04^2 - 1.2438^2}$$

$$X\% = \underline{7.9432}$$

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BCE | QWH |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 10 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

Dapper Input

| TRANSFORMER | Input Name | Plate Data |
|-----------------|------------|----------------|
| | Primary | Secondary |
| Bus | 2004 2A4 | 3006 2B6 |
| Bus Voltage | 4160 | 480 |
| Xfmr Voltage | 4055 | 480 |
| Xfmr Connection | D | YG |
| Nom KVA | 1000.0 | FL kVA 1000.0 |
| Type Code | DT | Loading DESIGN |
| Primary Tap(%) | | Status EX |
| % +/- Seq. | % 0 Seq. | Neut. Ohms |
| R 1.2438 | R 1.2438 | R |
| X 7.9432 | X 7.9432 | X |

4.2 CURRENT LIMITING REACTORS

Calculation Methodology

- The impedance of the reactors will be converted to per unit values with a 100MVA power base and nominal voltage base in accordance with the base conversion equations listed in Attachment 1.

(1) Startup #2 4160V Current Limiting Phase Reactors (X-05)

Given: (From Attachment 9)


$X=0.022\Omega$, $I_{Rated}=3150A$, $V_{Rated}=4160V$, Load Loss=14.300kW

$$X_{PU} = \frac{0.022\Omega}{\left(\frac{4.16KV^2}{100MVA}\right)} \quad (\text{Attachment 1, eq. 1.1 \& 1.2})$$

$$X_{PU} = 0.1271$$

$$Rated\ KVA = \frac{\sqrt{3} \times 4160V \times 3150A}{1000} \quad (\text{Attachment 1, eq. 3.1})$$

$$Rated\ KVA = 22,697KVA$$

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BCW | GWH |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 11 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

$$R_{PU} = \left(\frac{14.300kW}{22697kVA} \right) \left(\frac{100MVA}{22.697MVA} \right) \quad (\text{Attachment 1, eq. 1.3 \& 3.1})$$

$$R_{PU} = \underline{0.00278}$$

Dapper Input

| FEEDER DATA Input 100 MVA PU BASE | |
|-----------------------------------|--------------|
| From Bus 2901 | Name ST2-CLR |
| To Bus 2902 | Name ST2-A |
| Voltage 4160 | Line to Line |
| MVA Base 100 | Length 1000 |
| Positive Sequence | |
| R Pu 0.00278 | X Pu 0.1271 |
| Zero Sequence | |
| R Pu 0.00278 | X Pu 0.1271 |

(2) Bus 2A1 to 2A3 Current Limiting Phase Reactors

Given: (From Attachment 10)

Serial No. SCP28471

$R_{Ae} = .00487\Omega$, $R_{Be} = .00429\Omega$, $R_{Ce} = .00489\Omega$, $X = 0.160\Omega$


Convert Values to P.U. on 100MVA and 4160V Base

R = Average Resistance

$R = 0.00468\Omega$

$$R_{PU} = \frac{0.00468\Omega}{\left(\frac{4.16KV^2}{100MVA} \right)} \quad (\text{Attachment 1, eq. 1.1 \& 1.2})$$

$R_{PU} = \underline{0.0270}$

| | | | | | | |
|------|---------|-----|-------|--|--------------------|----------|
| 0 | 7/24/92 | BCU | gwt |  ARKANSAS NUCLEAR ONE | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | | PAGE NUMBER | 12 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

$$X_{PU} = \frac{0.160\Omega}{\left(\frac{4.16KV^2}{100MVA}\right)} \quad (\text{Attachment 1, eq. 1.1 \& 1.2})$$

$$X_{PU} = \underline{0.9246}$$

Dapper Input

| FEEDER DATA Input 100 MVA PU BASE | | | |
|-----------------------------------|--------|--------------|--------|
| From Bus | 2001 | Name | 2A1 |
| To Bus | 2003 | Name | 2A3 |
| Voltage | 4160 | Line to Line | |
| MVA Base | 100 | | |
| Positive Sequence | | | |
| R Pu | 0.0270 | X Pu | 0.9246 |
| Zero Sequence | | | |
| R Pu | 0.0270 | X Pu | 0.9246 |

(3) Bus 2A2 to 2A4 Current Limiting Phase Reactors

Given: (From Attachment 10)

Serial No. SCP28472

$R_{A0} = .00488\Omega$, $R_{B0} = .00428\Omega$, $R_{C0} = .00489\Omega$, $X = 0.160\Omega$


Convert Values to P.U. on 100MVA and 4160V Base

R = Average Resistance

$R = 0.00468\Omega$

$$R_{PU} = \frac{0.00468\Omega}{\left(\frac{4.16KV^2}{100MVA}\right)} \quad (\text{Attachment 1, eq. 1.2})$$

$$R_{PU} = \underline{0.0270}$$

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BCJ | QWH |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 13 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

$$R_{PU} = \frac{0.160\Omega}{\left(\frac{4.16KV^2}{100MVA}\right)} \quad (\text{Attachment 1, eq. 1.2})$$

$$X_{PU} = 0.9246$$

Dapper Input

| FEEDER DATA Input 100 MVA PU BASE | | | |
|-----------------------------------|--------|--------------|--------|
| From Bus | 2002 | Name | 2A2 |
| To Bus | 2004 | Name | 2A4 |
| Voltage | 4160 | Line to Line | |
| MVA Base | 100 | | |
| Positive Sequence | | | |
| R Pu | 0.0270 | X Pu | 0.9246 |
| Zero Sequence | | | |
| R Pu | 0.0270 | X Pu | 0.9246 |

4.3 MOTORS

Calculation Methodology

1. Motor running KW is calculated using the runout brake horsepower of the load and the efficiency of the motor in Reference 2.1.

(1) Service Water Pump 2P4A, 2P4B & 2P4C


Given: (From Attachment 11 & 12)

General Electric

800Hp, 4000V, Locked Rotor Amps 683, Power Factor (Starting) 24.0

Acceleration Time @ 80% Voltage with 100% Load 1.72 Seconds (Per Attachment 13)

$KW_R = 636.9$ & Power Factor = 88.0 (Per Reference 2.2)

| | | | | | | |
|------|---------|-----|-------|--|--------------------|----------|
| 0 | 7/29/92 | BCE | QWH |  ARKANSAS NUCLEAR ONE | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | | PAGE NUMBER | 14 OF 52 |

Calculate Running KVA

$$KVA_R = \frac{636.9KW}{0.880} \quad (\text{Attachment 1, eq. 2.1})$$

$$KVA_R = \underline{723.8 @ 88.0pf} \quad \text{or} \quad \underline{636.9 + j343.8KVA}$$

Calculate Starting KVA

$$KVA_S = \left(\frac{\sqrt{3} \times 4000V \times 683A}{1000} \right) \left(\frac{4160V}{4000V} \right)^2 \quad (\text{Attachment 1, eq. 2.2})$$

$$KVA_S = \underline{5118 @ 24.0pf} \quad \text{or} \quad \underline{1228 + j4968KVA}$$

(2) Emergency Feedwater Pump 2P7B

Given: (From Attachment 16, 17, & 18)

Allis-Chalmers

600Hp, 4000V, Locked Rotor Amps 546, Power Factor (Starting) 25.0,

Acceleration Time @ 80% Voltage with 100% Load 4.5 seconds

$$KW_R = 478.5 \quad \& \quad \text{Power Factor} = 89.0 \quad (\text{Per Reference 2.1})$$

Calculate Running KVA

$$KVA_R = \frac{478.5KW}{0.890} \quad (\text{Attachment 1, eq. 2.1})$$

$$KVA_R = \underline{537.6 @ 89.0pf} \quad \text{or} \quad \underline{478 + j245KVA}$$

Calculate Starting KVA

$$KVA_S = \left(\frac{\sqrt{3} \times 4000V \times 546A}{1000} \right) \left(\frac{4160V}{4000V} \right)^2 \quad (\text{Attachment 1, eq. 2.2})$$

$$KVA_S = \underline{4091 @ 25.0pf} \quad \text{or} \quad \underline{1023 + j3961KVA}$$

(3) Containment Spray Pump 2P35A & 2P35B


Given: (From Attachment 19, 20, & 21)

Allis-Chalmers

450Hp, 4000V, Locked Rotor Amps 374, Power Factor (Starting) 24.0,

Acceleration Time @ 80% Voltage with 100% Load 2.4 seconds

$$KW_R = 335.0 \quad \& \quad \text{Power Factor} = 89.5 \quad (\text{Per Reference 2.1})$$

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BCG | QWH |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 15 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

Calculate Running KVA

$$KVA_R = \frac{335.0KW}{0.895} \quad (\text{Attachment 1, eq. 2.1})$$

$$KVA_R = \underline{374.3 @ 89.5pf} \quad \text{or} \quad \underline{335 + j167KVA}$$

Calculate Starting KVA

$$KVA_S = \left(\frac{\sqrt{3} \times 4000V \times 374A}{1000} \right) \left(\frac{4160V}{4000V} \right)^2 \quad (\text{Attachment 1, eq. 2.2})$$

$$KVA_S = \underline{2803 @ 24.0pf} \quad \text{or} \quad \underline{673 + j2721KVA}$$

(4) Low Pressure Safety Injection Pump 2P60A

Given: (From Attachment 22 & 23)

Allis-Chalmers

450Hp, 4000V, Locked Rotor Amps 364, Power Factor (Starting) 28.5,

Acceleration Time @ 100% Voltage with 100% Load 1.18 seconds,

Acceleration Time @ 75% Voltage with 100% Load 2.44 seconds

$$KW_R = 194.5 \quad \& \quad \text{Power Factor} = 84.5 \quad (\text{Per Reference 2.1})$$

Calculate Running KVA

$$KVA_R = \frac{194.5KW}{0.845} \quad (\text{Attachment 1, eq. 2.1})$$

$$KVA_R = \underline{230.2 @ 84.5pf} \quad \text{or} \quad \underline{194.5 + j123.1KVA}$$

Calculate Starting KVA

$$KVA_S = \left(\frac{\sqrt{3} \times 4000V \times 364A}{1000} \right) \left(\frac{4160V}{4000V} \right)^2 \quad (\text{Attachment 1, eq. 2.2})$$

$$KVA_S = \underline{2728 @ 28.5pf} \quad \text{or} \quad \underline{777 + j2615KVA}$$

(5) Low Pressure Safety Injection Pump 2P60B

Given: (From Attachment 24, 25 & 26)


Allis-Chalmers

500Hp, 4000V, Locked Rotor Amps 410, Power Factor (Starting) 24.0,

Acceleration Time @ 100% Voltage with 100% Load 1.06 seconds,

Acceleration Time @ 75% Voltage with 100% Load 2.55 seconds

$$KW_R = 193.5 \quad \& \quad \text{Power Factor} = 84.5 \quad (\text{Per Reference 2.1})$$

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BCL | gwk |  Energy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 16 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

Calculate Running KVA

$$KVA_R = \frac{193.5 \text{ KW}}{0.845} \quad (\text{Attachment 1, eq. 2.1})$$

$$KVA_R = \underline{229 @ 84.5\text{pf}} \text{ or } \underline{193.5 + j122.5 \text{ KVA}}$$

Calculate Starting KVA

$$KVA_S = \left(\frac{\sqrt{3} \times 4000\text{V} \times 410\text{A}}{1000} \right) \left(\frac{4160\text{V}}{4000\text{V}} \right)^2 \quad (\text{Attachment 1, eq. 2.2})$$

$$KVA_S = \underline{3072 @ 24.0\text{pf}} \text{ or } \underline{737 + j2983 \text{ KVA}}$$

(6) High Pressure Safety Injection 2P89A, 2P89B, & 2P89C

Given: (From Attachment 27, 28, 29, & 41)

Allis-Chalmers

600Hp, 4000V, Locked Rotor Amps 490, Power Factor (Starting) 21.5,

Acceleration Time @ 100% Voltage with 100% Load 2.6 seconds,

Acceleration Time @ 90% Voltage with 100% Load 3.36 seconds

$$KW_R = 368.9 \text{ \& Power Factor} = 90.0 \quad (\text{Per Reference 2.1})$$

Calculate Running KVA

$$KVA_R = \frac{368.9 \text{ KW}}{0.900} \quad (\text{Attachment 1, eq. 2.1})$$

$$KVA_R = \underline{410 @ 90.0\text{pf}} \text{ or } \underline{369 + j179 \text{ KVA}}$$

Calculate Starting KVA

$$KVA_S = \left(\frac{\sqrt{3} \times 4000\text{V} \times 490\text{A}}{1000} \right) \left(\frac{4160\text{V}}{4000\text{V}} \right)^2 \quad (\text{Attachment 1, eq. 2.2})$$

$$KVA_S = \underline{3672 @ 21.5\text{pf}} \text{ or } \underline{789 + j3586 \text{ KVA}}$$

4.4 SYSTEM EQUIVALENT IMPEDANCE AND VOLTAGE


Per Attachment 30

$$V_{\text{SYS}} = .9912 \text{ pu on } 161 \text{ KV base}$$

$$Z_{\text{SYS}} = 0.01201 + j0.07492 \text{ pu on } 100 \text{ MVA base}$$

4.5 SYSTEM NETWORK DIAGRAM

The System Network Diagram is shown in Attachment 31.

| | | | | | | |
|------|---------|-----|-------|--|--------------------|----------|
| 0 | 7/24/92 | ELC | QWH |  Energy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 17 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

5.0 RELAY DATA

(1) Under Voltage Relays 27-1/B5, 27-2/B5, 27-1/B6, & 27-2/B6

ITE Model 211R4175

Function: These undervoltage relay monitor the voltage on the 480 V. safety busses B5 and B6. For a sustained degraded voltage condition, these relays will isolate the 4160 Volt safety buses from the non-safety/offsite busses and signal for the diesel to start.

Setting: Dropout 106.8V (Highest as left setting for conservatism, per Workplan 1403.121, 05/02/92.)

Time Delay 8 Seconds (Per Workplan 1403.121, 05/02/92)

Repeatability: 0.5 Volts delta for temperature range of 20-40°C (Per Attach. 32)
0.2 Volts delta for variation in control voltage (Per Attachment 32)

Reset Margin: 2% of pickup (Per Workplan 1403.121, 05/02/92)

Time Delay Tolerance: ± 1 Secnd (Per Tech. Spec.)

Determine Maximum Relay Dropout Voltage

$$\text{Relay Dropout}_{\text{MAX}} = 106.8\text{V} + 0.5\text{V} + 0.2\text{V}$$

$$\text{Relay Dropout}_{\text{MAX}} = 107.5\text{V}$$

Reflecting to primary

$$\text{Relay Dropout}_{\text{MAX}} = \left(\frac{480\text{V}}{120\text{V}} \right) \times 107.5\text{V}$$

$$\text{Relay Dropout}_{\text{MAX}} = 430\text{V} \text{ or } 93.5\% \text{ of Motor base}$$


Determine Maximum Relay Reset Voltage

$$\text{Reset Voltage}_{\text{MAX}} = 107.5\text{V} \times 1.02$$

Reflecting to primary

$$\text{Reset Voltage}_{\text{MAX}} = \left(\frac{480\text{V}}{120\text{V}} \right) \times 109.7\text{V}$$

$$\text{Reset Voltage}_{\text{MAX}} = \underline{438.8\text{V} \text{ or } 95.4\% \text{ of Motor base}}$$

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BCV | GWV |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 18 OF 52 |

(2) Under Voltage Relays 27-1/2B5, 27-2/2B5, 27-1/2B6, & 27-2/2B6

ITE Model 211R4175

Function: These undervoltage relay monitor the voltage on the 480 V. safety busses 2B5 and 2B6. For a sustained degraded voltage condition, these relays will isolate the 4160 Volt safety buses from the non-safety/offsite busses and signal for the diesel to start.

Setting: Dropout 105.9V (Highest as left setting for conservatism, per Workplan 1403.121, 03/91.)

Time Delay 8 Seconds (Per Workplan 1403.121, 03/91)

Repeatability: 0.5 Volts delta for temperature range of 20-40°C (Per Attach. 32)
0.2 Volts delta for variation in control voltage (Per Attachment 32)

Reset Margin: 2% of pickup (Per Workplan 1403.121, 03/91)

Time Delay Tolerance: ±0.8 Second (Per Tech. Spec.)

Determine Maximum Relay Dropout Voltage

$$\text{Relay Dropout}_{\text{MAX}} = 105.9\text{V} + 0.5\text{V} + 0.2\text{V}$$

$$\text{Relay Dropout}_{\text{MAX}} = 106.6\text{V}$$

Reflecting to primary

$$\text{Relay Dropout}_{\text{MAX}} = \left(\frac{480\text{V}}{120\text{V}}\right) \times 106.6\text{V}$$

$$\text{Relay Dropout}_{\text{MAX}} = 426.4\text{V or } 92.7\% \text{ of Motor base}$$

Determine Maximum Relay Reset Voltage

$$\text{Reset Voltage}_{\text{MAX}} = 106.6\text{V} \times 1.02$$

Reflecting to primary


$$\text{Reset Voltage}_{\text{MAX}} = \left(\frac{480\text{V}}{120\text{V}}\right) \times 108.8\text{V}$$

$$\text{Reset Voltage}_{\text{MAX}} = \underline{435.2\text{V or } 94.6\% \text{ of Motor base}}$$

6.0 DEGRADED VOLTAGE CASE RUNS

ACCEPTANCE CRITERIA

- (1) The voltage on Buses B5 and B6 must recover to 95.4% 460V (438.8V) after relay dropout, 93.5% of 460V (430V).

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BEW | QWN |  Entergy Operations ARKANSAS NUCLEAR ONE | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | | PAGE NUMBER | 19 OF 52 |

- (2) The voltage on Buses 2B5 and 2B6 must recover to 94.6% 460V (435.2V) after relay dropout, 92.7% of 460V (426.4V).
- (3) Minimum acceptable momentary voltage on 4160V buses with starting load is 0.82pu of 4000V motor base (3280V) or 0.80pu of 4000V motor base (3200V) at the motor terminals.
- (4) Minimum acceptable momentary voltage on 480V buses with starting load is 0.86pu of 460V motor base (395.6V) or 0.80pu of 460V motor base (368.0V) at the motor terminals.
- (5) Minimum acceptable momentary 480V bus voltages when motors are starting on other buses is 0.72pu of 460V motor base (331.2V).
- (6) Minimum acceptable momentary 4160V bus voltages when motors are starting on other buses is 0.80pu of 4000V motor base (3200V).

Methodology

Red Train Steady State

Conditions:

- (1) Red Train in Steady State
- (2) Swing Loads on Green Train
- (3) Green Train Sequencing

Green Train Steady State

Conditions:

- (1) Green Train in Steady State
- (2) Swing Loads on Red Train
- (3) Red Train Sequencing

Unit 1 Safe Shutdown Loads (LOOP) for All Cases

BUS A3

*1400.9+j613.1

BUS A4

*850.9+j394.0


BUS B5

*921.4+j442.3

BUS B6

*546.9+j283.3

*Per Attachment 33 Note: Swing loads are added to bus B5.

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/27/92 | BCW | GWK |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 20 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

6.1 CASE T=0 SECONDS, RED TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------|-----|---------|--------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| Emergency Feedwater Pump 2P7B | 600 | 478.0 | 245.0 | 0 | 0 |
| TOTAL | | 2013.4 | 1057.9 | 0 | 0 |

BUS 2A4

No Load

BUS 2B5


| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 900.0 | 490.4 | 0 | 0 |
| TOTAL | | 900.0 | 490.4 | 0 | 0 |

*For itemized loads see attachment 2

BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|------------|----|---------|------|----------|--------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Loads | - | 101.7 | 72.1 | 0 | 0 |
| *T>0 Loads | - | 0 | 0 | 399.4 | 1957.3 |
| TOTAL | | 101.7 | 72.1 | 399.4 | 1957.3 |

*For itemized loads see attachment 2

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/72 | BCW | gwn |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 21 OF 52 |

6.2 CASE T=0 SECONDS, GREEN TRAIN STEADY STATE

BUS 2A3

No Load

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 500 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P55B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5


| COMPONENT | HP | RUNNING | | STARTING | |
|------------|----|---------|-------|----------|--------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Loads | - | 228.0 | 148.5 | 0 | 0 |
| *T>0 Loads | - | 0 | 0 | 318.8 | 1562.0 |
| TOTAL | | 228.0 | 148.5 | 318.8 | 1562.0 |

*For itemized loads see attachment 2

BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 849.8 | 462.7 | 0 | 0 |
| TOTAL | | 849.8 | 462.7 | 0 | 0 |

*For itemized loads see attachment 2

| | | | | | | |
|-------------|-------------|-----------|--------------|---|---------------------------|----------|
| 0 | 7/24/92 | BLJ | 9WK |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 22 OF 52 |
| REV. | DATE | BY | CHK'D | | PAGE NUMBER | |

6.3 CASE T=4.5 SECONDS, RED TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------|-----|---------|--------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| Emergency Feedwater Pump 2P7B | 600 | 478.0 | 245.0 | 0 | 0 |
| TOTAL | | 2013.4 | 1057.9 | 0 | 0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------|-----|---------|------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 0 | 0 | 1228 | 4968 |
| TOTAL | | 0 | 0 | 1228 | 4968 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 900.0 | 490.4 | 0 | 0 |
| TOTAL | | 900.0 | 490.4 | 0 | 0 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|----------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Loads (W/Swing Loads) | - | 101.7 | 72.1 | 0 | 0 |
| *T>0 Loads (W/Swing Loads) | - | 254.4 | 216.3 | 0 | 0 |
| TOTAL | | 356.1 | 288.4 | 0 | 0 |

*For itemized loads see attachment 2

CASE NOTES:

1. No motor starting overlap as 2B6 per assumption 13.

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BEL | GWH |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 23 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

6.4 CASE T=4.5 SECONDS, GREEN TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------|-----|---------|------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 0 | 0 | 1228 | 4968 |
| TOTAL | | 0 | 0 | 1228 | 4968 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 500 | 193.5 | 122.5 | 0 | 0 |
| Containment spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Loads | - | 228.0 | 148.5 | 0 | 0 |
| *T>0 Loads | - | 214.5 | 189.8 | 0 | 0 |
| TOTAL | | 442.5 | 338.3 | 0 | 0 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 849.8 | 462.7 | 0 | 0 |
| TOTAL | | 849.8 | 462.7 | 0 | 0 |

*For itemized loads see attachment 2

CASE NOTES:

1. No motor starting overlap on Bus 2B5 per assumption 13.

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/02 | BLV | gwk |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 24 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

6.5 CASE T=10 SECONDS, RED TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------|-----|---------|--------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| Emergency Feedwater Pump 2P7B | 600 | 478.0 | 245.0 | 0 | 0 |
| TOTAL | | 2013.4 | 1057.9 | 0 | 0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 0 | 0 | 789 | 3586 |
| TOTAL | | 636.9 | 343.8 | 789 | 3586 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 900.0 | 490.4 | 0 | 0 |
| TOTAL | | 900.0 | 490.4 | 0 | 0 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|----------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Loads (W/Swing Loads) | - | 101.7 | 72.1 | 0 | 0 |
| *T>0 Loads (W/Swing Loads) | - | 254.4 | 216.3 | 0 | 0 |
| TOTAL | | 356.1 | 288.4 | 0 | 0 |

*For itemized loads see attachment 2

CASE NOTES:

On Bus 2A4, the Service Water Pump 2P4C will not overlap with the HPSI Pump 2P89B start, since it will accelerate it's load in 1.72 seconds at 80% voltage.

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BCL | QWN |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 25 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

6.6 CASE T=10 SECONDS, GREEN TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 0 | 0 | 789 | 3586 |
| TOTAL | | 636.9 | 343.8 | 789 | 3586 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 1P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 500 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Loads | - | 228.0 | 148.5 | 0 | 0 |
| *T>0 Loads | - | 214.5 | 189.8 | 0 | 0 |
| TOTAL | | 442.5 | 338.3 | 0 | 0 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 849.8 | 462.7 | 0 | 0 |
| TOTAL | | 849.8 | 462.7 | 0 | 0 |

*For itemized loads see attachment 2

CASE NOTES:

1. On Bus 2A3, the Service Water Pump 2P4A will not overlap with the HPSI Pump 2P89A start, since it will accelerate it's load in 1.72 seconds at 80% voltage.

| | | | | | | |
|------|---------|-----|-------|--|--------------------|----------|
| 0 | 7/24/92 | BCW | GWH |  Entergy Operations ARKANSAS NUCLEAR ONE | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | | PAGE NUMBER | 26 OF 52 |

6.7 CASE T=15 SECONDS, RED TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------|-----|---------|--------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| Emergency Feedwater Pump 2P7B | 600 | 478.0 | 245.0 | 0 | 0 |
| TOTAL | | 2013.4 | 1057.9 | 0 | 0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 0 | 0 | 789 | 3586 |
| LPSI Pump 2P60B | 500 | 0 | 0 | 737 | 2983 |
| TOTAL | | 636.9 | 343.8 | 1526 | 6569 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 900.0 | 490.4 | 0 | 0 |
| TOTAL | | 900.0 | 490.4 | 0 | 0 |

*For itemized loads see attachment 2


BUS 2F5

| COMPONENT | HP | RUNNING | | STARTING | |
|----------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Loads (W/Swing Loads) | - | 101.7 | 72.1 | 0 | 0 |
| *T>0 Loads (W/Swing Loads) | - | 254.4 | 216.3 | 0 | 0 |
| TOTAL | | 356.1 | 288.4 | 0 | 0 |

*For itemized loads see attachment 2

CASE NOTES:

1. On Bus 2A4, the HPSI Pump 2P89B may overlap the LPSI Pump 2P60B start, since it will accelerate it's load in 3.36 seconds at 90% voltage (greater than 90% voltage is verified per Attachment 48).

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/12 | BLW | QWN |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 27 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

6.8 CASE T=15 SECONDS, GREEN TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 0 | 0 | 789 | 3586 |
| LPSI Pump 2P60A | 450 | 0 | 0 | 777 | 2615 |
| TOTAL | | 636.9 | 343.8 | 1566 | 6201 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 500 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Loads | - | 228.0 | 148.5 | 0 | 0 |
| *T>0 Loads | - | 214.5 | 189.8 | 0 | 0 |
| TOTAL | | 442.5 | 338.3 | 0 | 0 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 849.8 | 462.7 | 0 | 0 |
| TOTAL | | 849.8 | 462.7 | 0 | 0 |

*For itemized loads see attachment 2

CASE NOTES:

1. On Bus 2A3, the HPSI Pump 2P89A may overlap with the LPSI Pump 2P60A start, since it will accelerate it's load in 3.36 seconds at 90% voltage (greater than 90% voltage is verified per Attachment 49).

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BCU | gwh |  Energy Operations ARKANSAS NUCLEAR ONE | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | | PAGE NUMBER | 28 OF 52 |

6.9 CASE T=18.2 SECONDS, RED TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------|-----|---------------|---------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| Emergency Feedwater Pump 2P7B | 600 | 478.0 | 245.0 | 0 | 0 |
| TOTAL | | 2013.4 | 1057.9 | 0 | 0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------|-----|---------------|--------------|------------|-------------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 500 | 0 | 0 | 737 | 2983 |
| TOTAL | | 1005.9 | 522.8 | 737 | 2983 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|--------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 900.0 | 490.4 | 0 | 0 |
| TOTAL | | 900.0 | 490.4 | 0 | 0 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------|----|--------------|--------------|--------------|---------------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Loads | - | 101.7 | 72.1 | 0 | 0 |
| *T>0 Loads | - | 254.4 | 216.3 | 0 | 0 |
| *T=18.2 Loads | - | 0 | 0 | 212.4 | 1040.2 |
| TOTAL | | 356.1 | 288.4 | 212.4 | 1040.2 |

*For itemized loads see attachment 2

CASE NOTES:

1. On Bus 2A4, the LPSI Pump 2P60B may still be accelerating, since it will accelerate it's load in 2.55 seconds at 75% voltage (the 80% voltage curve was not available).

| | | | | | | |
|-------------|-------------|-----------|--------------|---|---------------------------|----------|
| 0 | 7/24/92 | BCW | gwh |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 29 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

6.10 CASE T=18.2 SECONDS, GREEN TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------|-----|---------------|--------------|------------|-------------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 0 | 0 | 777 | 2615 |
| TOTAL | | 1005.9 | 522.8 | 777 | 2615 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 500 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|----------------------------|----|--------------|--------------|--------------|---------------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Loads (W/Swing Loads) | - | 228.0 | 148.5 | 0 | 0 |
| *T>C Loads (W/Swing Loads) | - | 214.5 | 189.8 | 0 | 0 |
| *T=18.2 Seconds Loads | - | 0 | 0 | 212.4 | 1040.2 |
| TOTAL | | 442.5 | 338.3 | 212.4 | 1040.2 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|--------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 849.8 | 462.7 | 0 | 0 |
| TOTAL | | 849.8 | 462.7 | 0 | 0 |

*For itemized loads see attachment 2

CASE NOTES:

1. On Bus 2A3, the LPSI Pump 2P60A may still be accelerating, since it will accelerate it's load in 2.44 seconds at 75% voltage (the 80% voltage curve was not available).

| | | | | | | |
|------|---------|-----|-------|---|---|----------------|
| 0 | 7/24/92 | BLJ | QWH |  Entergy Operations | CALCULATION NUMBER 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | | ARKANSAS NUCLEAR ONE | PAGE NUMBER |

6.11 CASE T=22.7 SECONDS, RED TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------|-----|---------------|---------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| Emergency Feedwater Pump 2P7B | 600 | 478.0 | 245.0 | 0 | 0 |
| TOTAL | | 2013.4 | 1057.9 | 0 | 0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------------|--------------|------------|-------------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 500 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 0 | 0 | 673 | 2721 |
| TOTAL | | 1199.4 | 645.3 | 673 | 2721 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|--------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 900.0 | 490.4 | 0 | 0 |
| TOTAL | | 900.0 | 490.4 | 0 | 0 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|-----------------------|----|--------------|--------------|--------------|---------------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Seconds Loads | - | 101.7 | 72.1 | 0 | 0 |
| *T > 0 Seconds Loads | - | 254.4 | 216.3 | 0 | 0 |
| *T=18.2 Seconds Loads | - | 0 | 0 | 212.4 | 1040.2 |
| *T=22.7 Seconds Loads | - | 0 | 0 | 7.1 | 34.7 |
| TOTAL | | 356.1 | 288.4 | 219.5 | 1074.9 |

*For itemized loads see attachment 2

CASE NOTES:

- On Bus 2A4, the LPSI Pump 2P60B will be fully accelerated, since it will accelerate it's load in 2.55 at 75% voltage.
- On Bus 2B6, the 18.2 second loads could overlap the 22.7 second loads, therefore, the 18.2 second loads are modeled as starting.

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BCE | GWH |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 31 OF 52 |

CASE T=22.7 SECONDS, GREEN TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------|-------|----------|--------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 0 | 0 | 673.0 | 2721.0 |
| TOTAL | | 1200.4 | 645.9 | 673.0 | 2721.0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 500 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|-----------------------|----|---------|-------|----------|--------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Seconds Loads | - | 228.0 | 148.5 | 0 | 0 |
| *T > 0 Seconds Loads | - | 214.5 | 189.8 | 0 | 0 |
| *T=18.2 Seconds Loads | - | 0 | 0 | 212.4 | 1040.2 |
| *T=22.7 Seconds Loads | - | 0 | 0 | 7.1 | 34.7 |
| TOTAL | | 442.5 | 338.3 | 219.5 | 1074.9 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 849.8 | 462.7 | 0 | 0 |
| TOTAL | | 849.8 | 462.7 | 0 | 0 |

*For itemized loads see attachment 2

CASE NOTES:

1. On Bus 2A3, the LPSI Pump 2P60A will be fully accelerated, since it will take 2.44 seconds to accelerate it's load at 75% voltage (80% voltage curves were not available).
2. On Bus 2B5, the 18.2 second loads could overlap the 22.7 second loads, therefore, the 18.2 second loads are modeled as starting.

| | | | | | | |
|-------------|-------------|-----------|--------------|---|---------------------------|----|
| 0 | 7/24/92 | DCU | JWH |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE | |
| REV. | DATE | BY | CHK'D | | NUMBER | 32 |

6.13 CASE T=50 SECONDS, RED TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------|-----|---------|--------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| Emergency Feedwater Pump 2P7B | 600 | 478.0 | 245.0 | 0 | 0 |
| TOTAL | | 2013.4 | 1057.9 | 0 | 0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 500 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 900.0 | 490.4 | 0 | 0 |
| TOTAL | | 900.0 | 490.4 | 0 | 0 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|-----------------------|----|---------|-------|----------|-------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Seconds Loads | - | 101.7 | 72.1 | 0 | 0 |
| *T>0 Seconds Loads | - | 254.4 | 216.3 | 0 | 0 |
| *T=18.2 Seconds Loads | - | 135.4 | 105.4 | 0 | 0 |
| *T=22.7 Seconds Loads | - | -96.0 | -97.8 | 0 | 0 |
| *T=50 Seconds Loads | - | 0 | 0 | 148.7 | 728.2 |
| TOTAL | | 395.5 | 296.0 | 148.7 | 728.2 |

*For itemized loads see attachment 2

CASE NOTES:

1. On Bus 2A4, the Containment Spray Pump 2P35B will be fully accelerated, since it will accelerate it's load in 2.4 seconds at 80% voltage.

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/02 | BCW | JWH |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 33 OF 52 |

6.14 CASE T= 50 SECONDS, GREEN TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1535.4 | 812.9 | 0 | 0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 450 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|-----------------------|----|---------|-------|----------|-------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Seconds Loads | - | 228.0 | 148.5 | 0 | 0 |
| *T>0 Seconds Loads | - | 214.5 | 189.8 | 0 | 0 |
| *T=18.2 Seconds Loads | - | 135.4 | 105.4 | 0 | 0 |
| *T=22.7 Seconds Loads | - | -96.0 | -97.8 | 0 | 0 |
| *T=50 Seconds Loads | - | 0 | 0 | 148.7 | 728.2 |
| TOTAL | | 481.9 | 345.9 | 148.7 | 728.2 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 849.8 | 462.7 | 0 | 0 |
| TOTAL | | 849.8 | 462.7 | 0 | 0 |

*For itemized loads see attachment 2

CASE NOTES:

1. On Bus 2A3, the Containment Spray Pump 2P35A will be fully accelerated, since it will accelerate it's load in 2.4 seconds at 80% voltage.

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BCL | GWK |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 34 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

6.15 CASE T=60 SECONDS, RED TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------|-----|---------------|---------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| Emergency Feedwater Pump 2P7B | 600 | 478.0 | 245.0 | 0 | 0 |
| TOTAL | | 2013.4 | 1057.9 | 0 | 0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 500 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|--------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 900.0 | 490.4 | 0 | 0 |
| TOTAL | | 900.0 | 490.4 | 0 | 0 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------------|----|--------------|--------------|--------------|---------------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Seconds Loads | - | 101.7 | 72.1 | 0 | 0 |
| *T>0 Seconds Loads | - | 254.4 | 216.3 | 0 | 0 |
| *T=18.2 Seconds Loads | - | 135.4 | 105.4 | 0 | 0 |
| *T=22.7 Seconds Loads | - | -96.0 | -97.8 | 0 | 0 |
| *T=50 Seconds Loads | - | 0 | 0 | 148.7 | 728.2 |
| *T=60 Seconds Loads (W/Swing Loads) | - | 0 | 0 | 148.7 | 728.2 |
| TOTAL | | 395.5 | 296.0 | 297.4 | 1456.4 |

*For itemized loads see attachment 2

CASE NOTES:

- On Bus 2B6, the 50 seconds loads could overlap the 60 seconds loads, therefore, the 50 seconds loads are modeled as starting.

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BCL | QWH |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 35 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

6.16 CASE T=60 SECONDS, GREEN TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1535.4 | 812.9 | 0 | 0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 450 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------------|----|--------------|--------------|--------------|---------------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Seconds Loads | - | 228.0 | 148.5 | 0 | 0 |
| *T>0 Seconds Loads | - | 214.5 | 189.8 | 0 | 0 |
| *T=18.2 Seconds Loads | - | 135.4 | 105.4 | 0 | 0 |
| *T=22.7 Seconds Loads | - | -96.0 | -97.8 | 0 | 0 |
| *T=50 Seconds Loads | - | 0 | 0 | 148.7 | 728.2 |
| *T=60 Seconds Loads (W/Swing Loads) | - | 0 | 0 | 148.7 | 728.2 |
| TOTAL | | 481.9 | 345.9 | 297.4 | 1456.4 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|--------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 849.8 | 462.7 | 0 | 0 |
| TOTAL | | 849.8 | 462.7 | 0 | 0 |

*For itemized loads see attachment 2

CASE NOTES:

1. On Bus 2B5, the 50 seconds loads could overlap the 60 seconds loads, therefore the 50 seconds loads are modeled as starting.

| | | | | | | |
|------|---------|------|-------|--|--------------------|----------|
| 0 | 7/24/92 | BCTJ | QWT |  ARKANSAS NUCLEAR ONE | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | | PAGE NUMBER | 36 OF 52 |

6.17 CASE T=70 SECONDS, RED TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------|-----|---------------|---------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| Emergency Feedwater Pump 2P7B | 600 | 478.0 | 245.0 | 0 | 0 |
| TOTAL | | 2013.4 | 1057.9 | 0 | 0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 500 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|--------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 900.0 | 490.4 | 0 | 0 |
| TOTAL | | 900.0 | 490.4 | 0 | 0 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------------|----|--------------|--------------|--------------|---------------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Seconds Loads | - | 101.7 | 72.1 | 0 | 0 |
| *T > 0 Seconds Loads | - | 234.4 | 216.3 | 0 | 0 |
| *T=18.2 Seconds Loads | - | 135.4 | 105.4 | 0 | 0 |
| *T=22.7 Seconds Loads | - | -96.0 | -97.8 | 0 | 0 |
| *T=50 Seconds Loads | - | 60.7 | 42.6 | 0 | 0 |
| *T=60 Seconds Loads (W/Swing Loads) | - | 0 | 0 | 148.7 | 728.2 |
| *T=70 Seconds Loads | - | 0 | 0 | 141.6 | 693.4 |
| TOTAL | | 456.2 | 338.6 | 290.3 | 1421.6 |

*For itemized loads see attachment 2

CASE NOTES:

1. On Bus 2B6, the 60 seconds loads could overlap the 70 seconds loads, therefore, the 60 seconds loads are modeled as starting.

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/02 | BCB | gwk |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 37 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

6.18 CASE T=70 SECONDS, GREEN TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1535.4 | 812.9 | 0 | 0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 450 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------------|----|--------------|--------------|--------------|---------------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Seconds Loads | - | 228.0 | 148.5 | 0 | 0 |
| *T > 0 Seconds Loads | - | 214.5 | 189.8 | 0 | 0 |
| *T=18.2 Seconds Loads | - | 135.4 | 105.4 | 0 | 0 |
| *T=22.7 Seconds Loads | - | -96.0 | -97.8 | 0 | 0 |
| *T=50 Seconds Loads | - | 60.7 | 42.6 | 0 | 0 |
| *T=60 Seconds Loads (W/Swing Loads) | - | 0 | 0 | 148.7 | 728.2 |
| *T=70 Seconds Loads | - | 0 | 0 | 70.8 | 346.6 |
| TOTAL | | 542.6 | 388.3 | 219.5 | 1074.8 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|--------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 849.8 | 462.7 | 0 | 0 |
| TOTAL | | 849.8 | 462.7 | 0 | 0 |

*For itemized loads see attachment 2

CASE NOTES:

1. On Bus 2B5, the 60 seconds loads could overlap the 70 seconds loads, therefore, the 60 seconds loads are modeled as starting.

| | | | | | | |
|------|---------|-----|-------|--|------------------------------------|-------------|
| 0 | 7/24/92 | BCJ | QWH |  ARKANSAS NUCLEAR ONE | CALCULATION NUMBER 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | | PAGE NUMBER | 38 OF 52 |

6.19 CASE T=80 SECONDS, RED TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------|-----|---------------|---------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| Emergency Feedwater Pump 2P7B | 600 | 478.0 | 245.0 | 0 | 0 |
| TOTAL | | 2013.4 | 1057.9 | 0 | 0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 500 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|--------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 900.0 | 490.4 | 0 | 0 |
| TOTAL | | 900.0 | 490.4 | 0 | 0 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------------|----|--------------|--------------|--------------|--------------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Seconds Loads | - | 101.7 | 72.1 | 0 | 0 |
| *T > 0 Seconds Loads | - | 254.4 | 216.3 | 0 | 0 |
| *T=18.2 Seconds Loads | - | 135.4 | 105.4 | 0 | 0 |
| *T=22.7 Seconds Loads | - | -96.0 | -97.8 | 0 | 0 |
| *T=50 Seconds Loads | - | 60.7 | 42.6 | 0 | 0 |
| *T=60 Seconds Loads (W/Swing Loads) | - | 60.7 | 42.6 | 0 | 0 |
| *T=70 Seconds Loads | - | 0 | 0 | 141.5 | 693.5 |
| *T=80 Seconds Loads | - | 0 | 0 | 52.5 | 256.5 |
| TOTAL | | 516.9 | 381.2 | 194.0 | 950.0 |

*For itemized loads see attachment 2

CASE NOTES:

- On Bus 2B6, the 70 seconds loads could overlap the 80 seconds loads, therefore, the 70 seconds loads are modeled as starting.

| | | | | | | |
|-------------|-------------|-----------|--------------|--|---------------------------|----------|
| 0 | 7/24/12 | BLU | JWH |  Energy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 39 OF 52 |

6.20 CASE T=80 SECONDS, GREEN TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.9 | 0 | 0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 450 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------------|----|---------|-------|----------|-------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Seconds Loads | - | 228.0 | 148.5 | 0 | 0 |
| *T>0 Seconds Loads | - | 214.5 | 149.8 | 0 | 0 |
| *T=18.2 Seconds Loads | - | 135.4 | 105.4 | 0 | 0 |
| *T=22.7 Seconds Loads | - | -96.0 | -97.8 | 0 | 0 |
| *T=50 Seconds Loads | - | 60.7 | 42.6 | 0 | 0 |
| *T=60 Seconds Loads (W/Swing Loads) | - | 60.7 | 42.6 | 0 | 0 |
| *T=70 Seconds Loads | - | 0 | 0 | 70.8 | 346.6 |
| *T=80 Seconds Loads | - | 0 | 0 | 33.9 | 312.1 |
| TOTAL | | 603.3 | 431.1 | 134.7 | 658.7 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 849.8 | 462.7 | 0 | 0 |
| TOTAL | | 849.8 | 462.7 | 0 | 0 |

*For itemized loads see attachment 2

CASE NOTES:

1. On Bus 2B5, the 70 second loads could overlap the 80 second loads, therefore, the 70 second loads are modeled as starting.

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BEU | JWA |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 40 OF 52 |

6.21 CASE T=85 SECONDS, GREEN TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------|-----|---------|-------|----------|--------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| Emergency Feedwater Pump 2P7B | 600 | 0 | 0 | 1023.0 | 3961.0 |
| TOTAL | | 1535.4 | 812.9 | 1023.0 | 3961.0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 450 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------------|----|---------|-------|----------|-------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Seconds Loads | - | 228.0 | 148.5 | 0 | 0 |
| *T>0 Seconds Loads | - | 214.5 | 189.8 | 0 | 0 |
| *T=18.2 Seconds Loads | - | 135.4 | 105.4 | 0 | 0 |
| *T=22.7 Seconds Loads | - | -96.0 | -97.8 | 0 | 0 |
| *T=50 Seconds Loads | - | 60.7 | 42.6 | 0 | 0 |
| *T=60 Seconds Loads (W/Swing Loads) | - | 60.7 | 42.6 | 0 | 0 |
| *T=70 Seconds Loads | - | 0 | 0 | 70.8 | 346.6 |
| *T=80 Seconds Loads | - | 0 | 0 | 63.9 | 312.1 |
| *T=85 Seconds Loads | - | 0 | 0 | 14.2 | 69.3 |
| TOTAL | | 603.3 | 431.1 | 148.9 | 728.0 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 849.8 | 462.7 | 0 | 0 |
| TOTAL | | 849.8 | 462.7 | 0 | 0 |

*For itemized loads see attachment 2

CASE NOTES:

1. On Bus 2B5, the 70 second and the 80 second loads could overlap the 85 second loads, therefore, the 70 second and the 80 second loads are modeled as starting.

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BCW | gwh |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 41 OF 52 |

6.22 CASE T=90 SECONDS, RED TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------|-----|---------|--------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| Emergency Feedwater Pump 2P7B | 600 | 478.0 | 245.0 | 0 | 0 |
| TOTAL | | 2013.4 | 1057.9 | 0 | 0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 500 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 900.0 | 490.4 | 0 | 0 |
| TOTAL | | 900.0 | 490.4 | 0 | 0 |

*For itemized loads see attachment 2


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------------|----|---------|-------|----------|-------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Seconds Loads | - | 101.7 | 72.1 | 0 | 0 |
| *T>0 Seconds Loads | - | 254.4 | 216.3 | 0 | 0 |
| *T=18.2 Seconds Loads | - | 135.4 | 105.4 | 0 | 0 |
| *T=22.7 Seconds Loads | - | -96.0 | -97.8 | 0 | 0 |
| *T=50 Seconds Loads | - | 60.7 | 42.6 | 0 | 0 |
| *T=60 Seconds Loads (W/Swing Loads) | - | 60.7 | 42.6 | 0 | 0 |
| *T=70 Seconds Loads | - | 85.6 | 61.9 | 0 | 0 |
| *T=80 Seconds Loads | - | 0 | 0 | 52.5 | 256.5 |
| *T=90 Seconds Loads | - | 0 | 0 | 49.6 | 242.7 |
| TOTAL | | 502.5 | 443.1 | 102.1 | 499.2 |

*For itemized loads see attachment 2

CASE NOTES:

1. On Bus 2B6, the 80 second loads could overlap the 90 second loads, therefore, the 80 second loads are modeled as starting.

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BLL | GWH |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 42 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

6.23 CASE T=90 SECONDS, GREEN TRAIN STEADY STATE

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------|-----|---------|-------|----------|--------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| Emergency Feedwater Pump 2P7B | 600 | 0 | 0 | 1023.0 | 3961.0 |
| TOTAL | | 1535.4 | 812.9 | 1023.0 | 3961.0 |


BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 450 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------------|----|---------|-------|----------|-------|
| | | KW | KVAR | KW | KVAR |
| *T=0 Seconds Loads | - | 228.0 | 148.5 | 0 | 0 |
| *T>0 Seconds Loads | - | 214.5 | 189.8 | 0 | 0 |
| *T=18.2 Seconds Loads | - | 133.4 | 105.4 | 0 | 0 |
| *T=22.7 Seconds Loads | - | -96.0 | -97.8 | 0 | 0 |
| *T=50 Seconds Loads | - | 60.7 | 42.6 | 0 | 0 |
| *T=60 Seconds Loads (W/Swing Loads) | - | 60.7 | 42.6 | 0 | 0 |
| *T=70 Seconds Loads | - | 43.4 | 35.1 | 0 | 0 |
| *T=80 Seconds Loads | - | 0 | 0 | 63.9 | 312.1 |
| *T=85 Seconds Loads | - | 0 | 0 | 14.2 | 69.3 |
| *T=90 Seconds Loads | - | 0 | 0 | 35.4 | 173.4 |
| TOTAL | | 646.7 | 466.2 | 113.5 | 554.8 |

*For itemized loads see attachment 2

| | | | | | | |
|------|---------|-----|-------|--|--------------------|----------|
| 0 | 7/24/92 | BLJ | QWH |  Entergy Operations ARKANSAS NUCLEAR ONE | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | | PAGE NUMBER | 43 OF 52 |


BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|--------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| *steady State Loads (W/O Swing Loads) | - | 849.8 | 462.7 | 0 | 0 |
| TOTAL | | 849.8 | 462.7 | 0 | 0 |

*For itemized loads see attachment 2

CASE NOTES:

1. On Bus 2A3, the Emergency Feedwater Pump 2P7B could still be accelerating it's load, since it will accelerate it's load in 4.5 seconds at 80% voltage.
2. On Bus 2B5, the 80 second and the 85 second loads could overlap the 90 second loads, therefore, the 80 second and the 85 second loads are modeled as starting.

| | | | | | | |
|-------------|-------------|-----------|--------------|---|---------------------------|----------|
| 0 | 7/29/92 | BCL | JWK |  Entergy Operations ARKANSAS NUCLEAR ONE | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | | PAGE NUMBER | 44 OF 52 |

6.24 CASE T=STEADY STATE BUS LOADS, WITH SWING LOADS ON BUS 2B5

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------|-----|---------|--------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| Emergency Feedwater Pump 2P7B | 600 | 478.0 | 245.0 | 0 | 0 |
| TOTAL | | 2013.4 | 1057.9 | 0 | 0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 800 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 500 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35B | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1534.4 | 812.3 | 0 | 0 |

BUS 2B5


| COMPONENT | HP | RUNNING | | STARTING | |
|--------------------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/ Swing Loads) | - | 960.7 | 533.0 | 0 | 0 |
| TOTAL | | 960.7 | 533.0 | 0 | 0 |

*For itemized loads see attachment 2

BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|---------|-------|----------|------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 849.8 | 462.7 | 0 | 0 |
| TOTAL | | 849.8 | 462.7 | 0 | 0 |

*For itemized loads see attachment 2

| | | | | | | |
|------|---------|-----|-------|--|--------------------|----------|
| 0 | 7/24/92 | BCU | GWK |  Entergy Operations ARKANSAS NUCLEAR ONE | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | | PAGE NUMBER | 45 OF 52 |

6.23 CASE T=STEADY STATE BUS LOADS, WITH SWING LOADS ON BUS 2B6

BUS 2A3

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------|-----|---------------|---------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4A | 600 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89A | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60A | 450 | 194.5 | 123.1 | 0 | 0 |
| Containment Spray Pump 2P35A | 450 | 335.0 | 167.0 | 0 | 0 |
| Emergency Feedwater Pump 2P7B | 600 | 478.0 | 245.0 | 0 | 0 |
| TOTAL | | 2013.4 | 1057.9 | 0 | 0 |

BUS 2A4

| COMPONENT | HP | RUNNING | | STARTING | |
|------------------------------|-----|---------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| Service Water Pump 2P4C | 600 | 636.9 | 343.8 | 0 | 0 |
| HPSI Pump 2P89B | 600 | 369.0 | 179.0 | 0 | 0 |
| LPSI Pump 2P60B | 500 | 193.5 | 122.5 | 0 | 0 |
| Containment Spray Pump 2P35E | 450 | 335.0 | 167.0 | 0 | 0 |
| TOTAL | | 1834.4 | 812.3 | 0 | 0 |

BUS 2B5


| COMPONENT | HP | RUNNING | | STARTING | |
|---------------------------------------|----|--------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/O Swing Loads) | - | 900.0 | 490.4 | 0 | 0 |
| TOTAL | | 900.0 | 490.4 | 0 | 0 |

*For itemized loads see attachment 2

BUS 2B6

| COMPONENT | HP | RUNNING | | STARTING | |
|-------------------------------------|----|--------------|--------------|----------|----------|
| | | KW | KVAR | KW | KVAR |
| *Steady State Loads (W/Swing Loads) | - | 910.5 | 505.3 | 0 | 0 |
| TOTAL | | 910.5 | 505.3 | 0 | 0 |

*For itemized loads see attachment 2

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BCL | gwt |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 46 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

7.0 MINIMUM LOAD CASE RUN

7.1 CASE SYSTEM VOLTAGE=1.05 pu, Minimum Expected Loading

Per Reference 2.5, except where noted.

BUS 2A1

| COMPONENT | HP | RUNNING | |
|---------------------|-----|---------|-------|
| | | KW | KVAR |
| Main Chiller 2VCH1A | 950 | 667.0 | 323.0 |
| Load Centers | - | 246.0 | 171.7 |
| TOTAL | | 913.0 | 494.7 |

BUS 2A3

| COMPONENT | HP | RUNNING | |
|-------------------------|-----|---------|-------|
| | | KW | KVAR |
| Service Water Pump 2P4A | 800 | 636.9 | 343.8 |
| LPS1 Pump 2P60A | 450 | 194.5 | 123.1 |
| TOTAL | | 831.4 | 466.9 |

BUS 2A4

No Load

BUS 2B5


| COMPONENT | HP | RUNNING | |
|------------------------|----|---------|-------|
| | | KW | KVAR |
| Ventilation & Lighting | - | 360.8 | 251.8 |
| TOTAL | | 360.8 | 251.8 |

BUS 2B6

| COMPONENT | HP | RUNNING | |
|------------------------|----|---------|-------|
| | | KW | KVAR |
| Ventilation & Lighting | - | 360.8 | 251.8 |
| TOTAL | | 360.8 | 251.8 |

Notes:

1. Per Attachment 40.
2. Power factor of 0.90 assumed.
3. Power factor of 0.82 assumed.


| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BCW | gwh |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 47 OF 52 |

8.0 CONCLUSION

RESULTS

| CALCULATED VOLTAGES (ON MOTOR BASE) | | | | | | | | | |
|-------------------------------------|-----------------|-------|-------|-------|-------|-------|-------|-------|-------|
| CASE | BUS | A3 | A4 | B5 | B6 | 2A3 | 2A4 | 2B5 | 2B6 |
| T=0 Sec, Red SS | V _{PU} | 1.022 | 1.022 | 0.998 | 1.020 | 1.004 | 1.004 | 0.978 | 0.883 |
| T=0 Sec, Green SS | V _{PU} | 1.025 | 1.025 | 1.002 | 1.024 | 1.010 | 1.011 | 0.911 | 0.987 |
| T=4.5 Sec, Red SS | V _{PU} | 1.002 | 1.002 | 0.976 | 0.998 | 0.984 | 0.955 | 0.954 | 0.950 |
| T=4.5 Sec, Green SS | V _{PU} | 1.004 | 1.004 | 0.978 | 1.000 | 0.956 | 0.989 | 0.948 | 0.963 |
| T=10 Sec, Red SS | V _{PU} | 1.007 | 1.007 | 0.983 | 1.004 | 0.989 | 0.968 | 0.961 | 0.965 |
| T=10 Sec, Green SS | V _{PU} | 1.009 | 1.009 | 0.985 | 1.007 | 0.969 | 0.994 | 0.961 | 0.967 |
| T=15 Sec, Red SS | V _{PU} | 0.991 | 0.991 | 0.965 | 0.987 | 0.973 | 0.927 | 0.943 | 0.922 |
| T=15 Sec, Green SS | V _{PU} | 0.995 | 0.995 | 0.967 | 0.991 | 0.933 | 0.980 | 0.922 | 0.952 |
| T=18.2 Sec, Red SS | V _{PU} | 1.003 | 1.003 | 0.978 | 1.000 | 0.985 | 0.959 | 0.957 | 0.878 |
| T=18.2 Sec, Green SS | V _{PU} | 1.007 | 1.007 | 0.983 | 1.004 | 0.965 | 0.993 | 0.880 | 0.965 |
| T=22.7 Sec, Red SS | V _{PU} | 1.004 | 1.004 | 0.978 | 1.000 | 0.986 | 0.959 | 0.957 | 0.876 |
| T=22.7 Sec, Green SS | V _{PU} | 1.006 | 1.006 | 0.980 | 1.002 | 0.960 | 0.991 | 0.874 | 0.963 |
| T=50 Sec, Red SS | V _{PU} | 1.020 | 1.020 | 0.996 | 1.017 | 1.003 | 1.001 | 0.976 | 0.941 |
| T=50 Sec, Green SS | V _{PU} | 1.022 | 1.022 | 0.998 | 1.020 | 1.002 | 1.008 | 0.939 | 0.983 |
| T=60 Sec, Red SS | V _{PU} | 1.016 | 1.016 | 0.991 | 1.013 | 0.998 | 0.991 | 0.972 | 0.878 |
| T=60 Sec, Green SS | V _{PU} | 1.018 | 1.018 | 0.993 | 1.015 | 0.992 | 1.003 | 0.880 | 0.978 |
| T=70 Sec, Red SS | V _{PU} | 1.016 | 1.016 | 0.991 | 1.013 | 0.998 | 0.991 | 0.972 | 0.876 |
| T=70 Sec, Green SS | V _{PU} | 1.020 | 1.020 | 0.996 | 1.017 | 0.997 | 1.005 | 0.904 | 0.980 |
| T=80 Sec, Red SS | V _{PU} | 1.018 | 1.018 | 0.993 | 1.015 | 1.000 | 0.996 | 0.974 | 0.909 |
| T=80 Sec, Green SS | V _{PU} | 1.022 | 1.022 | 0.998 | 1.020 | 1.002 | 1.007 | 0.935 | 0.983 |
| T=85 Sec, Green SS | V _{PU} | 0.998 | 0.998 | 0.972 | 0.993 | 0.942 | 0.983 | 0.867 | 0.957 |
| T=90 Sec, Red SS | V _{PU} | 1.020 | 1.020 | 0.996 | 1.017 | 1.003 | 1.002 | 0.976 | 0.941 |
| T=90 Sec, Green SS | V _{PU} | 0.999 | 0.999 | 0.972 | 0.993 | 0.943 | 0.984 | 0.876 | 0.957 |
| SS, Red W/Swing | V _{PU} | 1.022 | 1.022 | 0.998 | 1.020 | 1.004 | 1.008 | 0.972 | 0.983 |
| SS, Green W/Swing | V _{PU} | 1.022 | 1.022 | 0.998 | 1.020 | 1.005 | 1.007 | 0.978 | 0.976 |
| Min. Loading | V _{PU} | - | - | - | - | 1.105 | 1.110 | 1.115 | 1.117 |

This analysis evaluated the impact of severely degraded offsite voltage levels while the second offsite source (Start-up #2 Transformer) was supplying both the Unit 2 safety loads expected during an accident condition and the Unit 1 safe shutdown safety loads. This severely degraded voltage condition assumes the outage of the 500/161 KV autotransformer concurrent with the outage of both ANO nuclear units along with the outage of all four of the nearby hydro-generators during summer peak load hour conditions.

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BCD | QWJ |  Entergy Operations ARKANSAS NUCLEAR ONE | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | | PAGE NUMBER | 48 OF 52 |


The results listed above indicate that adequate voltages will be delivered to the safety busses for the abnormal condition when the offsite transmission voltage levels falls to 0.9912 p.u. (159.6 KV). All of the Millstone voltage criteria, established to assure that all safety equipment (1) has adequate voltage to accelerate its load to rated speed and (2) has adequate steady state voltage to supply the vital safety loads so they can perform their necessary safety functions, are maintained.

The steady state voltages on the safety busses (after all the safety loads are energized) ranges from a lowest voltage of 0.972 p.u. (447 volts) on 2B5 and 0.998 p.u. (459 V) on B5 to a high of 1.022 (4088 V) on A3. These minimum voltage levels are well above the voltage levels required to actuate the Millstone undervoltage relays (0.935 for B5 and B6 and 0.927 for 2B5 and 2B6). Thus adequate steady-state voltage levels are maintained.

The momentary voltages that occur as the safety equipment is sequenced onto the offsite power supply range from a lowest of 0.867 p.u. (399 V) on the 2B5 480 volt bus at time = 85 seconds and another low value of 0.876 p.u.(403 V) on 2B6 480 volt bus at time = 22.7 seconds into the sequencing to a high of 0.987 p.u.(454 V) for 2B6 at time = 0 seconds. These are above the minimum momentary value of 0.86 p.u.(396 V) that is allowed per Millstone Criteria for motors starting on the 480 volt safety busses. The lowest momentary 4160 volt safety bus voltage occurred at time = 15 seconds when 2A4 voltage fell to 0.927 p.u. (3708 V.) and A3 voltage fell to 0.991 p.u. (3964 V.). This is well above the 0.82 p.u. (3280 V.) minimum allowable momentary voltage per the Millstone Criteria while motors are being started. Thus the Millstone voltage criteria is satisfied for the momentary voltage dips that occur as the safety equipment is sequentially started from the offsite power source (Start-up #2 and the 161 KV transmission system).

An analysis was also performed to determine the highest voltage levels that could occur on the onsite auxiliary busses during minimum plant load conditions (Unit 2 in cold shutdown and minimum bus loads during the shutdown) coincident with the offsite transmission system voltage at the maximum expected value (1.05 p.u. or 169 KV.). The results of this analysis indicated that the voltage on Bus 2B6 could rise to 1.117 p.u. This high voltage could only occur for limited periods during an outage when auxiliary loads are at absolute minimum, resulting in little voltage drop on the onsite distribution system. This condition can affect only those busses that have loads energized at this time. Existing operating procedures will prevent any possible prolonged exposure of equipment to overvoltage.


The measures which may be necessary to control overvoltage conditions are: (1) transmission system operator actions such as energization of reactors , de-energization of capacitors, and removal of EHV transmission lines (2) energization of additional load on the onsite distribution system to increase voltage drop (3) placing the safety busses on the EDG's instead of the offsite power source. The third action would be taken only if the other actions did not sufficiently mitigate the high voltage condition. It should be noted that immediate action would not be

| | | | | | | |
|-------------|-------------|-----------|--------------|--|---------------------------|----------|
| 0 | 7/24/92 | BCL | GWK |  Entergy Operations ARKANSAS NUCLEAR ONE | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | | PAGE NUMBER | 49 OF 52 |


required for slight high voltage conditions (i.e. slightly above 110% voltage). Detrimental affects from high voltages occur over extended periods of time (equipment heating effects due to overexcitation etc:). There would be sufficient time to follow procedural steps to mitigate the high voltage. The Unit 2 procedures direct the operator to take the above recommended actions to reduce voltage on the safety busses before placing them on the EDG's. This third action (placing load on the EDG's) has never been required at ANO to this date. The times when the above-mentioned high voltage conditions could be encountered at ANO are deemed to be minimal. Generally, if one of the two nuclear units is operating, the offsite voltages can be controlled by the operating generator. Thus, the frequency and duration of these high voltages would be expected to be very limited and are therefore considered to be acceptable.

9.0 ATTACHMENTS


- (1) Equations, 3 pages
- (2) 480V Bus Loads, 4 pages
- (3) Startup Transformer No. 2 Test Report, 2 pages
- (4) Transformer Test Report for Load Centers B5 and B6, 1 page
- (5) Transformer Data Sheets, 3 pages
- (6) Load Center Transformer Data Sheets, 6 pages
- (7) Transformer Test Report for Load Center 2B5, 1 page
- (8) Transformer Test Report for Load Center 2B6, 1 page
- (9) Startup No. 2 Current Limiting Reactors Performance Specification, 1 page
- (10) Bus 2A1 to 2A3 and Bus 2A2 to 2A4 Current Limiting Reactor Test Reports, 1 page
- (11) Service Water Pumps 2P4A, 2P4B, & 2P4C, Motor Data Sheet, 1 page
- (12) Service Water Pumps 2P4A, 2P4B, & 2P4C, Motor Data Sheet, 1 page
- (13) Service Water Pumps 2P4A, 2P4B, & 2P4C, Acceleration Calculation, 1 page
- (14) Service Water Pumps 2P4A, 2P4B, & 2P4C, Pump Speed/Torque Curve & Motor Speed/Torque Curve, 1 page
- (15) Service Water Pumps 2P4A, 2P4B, & 2P4C, Pump Data Sheet, 1 page
- (16) Emergency Feedwater Pump 2P7B, Motor Data Sheet, 1 page
- (17) Emergency Feedwater Pump 2P7B, RPM/Time Curve at 100% and 80% Line Voltage, 1 page
- (18) Emergency Feedwater Pump 2P7B, RPM/Time & Current/RPM Curves, 1 page
- (19) Containment Spray Pump 2P35A & 2P35B, Motor Data Sheet, 1 page
- (20) Containment Spray Pump 2P35A & 2P35B, RPM/Current & RPM/Power Factor Curves, 1 page
- (21) Containment Spray Pump 2P35A & 2P35B, RPM/Accelerating Time Curves at 100% and 80% Line Voltage, 1 page
- (22) Low Pressure Safety Injection Pump 2P60A, Motor Data Sheet, 1 page

| | | | | | | |
|------|---------|-----|-------|---|--------------------|----------|
| 0 | 7/24/92 | BLU | JWT |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE NUMBER | 50 OF 52 |
| REV. | DATE | BY | CHK'D | | | |

- (23) Low Pressure Safety Injection Pump 2P60A, Pump Torque/Speed Curve & Motor Torque/Speed Curves at 100% and 75% Line Voltage, 1 page
- (24) Low Pressure Safety Injection Pump 2P60B, Motor Data Sheet, 1 page
- (25) Low Pressure Safety Injection Pump 2P60B, Motor RPM/Power Factor & RPM/Current Curves, 1 page
- (26) Low Pressure Safety Injection Pump 2P60B, Pump Torque/Speed Curve & Motor Torque/Speed Curves at 100% and 75% Line Voltage, 1 page
- (27) High Pressure Safety Injection Pump 2P89A, 2P89B, & 2P89C, Motor Data Sheet, 1 page
- (28) High Pressure Safety Injection Pump 2P89A, 2P89B, & 2P89C, Motor RPM/Current & RPM/Power Factor Curves, 1 page
- (29) High Pressure Safety Injection Pump 2P89A, 2P89B, & 2P89C, Pump Torque/Speed & Motor Torque/Speed Curves at 100% and 75% Line Voltage, 1 page
- (30) Table provided by N.K. Saini of Entergy Bulk Transmission Planning documenting system voltage and system impedance, 1 page
- (31) System Network Diagram, 1 page
- (32) Relay Specification for ITE Model 211R4175, 1 page
- (33) Unit 1 LOOP Loads Table, 3 pages
- (34) Instrument Transformer 2X13 Load Measurement Work Sheet, 1 page
- (35) Instrument Transformer 2X11 Load Measurement Work Sheet, 1 page
- (36) Power and Lighting Panel 21PC Load Measurement Work Sheet, 1 page
- (37) Instrument Transformer 2X14 Load Measurement Work Sheet, 1 page
- (38) Instrument Transformer 2X12 Load Measurement Work Sheet, 1 page
- (39) 208/120 Panel 43LA Load Measurement Work Sheet, 1 page
- (40) Main Chiller 2VCH1A, Motor Data Sheet, 1 page
- (41) High Pressure Safety Injection Pump 2P89A, 2P89B, & 2P89C, Acceleration Calculation, 1 page
- (42) High Pressure Safety Injection Pump 2P89A, 2P89B, & 2P89C, Motor Data Sheet, 1 page
- (43) Telefax from Ingersoll-Rand stating High Pressure Safety Injection Pump 2P89A, 2P89B, & 2P89C pump inertia, 1 page
- (44) Case T=0 seconds, Red Train Steady State, DAPPER Run, 12 pages
- (45) Case T=0 seconds, Green Train Steady State, DAPPER Run, 12 pages
- (46) Case T=4.5 seconds, Red Train Steady State, DAPPER Run, 12 pages
- (47) Case T=4.5 seconds, Green Train Steady State, DAPPER Run, 12 pages
- (48) Case T=10 seconds, Red Train Steady State, DAPPER Run, 12 pages
- (49) Case T=10 seconds, Green Train Steady State, DAPPER Run, 12 pages
- (50) Case T=15 seconds, Red Train Steady State, DAPPER Run, 12 pages
- (51) Case T=15 seconds, Green Train Steady State, DAPPER Run, 12 pages
- (52) Case T=18.2 seconds, Red Train Steady State, DAPPER Run, 12 pages

| | | | | | | |
|-------------|-------------|-----------|--------------|--|---------------------------|----|
| 0 | 7/24/92 | BCL | GWH |  Entergy Operations | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| | | | | ARKANSAS NUCLEAR ONE | PAGE | |
| REV. | DATE | BY | CHK'D | | NUMBER | 51 |

- (53) Case T=18.2 seconds, Green Train Steady State, DAPPER Run, 12 pages
- (54) Case T=22.7 seconds, Red Train Steady State, DAPPER Run, 12 pages
- (55) Case T=22.7 seconds, Green Train Steady State, DAPPER Run, 12 pages
- (56) Case T=50 seconds, Red Train Steady State, DAPPER Run, 12 pages
- (57) Case T=50 seconds, Green Train Steady State, DAPPER Run, 12 pages
- (58) Case T=60 seconds, Red Train Steady State, DAPPER Run, 12 pages
- (59) Case T=60 seconds, Green Train Steady State, DAPPER Run, 12 pages
- (60) Case T=70 seconds, Red Train Steady State, DAPPER Run, 12 pages
- (61) Case T=70 seconds, Green Train Steady State, DAPPER Run, 12 pages
- (62) Case T=80 seconds, Red Train Steady State, DAPPER Run, 12 pages
- (63) Case T=80 seconds, Green Train Steady State, DAPPER Run, 12 pages
- (64) Case T=85 seconds, Green Train Steady State, DAPPER Run, 12 pages
- (65) Case T=90 seconds, Red Train Steady State, DAPPER Run, 12 pages
- (66) Case T=90 seconds, Green Train Steady State, DAPPER Run, 12 pages
- (67) Case T=Steady State Bus Loads, 2B5 With Swing Loads, DAPPER Run, 12 pages
- (68) Case T=Steady State Bus Loads, 2B6 With Swing Loads, DAPPER Run, 12 pages
- (69) Case System Voltage=1.05 pu, Bus B5 W/Swing Loads, DAPPER Run, 11 pages

| | | | | | | |
|-------------|-------------|-----------|--------------|--|---------------------------|----------|
| 0 | 7/24/12 | B&W | GWH |  Entergy Operations ARKANSAS NUCLEAR ONE | CALCULATION NUMBER | |
| | | | | | 92-E-0065-01 | |
| REV. | DATE | BY | CHK'D | | PAGE NUMBER | 52 OF 52 |

ATTACHMENT 1

EQUATIONS

1.0 BASE CONVERSION EQUATIONS

Z_{PU} = Per Unit Impedance
 Z_{Ω} = Impedance in Ohms
 KV_{BASE} = Base KV Line to Line
 MVA_{BASE} = Base 3 ϕ Power

$$1.1 \quad Z_{BASE} = (KV_{BASE})^2 / MVA_{BASE}$$

$$1.2 \quad Z_{PU} = Z_{\Omega} / Z_{BASE}$$

$$1.3 \quad PU Z_{NEW} = PU Z_{GIVEN} \times \left(\frac{GIVEN \, KV_{BASE}}{NEW \, KV_{BASE}} \right)^2 \times \left(\frac{NEW \, MVA_{BASE}}{GIVEN \, MVA_{BASE}} \right)$$

2.0 MOTOR EQUATIONS

KVA_R = Running Motor KVA
 KVA_S = Starting Motor KVA
 KW_R = Running Motor KW
 V_R = Rated Motor Voltage
 V_{BUS} = Bus Voltage
 I_{LR} = Motor Locked Rotor Current
 pf = Power Factor

$$2.1 \quad KVA_R = \frac{KW}{pf}$$

$$2.2 \quad KVA_S = \frac{\sqrt{3} \, V_R \, I_{LR}}{1000} \left(\frac{V_{BUS}}{V_R} \right)^2$$

ATTACHMENT 1

3.0 TRANSFORMER EQUATIONS

$R\%$ = Transformer Percent Resistance

$X\%$ = Transformer Percent Reactance

$Z\%$ = Transformer Percent Impedance

$$3.1 \quad R\% = \frac{(\text{Load Loss kW})}{(\text{Rated kVA})} \times 100$$

$$3.2 \quad X\% = \sqrt{Z\%^2 - R\%^2}$$

$$3.3 \quad X\% = Z\% \sqrt{\frac{\left(\frac{X}{R}\right)^2}{\left(\frac{X}{R}\right)^2 + 1}}$$

$$3.4 \quad R\% = \frac{X\%}{\left(\frac{X}{R}\right)}$$

$$3.5 \quad \% \text{Tap} = \left(\frac{V_{\text{ACTUAL}}}{V_{\text{NOMINAL}}} - 1 \right) \times 100$$

ATTACHMENT 1

4.0 POWER EQUATIONS

S = Single Phase Power
 V_{ϕ} = Line to Neutral Voltage
 I^* = Conjugate of the Line Current
 θ = Angle between V_{ϕ} and I

$$4.1 \quad S = V_{\phi} I^*$$

$$4.2 \quad pf = \cos\theta$$

ATTACHMENT 2

CALC 92-E-0065-01
PAGE 1 OF 4

| 2B5 LOAD | HP | EFF | PF | 1RUNNING | | 2STARTING | |
|--|-----------------|------|------|--------------|--------------|--------------|---------------|
| | | | | KW | KVAR | KW | KVAR |
| Instrument Transformer 2X13 | - | 96.8 | 92.0 | 1.7 | 7.5 | - | - |
| Instrument Transformer 2X11 | - | 96.0 | 96.9 | 11.9 | 9.9 | - | - |
| Power & Lighting Panel 27LA | - | - | 90.0 | 25.8 | 26.3 | - | - |
| Cooling Tower Panel 60PA | - | - | 90.0 | 13.5 | 13.8 | - | - |
| Battery Charger 2D33 | - | 75.0 | 80.0 | 43.3 | 32.5 | - | - |
| Boric Acid Make-Up Tank Heater 2M43A | - | 100 | 100 | 7.0 | 0 | - | - |
| Boric Acid Make-Up Tank Heater 2M43C | - | 100 | 100 | 7.0 | 0 | - | - |
| Boric Acid Heater Trace Transformer 2X95 | - | 96.0 | 100 | 5.0 | 0 | - | - |
| Boric Acid Heater Trace Transformer 2X94 | - | 96.0 | 100 | 5.0 | 0 | - | - |
| Power & Lighting Panel 21PC | - | - | 99.9 | 47.6 | 2.1 | - | - |
| Battery Charger 2D31 | - | 85.0 | 73.0 | 60.2 | 56.4 | - | - |
| T=0 | Subtotal | | | 228.0 | 148.5 | 0 | 0 |
| Post Accident Panel 2C128A | 2.0 | 95.0 | 95.0 | 2.0 | 1.8 | 2.8 | 13.9 |
| EDG Room Exhaust Fan Dampers | 0.7 | 95.0 | 90.0 | 0.7 | 0.7 | 1.0 | 4.9 |
| EDG Start Air Compressor 2C4A | 5.0 | 83.5 | 78.5 | 4.5 | 3.6 | 7.1 | 34.7 |
| EDG Start Air Compressor 2C4B | 5.0 | 83.5 | 78.5 | 4.5 | 3.6 | 7.1 | 37.7 |
| EDG Fuel Transfer Pump 2P16A | 2.0 | 80.0 | 72.0 | 1.9 | 1.8 | 2.8 | 13.9 |
| Computer Room A/C 2VUC30 | 38.0 | - | 90.0 | 38.0 | 28.5 | 53.8 | 263.5 |
| Control Room Air Filter 2VVF9 | 5.0 | 84.0 | 78.0 | 4.4 | 3.5 | 7.1 | 34.7 |
| MFW Lube Oil Pump 2P27 | 20.0 | 86.5 | 87.0 | 17.2 | 9.7 | 28.3 | 138.7 |
| RCP Oil Lift Pump 2P63A1/A2 | 3.0 | 81.5 | 68.5 | 2.7 | 2.9 | 4.2 | 20.8 |
| RCP Oil Lift Pump 2P63B1/B2 | 3.0 | 81.5 | 68.5 | 2.7 | 2.9 | 4.2 | 20.8 |
| MFW Pump Turbine Turning Gear 2K7A | 1.5 | 78.5 | 65.5 | 1.4 | 1.6 | 2.1 | 10.4 |
| TG Bearing Lift Pump 2P90R | 5.0 | 81.5 | 69.0 | 4.6 | 4.8 | 7.1 | 34.7 |
| TG Bearing Lift Pump 2P90D | 5.0 | 81.5 | 69.0 | 4.6 | 4.8 | 7.1 | 34.7 |
| TG Bearing Lift Pump 2P90E | 5.0 | 81.5 | 69.0 | 4.6 | 4.8 | 7.1 | 34.7 |
| MOV's (various) | 100.0 | - | 70.0 | 100.0 | 102.0 | 141.6 | 693.5 |
| Switchgear Room Exhaust Fan 2VEF5JB | 25.0 | 90.0 | 85.0 | 20.7 | 12.8 | 35.4 | 173.4 |
| T>0 | Subtotal | | | 214.5 | 189.8 | 318.8 | 1565.0 |
| Containment Cooling Fan 2VVF1A | 75.0 | 93.1 | 78.9 | 67.7 | 52.7 | 106.2 | 520.1 |
| Containment Cooling Fan 2VVF1B | 75.0 | 93.1 | 78.9 | 67.7 | 52.7 | 106.2 | 520.1 |
| T=18.2 | Subtotal | | | 135.4 | 105.4 | 212.4 | 1040.2 |
| NAOH Addition Pump 2P136A | 5.0 | 81.9 | 68.9 | 4.0 | 4.2 | 7.1 | 34.7 |
| MOV's (various) | 100.0 | - | 70.0 | -100.0 | -102.0 | 0 | 0 |
| T=22.7 | Subtotal | | | -96.0 | -97.8 | 7.1 | 34.7 |
| Charging Pump 2P36A | 100.0 | 93.0 | 82.5 | 56.1 | 38.4 | 141.6 | 693.5 |
| Charging Pump Room Cooler 2VUC7A-1 | 5.0 | 81.1 | 73.8 | 4.6 | 4.2 | 7.1 | 34.7 |
| T=50 | Subtotal | | | 60.7 | 42.6 | 148.7 | 728.2 |

| 2B5 LOAD | HP | EFF | PF | 1RUNNING | | 2STARTING | |
|--|------------------|------|------|--------------|--------------|--------------|--------------|
| | | | | KW | KVAR | KW | KVAR |
| Charging Pump 2P36C (Swing) | 100.0 | 93.0 | 82.5 | 105.1 | 38.4 | 141.6 | 693.5 |
| Charging Pump Room Cooler 2VUC7C-5 (Swing) | 5.0 | 81.1 | 73.8 | 4.6 | 4.2 | 7.1 | 34.7 |
| T=60 Subtotal | W/Swing Loads | | | 60.7 | 42.6 | 148.7 | 728.2 |
| | W/O Swing Loads | | | 0 | 0 | 0 | 0 |
| EDG Exhaust Fan 2VEF24A | 15.0 | 86.4 | 72.8 | 12.9 | 12.1 | 21.2 | 104.0 |
| EDG Exhaust Fan 2VEF24B | 15.0 | 86.4 | 72.8 | 12.9 | 12.1 | 21.2 | 104.0 |
| Intake Structure Exhaust Fan 2VEF25A-1 | 10.0 | 86.0 | 85.0 | 8.7 | 5.4 | 14.2 | 69.3 |
| Pent. Room Exhaust Fan 2VEF38A-1 | 10.0 | 83.5 | 85.0 | 8.9 | 5.5 | 14.2 | 69.3 |
| T=70 Subtotal | | | | 43.4 | 35.1 | 70.8 | 346.6 |
| Switchgear Room Unit Cooler 2VUC2C | 5.0 | 81.1 | 73.8 | 4.6 | 4.2 | 7.1 | 34.7 |
| Switchgear Room Unit Cooler 2VUC2D | 5.0 | 81.1 | 73.8 | 4.6 | 4.2 | 7.1 | 34.7 |
| Shutdown Heat Exchanger Room Cooler 2VUC1A | 10.0 | 89.0 | 77.7 | 8.4 | 6.8 | 14.2 | 69.3 |
| Shutdown Heat Exchanger Room Cooler 2VUC1B | 10.0 | 89.0 | 77.7 | 8.4 | 6.8 | 14.2 | 69.3 |
| HPSI Pump Room Cooler 2VUC11A | 5.0 | 83.4 | 79.9 | 4.5 | 3.4 | 7.1 | 34.7 |
| Electrical Equipment Room Cooler 2VUC19A-1 | 5.0 | 81.1 | 73.8 | 4.6 | 4.2 | 7.1 | 34.7 |
| Electrical Equipment Room Cooler 2VUC19B-1 | 5.0 | 81.1 | 73.8 | 4.6 | 4.2 | 7.1 | 34.7 |
| T=80 Subtotal | | | | 39.7 | 33.8 | 63.9 | 312.1 |
| EFW Pump Room Cooler 2VUC6B-1 | 10.0 | 89.0 | 77.7 | 8.4 | 6.8 | 14.2 | 69.3 |
| T=85 Subtotal | | | | 8.4 | 6.8 | 14.2 | 69.3 |
| Electrical Equipment Room Exhaust Fan 2VEF63 | 25.0 | 90.0 | 83.0 | 20.7 | 13.9 | 35.4 | 173.4 |
| T=90 Subtotal | | | | 20.7 | 13.9 | 35.4 | 173.4 |
| Pressurizer Proportional Heaters | - | 100 | 100 | 179.6 | 0 | - | - |
| Control Room Heater 2VUC27A-1 | - | 100 | 100 | 50.0 | 0 | - | - |
| Electrical Room Cooler 2VUC25A-1 | 3.0 | 77.9 | 68.1 | 2.9 | 3.1 | - | - |
| Control Room Cooling Fan 2VUC27A-1 | 10.0 | 84.1 | 82.7 | 8.9 | 6.1 | - | - |
| Pent. Room Radiation Monitor 2RE-8845-1 | 1.5 | - | 70.0 | 1.5 | 1.5 | - | - |
| Battery Room Exhaust Fan 2VEF61 | 2.5 | 81.0 | 82.0 | 2.3 | 1.6 | - | - |
| Manual Subtotal | | | | 245.2 | 12.3 | - | - |
| Steady State Total | W/Swing Loads | | | 960.7 | 533.0 | - | - |
| | W/O Swings Loads | | | 900.0 | 490.4 | - | - |

- Notes:
1. Running KW=(HP x 0.7456)/Eff. (Except where actual Running KW has been calculated.)
 2. Starting KVA=((480/460)² x 6.5)(HP) @ 0.20pf
 3. Per Attachment 34 and Attachment 1, equations 4.1 and 4.2.
 4. Per Attachment 35 and Attachment 1, equations 4.1 and 4.2.
 5. Per Reference 2.7, page 371, using 70% for conservatism.
 6. The load consists of lights and valves, for conservatism use 70% per Reference 2.7, page 371 and page 386, Figure 137.
 7. Per Attachment 36 and Attachment 1, equations 4.1 and 4.2.
 8. Assumed per Reference 2.2, assumption 3.5.
 9. Per Reference 2.7, page 386, Figure 137 rounded to lowest 5%.
 10. Calculated per Reference 2.8.

ATTACHMENT 2

CALC 92-E-0065-01

PAGE 3 OF 4

| 2B6 LOAD | HP | EFF | PF | 1RUNNING | | 2STARTING | |
|--|-------|------|------|--------------|--------------|--------------|---------------|
| | | | | KW | KVAR | KW | KVAR |
| Instrument Transformer 2X14 | - | 96.8 | 49.9 | 1.8 | 3.1 | - | - |
| Instrument Transformer 2X12 | - | 96.0 | 61.9 | 8.2 | 10.4 | - | - |
| Boric Acid Make-Up Tank Heater 2M43B | - | 100 | 100 | 7.0 | 0 | - | - |
| Boric Acid Make-Up Tank Heater 2M43D | - | 100 | 100 | 7.0 | 0 | - | - |
| Boric Acid Heater Trace Transformer 2X97 | - | 96.0 | 100 | 5.0 | 0 | - | - |
| Boric Acid Heater Trace Transformer 2X98 | - | 96.0 | 100 | 5.0 | 0 | - | - |
| 208/120 Panel 43LA | - | - | 96.1 | 7.5 | 2.2 | - | - |
| Battery Charger 2D32 | - | 85.0 | 73.0 | 60.2 | 56.4 | - | - |
| T=0 Subtotal | | | | 101.7 | 72.1 | 0 | 0 |
| Post Accident Panel 2C128B | 2.0 | 75.0 | 75.0 | 2.0 | 1.8 | 2.8 | 13.9 |
| EDG Room Exhaust Fan Dampers | 0.7 | 75.0 | 70.0 | 0.7 | 0.7 | 1.0 | 4.9 |
| EDG Start Air Compressor 2C4C | 5.0 | 83.5 | 78.5 | 4.5 | 3.6 | 7.1 | 34.7 |
| EDG Start Air Compressor 2C4D | 5.0 | 83.5 | 78.5 | 4.5 | 3.6 | 7.1 | 34.7 |
| EDG Fuel Transfer Pump 2P16B | 2.0 | 80.0 | 72.0 | 1.9 | 1.8 | 2.8 | 13.9 |
| MFW Lube Oil Pump 2P26 | 20.0 | 86.5 | 87.0 | 17.2 | 9.7 | 28.3 | 138.7 |
| RCP Oil Lift Pump 2P63C1/C2 | 3.0 | 81.5 | 68.5 | 2.7 | 2.9 | 4.2 | 20.8 |
| TG Turning Gear Oil Pump 2P76 | 40.0 | 90.2 | 80.0 | 33.1 | 24.8 | 56.6 | 277.4 |
| TG Turning Gear 2K6 | 60.0 | 91.0 | 82.5 | 49.2 | 33.7 | 84.9 | 416.1 |
| RCP Oil Lift Pump 2P63D1/D2 | 3.0 | 81.5 | 68.5 | 2.7 | 2.9 | 4.2 | 20.8 |
| MFW Pump Turbine Turning Gear 2K7B | 1.5 | 78.5 | 65.5 | 1.4 | 1.6 | 2.1 | 10.4 |
| TG Bearing Lift Pump 2P90A | 5.0 | 81.5 | 69.0 | 4.6 | 4.8 | 7.1 | 34.7 |
| TG Bearing Lift Pump 2P90C | 5.0 | 81.5 | 69.0 | 4.6 | 4.8 | 7.1 | 34.7 |
| TG Bearing Lift Pump 2P90F | 5.0 | 81.5 | 69.0 | 4.6 | 4.8 | 7.1 | 34.7 |
| MOV's (various) | 100.0 | - | 70.0 | 100.0 | 102.0 | 141.6 | 693.5 |
| Switchgear Room Exhaust Fan 2VEF56A | 25.0 | 90.0 | 85.0 | 20.7 | 12.8 | 35.4 | 173.4 |
| T>0 Subtotal | | | | 254.4 | 216.3 | 399.4 | 1957.3 |
| Containment Cooling Fan 2VSF1C | 75.0 | 93.1 | 78.9 | 67.7 | 52.7 | 106.2 | 520.1 |
| Containment Cooling Fan 2VSF1D | 75.0 | 93.1 | 78.9 | 67.7 | 52.7 | 106.2 | 520.1 |
| T=18.2 Subtotal | | | | 135.4 | 105.4 | 212.4 | 1040.2 |
| NAOH Addition Pump 2P136B | 5.0 | 81.9 | 68.9 | 4.0 | 4.2 | 7.1 | 34.7 |
| MOV's (various) | 100.0 | - | 70.0 | -100 | -102.0 | 0 | 0 |
| T=22.7 Subtotal | | | | -96.0 | -97.8 | 7.1 | 34.7 |
| Charging Pump 2P36B | 100.0 | 93.0 | 82.5 | 56.1 | 38.4 | 141.6 | 693.5 |
| Charging Pump Room Cooler 2VUC7B-2 | 5.0 | 81.1 | 73.8 | 4.6 | 4.2 | 7.1 | 34.7 |
| T=50 Subtotal | | | | 60.7 | 42.6 | 148.7 | 728.2 |
| Charging Pump 2P36C (Swing) | 100.0 | 92.0 | 85.0 | 56.1 | 38.4 | 141.6 | 693.5 |
| Charging Pump Room Cooler 2VUC7C-5 (Swing) | 5.0 | 81.1 | 73.8 | 4.6 | 4.2 | 7.1 | 34.7 |

| 2B6 LOAD | | HP | EFF | PF | 1RUNNING | | 2STARTING | |
|--------------|--|------------------|------|------|----------|-------|-----------|-------|
| | | | | | KW | KVAR | KW | KVAR |
| T=60 | Subtotal | W/Swing Loads | | | 60.7 | 42.6 | 148.7 | 728.2 |
| | | W/O Swing Loads | | | 0 | 0 | 0 | 0 |
| | EDG Exhaust Fan 2VEF24C | 15.0 | 86.4 | 72.8 | 12.9 | 12.1 | 21.2 | 104.0 |
| | EDG Exhaust Fan 2VEF24D | 15.0 | 86.4 | 72.8 | 12.9 | 12.1 | 21.2 | 104.0 |
| | Boric Acid Make-Up Pump 2P39B | 25.0 | 88.5 | 84.5 | 21.1 | 13.4 | 35.4 | 173.4 |
| | Boric Acid Make-Up Pump 2P39A | 25.0 | 88.5 | 84.5 | 21.1 | 13.4 | 35.4 | 173.4 |
| | Intake Structure Exhaust Fan 2VEF25B-2 | 10.0 | 86.0 | 85.0 | 8.7 | 5.4 | 14.2 | 69.3 |
| | Pent. Room Exhaust Fan 2VEF38B-2 | 10.0 | 83.5 | 85.0 | 8.9 | 5.5 | 14.2 | 69.3 |
| T=70 | Subtotal | | | | 85.6 | 61.9 | 141.6 | 693.4 |
| | Switchgear Room Unit Cooler 2VUC2A | 5.0 | 81.1 | 73.8 | 4.6 | 4.2 | 7.1 | 34.7 |
| | Switchgear Room Unit Cooler 2VUC2B | 5.0 | 81.1 | 73.8 | 4.6 | 4.2 | 7.1 | 34.7 |
| | Shutdown Heat Exchanger Room Cooler 2VUC1E | 10.0 | 89.0 | 77.7 | 8.4 | 6.8 | 14.2 | 69.3 |
| | Shutdown Heat Exchanger Room Cooler 2VUC1D | 10.0 | 89.0 | 77.7 | 8.4 | 6.8 | 14.2 | 69.3 |
| | HPSI Pump Room Cooler 2VUC11B | 5.0 | 83.4 | 79.9 | 4.5 | 3.4 | 7.1 | 34.7 |
| | Electrical Equipment Room Cooler 2VUC20A-2 | 1.0 | 71.8 | 66.2 | 1.0 | 1.1 | 1.4 | 6.9 |
| | Electrical Equipment Room Cooler 2VUC20B-2 | 1.0 | 76.0 | 63.0 | 1.0 | 1.2 | 1.4 | 6.9 |
| T=80 | Subtotal | | | | 32.5 | 27.7 | 52.5 | 256.5 |
| | EFW Pump Room Cooler 2VUC6A-2 | 10.0 | 89.0 | 77.7 | 8.4 | 6.8 | 14.2 | 69.3 |
| | Electrical Equipment Room Exhaust Fan 2VEF64 | 25.0 | 89.0 | 83.0 | 20.7 | 13.9 | 35.4 | 173.4 |
| T=90 | Subtotal | | | | 29.1 | 20.7 | 49.6 | 242.7 |
| | Pressurizer Proportional Heaters | - | 100 | 100 | 179.6 | 0 | - | - |
| | Control Room Heater 2VUC27B-2 | - | 100 | 100 | 50.0 | 0 | - | - |
| | Electrical Room Cooler 2VUC25B-2 | 3.0 | 77.9 | 68.1 | 2.9 | 3.1 | - | - |
| | Control Room Cooling Fan 2VUC27B-2 | 10.0 | 84.1 | 82.7 | 8.9 | 6.1 | - | - |
| | Pent. Room Radiation Monitor 2RE-8846-2 | 1.5 | - | 70.0 | 1.5 | 1.5 | - | - |
| | Battery Room Exhaust Fan 2VEF65 | 2.5 | 81.0 | 77.0 | 2.3 | 1.9 | - | - |
| | Battery Room Exhaust Fan 2VEF49 | 1.0 | 75.0 | 70.0 | 1.0 | 1.0 | - | - |
| Manual | Subtotal | | | | 246.4 | 13.6 | - | - |
| Steady State | Total | W/Swing Loads | | | 910.5 | 505.1 | - | - |
| | | W/O Swings Loads | | | 849.8 | 462.5 | - | - |

- Notes:
1. Running KW = (HP x 0.7456)/Eff. (Except where actual Running KW has been calculated.)
 2. Starting KVA = ((480/460)² x 6.5)(HP) @ 0.20pf
 3. Per Attachment 37 and Attachment 1, equations 4.1 and 4.2.
 4. Per Attachment 38 and Attachment 1, equations 4.1 and 4.2.
 5. Per Attachment 39 and Attachment 1, equations 4.1 and 4.2.
 6. Assumed per Reference 2.7, assumption 3.5
 7. Per Reference 2.7, page 386, Figure 137 rounded to lowest 5%.
 8. Calculated per Reference 2.8

POWER TRANSFORMER DEPARTMENT



PITTSFIELD, MASS.

RT P71-99

Date of Test March 1971

REPORT OF TEST ON TRANSFORMERS

Purchaser Bechtel Corp. For Arkansas Power & Light Co.

RATING ****27000/36000/45000KVA**

| H - Winding | X - Winding | Y - Winding | Purchaser's Order No. |
|---------------------------------------|-------------------|--------------|---------------------------|
| Volt 15700GRY/90840 | 6900Y | 4160Y/2400 | 6500-2-3-AC |
| Kv 27 | 15000/20000/25000 | 12600/15800/ | G. E. Req'n No. 474-68674 |
| Taps as per attached Nameplate 254522 | | | G. E. Contract No. |
| | | | 21000 |

CHARACTERISTICS

Losses, efficiencies and regulations are based on wattmeter measurements and, unless otherwise stated, on normal rating. For three phase transformers the resistances given are the sum of the three phases.

| Serial | Resistance @85 C | | | NO LOAD LOSS WATTS AT 100% VOLTAGE | % EXCIT. CURRENT AT 100% VOLTAGE | 157GRY Kv | | Kv | | Kv | |
|-------------------------------|------------------|-----------|----------|------------------------------------|----------------------------------|--------------|----------|----------|----------|----|-----|
| | H | X | Y | | | To 69Y-4.16V | Kv | To | Kv | To | Kv |
| | Stab. | | | | | AL 27000 (*) | Evo | AL | Evo | AL | Evo |
| B409010 | 5.413 | .01290 | .005252 | 53500 | 1.29 | 91880 | 4.93 | | | | |
| AVERAGE | | | | | | | | | | | |
| GUARANTEE | | | | 72000 | | | | | | | |
| Total Loss Watts @85 C | | | | AVERAGE | | 145330 | | | | | |
| | | | | GUARANTEE | | 154000 | | | | | |
| EFFICIENCIES AT 75C 100% P.F. | | | | | REGULATION AT 75C | | | | | | |
| Load | | Full Load | 1/2 Load | 1/4 Load | 1/2 Load | 100% P.F. | 90% P.F. | 80% P.F. | 70% P.F. | | |
| AVERAGE | | 99.46 | 99.48 | 99.44 | 99.13 | See Page #2 | | | | | |
| GUARANTEE | | 99.44 | 99.43 | 99.33 | 99.88 | GUARANTEE | | | | | |

TEMPERATURE RISE (Serial No. *******)

Average ultimate temperature rise in deg C corrected to instant of shutdown

| | | H - Winding | | X - Winding | | Y - Winding | | | |
|--------------------|-------|-------------|------|-------------|------|-------------|------|-------------------|--------|
| Winding Connection | | 149150 | Y. | 6900 | Y. | 4160 | Y. | Method of cooling | ON |
| MVA | Amp. | 27 | 104 | 15 | 1255 | 12 | 1665 | Top oil rise | 57.6 C |
| Rise Test | Quar. | 58.7 C | 65 C | 55.4 C | 65 C | 55.7 C | 65 C | Ambient | 25.0 C |
| Winding Temp. Ind. | | deg C | | deg C | | deg C | | | |
| Winding Connection | | 149150 | Y. | 6900 | Y. | 4160 | Y. | Method of cooling | ON |
| MVA | Amp. | 45 | 174 | 26 | 2090 | 21 | 2910 | Top oil rise | 82.3 C |
| Rise Test | Quar. | 59.4 C | 65 C | 53.0 C | 65 C | 62.3 C | 65 C | Ambient | 35.0 C |
| Winding Temp. Ind. | | deg C | | deg C | | deg C | | | |

DIELECTRIC TESTS

| APPLIED POTENTIAL TEST | VOLTAGE OF WINDING TESTED | TEST VOLTAGE APPLIED | DURATION IN SECONDS |
|---|---------------------------|----------------------|-------------------------|
| Voltage applied to each winding in turn with all other windings connected to core and ground. | H | 50000 | 60 seconds for oil test |
| Line Terminal To Ground | X | 26000 | |
| | Y Stab. | 19000 34000 | |
| Induced voltage test: 275KV/EV 275KV/27000KVA for 7200 cycles | | | |

Remarks (*)157KV = 27000KVA, 6.9KV = 15000KVA and 4.16KV = 12000KVA
Note: Efficiencies are based on 3 Wdg. loading, H @ 27MVA, X @ 15MVA, Y @ 12MVA, on a 27MVA Base.

*Temperature values are based on design data obtained from thermally similar transformers.

(Continued on Page #2)

I hereby certify that this is a true report based on factory tests made in accordance with the American Standard Test Code for Distribution, Power and Regulating Transformers, C57.12 or latest revision thereof, and that each transformer withstood the above insulation tests.

Signed P.M. Esbette Date 4-12-71 Approved by F. Peronto



TRANSFORMER TEST REPORT

PURCHASER Arkansas Power & Light Co. Russellville, Ark.
 DATE OF TEST 3/21/70 PURCHASER'S ORDER NO. 6500-E-10 MFR'S. REF. NO. AR-0335B
 TYPE GA PHASE Three CYCLES 60 INSULATING FLUID Oil
 WINDING 1 1150 VOLTS WINDING 2 1000 VOLTS WINDING 3 _____ VOLTS
 _____ KVA _____ KVA _____ KVA
 RESISTANCES, EXCITING CURRENT, LOSSES, AND IMPEDANCE ARE BASED ON NOMINAL RATING UNLESS OTHER-
 WISE STATED. LOSSES AND REGULATION ARE BASED ON RATED MEASUREMENTS. FOR SMALL PHASE TRANS-
 FORMERS THE RESISTANCES GIVEN ARE THE SUM OF THE THREE PHASE SERIES RESISTANCES.

| SERIAL NO. | RESISTANCE IN OHMS AT 170C | | | EXCITING CURRENT AT 100% RATED VOLTAGE | NO LOAD LOSS WATTS AT 100% RATED VOLTAGE | LOAD LOSS WATTS | | |
|------------------|----------------------------|------|-----|--|--|-----------------|-------|------------|
| | (1) | (2) | (3) | | | 170C | 170C | 170C |
| 18872 | 53 | 0039 | | 01 | 2813 | 11075 | 8.09 | |
| 18880 | 50 | 0037 | | 04 | 2857 | 12366 | 8.10 | |
| 18881 | 53 | 0037 | | 00 | 2880 | | | 12532 8.11 |
| TOTAL LOSS WATTS | | | | | | 14728 | 15268 | 15412 |

| REGULATION AT 170C | | AVERAGE | |
|--------------------|-------|---------|------|
| 100% PF | % PF | 100% PF | % PF |
| AVERAGE | 11.50 | | 5.86 |
| GUARANTEE | | | |

TEMPERATURE RISES ARE AVERAGE IN RISES IN DEGREE C. CORRECTED TO INFLUENCE OF SHUTDOWNS.
 SERIAL NO. _____ WITH WINDINGS CONNECTED AND LOADED AS FOLLOWS:
 (1) _____ KV AMP (2) _____ KV AMP
 (3) _____ KV AMP UNTIL CONSTANT TEMPERATURE RISE WAS REACHED.

| TEMP RISE OF WINDINGS BY RES. DEG C | | | | TEMP FLUID | AMBIENT TEMP | | | WATER | |
|-------------------------------------|-----|-----|-----------|------------|--------------|------|-----------|-----------------|-----------------|
| (1) | (2) | (3) | GUARANTEE | | WINDING | COIL | TEMP RISE | GALLONS PER MIN | POUNDS PRESSURE |
| 37 | 13 | 0 | 100 | | | 25.0 | | | |

| APPLIED POTENTIAL TESTS VOLTAGE APPLIED BETWEEN EACH WINDING AND ALL OTHER WINDINGS CONNECTED TO CORE AND GROUND | VOLTAGE RATING OF WINDING TESTED | TESTING TIME APPLIED IN CYCLES | DURATION OF TEST IN SECONDS |
|---|----------------------------------|--------------------------------|-----------------------------|
| | | | |
| 1150 | 1150 | 10 | 60 |
| 1000 | 1000 | 10 | 60 |

INDUCED POTENTIAL TEST
 BY FROM _____ AT LINE TERMINAL TO GROUND
 AT _____ CYCLES PER SECOND FOR _____ 7200 _____ CYCLES

REMARKS:
 I HEREBY CERTIFY THAT THIS IS A TRUE REPORT BASED ON FACTORY TESTS MADE IN ACCORDANCE WITH THE
 AMERICAN STANDARD TEST CODE FOR DISTRIBUTION, POWER AND REGULATING TRANSFORMERS, C57.12, OR LATEST
 REVISION THEREOF, AND THAT EACH TRANSFORMER WITHSTOOD THE ABOVE REGULATION TESTS.
 SIGNED Henry R. Mayers DATE 3/25/70 APPROVED William Hutscher
 _____ ENGINEERING DEPT.

Temperature is a
 taken from a
 transformer of
 similar design

TRANSFORMER DATA SHEET

UNIT 1

Main Transformer (X-01)

Serial No. 7001702, 7001703, 7001704, & 7001705

| AVAILABLE TAPS | DIAL POSITION |
|------------------|---------------|
| <u>537500</u> KV | <u>1</u> |
| <u>525000</u> KV | <u>2</u> |
| <u>512500</u> KV | <u>3</u> |
| <u>500000</u> KV | <u>4</u> |
| <u>487500</u> KV | <u>5</u> |

CURRENT DIAL POSITION 4

Unit Auxiliary Transformer (X-02)

Serial No. H409011

| AVAILABLE TAPS | DIAL POSITION |
|-----------------|---------------|
| <u>22575</u> KV | <u>1</u> |
| <u>22037</u> KV | <u>2</u> |
| <u>21500</u> KV | <u>3</u> |
| <u>20962</u> KV | <u>4</u> |
| <u>20425</u> KV | <u>5</u> |

CURRENT DIAL POSITION 3

Startup No. 1 Transformer (X-03)

Serial No. H409012

| AVAILABLE TAPS | DIAL POSITION |
|-----------------|---------------|
| <u>22575</u> KV | <u>1</u> |
| <u>22037</u> KV | <u>2</u> |
| <u>21500</u> KV | <u>3</u> |
| <u>20962</u> KV | <u>4</u> |
| <u>20425</u> KV | <u>5</u> |

CURRENT DIAL POSITION 3

Verified Brian Williams Date 10/24/91

Startup No. 2 Transformer (X-04)

Serial No. H409010

| AVAILABLE TAPS | DIAL POSITION |
|------------------|---------------|
| <u>164850</u> KV | <u>1</u> |
| <u>160925</u> KV | <u>2</u> |
| <u>157000</u> KV | <u>3</u> |
| <u>153075</u> KV | <u>4</u> |
| <u>149150</u> KV | <u>5</u> |

CURRENT DIAL POSITION 3

UNIT 2

Main Power Transformer (2X-01)

Serial No. H409949, H409950, & H409951

| AVAILABLE TAPS | DIAL POSITION |
|------------------|---------------|
| <u>537500</u> KV | <u>1</u> |
| <u>525000</u> KV | <u>2</u> |
| <u>512500</u> KV | <u>3</u> |
| <u>500000</u> KV | <u>4</u> |
| <u>487500</u> KV | <u>5</u> |

CURRENT DIAL POSITION 4

Unit Auxiliary Transformer (2X-02)

Serial No. H409966

| AVAILABLE TAPS | DIAL POSITION |
|-----------------|---------------|
| <u>22570</u> KV | <u>1</u> |
| <u>22040</u> KV | <u>2</u> |
| <u>21500</u> KV | <u>3</u> |
| <u>20960</u> KV | <u>4</u> |
| <u>20420</u> KV | <u>5</u> |

CURRENT DIAL POSITION 4

Verified Brian Villain Date 10/29/91

Startup No. 3 Transformer (2X-03)

Serial No. H409965

| AVAILABLE TAPS | DIAL POSITION |
|-----------------|---------------|
| <u>22574</u> KV | <u>1</u> |
| <u>22640</u> KV | <u>2</u> |
| <u>21500</u> KV | <u>3</u> |
| <u>20460</u> KV | <u>4</u> |
| <u>20420</u> KV | <u>5</u> |

CURRENT DIAL POSITION 3

SWITCHYARD

Autotransformer

Serial No. D-596828, D-596829, D-596830, & D-596831

| AVAILABLE TAPS | DIAL POSITION |
|------------------|---------------|
| <u>525010</u> KV | <u>1</u> |
| <u>512500</u> KV | <u>2</u> |
| <u>500000</u> KV | <u>3</u> |
| <u>487500</u> KV | <u>4</u> |
| <u>475000</u> KV | <u>5</u> |

CURRENT DIAL POSITION 3

Verified Eric J. Miller Date 10/24/91

LOAD CENTER TRANSFORMER DATA SHEET

UNIT 1

B1 Load Center Transformer (X-1)

Serial No. 18879

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION C

B2 Load Center Transformer (X-2)

Serial No. 18877

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION C

B3 Load Center Transformer (X-3)

Serial No. 18882

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION C

Verified Brian Wilcox Date 4/3/92

Verified John Hon Date 4/3/92

B4 Load Center Transformer (X-4)

Serial No. 18878

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION C

B5 Load Center Transformer (X-5)

Serial No. 18880

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION D

B6 Load Center Transformer (X-6)

Serial No. 18881

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION D

Verified Bia Villan Date 4/3/92

Verified John Hotz Date 4/3/92

B7 Load Center Transformer (X-7)

Serial No. 93355E2

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION C

UNIT 2

2B1 Load Center Transformer (2X-21)

Serial No. 21288-B01

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION C

2B2 Load Center Transformer (2X-22)

Serial No. 21288-A01

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION C

Verified Bia Wilkin Date 4/3/92

Verified John Hotz Date 4/3/92

2B3 Load Center Transformer (2X-23)

Serial No. 21288-A02

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION C

2B4 Load Center Transformer (2X-24)

Serial No. 21288-B02

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION C

2B5 Load Center Transformer (2X-25)

Serial No. 21288-B03

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION D

Verified Brian Wilkerson Date 4/3/92

Verified John W. Hotz Date 4/6/92

2B6 Load Center Transformer (2X-26)

Serial No. 18883

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION D

2B7 Load Center Transformer (2X-27)

Serial No. 21288-C01

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION C

2B8 Load Center Transformer (2X-28)

Serial No. 21288-B05

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION C

Verified Brian Villan Date 4/16/92

Verified John W. Holz Date 4/16/92

2B9 Load Center Transformer (2X-29)

Serial No. 21288-D01

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION C

2B10 Load Center Transformer (2X-30)

Serial No. 21288-E01

| AVAILABLE TAPS | DIAL POSITION |
|----------------|---------------|
| <u>4360V</u> | <u>A</u> |
| <u>4260V</u> | <u>B</u> |
| <u>4160V</u> | <u>C</u> |
| <u>4055V</u> | <u>D</u> |
| <u>3950V</u> | <u>E</u> |

CURRENT DIAL POSITION C

Verified Birg W. Williams Date 4/16/92

Verified John H. King Date 4/16/92



TRANSFORMER TEST REPORT

PURCHASER Bechtel-Arkansas Power & Light
 DATE OF TEST 11-20-72 PURCHASER'S ORDER NO. _____ MFR'S. REF. NO. 48-21288
 TYPE GA PHASE Three CYCLES 60 INSULATING FLUID G2F6
 WINDING 1: 4160 VOLTS WINDING 2: 480Y/277 VOLTS WINDING 3: _____ VOLTS
1000 KVA WINDING 2: 1000 KVA WINDING 3: _____ KVA

RESISTANCES, EXCITING CURRENT, LOSSES, AND IMPEDANCE ARE BASED ON NORMAL RATING UNLESS OTHERWISE STATED. LOSSES AND REGULATION ARE BASED ON WATTMETER MEASUREMENTS. FOR THREE-PHASE TRANSFORMERS THE RESISTANCES GIVEN ARE THE SUM OF THE THREE PHASES IN SERIES.

| SERIAL NO. | RESISTANCE IN OHMS AT 170 C | | | % EXCITING CURRENT AT 100% RATED VOLTAGE | NO LOAD LOSS WATTS AT 100% RATED VOLTAGE | KV | | KV | | KV | |
|------------|-----------------------------|--------|-----|--|--|------------------|------|-------|------------------|-------|-------|
| | (1) | (2) | (3) | | | To | From | To | From | To | From |
| R-01 | .880 | .00345 | | .99 | 3120 | 12257 | 170 | 170 | 12390 | 170 | 170 |
| B-02 | .992 | .00348 | | .93 | 3000 | | | | 12390 | 170 | 170 |
| B-03 | .985 | .00348 | | 1.01 | 2920 | | | | | 12315 | 170 |
| | | | | | | TOTAL LOSS WATTS | 170 | 15377 | TOTAL LOSS WATTS | 170 | 15390 |
| | | | | | | TOTAL LOSS WATTS | 170 | 15235 | TOTAL LOSS WATTS | 170 | 15235 |

S/N B-01
REGULATION AT 170C

| AVERAGE | | | |
|-----------|---------|------|--------|
| GUARANTEE | | | |
| | 100% PF | % PF | 80% PF |
| AVERAGE | 1.52 | | 5.68 |
| GUARANTEE | | | |

TEMPERATURE RISES ARE AVERAGE IN RISES IN DEGREES C. CORRECTED TO INSTANT OF SHUTDOWN.

SERIAL NO. R-01 WITH WINDINGS CONNECTED AND LOADED AS FOLLOWS:
 (1) .302 KV 146 AMP. (2) SHORT CIRCUITED AMP.
 (3) _____ KV _____ AMP. UNTIL CONSTANT TEMPERATURE RISE WAS REACHED.

| TEMP RISE OF WINDINGS BY RES. DEG C | | | | TOP AMBIENT TEMP | | | WATER | | |
|-------------------------------------|-------|-----|-----------|------------------|---------------|---------------|-----------------|-----------------|-----------------|
| (1) | (2) | (3) | GUARANTEE | TEMP RISE | INGOING WATER | ISLER OF ROOM | TEMP RISE DEG C | GALLONS PER MIN | POUNDS PRESSURE |
| 137.0 | 129.6 | | 150.0 | 97.0 | | 26.0 | | | |

DIELECTRIC TESTS

| APPLIED-POTENTIAL TESTS (VOLTAGE APPLIED BETWEEN EACH WINDING AND ALL OTHER WINDINGS CONNECTED TO CORE AND GROUND) | VOLTAGE RATING OF WINDING TESTED | TEST VOLTAGE APPLIED IN KV | DURATION OF TEST IN SECONDS |
|---|----------------------------------|----------------------------|-----------------------------|
| | 4160 | 19 | 60 |
| | 480Y/277 | 10 | 60 |

TWO TIMES RATED VOLTAGE ACROSS FULL WINDING;
 INDUCED-POTENTIAL TEST BY FROM _____ BY LINE TERMINAL TO GROUND;
 AT 400 CYCLES PER SECOND FOR 7200 CYCLES.

REMARKS:

I HEREBY CERTIFY THAT THIS IS A TRUE REPORT BASED ON FACTORY TESTS MADE IN ACCORDANCE WITH THE American Standard Test Code for Distribution, Power and Regulating Transformers, C57.22, OR LATEST REVISION THEREOF, AND THAT EACH TRANSFORMER WITHSTOOD THE ABOVE INSULATION TESTS.

SIGNED Henry R. Meyers DATE 5/31/73 APPROVED William H. Mutschler, Jr.
 Henry R. Meyers TRANSFORMER ENGINEERING DEPT.
 PAGES 4 PAGE 2 William H. Mutschler, Jr.
 ADOPTED STANDARD 7-22-1943.

TRANSFORMER TEST REPORT

PLUCK SER Arkansas Power & Light Co. Arkansas
 DATE OF TEST 3/20/70 PURCHASER'S ORDER NO. 92-2-10 LTR'S. REF. NO. 10-03355
 TYPE QA PHASE Three CYCLES 50 INSULATING FLUID None
 WINDING 1 4360 VOLTS 4300000 VOLTS
 WINDING 2 1000 VOLTS WINDING 3 1000 VOLTS
 RESISTANCES, EXCITING CURRENT, LOSSES, AND IMPEDANCE ARE BASED ON NORMAL RATING UNLESS OTHER WINDING RATINGS AND REGULATIONS ARE BASED ON FACTORY MEASUREMENTS. FOR THREE PHASE TRANSFORMERS THE RESISTANCES GIVEN ARE THE SUM OF THE THREE PHASES IN SERIES.

100003402

| SERIAL NO | RESISTANCE IN OHMS AT 170°C | | | EXCITING CURRENT AT 100% RATED VOLTAGE | NO-LOAD LOSS WATTS AT 100% RATED VOLTAGE | LOAD LOSS WATTS | LOAD LOSS % | LOAD LOSS WATTS | LOAD LOSS % |
|------------------|-----------------------------|------|-----|--|--|-----------------|-------------|-----------------|-------------|
| | (1) | (2) | (3) | | | | | | |
| 18883 | 502 | 0037 | | 02 | 2653 | 12438 | 8.2 | | |
| TOTAL LOSS WATTS | | | | | | 170°C | 5123 | | |

REGULATION AT 170°C

TEMPERATURE RISES ARE AVERAGE IN RISES, IN PERCENTS C. CONNECTED TO INSTALLED EXCITATION. WITH WINDINGS CONNECTED TO FOLLOWING SERIAL NO. (1) (2) (3) UNTIL CONSTANT TEMPERATURE REACHED.

| TEMP RISE OF WINDINGS BY RES. DEG C | | | TOP FLUID TEMP RISE | AMBIENT TEMP | | |
|-------------------------------------|------|-----|---------------------|--------------|--------|-------------------|
| (1) | (2) | (3) | | IN WINDING | IN OIL | TEMP RISE (DEG C) |
| 37.0 | 13.0 | | 150.0 | | 25 | |

| APPLIED POTENTIAL TESTS VOLTAGE APPLIED BETWEEN EACH WINDING, AND ALL OTHER WINDINGS CONNECTED TO CORE AND TAPPOST | VOLTAGE RATING OF WINDINGS TESTED | TEST VOLTAGE APPLIED IN KVP | DURATION OF TEST IN SECONDS | |
|---|-----------------------------------|-----------------------------|-----------------------------|-----|
| | | | (1) | (2) |
| | 4160 | 119 | 60 | |
| | 580 | 110 | 60 | |

INDUCED POTENTIAL TEST
 TIMES RATED TO PASS ACROSS EACH WINDING.
 100 CYCLES PER SECOND/70%
 REMARKS:
 I HEREBY CERTIFY THAT THIS IS A TRUE REPORT BASED ON FACTORY TESTS MADE IN ACCORDANCE WITH THE American Standards Test Code for Distribution, Power and Regulating Transformers, AND THE LATEST REVISION THEREOF, AND THAT EACH TRANSFORMER WITHSTOOD THE ABOVE INSULATION TESTS.
 SIGNED Henry R. Moyers DATE 4/15/70
 HENRY R. MOYERS
 WILLIAM H. SCHULTZ

Temperature data taken from a transformer of similar design.

REACTOR PERFORMANCE SPECIFICATION

FOR BECHTEL - ARKANSAS POWER AND LIGHT

REG. NO. NSFD-4201 SPECIFICATION NO. 294576 DATE 6-24-69

RATING

| CLASS | KVA | PHASE | CYCLES | INDUCTIVE DROOP-VOLTS | AMPERES | OHMS REACTANCE | INSULATING MEDIUM | SERVICE |
|-------|-----|-------|--------|-----------------------|---------|----------------|-------------------|---------|
| B | 655 | 3 | 60 | 69.3 | 3150 | 0.022 | Air | Indoor |

CONDITIONS OF OPERATION

| REACTORS IN GROUP | SYSTEM | | | | PERCENT REACTANCE | APPLICATION |
|-------------------|--------|-------|--------------|----------|-------------------|------------------|
| | KVA | PHASE | LINE VOLTAGE | NEUTRAL | | |
| 1 | | 3 | 4160 | Grounded | 2.9 | Current Limiting |

TEMPERATURE RISE

| LOAD IN % RATED KVA | TIME | MAX. RISE BY RESIST. | METHOD OF COOLING | LOSSES-Reactor only |
|---------------------|------------|----------------------|-------------------|---|
| 100 | Continuous | 80 °C | Self | TOTAL WATTMETER LOSS AT 75°C 14300 WATTS |

DIELECTRIC TESTS

| INSULATION CLASS | APPLIED VOLTAGE TESTS | | INDUCED VOLTAGE TEST IN EACH WINDING | BIL - REACTOR |
|------------------|-----------------------|-------------------|--------------------------------------|---------------|
| | BETWEEN PHASES | WINDING TO GROUND | | |
| 5 KV | 26 KV | 26 KV | 26 KV | 75 KV |

BIL - Bus - 60 KV

SHORT CIRCUIT

| AMPERES | SECONDS | FINAL TEMPERATURE |
|---------|---------|-------------------|
| 50000 | 3 | 350 °C |

ARRESTER

| PROTECTIVE SHUNT ARRESTER |
|---------------------------|
| |

DIMENSIONS

Copper wound with silver plated copper terminals

| | | | | | |
|--|------|------|------|------|-----|
| OUTLINE <u>DS 47-805-2 Fig. 1</u> | A=92 | B=24 | C=40 | D=19 | F=6 |
| TERMINAL <u>FIG. _____</u> | G=35 | H=65 | K=86 | θ=0° | |
| Approximate Reactor weight = 4250 lbs. | | | | | |

Outdoor housing with incoming and outgoing copper bus terminating inside housing throat flanges located on same side of housing.

Approximate housing dimensions: 80 wide X 100 Deep X 120 High
Weight - 2800 lbs.

Total losses reactor plus housing - 28000 watts.

NUCLEAR

G.E. REQ NO: 409-58283
ITEM NO:
CUSTOMER: COLT INDUSTRIES/ARKANSAS POWER & LIGHT CO.
ORDER NO: P-070020A-5
INSTALLATION SITE: ARKANSAS NUCLEAR ONE UNIT NO. 2 LONDON, ARKANSAS
APPLICATION: SERVICE WATER PUMPS 2PMA, B&C
CUST. SPEC. NO: BECHTEL NO. 6600-M-2011

TYPE: K - SCJIREL CAGE INDUCTION
FRAME: 6339P36
HORSEPOWER: 800
TIME RATING: CONTINUOUS
TEMP. RISE BY THERMOMETER: 70 DEG. C.

MOTOR RATING & DESCRIPTION
F.L. SPEED: 885 RPM
RATED VOLTAGE: 4000 VOLTS
F.L. CURRENT: 106 AMPS
SERVICE FACTOR: 1.0
RATED FREQ: 60 CPS (HERTZ)
INSTRUCTION BOOK:

NO. OF PHASES: 3
CODE LETTER: 103
DESIGN LETTER: 103
ROTOR INERTIA: 860 LB. FT.
ALL OPENINGS ARE SCREENED

WINDING TYPE: FORM COIL RANDOM COIL
INSULATION CLASS & SERVICE CONDITIONS: CLASS B POWERHOUSE
ENCLOSURE & VENTILATION: OPEN DRIPPROOF
MOTOR LEAD TERMINAL LUGS (INTERNAL) BLACKBURN L-125-2H FOR MOTOR #2 AWG LEADS

ROTATION DIRECTION: CCW LOOKING DOWN ON TOP

MOTOR PERFORMANCE CHARACTERISTICS AT RATED VOLTAGE & FREQUENCY

| | FULL LOAD | 3/4 LOAD | 1/2 LOAD | LOCKED ROTOR CURRENT: |
|---|-----------|----------|----------|---------------------------------------|
| EFFICIENCY* | 83 | 92.5 | 91.5 | 690 AMPS |
| POWER FACTOR | 87 | 84 | 77 | LOCKED ROTOR P.F. (APPROX.): 29 |
| *EXCLUSIVE OF .35 KW BRG. LOSS DUE TO EXTERNAL THRUST | | | | LOCKED ROTOR TORQUE: 100% F.L. TORQUE |
| | | | | MAXIMUM TORQUE: 200% F.L. TORQUE |
| | | | | FULL LOAD TORQUE: 4750 LB. FT. |

MAXIMUM ALLOWABLE STALL TIME: 14 SEC FROM 80°C OR 20 SEC FROM 30°C INITIAL TEMPERATURE
STATOR WINDING RESISTANCE - LINE TO LINE: .53 OHMS AT 25°C (APPROX.)

SOUND PRESSURE LEVEL: 85 dB-C MAX. AVERAGE OVERALL
ACCELERATION TIME - UNDER 4 SECONDS

MOTOR BEARING & LUBRICATION DATA

BEARING TYPE: INSULATED ANGULAR CONTACT BALL
BEARING CATALOGUE NO: 629A 230 G2 (2) 7230 DT
LUBRICANT TYPE: OIL
QUANTITY OF LUBRICANT: 48 QUARTS
RECOMMENDED LUBRICANT: OXIDATION & CORROSION INHIBITED TURBINE OIL
WITH VISCOSITY AT 100°F: 150 SUS
WITH VISCOSITY AT 210°F: 45 SUS

UPPER BEARING: INSULATED ANGULAR CONTACT BALL
LOWER BEARING: RADIAL BALL
289-2334P 25 (226-5)
OIL
5 QUARTS

THRUST BEARING RATED CAPACITY & RATED LIFE (EXTERNAL LOAD):
CONTINUOUS DOWN-THRUST: 10,000 LBS. OVER 4 YRS. MIN. LIFE
CONTINUOUS UP-THRUST: _____ LBS. _____ LIFE
MAX MOMENTARY DOWN-THRUST: 15,000 LBS.
MAX MOMENTARY UP-THRUST: 3,000 LBS.

MAXIMUM ALLOWABLE CONTINUOUS DOWN-THRUST TO PREVENT DAMAGE TO GUIDE BRG. 0 LBS.
MOMENTARY PERIODS OF UP-THRUST OR LIGHTER DOWN-THRUST ARE PERMISSIBLE.
THRUST BEARING COOLING WATER: _____ GPM (REQUIRED) _____ GPM (MAX) _____ PSI MAX. (INLET), _____ °F MAX. (INLET)
PRESSURE DROP ACROSS COIL _____ PSI FOR _____ FLOW
TOTAL AXIAL EXPLAY: .005 INCHES

MOTOR ACCESSORY EQUIPMENT DATA

SPACE HEATERS: 120 VOLT 5.45 AMPS 655 WATTS (SINGLE-PHASE)
WINDING TEMP. DEVICE: (6) 100 OHM PLATINUM RESISTANCE TEMPERATURE DETECTORS
BEARING TEMP. DEVICE: (1) DUAL ELEMENT CHROMEL CONSTANTAN THERMOCOUPLE EACH BRG.

SYSTEM CRITICAL REED FREQUENCY CALCULATION DATA

IN ORDER TO AVOID EXCESSIVE VIBRATION IT IS NECESSARY THAT THE REED CRITICAL FREQUENCY (CPM) OF THE MOTOR-PUMP SYSTEM BE NUMERICALLY AT LEAST 25% ABOVE OR BELOW MOTOR OPERATING SPEED (RPM). DESIGN OF COMPLETE SYSTEM (MOTOR, PUMP, FOUNDATIONS & PIPING) MUST PROVIDE FOR THIS. MOTOR DATA FOR SYSTEM CRITICAL CALCULATIONS ARE BELOW. REED CRITICAL FREQUENCY AND DEFLECTION OF MOTOR AT CENTER OF GRAVITY (C.G.) ARE SHOWN FOR MOTOR BOLTED TO A RIGID MASS AND CONSIDERED AS A HORIZONTAL CANTILEVER BEAM. DEFLECTION OF MOTOR AT C.G. IS THAT CAUSED BY WEIGHT OF MOTOR ONLY, AT STANDSTILL.

| | | |
|--------------------------------------|-------|--------|
| MOTOR WEIGHT | 7200 | LBS. |
| DIST. FROM MOTOR BASE TO C.G. | 33 | INCHES |
| MOTOR REED CRITICAL FREQ. | 2230 | CPM |
| DEFLECTION OF MOTOR AT C.G. | .0071 | INCHES |
| SUGGESTED SYSTEM REED CRITICAL FREQ. | 1125 | CPM |

PROPOSED DEPARTURES FROM SPECIFICATIONS

6600-2-M2011-6-6

| REVISIONS | REVISED TO |
|-----------|------------|
| 30/10/84 | 15 |
| 1/10/84 | 8 |
| | 3 |
| | 28 |
| | 2 |

234C788DF



3/25/84

ATTACHMENT 13

SERVICE WATER PUMP ACCELERATION CALCULATION

Motor & Pump $WK^2 = 994 \text{ lb-ft}^2$
RPM (Synchronous) = 900

(Per Attachments 12 & 15)

(Per Attachments 11 & 15)

$$NT_i = \frac{(MT_i + MT_{i-1})}{2} - \frac{(LT_i + LT_{i-1})}{2}$$

(Per Reference 2.6, pages 6-38 thru 6-39)

$$TIME_i = \frac{(WK^2 \times (RPM_i - RPM_{i-1}))}{(308 \times NT_i)}$$

(Per Reference 2.6, page 6-38)

| <u>% SYNCH.</u> <u>SPEED</u> | <u>MOTOR¹</u> <u>TORQUE (MT)</u> | <u>LOAD¹</u> <u>TORQUE (LT)</u> | <u>NET</u> <u>TORQUE (NT)</u> | <u>TIME</u> <u>(SECONDS)</u> |
|---------------------------------|--|---|----------------------------------|---------------------------------|
| 0 | 3040 | 665 | ----- | ----- |
| 5 | 3040 | 285 | 2562 | 0.056618 |
| 10 | 3040 | 143 | 2826 | 0.051389 |
| 15 | 3040 | 71 | 2933 | 0.049514 |
| 20 | 3040 | 143 | 2933 | 0.049514 |
| 25 | 3040 | 261 | 2838 | 0.051172 |
| 30 | 3040 | 380 | 2719.5 | 0.053402 |
| 35 | 3040 | 523 | 2588.5 | 0.056104 |
| 40 | 3040 | 760 | 2398.5 | 0.060549 |
| 45 | 3040 | 903 | 2208.5 | 0.065758 |
| 50 | 3040 | 1140 | 2018.5 | 0.071948 |
| 55 | 3040 | 1378 | 1781 | 0.081542 |
| 60 | 3040 | 1615 | 1543.5 | 0.094089 |
| 65 | 3040 | 1900 | 1282.5 | 0.113237 |
| 70 | 3040 | 2233 | 973.5 | 0.149180 |
| 75 | 3268 | 2613 | 731 | 0.198669 |
| 80 | 4104 | 2945 | 907 | 0.160118 |
| 85 | 5092 | 3420 | 1415.5 | 0.102597 |
| 90 | 5928 | 3800 | 1900 | 0.076435 |
| 95 | 5700 | 4180 | 1824 | 0.079620 |
| 98 | 4560 | 4560 | 760 | 0.103187 |

Total 1.724642

1. Per Attachment 14


TK2R2-070020 A

3/4" FIG. 7000

MOTOR FULL LOAD TORQUE=4750 FT.-LB.

JAL 12-14-73, REV. F.K. 9-26-74, APPV. *[Signature]*

ARKANSAS POWER & LIGHT CO,
ARKANSAS NUCLEAR ONE - UNIT 2
EQUIP. NO. 2P4A, B, C
SERVICE WATER PUMPS



Attachment 14
Calc 92-E-0065-01
Page 1 of 1

6500 M201 IAC-029-3 See Cover Sheet for Details

[Handwritten signature]

Item No. 2P4A,B,C
No. Req'd 3
Cont. Code
Mfr. FAIRBANKS MORSE

Service SERVICE WATER Req'n. No.
Plant _____ Spec. No.
Location _____ P.O. No.
Draw'n Ref. _____ (Lvdn't)

| | | |
|----|--|---|
| 1 | Liquid Pumping | RIVER WATER |
| 2 | Viscosity (cSt) / Vapour Pressure (PSIA) | NA |
| 3 | Temperature (°F): Max. / Min. // Specific Gravity @ _____ °F. | 120° / 35° / 1.00 |
| 4 | Flow: Rating / Min. / Max. (GPM) | 12,000 / 3,200 / NA |
| 5 | Suction Pressure (Flange) (Water Level) (PSIA) | NA |
| 6 | Discharge Pressure (Flange) (PSIA) | NA |
| 7 | Diff. Press: Rating / Shutoff (Feet) (Max) | 200' |
| 8 | Submergence: Available / Req'd @ _____ Elev. (Ft) | 12'-5 1/2" / 350' |
| 9 | Type of Pump / Model / No. Stds. | VERT TURBINE 24"-7000 2 |
| 10 | RPM / Rotation (View from Motor Facing Pump) | 880 / CCW |
| 11 | Efficiency / BHP at Rating / BHP Max. @ _____ CFM | 83 / 748 / 780 |
| 12 | Impeller Diameter: Bld / Max. / Min. | 21 7/8" / 22" / 18 1/2" |
| 13 | Impeller: Eye Area / Periph. Vel. | 219 sq in / 98 FPS |
| 14 | Working Press. Max. / Hydrotest PSIG | 175 PSIG / 346 PSIG |
| 15 | Clearance: Rear Ring / Bearing / Impeller | .024-.028 / .010-.012 / NA |
| 16 | Hydraulic Thrust: Rating / Max. / Up | 9646 LBS / 1724 LBS / 3000 LBS/MO |
| 17 | Wk'g / Speed Torque: Rating / Speed-Torque Max. (Lb Ft @ / Lb Ft) | 134 / 2265 / 4655 |
| 18 | Suction: Size / Rating / Facing / Position | 32" / BELL / NA / NA |
| 19 | Discharge: Size / Rating / Facing / Position | 20" / 150" / F.F. / NA |
| 20 | Base Plate / Sole Plate | 24" x 54" sq / 1 1/2" x 54" sq |
| 21 | Coupling: Type / Mfr. / Furn. By | SOLID ADJ. / F.M. / F.M. |
| 22 | Suction: Strainer Mfr. / Splitter Mfr. | NA / NA / NA |
| 23 | Bearing Lube: Type / GPM / Pressure / Max. Micron | WATER / N.A. / NA / N.A. |
| 24 | Shaft Seal: Type / Sealing Conn. / Cooling (GPM) | STD. PARKING / N.A. / NA |
| 25 | Coupling Guard Type (Horn. only) | NA |
| 26 | Material: Case or Bowl | SA-216 GR. WGB. |
| 27 | (& Size) Barrel | NA |
| 28 | Shaft: Case or Bowl / (Dia.) | SA-479 TY410 / 3 3/4" |
| 29 | Shaft: Sleeve: Brg / Stuff. Box | NA / A-296 GA 15 |
| 30 | Wear Ring: Case / Impeller | B-147 AL 937 / B-144 AL 937 |
| 31 | Impellers / Liners | 55-144 AL 937 / NA |
| 32 | VERT. ONLY | Disch. Head / Column (Dia. x Thickness) 2 3/4" x 1/2" |
| 33 | | Shaft End. T. Coe / (Dia. x Thickness) |
| 34 | | Lineshaft: (Dia.) / (Brg. Spacing) |
| 35 | | Sleeve Bearing: Bottom / Bowl / Lineshaft |
| 36 | Driver: Type (Motor - _____) (Solid - _____) / RPM / HP | MOTOR / SOLID / 910 / 800 |
| 37 | Furn. By / Weight / Dwg. Ref. / Mfr. | FM / 17200" / 1234CTA02FIG.E |
| 38 | Bearing Description / Thrust Rating | BALL BRG. / 10000" |
| 39 | Lubrication: Thrust / Radial / Cooling | OIL / OIL / NA |
| 40 | Drawing No.: Outline / Sectional / Performance Curve | SK2R2-070220 SMD-486 + CK252-070024 |
| 41 | Net Weight: Pump / Removable / Rotating Elem. | 13,162" / NA / 11799" |
| 42 | Inspection: Std. / Nuc. Class I, II or III / ASME III or VIII | NA / CLASS III / ASME III |
| 43 | Testing: Ultrasonic / Eddy Cur. / A'ad. Part. / Lid. Pen. / Radia. | YES 1 / NO / YES 2 / YES 3 / YES 4 |
| 44 | Hydrostatic / Witness // NPSH / Witness | YES / YES / NO / NO |
| 45 | Performance / Witness / Field | YES / YES / YES (4) |
| 46 | Quality Assurance: Mfr. Std. / Documented | NO / YES |
| 47 | Seismic Design Req's: Class I / Class II | NO / -YES |

FILL IN ALL BLANKS: IF NOT APPLICABLE MARK "NA" By BECHTEL

| | | |
|-----|---------|-----------------------------------|
| NO. | DATE | REVISIONS |
| 1 | 7/13/71 | ISSUED FOR QUOTATIONS E.G.W. |
| 2 | 8/17/71 | ISSUED FOR CLIENT APPROVAL E.G.W. |

CENTRIFUGAL PUMP DATA SHEET

SERVICE WATER PUMPS 2P4A,B&C
ARKANSAS NUCLEAR ONE - UNIT 2
ARKANSAS POWER & LIGHT CO.

6600-2
DATA SHEET NUMBER
FORM M-307E
6600-M-2011-DST



They are hereby acknowledged, and as the property of BECHTEL, they shall remain the property of BECHTEL. They may not be used, copied, loaned, exhibited, or used except in the limited way and for the purposes intended by the terms of the agreement that they are hereby acknowledged.

05-19 05-19

| | | |
|-------------------------------------|------------------------|---------------|
| Motor Tag Number | 3927B | POOR ORIGINAL |
| SERVICE | EMER. FEEDWATER PUMP | |
| MANUFACTURER | Allis Chalmers | |
| TYPE | RG | |
| FRAME DESIGNATION | 588 US | |
| HORSEPOWER OUTPUT | 600 | |
| TIME RATING/TEMP. RISE °C | cont 80 | |
| RPM AT FULL LOAD | 3757 3575 3600 | |
| VOLTAGE | 4000 | |
| FULL LOAD AMPS | 77.5 | |
| *ENCLOSURE | ODP | |
| VERTICAL OR HORIZONTAL | U | |
| BEARINGS (SLEEVE OR BALL) | sleeve | |
| TYPE OF LUBRICATION | oil | |
| INSULATION CLASS | B, Power House | |
| ROTATION (VIEWED FROM END OPP. SHY) | either | |
| FULL LOAD TORQUE | 8883 | |
| STARTING TORQUE-% OF FULL LOAD | 75% | |
| EFFICIENCY - 100% LOAD | 93.5 | |
| - 75% LOAD | 93.5 | |
| - 50% LOAD | 92 | |
| SERVICE FACTOR | 1.0 | |
| IS THERMAL PROTECTION PROVIDED | stator RTD's | |
| WEIGHT | 4200 | |
| PHASE | 3 | |
| FREQUENCY | 60 | |
| LOCKED ROTOR CURRENT | 546 | |
| POWERFACTOR - 100% LOAD | 89 | |
| - 75% LOAD | 89 | |
| - 50% LOAD | 84 | |
| NEMA DESIGN LETTER | | |
| SECONDARY AMPS @ FULL LOAD | | |
| SECONDARY VOLTAGE | | |
| SECONDARY OHMS | | |
| BREAKDOWN OR PULLOUT TORQUE-% | 200% | |
| RATED FIELD CURRENT | | |
| RATED EXCITER VOLTAGE | | |
| RATED POWER FACTOR | | |
| PULL IN TORQUE - % OF FULL LOAD | | |
| TYPE OF WINDING | form | |
| SHUNT FIELD CURRENT | | |
| ALLOWABLE WK ² OF LOAD | 443 lb ft ² | |
| SPACE HEATERS - WATTS/VOLTS | 500 / 115 | |
| TWO SPEED MOTORS-NO OF WINDINGS | | |
| TORQUE | | |
| THRUST BEARING CAPACITY-UP (LBS) | | |
| CAPACITY-DOWN (LBS) | | |


0001430
 2 Issues For Reference

ENCLOSURE: DRIPPROOF (DP), DUSTPROOF (DP), WEATHER PROTECTED (WP), TOTALLY ENCLOSED NON-VENTILATED (TENV), TOTALLY ENCLOSED FAN COOLED (TEFC), TOTALLY ENCLOSED PIPE VENTILATED (TEPV) ETC., EXPLOSIONPROOF WP, TO INDICATE GUARDED ADD "G".



ELECTRIC MOTOR DATA SHEET
 ZPM 7B
 EMERGENCY FEEDWATER PUMP MOTOR
 ARKANSAS POWER AND LIGHT COMPANY
 ARKANSAS NUCLEAR ONE - UNIT 2

6600-M-2018-3
 OCT 2 1971



150-V 511

1-5117-49200

| | | |
|--|-----------------|-----------------|
| SERVICE | Cont. Spray | Cont. Spray |
| MANUFACTURER | | Allis-Chalmers |
| TYPE | AC Induction | GV |
| FRAME DESIGNATION | | 58UB58 |
| HORSEPOWER OUTPUT | | 450 |
| TIME RATING/TEMP. RISE °C | / / / | Cont. 90 at I.I |
| RPM AT FULL LOAD | | 1780 |
| VOLTAGE | 4000 | 4000 |
| FULL LOAD AMPS | | 57.5 |
| *ENCLOSURE | DP | DP |
| VERTICAL OR HORIZONTAL | | VERTICAL |
| BEARINGS (SLEEVE OR BALL) | | BALL |
| TYPE OF LUBRICATION | | OIL THRUST/gre |
| INSULATION CLASS | | F-PH QUI |
| ROTATION (VIEWED FROM END OPP SHYTD) | | EITHER |
| FULL LOAD TORQUE lb.ft. | 1b.ft. Δ | 1325 |
| STARTING TORQUE % OF FULL LOAD | | 100 |
| EFFICIENCY - 100% LOAD | | 92.5 |
| - 75% LOAD | | 92.5 |
| - 50% LOAD | | 92.5 |
| SERVICE FACTOR | 1.15 | 1.15 |
| IS THERMAL PROTECTION PROVIDED | Yes | YES |
| WEIGHT | | 4500# |
| PHASE | | 3 |
| FREQUENCY | | 60 |
| LOCKED ROTOR CURRENT | | 374 |
| POWERFACTOR - 100% LOAD | | 89.5 |
| - 75% LOAD | | 88.5 |
| - 50% LOAD | | 84.5 |
| NEMA DESIGN LETTER | | N/A |
| SECONDARY AMPS @ FULL LOAD | | -- |
| SECONDARY VOLTAGE | | -- |
| SECONDARY OHMS | | -- |
| BREAKDOWN OR PULLOUT TORQUE % | | 200 |
| RATED FIELD CURRENT | | -- |
| RATED EXCITER VOLTAGE | | -- |
| RATED POWER FACTOR | | -- |
| PULL IN TORQUE - % OF FULL LOAD | | -- |
| TYPE OF WINDING | | -- |
| SHUNT FIELD CURRENT | | -- |
| ALLOWABLE WK ² OF LOAD lb.ft ² | Δ | 120 |
| SPACE HEATERS - WATTS/VOLTS | / / / | 500 / 120 / |
| TWO SPEED MOTORS-NO OF WINDINGS TORQUE | | -- |
| THRUST BEARING CAPACITY-UP (LBS) | | 2500 |
| CAPACITY-DOWN (LBS) | | 2500 |

* ENCLOSURE: DRIPPROOF (DP), SPLASHPROOF (SP), WEATHER PROTECTED (WP), TOTALLY ENCLOSED NON-VENTILATED (TENV), TOTALLY ENCLOSED FAN COOLED (TEFC), TOTALLY ENCLOSED PIPE VENTILATED (TEPV) ETC., EXPLOSIONPROOF XP, TO INDICATE GUARDED ADD *G*.

DATE APPROVAL DATE EQUIP. NO. CHECKED BY DATE OF WINDING R. SPECIAL FEATURES
 Issued for Quotation
 REVISED AS TOLD TO
 REV. DESCRIPTION



ELECTRIC MOTOR DATA SHEET
 ARKANSAS POWER & LIGHT COMPANY
 ARKANSAS NUCLEAR ONE - UNIT 2
 EQUIP. NOS. 2P35A & 2P35B

JOB No 6600-02
 6600-M-2017
 REV. 4

ALLIS-CHALMERS
 MONROE, OHIO
 450 HP - 1800 RPM SYN. 2 PH - 60 HZ

SPEED VS CURRENT & POWER FACTOR

Combustion Engineering
 Plant - Arkansas 184, N. 1st Ave - #2
 C. E. P. O. #910123
 C. E. Contract #6.70
 Service - Low Pressure Safety Injection

15-115


AMPERE

POWER FACTOR

REVOLUTIONS PER MINUTE

PERCENT POWER FACTOR

LINE CURRENT



100

500

100

50

0

10

20

30

40

50

60

70

80

90

100

110

120

130

140

150

160

170

180

190

200

210

220

230

240

250

260

270

280

290

300

310

320

330

340

350

360

370

380

390

400

410

420

430

440

450

460

470

480

490

500

510

520

530

540

550

560

570

580

590

600

610

620

630

640

650

660

670

680

690

700

710

720

730

740

750

760

770

780

790

800

810

820

830

840

850

860

870

880

890

900

910

920

930

940

950

960

970

980

990

1000

1010

1020

1030

1040

1050

1060

1070

1080

1090

1100

1110

1120

1130

1140

1150

1160

1170

1180

1190

1200

1210

1220

1230

1240

1250

1260

1270

1280

1290

1300

1310

1320

1330

1340

1350

1360

1370

1380

1390

1400

1410

1420

1430

1440

1450

1460

1470

1480

1490

1500

300-M-20 17-1F-1
BECHTEL AS TURBINE ONT.

5840-11000
TYPE GY
FFM CODES

CONTINUIT PRY PIPE
2P35A+B

SPEED VS. ACCELERATING TIME



| REV. DATE | REV. TIME | REV. MIN. | REV. MAX. | REV. AVE. | REV. STDEV. | REV. CORR. | REV. TOL. | REV. TYP. | REV. UNIT | REV. CODE | REV. ORDER | REV. SAN FRANCISCO |
|-----------|-----------|-----------|-----------|-----------|-------------|------------|-----------|-----------|-----------|-----------|------------|--------------------|
| | | | | | | | | | | | | |

BECHTEL JOB No.
SAN FRANCISCO 6500

VEHICLE DRIVING REVIEW

Approved - 4 - Manufacturing

2 - Manufacturing

3 - Approved subject to be used

4 - No Approval - Closed

5 - Rejected - 6 - Used

ADDITIONAL COMMENTS: DISCOUNTS NOT REFLECTED IN THIS REVIEW. DISCOUNTS WITH CUTOFF IN PURCHASE ORDER ENGINEERING.

By: *[Signature]* Date: 5/27/12

4 0397

SERVICE: LOW PRESSURE SAFETY INJECTION PUMPS

DESCRIPTION: Squirrel-cage, induction motor for 4000 volts, 3 phase, 60 cycle service. Enclosure to be drip-proof. Insulation to be Class B NEMA, and service factor 1.15.

Attachment 22
Calc 92-E-0065-01
Page 1 of 1

- 5 QUANTITY: 4
- 6
- 7 ACCESSORIES: Space heater, 120 vac. single phase.
- 8 Main terminal box with 3 size lugs as normal.
- 9 Separate space heater terminal box.
- 10 Separate STD terminal box for 2 inch conduit.
- 11 200 amp STD temperature attention in sleeve bearings and stator.
- 12 Grounding pads on cast-iron side (drive end), tapped for 5/8" x 11 bronze bolts.
- 13
- 14 SPECIAL REQUIREMENTS:
- 15 Motor shall accelerate to rated RPM at rated load on 3000 volts
- 16 Acceleration time, 3000 volts, .6 secs. rated volts, .4 secs.
- 17 Routine NEMA tests.
- 18 Curves: Speed/Torque/Current/Power Factor
- 19

DATA BY SUPPLIER

| | | | | | | |
|----|-------------------------|---------------------------|------------------------|-----------|---------------------|--------------------|
| 21 | Motor Manufacturer | Allis-Chalmers | Frame No. | 580BS-8 | H. P. | 450 |
| 22 | Service Factor | 1.15 | RPM | 1800/1780 | Volts | 4000 |
| 23 | Approx. full load | 38.5 | locked rotor | 364 | | |
| 24 | Torque: starting @ F.L. | 100 | Full-out @ F.L. | N/A | Breakdown @ F.L. | |
| 25 | Losses: F.L. % | 71 | 3/4 load % | 7.0 | 1/2 load % | 8.0 No Load 10400W |
| 26 | Power Factor: F.L. % | 89.5 | 3/4 load % | 88.5 | 1/2 load % | 84.5 Start 28.5 |
| 27 | Temp. rise by test | 90 at 1.15 load | safe locked rotor time | 15 secs. | | |
| 28 | NEMA design | N/A | Enclosure | ODP | | |
| 29 | Space Htr. - Watts | 500W | | | | |
| 30 | Bearing type | AF | Anti-Friction | | | |
| 31 | Motor Weight | 4500# | | | | |
| 32 | Permissible starts | 2 cold, 1 hot | | | C.E.I. P.O. No. | 9101523 |
| 33 | Motor Wt. | 200 # Ft. | | | C.E.I. Contract No. | 6370 |
| 34 | Terminal box size | Typ. 51-751-405 | | | I-K Order No. | 001-36134 |
| 35 | Insulation | Class B | | | Customer: | Arkansas P&L |
| 36 | Direction of rotation | CCW looking down on motor | | | Component Code: | 31 15-54-4322- |
| 37 | | | | | Plant Site: | Ark. Nuclear One- |
| | | | | | | LPSI Pumps |

MOTOR DATA SHEET

THIS DRAWING IS THE PROPERTY OF COMBUSTION ENGINEERING, NUCLEAR POWER DIVISION, WINDSOR, CONNECTICUT AND IS NOT TO BE REPRODUCED OR USED TO FURNISH ANY INFORMATION FOR THE DESIGN OR CONSTRUCTION OF EQUIPMENT WITHOUT THE WRITTEN PERMISSION OF COMBUSTION ENGINEERING.

SEE NO. 0170-75-110

SHEET 2

ALLEN-DAVIDSON
 E.L.D. B. AL P. L. A


EQUIPMENT: Logansport Rand Co
 CUSTOMER'S ORDER NO.: C-594 657 N
 SERIAL NO.: 1-5117-47924-1
 TYPE: GV
 HORSEPOWER: 500
 VOLTAGE: 4000 MOTOR
 PHASES: 3 BORROWED OR
 HEIGHT: 60 BOUGHT FROM
 FRAME: 580 C 58 L PL
 SYNC. R.P.M.: 1800 TO REPLACE
 F.L. R.P.M.: 1780 2PM 60 B
 EFFICIENCY: 1/2 92.5
 3/4 93.5
 F.L. 93.5
 POWER FACTOR: 1/2 84.5 D. 100% 100%
 V.L. 88.5 100% 100%
 F.L. 89.5 100% 100%
 F.L. AMPS: 64 100% 100%
 L.R. AMPS: 410 100% 100%
 FULL LOAD TORQUE (LBS.-FT.): 1480
 STARTING TORQUE (LBS.-FT.): 1480
 FLIGHT TORQUE (LBS.-FT.): _____
 INSULATION: B
 SERVICE FACTOR: 1.15
 AMBIENT TEMPERATURE: 40°C

CERTIFIED PRINT
 CUSTOMER INITIATED
 CHANGES MAY AFFECT
 PRICE AND DELIVERY


8-5117-90203 REF. NO 00136135
 COMBUSTION ENGINEERING UNIT NO 3
 PLANT-LOUISIANA POWER & LIGHT WATERFORD STEAM ELECTRIC STA
 C.E. PO # 9101524 C.E. CONTRACT # 9279
 SERVICE-LOW PRESSURE SAFETY INJECTION
 "COMPONENT CODE NUMBER 31 15-54-4322-00" LPSI

LPSI
 29600

ALLIS-CHAMBERLAIN
 NORWOOD, OHIO
 500 HP - 1800 SYN RPM - 3PH - 60HZ - 4000 VOLTS
 TYPE G FRAME 580058




A-8661




A-8518

1-8701



REVOLUTIONS PER MINUTE

3000
2800
2600
2400
2200
2000
1800
1600
1400
1200
1000
800
600
400
200
0



Handwritten notes on the right side of the graph, including 'CALC 92-E-0065-01' and other illegible text.

Handwritten notes at the bottom of the graph, including 'REVOLUTIONS PER MINUTE' and other illegible text.

TABLE 1

DATA FOR ANO 161 kV BUS

| ASSUMED CONDITION | 3 PHASE FAULT MVA (MVA) | POSITIVE SEQ. THEVENIN IMPEDENCE (pu) (1) | VOLTAGE V thevenin (pu) (2) |
|--|-------------------------------|--|-----------------------------------|
| 1. Normal Condition (3) | 4664.0 | 0.00102 + j0.02142 | 1.0290 |
| 2. Outage Condition (4) | 4111.0 | 0.00152 + j0.02428 | 1.0375 |
| 3. ANO Units and 500/161 kV auto out of service. | 1413.0 | 0.01007 + j0.07005 | 1.0203 |
| 4. ANO Units, 500/161 kV auto, and ANO Russellville East 161 kV line out of service. | 608.0 | 0.02395 + j0.16273 | 1.0441 |
| 5. ANO Units, 500/161 kV auto, and Dardanelle Dam out of service. | 1318.0 | 0.01201 + j0.07492 | 0.9912 |

- (1) Thevenin impedance values given in per unit on 100 MVA base.
- (2) Voltage at the ANO 161 kV bus for the assumed condition using 1992 summer peak conditions with no ANO plant load modeled on the ANO 161 kV bus. The two proposed 161 kV capacitor banks (ANO & Russ. E.) and autotransformer tap change at N byflower is assumed in service.
- (3) Normal conditions assume ANO units are on line and transmission facilities are in service.
- (4) Outage conditions assume ANO units are off line and transmission facilities are in service.

SPECIFICATIONS

Input Circuit:

Rating: 160V, 50/60 Hz. continuous,
300V, 10 seconds.

Burden: 1.2 VA, 1.0 pf at 120 volts.

Taps: available models include:

Types 27, -27D, -27H : 60, 70, 80, 90, 100, 110v

Types 27D, -27H: 30, 35, 40, 45, 50, 55v

15, 18, 21, 24, 27, 30v

Types 59D, -59H: 100, 110, 120, 130, 140, 150v

60, 65, 70, 75, 80, 90v

Differential between Operate and Reset Voltages:

Type 27: less than 0.5 percent.

Types 27D, -27H, ITE-59D, -59H: approximately 3 percent.

Operating Time: See Time-Voltage characteristic curves that follow.

Output Circuit:

Each contact @ 125 Vdc: 30 ampere tripping duty,
5 ampere continuous,
0.3 ampere break.

Operating Temperature Range: -30 to +70 deg. C.

Control Power:

Models available for 48/125 vdc @ 0.08 A max.
48/110 vdc @ 0.08 A max.
24/ 32 vdc @ 0.08 A max.
120 vac 50/60 Hz. @ 0.08 A.

| | | |
|----------------------|----------------|--------------|
| Allowable variation: | 24vdc nominal: | 19- 29 vdc |
| | 32vdc | " 25- 38 |
| | 48vdc | " 38- 58 |
| | 110vdc | " 88-125 |
| | 125vdc | " 100-140 |
| | 120vac | " 95-135 vac |

Tolerances: Operating Voltage: +/- 5%
Operating Time: +/-10%

These tolerances are based on the printed dial markings. By using the calibration procedures given later in this book, the relay may be set precisely to the desired values of operating voltage and delay with excellent repeatability.

Repeatability: variation in operating voltage for a 10 volt variation in control voltage: 0.2 volt, typical.

variation in operating voltage over the temperature range 20-40 deg C: 0.5 volt, typical.

Dielectric Strength:

1500 vac, 50/60 Hz., all circuits to ground.

Seismic Capability:

More than 6g ZPA biaxial broadband multifrequency vibration without damage or malfunction. (ANSI C37.98-1978)

UNIT 1 LOOP LOADS

| *A3 LOAD | HP | PF | RUNNING | |
|------------------------------|-----|------|---------|-------|
| | | | KW | KVAR |
| Service Water Pump P4A | 350 | 88.5 | 280.9 | 147.8 |
| Primary Make-Up P36A | 700 | 91.8 | 570.0 | 246.2 |
| Emergency Feedwater Pump P7B | 700 | 92.9 | 550.0 | 219.1 |
| Total | | | 1400.9 | 613.1 |

| *B5 LOAD | HP | EFF | PF | RUNNING | |
|---|------|------|------|---------|------|
| | | | | KW | KVAR |
| Pressurizer Proportional Heaters Group #13 | - | 100 | 100 | 84.0 | 0 |
| Inverter Y11 | - | 92.0 | 85.0 | 7.0 | 4.3 |
| Piping H/T Xfm XL15 | - | 95.0 | 95.0 | 30.0 | 9.9 |
| Battery Charger D03 | - | 85.0 | 70.0 | 36.0 | 36.7 |
| Instrument AC Xfmr. X6A | - | 95.0 | 95.0 | 30.0 | 9.9 |
| Inverter Y13 | - | 92.0 | 85.0 | 7.0 | 4.3 |
| *Computer Power Supply Y26 | - | 92.0 | 90.0 | 9.0 | 4.4 |
| *Instrument Air Dryer M1 | - | 100 | 100 | 2.4 | 0 |
| *Cr. Air Em. Unit CLR VUC9 | - | ** | ** | 15.0 | 0 |
| *Power Supply Inverter Y25 | - | 92.0 | 85.0 | 7.0 | 4.3 |
| Instrument AC Panel Y3 | - | 96.9 | 75.0 | 4.5 | 4.0 |
| *AB Lighting Panel 1PC | - | 100 | 100 | 33.0 | 0 |
| *Pressurizer Proportional Htr. Rub. 14&15 | - | 100 | 100 | 84.0 | 0 |
| *Lighting Xfmr XL7 | - | 96.9 | 75.0 | 23.1 | 20.4 |
| EDG Room Exhaust Fan VEF24A | 7.5 | 84.5 | 80.5 | 6.6 | 4.9 |
| EDG Room Exhaust Fan VEF24B | 7.5 | 84.5 | 80.5 | 6.6 | 4.9 |
| Diesel Generator 1 Oil Circulating Pump PM106A3 | 0.75 | 72.0 | 69.0 | 0.8 | 0.8 |
| Elect. Room Emergency Chiller VCH4B | 40.0 | 90.0 | 85.0 | 33.1 | 20.5 |
| Diesel Generator 1 Soak Back Pump PM106A2 | 1.0 | 72.0 | 69.0 | 1.0 | 1.0 |
| Diesel Fuel Xfer. Pump PM16A | 0.5 | 70.0 | 58.0 | 0.5 | 0.7 |
| PMU Pump Auxiliary Lube Oil Pump P64A | 0.5 | 70.0 | 58.0 | 0.5 | 0.7 |
| Relay Room Unit Clr VUC4A | 0.75 | 72.0 | 66.0 | 0.8 | 0.9 |
| S DC Room Unit Clr VUC14C | 1.5 | 77.5 | 69.5 | 1.4 | 1.4 |
| S Electrical Room Unit Clr VUC14D | 0.5 | 75.5 | 61.0 | 0.5 | 0.6 |
| Battery Room Exhaust Fan VEI'M33 | 1.0 | 78.5 | 73.0 | 1.0 | 0.9 |

| *B5 LOAD | HP | EFF | PF | RUNNING | |
|---|-------|------|------|--------------|--------------|
| | | | | KW | KVAR |
| Prt. Pump Room Clr VUC7A | 7.5 | 84.0 | 78.5 | 6.7 | 5.3 |
| SW System Radiation Monitor RE3814 | 3.0 | 78.6 | 88.8 | 2.8 | 1.4 |
| Switchgear Room Unit Clr VUC2B | 2.0 | 84.0 | 85.7 | 1.8 | 1.1 |
| *Electrical Equipment Room Evap. VUC13B | 0.75 | 72.0 | 69.0 | 0.8 | 0.8 |
| *Electrical Equipment Room Evap. VUC13A | 0.75 | 72.0 | 69.0 | 0.8 | 0.8 |
| *Electrical Equipment Room Cond. VE1B | 10.0 | 85.5 | 80.5 | 8.7 | 6.4 |
| *Electrical Equipment Room Cond. VE1A | 10.0 | 85.5 | 80.5 | 8.7 | 6.4 |
| *AB Switchgear Room Clr VUCM2A | 2.0 | 84.0 | 85.7 | 1.8 | 1.1 |
| *AB Switchgear Room Clr VUCM2C | 2.0 | 84.0 | 85.7 | 1.8 | 1.1 |
| *RCP BU B/S Lube Oil Pump PM82A | 0.5 | 70.0 | 58.0 | 0.5 | 0.7 |
| *RCP BU B/S Lube Oil Pump PM82B | 0.5 | 70.0 | 58.0 | 0.5 | 0.7 |
| *RCP BU B/S Lube Oil Pump PM82C | 0.5 | 70.0 | 58.0 | 0.5 | 0.7 |
| *RCP BU B/S Lube Oil Pump PM82D | 0.5 | 70.0 | 58.0 | 0.5 | 0.7 |
| *CR Air EM Unit CLR VUCM9 | 18 | ** | ** | 15.5 | 12.1 |
| Pent. Room Exhaust Fan VEF38A | 10.0 | 84.0 | 87.0 | 8.9 | 5.0 |
| *PMU Pump Room Clr VUC7B | 7.5 | 84.0 | 78.5 | 6.7 | 5.3 |
| D/H System R/M RE3809 | 3.0 | 78.6 | 88.8 | 2.8 | 1.4 |
| DHR Room Unit CLR VUCM1A | 10.0 | 87.5 | 79.0 | 8.5 | 6.6 |
| Reactor Building CLR Fan VSFM1B | 125.0 | 92.0 | 88.0 | 82.6 | 44.6 |
| Reactor Building CLR Fan VSFM1A | 125.0 | 92.0 | 88.0 | 82.6 | 44.6 |
| *Turbine Turning Gear KM6 | 50.0 | 90.7 | 86.0 | 41.1 | 24.4 |
| *T/G Bearing Lift Oil Pump PM76 | 20.0 | 88.5 | 84.0 | 16.9 | 10.9 |
| *T/G Emergency Bearing Oil Pump PM20 | 60.0 | 90.3 | 84.0 | 49.5 | 32.0 |
| *Boric Acid Pump PM39A | 2.0 | 83.0 | 88.0 | 1.8 | 1.0 |
| *Boric Acid Pump PM39B | 2.0 | 83.0 | 88.0 | 1.8 | 1.0 |
| Dis Flume Rad. Monitor RE3618 | 3.0 | 80.0 | 91.5 | 2.8 | 1.2 |
| Int. Clg. System R/M RE2236 | 3.0 | 78.6 | 88.8 | 2.8 | 1.4 |
| Spent Fuel Pool Circulating Pump PM40A | 40.0 | 87.8 | 85.3 | 34.0 | 20.8 |
| Instrument Air Compressor CM2A | 50.0 | 91.1 | 82.9 | 40.9 | 27.6 |
| Control Room Chiller VCH2A | 75.0 | 90.9 | 84.0 | 61.5 | 39.7 |
| Total | | | | 921.4 | 442.3 |

| *A4 LOAD | HP | PF | RUNNING | |
|------------------------|-----|------|--------------|--------------|
| | | | KW | KVAR |
| Service Water Pump P4C | 350 | 88.5 | 280.9 | 147.8 |
| Primary Make-Up P36C | 700 | 91.8 | 570.0 | 246.2 |
| Total | | | 850.9 | 394.0 |

| *B6 LOAD | HP | EFF | PF | RUNNING | |
|---|-------|------|------|--------------|--------------|
| | | | | KW | KVAR |
| Inverter Y22 | - | 92.0 | 85.0 | 6.0 | 3.7 |
| Inverter Y28 | - | - | 85.0 | 3.0 | 1.9 |
| Battery Charger D04 | - | 85.0 | 70.0 | 39.0 | 39.8 |
| Instrument AC Xfmr. X6B | - | 95.0 | 95.0 | 30.0 | 9.9 |
| Pressurizer Proportional Heaters Group #14 | - | 100 | 100 | 84.0 | 0 |
| inverter Y24 | - | 92.0 | 85.0 | 6.0 | 3.7 |
| Piping Ht. Transformer XL16 | - | 95.0 | 95.0 | 30.0 | 9.9 |
| Instrument AC Panel Y4 | - | 96.9 | 75.0 | 4.5 | 4.0 |
| EDG Room Exhaust Fan VEF24C | 7.5 | 84.5 | 80.5 | 6.6 | 4.9 |
| EDG Room Exhaust Fan VEF24D | 7.5 | 84.5 | 80.5 | 6.6 | 4.9 |
| Diesel Generator 2 Oil Circulating Pump PM106B3 | 0.75 | 72.0 | 69.0 | 0.8 | 0.8 |
| Emergency Chiller VCH4A | 40.0 | 90.0 | 85.0 | 33.1 | 20.5 |
| Diesel Generator 2 Soak Back Pump PM106B2 | 1.0 | 72.0 | 69.0 | 1.0 | 1.0 |
| Diesel Fuel Xfer. Pump PM16B | 0.5 | 70.0 | 58.0 | 0.5 | 0.7 |
| Relay Room Unit Clr VUCM4B | 0.75 | 72.0 | 66.0 | 0.8 | 0.9 |
| N DC Room Unit Clr VUC14A | 1.0 | 78.5 | 73.0 | 1.0 | 0.9 |
| PMU Pump Auxiliary Lube Oil Pump PM64C | 0.5 | 70.0 | 58.0 | 0.5 | 0.7 |
| N EL Room Unit Clr VUC14B | 0.5 | 75.5 | 61.0 | 0.5 | 0.6 |
| PMU Pump Room Clr VUC7C | 7.5 | 84.0 | 78.5 | 6.7 | 5.3 |
| Battery Room Exhaust Fan VEFM34 | 1.0 | 78.5 | 73.0 | 0.9 | 0.9 |
| SW System R/M RE3815 | 3.0 | 80.0 | 88.5 | 2.8 | 1.5 |
| Switchgear Room Unit Clr VUC2D | 2.0 | 84.0 | 85.7 | 1.8 | 1.1 |
| DHR System R/M RE3810 | 3.0 | 78.6 | 88.8 | 2.8 | 1.4 |
| DHR Room Unit CLR VUCM1C | 10.0 | 87.5 | 79.0 | 8.5 | 6.6 |
| Reactor Building CLR Fan VSFM1C | 125.0 | 92.0 | 88.0 | 82.6 | 44.6 |
| Reactor Building CLR Fan VSFM1D | 125.0 | 92.0 | 88.0 | 82.6 | 44.6 |
| Stack Rad Monitor RE7400 | 2.0 | 80.0 | 84.0 | 1.9 | 1.2 |
| Instrument Air Compressor CM2B | 50.0 | 91.1 | 82.9 | 40.9 | 27.6 |
| Control Room Chiller VCH2B | 75.0 | 90.9 | 84.0 | 61.5 | 39.7 |
| Total | | | | 546.9 | 283.3 |

*Swing Loads

** 2-7.5 Hp 78.5% pf

1-3.0 Hp 80.0% pf

- ▲ Obtained from Ref. 2.1 with the exception of Battery Room Exhaust Fans VEFM33 (1KW) & VEFM34 (0.9KW) and Electrical Equipment Room Evaps. VUC13A & VUC13B, 0.8KW each which are added since they could be running although very intermittently. Primary Makeup Pump Aux Lube Oil Pump PM64B, 0.5KW which is removed since it only runs, if the swing pump P36B is running. Load Center Transformer losses are also removed, since DAPPER calculates it and Control Room Emergency Heater/Cooler 2VUC27B-2 (58.4KW) is removed since it is only fed from Unit 1, if Unit 2 is in an outage (not MSLB).

Note: Running Loads = (HP x 0.7456) / Eff

ARKANSAS NUCLEAR ONE
SIMS JOB ORDER ATTACHMENT
THIS DOCUMENT IS PART OF A JOB ORDER
PACKAGE AND IS NOT TO BE SEPARATED FROM IT

PAGE: 2

JO# 00855618 JR# 871068 Work Center MNTC ATTACHMENT _____ OF _____
Work Desc CRAFT IS TO TAKE VOLTAGE, CURRENT, AND POWER FACTOR READINGS
ON EACH LOAD PHASE, AND SUPPLY RESULTS TO BRAD RISNER,
DESIGN ENGINEERING. SEE JOB ORDER ATTACHMENT
Comp 2B-51A3 CKTBRK
Comp Desc 2X13, INSTRUMENTATION Loc RAB-374-C-3.5
TRANSFORMER Work Type CM

PLANNERS NOTES

BRAD RISNER, (8512) HAS REQUESTED THAT THESE READINGS BE TAKEN AND THE RESULTS GIVEN TO HIM. THIS JOB ORDER IS FOR THE CRAFT TO PERFORM THIS WORK.

NO LEADS ARE TO BE LIFTED, AND ELECTRICAL ISOLATION CAN NOT BE OBTAINED, THE CRAFT ARE TO USE THE SAFETY PRECAUTIONS AS DIRECTED BY THE SUPERVISOR IN PERFORMING THIS WORK.

WORK SCOPE

1. TAKE, RECORD, AND SUPPLY RESULTS, OF THE VOLTAGE, CURRENT, AND POWER FACTOR OF CIRCUIT BREAKER 2B51-A3.

LEFT PHASE

VOLTAGE 273 VAC CURRENT 8.2 AMPS POWER FACTOR 27.8

MIDDLE PHASE

VOLTAGE 271 VAC CURRENT 10.1 AMPS POWER FACTOR 6.2

RIGHT PHASE

VOLTAGE 270 VAC CURRENT 10.8 AMPS POWER FACTOR 31.9

SUPPLY A COPY OF RESULTS TO BRAD RISNER, GSB-3E.

POST MAINTENANCE TEST

NO CORRECTIVE MAINTENANCE PERFORMED BY THIS JOB ORDER, NO PMT REQUIRED.

REVIEWED AND AGREED TO BY

Richard P. Balala
ENGINEERING SIGNATURE

DATE

11/11/91

ARKANSAS NUCLEAR ONE
SIMS JOB ORDER ATTACHMENT
THIS DOCUMENT IS PART OF A JOB ORDER
PACKAGE AND IS NOT TO BE SEPARATED FROM IT

JO# 00855703 JR# 871069 Work Center MNTC ATTACHMENT _____ OF _____
Work Desc CRAFT IS TO TAKE VOLTAGE, CURRENT, AND POWER FACTOR READINGS
ON EACH LOAD PHASE, AND SUPPLY RESULTS TO BRAD RISNER,
DESIGN ENGINEERING. SEE JOB ORDER ATTACHMENT
Comp 2B-51D1 CKTBRK
Comp Desc 2X-11 INSTRUMENTATION Loc RAB-374-C-3.5
TRANSFORMER Work Type CH

PLANNERS NOTES

BRAD RISNER, (8512) HAS REQUESTED THAT THESE READINGS BE TAKEN AND THE RESULTS GIVEN TO HIM. THIS JOB ORDER IS FOR THE CRAFT TO PERFORM THIS WORK.

NO LEADS ARE TO BE LIFTED, AND ELECTRICAL ISOLATION CAN NOT BE OBTAINED, THE CRAFT ARE TO USE THE SAFETY PRECAUTIONS AS DIRECTED BY THE SUPERVISOR IN PERFORMING THIS WORK.

WORK SCOPE

1. TAKE, RECORD, AND SUPPLY RESULTS, OF THE VOLTAGE, CURRENT, AND POWER FACTOR OF CIRCUIT BREAKER 2B51-D1.

LEFT PHASE

VOLTAGE 271 VAC CURRENT 16.2 AMPS POWER FACTOR 82.2

MIDDLE PHASE

VOLTAGE 272 VAC CURRENT 21.8 AMPS POWER FACTOR 83.1

RIGHT PHASE

VOLTAGE 271 VAC CURRENT 19.5 AMPS POWER FACTOR 63.5

SUPPLY A COPY OF RESULTS TO BRAD RISNER, GSB-3E.

POST MAINTENANCE TEST

NO CORRECTIVE MAINTENANCE PERFORMED BY THIS JOB ORDER, NO PMT REQUIRED.
DOCUMENTED ON JOB ORDER 855618.

ARKANSAS NUCLEAR ONE
SIMS JOB ORDER ATTACHMENT
THIS DOCUMENT IS PART OF A JOB ORDER
PACKAGE AND IS NOT TO BE SEPARATED FROM IT

JO# 00855706 JR# 871065 Work Center MNTC ATTACHMENT _____ OF _____
Work Desc CRAFT IS TO TAKE VOLTAGE, CURRENT, AND POWER FACTOR READINGS
ON EACH LOAD PHASE, AND SUPPLY RESULTS TO BRAD RISNER,
DESIGN ENGINEERING. SEE JOB ORDER ATTACHMENT
Comp 2B-54J1 CKTBRK
Comp Desc POWER & LIGHTING PANEL Loc RA3-372-E-5.5
2S01/21PC Work Type CM

PLANNERS NOTES

BRAD RISNER, (8512) HAS REQUESTED THAT THESE READINGS BE TAKEN AND THE RESULTS GIVEN TO HIM. THIS JOB ORDER IS FOR THE CRAFT TO PERFORM THIS WORK.

NO LEADS ARE TO BE LIFTED, AND ELECTRICAL ISOLATION CAN NOT BE OBTAINED, THE CRAFT ARE TO USE THE SAFETY PRECAUTIONS AS DIRECTED BY THE SUPERVISOR IN PERFORMING THIS WORK.

WORK SCOPE

1. TAKE, RECORD, AND SUPPLY RESULTS, OF THE VOLTAGE, CURRENT, AND POWER FACTOR OF CIRCUIT BREAKER 2B54-J1.

LEFT PHASE

VOLTAGE 271 VAC CURRENT 62.6 AMPS POWER FACTOR 99.7

MIDDLE PHASE

VOLTAGE 272 VAC CURRENT 61.5 AMPS POWER FACTOR 99.9

RIGHT PHASE

VOLTAGE 271 VAC CURRENT 51.4 AMPS POWER FACTOR 100

SUPPLY A COPY OF RESULTS TO BRAD RISNER, GSB-3E.

POST MAINTENANCE TEST

NO CORRECTIVE MAINTENANCE PERFORMED BY THIS JOB ORDER, NO PMT REQUIRED.
DOCUMENTED ON JOB ORDER 855618.

ARKANSAS NUCLEAR ONE
SIMS JOB ORDER ATTACHMENT
THIS DOCUMENT IS PART OF A JOB ORDER
PACKAGE AND IS NOT TO BE SEPARATED FROM IT

JO# 00855702 JR# 871066 Work Center MNTC ATTACHMENT _____ OF _____
Work Desc CRAFT IS TO TAKE VOLTAGE, CURRENT, AND POWER FACTOR READINGS
ON EACH LOAD PHASE, AND SUPPLY RESULTS TO BRAD RISNER,
DESIGN ENGINEERING. SEE JOB ORDER ATTACHMENT
Comp 2B-61C6 CKTBRK
Comp Desc INSTRUMENTATION XFMR 2X14 Loc RAB-386-C-2.5
Work Type CM

PLANNERS NOTES

BRAD RISNER, (8512) HAS REQUESTED THAT THESE READINGS BE TAKEN AND THE RESULTS GIVEN TO HIM. THIS JOB ORDER IS FOR THE CRAFT TO PERFORM THIS WORK.

NO LEADS ARE TO BE LIFTED, AND ELECTRICAL ISOLATION CAN NOT BE OBTAINED, THE CRAFT ARE TO USE THE SAFETY PRECAUTIONS AS DIRECTED BY THE SUPERVISOR IN PERFORMING THIS WORK.

WORK SCOPE

1. TAKE, RECORD, AND SUPPLY RESULTS, OF THE VOLTAGE, CURRENT, AND POWER FACTOR OF CIRCUIT BREAKER 2B61-C6.

LEFT PHASE

VOLTAGE 272 VAC CURRENT 3.5 AMPS POWER FACTOR 15.6

MIDDLE PHASE

VOLTAGE 273 VAC CURRENT 4.3 AMPS POWER FACTOR 80.1

RIGHT PHASE

VOLTAGE 272 VAC CURRENT 5.8 AMPS POWER FACTOR 43

SUPPLY A COPY OF RESULTS TO BRAD RISNER, GSB-3E.

OUT MAINTENANCE TEST

NO CORRECTIVE MAINTENANCE PERFORMED BY THIS JOB ORDER, NO PMT REQUIRED.
DOCUMENTED ON JOB ORDER 855618.

ARKANSAS NUCLEAR ONE
SIMS JOB ORDER ATTACHMENT
THIS DOCUMENT IS PART OF A JOB ORDER
PACKAGE AND IS NOT TO BE SEPARATED FROM IT

PAGE: 2

JO# 00855704 JR# 871067 Work Center MNTC ATTACHMENT _____ OF _____
Work Desc CRAFT IS TO TAKE VOLTAGE, CURRENT, AND POWER FACTOR READINGS
ON EACH LOAD PHASE, AND SUPPLY RESULTS TO BRAD RISNER,
DESIGN ENGINEERING. SEE JOB ORDER ATTACHMENT
Comp 2B-61D1 CKTBRK
Comp Desc INSTRUMENTATION XFMR 2X12 Loc RAB-386-C-2.5
Work Type CM

PLANNERS NOTES

BRAD RISNER, (8512) HAS REQUESTED THAT THESE READINGS BE TAKEN AND THE RESULTS GIVEN TO HIM. THIS JOB ORDER IS FOR THE CRAFT TO PERFORM THIS WORK.

NO LEADS ARE TO BE LIFTED, AND ELECTRICAL ISOLATION CAN NOT BE OBTAINED, THE CRAFT ARE TO USE THE SAFETY PRECAUTIONS AS DIRECTED BY THE SUPERVISOR IN PERFORMING THIS WORK.

WORK SCOPE

1. TAKE, RECORD, AND SUPPLY RESULTS, OF THE VOLTAGE, CURRENT, AND POWER FACTOR OF CIRCUIT BREAKER 2B61-D1.

LEFT PHASE

VOLTAGE _____ VAC CURRENT _____ AMPS POWER FACTOR _____

MIDDLE PHASE

VOLTAGE 274 VAC CURRENT 16.8 AMPS POWER FACTOR 61.3

RIGHT PHASE

VOLTAGE 272 VAC CURRENT 14.6 AMPS POWER FACTOR 63.2

SUPPLY A COPY OF RESULTS TO BRAD RISNER, GSB-3E.

POST MAINTENANCE TEST

NO CORRECTIVE MAINTENANCE PERFORMED BY THIS JOB ORDER, NO PMT REQUIRED.
DOCUMENTED ON JOB ORDER 855618.

ARKANSAS NUCLEAR ONE
SIMS JOB ORDER ATTACHMENT
THIS DOCUMENT IS PART OF A JOB ORDER
PACKAGE AND IS NOT TO BE SEPARATED FROM IT

JOB# 00b-5705 JR# 871062 Work Center MNTC ATTACHMENT _____ OF _____
Work Desc CRAFT IS TO TAKE VOLTAGE, CURRENT, AND POWER FACTOR READINGS
ON EACH LOAD PHASE, AND SUPPLY RESULTS TO BRAD RISNER,
DESIGN ENGINEERING. SEE JOB ORDER ATTACHMENT
Comp 2B-64D2 CKTBRK
Comp Desc 43LA, 208/120 PANEL Loc RAB-372-D-5.5
Work Type CM

PLANNERS NOTES

BRAD RISNER, (8512) HAS REQUESTED THAT THESE READINGS BE TAKEN AND THE RESULTS GIVEN TO HIM. THIS JOB ORDER IS FOR THE CRAFT TO PERFORM THIS WORK.

NO LEADS ARE TO BE LIFTED, AND ELECTRICAL ISOLATION CAN NOT BE OBTAINED, THE CRAFT ARE TO USE THE SAFETY PRECAUTIONS AS DIRECTED BY THE SUPERVISOR IN PERFORMING THIS WORK.

WORK SCOPE

1. TAKE, RECORD, AND SUPPLY RESULTS, OF THE VOLTAGE, CURRENT, AND POWER FACTOR OF CIRCUIT BREAKER 2B64-D2.

LEFT PHASE

VOLTAGE 272 VAC CURRENT 11.6 AMPS POWER FACTOR 95.5

MIDDLE PHASE

VOLTAGE 274 VAC CURRENT 8.5 AMPS POWER FACTOR 88.8

RIGHT PHASE


VOLTAGE 272 VAC CURRENT 9.0 AMPS POWER FACTOR 99.8

SUPPLY A COPY OF RESULTS TO BRAD RISNER, GSB-3E.


POST MAINTENANCE TEST

NO CORRECTIVE MAINTENANCE PERFORMED BY THIS JOB ORDER, NO PMT REQUIRED.
DOCUMENTED ON JOB ORDER 855618.

| CARRIER | TRANE | CHRYSLER AIRTEMP | YORK |
|---|---|---|--|
| 480 AMPS 112 AMPS 3600 RPM 752 KW | 730 AMPS 120 AMPS 3500 RPM 517 KW | 475 (LOCKED ROTOR) 103 AMPS 3600 RPM 667 KW | 572 AMPS 137 A 3600 RPM 780 KW |
| 3600 RPM 991 TONS 1028 TONS | 3600 980 980 | 3600 940 440 | 480 TONS 480 TONS |
| 2600 GPM 11.4 FT H ₂ O 8 FPS | 3000 GPM 9.4 FT 12.4 FT H ₂ O 7.6 FPS | 2600 GPM 10.4 2 PASS 16.5 FT H ₂ O 8 FPS | 2600 GPM 11.1 FT 16.8 FT H ₂ O 8.9 FPS |
| 1320 GPM WTR 18.4 FT H ₂ O 8 FPS | 1320 GPM 7 FT H ₂ O 5.1 FPS | 1320 GPM 3 PASS 10 FT H ₂ O 7 FPS | 1320 GPM 21.7 FT H ₂ O 7.2 FPS |
| 1/2 HP 460/3/60 | 1/4 HP 440-3-60 1750 WILL ADVISE | 1/3 HP 115 V-60 1750 5.4 GPM | 1/2 HP 115/1/60 1750 RPM 12 GPM |
| 15 GAL | FROM CHILLED WTR. CIRCUIT 10 GAL | NA - PERMITS BUILT AIR W/3/4" CAST DOWN PIPING (6.7 GAL OIL CHARGE) | N/A PERMITS BUILT 100% U 12 GAL |
| 1/4 HP 115/1/60 2550 | 1/4 HP 115-1-60 1750 WILL ADVISE | 1/3 HP 115-1-60 900 RPM .5 CFM BELT | N/A |
| 2 BELT | BELT | | 7 |
| 348 AMPS 189 AMPS 1730 RPM 125 KW | WILL ADVISE " " 1750 RPM WILL ADVISE | 125 HP T. EXHAUST MOTOR 905 AMPS 196 1800 RPM 76.5 KW | 1225 AMPS 180 AMPS 1800 RPM 100 KW |
| 95 TONS 95 TONS | 95 TONS 95 TONS | 95 TONS 106.5 TONS | 95 TONS 95 TONS |

| | | | |
|--|---|------------------------------------|-----------------|
| <p>SUMMARY OF BIDS</p> <p>WATER CHILLERS</p> <p>SHT 2 OF 5</p> |  <p>BECHTEL POWER AND INDUSTRIAL DIVISION</p> | <p>JOB No 6600-2</p> | <p>REVISION</p> |
| | | <p>P.O. NO.</p> <p>6600-M-2055</p> | |

| CARRIER | TRANE | CHRYSLER AIRTEMP | YORK |
|---|--|---|---|
| 480 AMPS 118 AMPS 3600 RPM 752 KW | 730 AMPS 120 AMPS 3600 RPM 817 KW | 475 (LOCKED ROTOR) 103 AMPS 3600 RPM 667 KW | 572 AMPS 127 A 3600 RPM 780 KW |
| 3600 RPM 991 TONS 1028 TONS | 360 980 980 | 3600 940 940 | 480 TONS 980 TONS |
| 2600 GPM 11.2 16.4 FT H ₂ O 8 FPS | 3000 GPM 8.9 13.1 FT H ₂ O 7.6 FPS | 2600 GPM 10.2 2 PASS 16.5 FT H ₂ O 8 FPS | 2600 GPM 11.1 16.8 FT H ₂ O 8.9 FPS |
| 1320 GPM WTR 18.4 FT H ₂ O 8 FPS | 1320 GPM 7 FT H ₂ O 5.1 FPS | 1320 GPM 3 PASS 10 FT H ₂ O 7 FPS | 1320 GPM 21.7 FT H ₂ O 7.2 FPS |
| 1/2 HP 460/3/60 | 1/4 HP 460-3-60 1750 WILL ADVISE | 1/3 HP 115-115V-60 1750 5.4 GPM | 1/2 HP 115/1/60 1750 KWHI 12 GPM |
| 15 GAL | FROM CHILLED WTR CIRCUIT 10 GAL | NA - PERMANENT COOLED MTR 11.5 GAL. COAST DOWN RESERVE (6 GAL OIL CHARGE) | N/A PLT FILL THAT TUBED 12 GAL |
| 1/8 HP 115/1/60 3550 | 1/8 HP 115-1-60 1750 WILL ADVISE BELT | 1/3 HP 115-1-60 900 RPM 5 CFM BELT | N/A |
| 348 AMPS 189 AMPS 1750 RPM 128 KW | WILL ADVISE " " 1750 KWHI WILL ADVISE | 125 HP T. LINE MOTOR 908 AMPS 146 1800 RPM 76.5 KW | 1225 AMPS 180 AMPS 1800 RPM 100 KW |
| 95 TONS 95 TONS | 95 TONS 95 TONS | 95 TONS 106.5 TONS | 95 TONS 95 TONS |

| | | | |
|--|--|------------------------------------|-----------------|
| <p>SUMMARY OF BIDS</p> <p>WATER CHILLERS</p> <p>SHT 2 OF 5</p> |  <p>BECHTEL</p> <p>POWER AND INDUSTRIAL DIVISION</p> | <p>JOB No 6600-2</p> | <p>REVISION</p> |
| | | <p>P.O. NO.</p> <p>6600-M-2055</p> | |

ATTACHMENT 41

HPSI PUMP 2P89A,B,& C ACCELERATION CALCULATION

Acceleration Time at 90% Voltage
Motor & Pump $WF^2 = 155.2 \text{ lb-ft}^2$
RPM (Synchronous) = 3600

(Per Attachments 42 & 43)
(Per Attachment 29)

$$NT_i = \frac{(MT_i + MT_{i-1})}{2} - \frac{(LT_i + LT_{i-1})}{2} \quad \text{(Per Reference 2.6, pages 6-38 thru 6-39)}$$

$$TIME_i = \frac{(W.K^2 \times (RPM_i - RPM_{i-1}))}{(308 \times NT_i)} \quad \text{(Per Reference 2.6, page 6-38)}$$

| % SYNCH. SPEED | (90% Voltage) MOTOR ¹ TORQUE (MT) | LOAD ¹ TORQUE (LT) | NET TORQUE (NT) | TIME (SECONDS) |
|-------------------|--|----------------------------------|--------------------|-------------------|
| 0 | 504 | 120 | ----- | ----- |
| 200 | 511 | 70 | 412.5 | 0.244313 |
| 400 | 518 | 40 | 459.5 | 0.219323 |
| 600 | 533 | 30 | 490.5 | 0.205462 |
| 800 | 547 | 40 | 505 | 0.199562 |
| 1000 | 576 | 60 | 511.5 | 0.197026 |
| 1200 | 605 | 85 | 518 | 0.194544 |
| 1400 | 634 | 115 | 519.5 | 0.193992 |
| 1600 | 677 | 150 | 523 | 0.192694 |
| 1800 | 749 | 190 | 543 | 0.185597 |
| 2000 | 878 | 235 | 601 | 0.167685 |
| 2200 | 1037 | 285 | 697.5 | 0.144486 |
| 2400 | 1152 | 340 | 782 | 0.128873 |
| 2600 | 1210 | 400 | 811 | 0.124265 |
| 2800 | 1246 | 470 | 793 | 0.127086 |
| 3000 | 1246 | 540 | 741 | 0.136004 |
| 3200 | 1224 | 620 | 655 | 0.153861 |
| 3400 | 1138 | 690 | 526 | 0.191595 |
| 3500 | 1066 | 730 | 392 | 0.128544 |
| 3575 | 760 | 760 | 168 | 0.224953 |
| | | | | Total 3.359875 |

1. Per Attachment 29

TO DAVID SHEHADEH
 501-377-4359 *wrong no.*

FROM
 Attention: Mr. Frank Giandori
 Phone 841-3421
 teletype Number : 1-513-841-3290

We need the wk^2 for all motors, some of these motors wk^2 are questionable. Also, we need the torque speed curve for 2P7B. Please note that 2P60B motor was obtained from the Waterford Plant and its hp is 500 replacing the 450 hp.

| Motor Serial Number. D. | hp | RPM | Frame | Volt | wk^2 | Service | wk^2 lb-FT ² |
|----------------------------|-----|------|----------|------|--------|---------|------------------------------|
| 2P35A 8-5117-90208-1-1 | 450 | 1780 | 580 BS | 4000 | 48 | Spray | 200.0 |
| 2P35B 8-5117-90251-1-1 | 450 | 1780 | 580 BS | 4000 | 48 | Spray | |
| 2P7B 8-5114-90209-1-1 | 600 | 3575 | 588 US | 4000 | 443 | EPW | 138.0 |
| 2P89A 8-5114-90209-1-2 | 600 | 3575 | 588 US R | 4000 | ? | HPI | |
| 2P89B 8-5114-90209-1-3 | 600 | 3575 | 588 US | 4000 | ? | HPI | |
| 2P89C 8-5114-90209-1-1 | 600 | 3575 | 588 US | 4000 | ? | HPI | |
| 2P60A 8-5117-90203-1-1 | 450 | 1780 | 580 B | 4000 | ? | LPSI | 200.0 |
| 2P60B 8-5117-90203-1-1* | 500 | 1780 | 580 CS | 4000 | 200 | LPSI | 216.9 |

Note: We are interested in any information you may have on the wk^2 of the pumps. We appreciate your efforts in satisfying this request.

David Shehadeh 501 377-3857 (teletype 501 377-4359)
 Arkansas Power and Light Company
 P.O. Box 552
 Little Rock, AR. 72203

WE DO NOT HAVE ANY INFORMATION
 ON THE wk^2 OF THE PUMPS.

THE SPEED TORQUE CURVE FOR 2P7B
~~WILL BE SENT SEPARATELY~~ A-22314
 IS ATTACHED

Frank Giandori
 4/3/90

RECEIVED

APR 11 1990

ARKANSAS POWER & LIGHT CO.
 ELECTRICAL I & O DESIGN

I N G E R S O L L - F A N DCUSTOMER SERVICE DEPT.
942 MEMORIAL PARKWAY
PHILLIPSBURG, NEW JERSEYDATE: 5-23-90TO: Bryan DiaperCOMPANY LOCATION Arkansas P&JTELECOPIER NUMBER (501) 377-5997FROM: T. H. BROWN

TELEPHONE: (201) 859-7069

NUMBER OF PAGES BEING SENT 1
(INCLUDING COVER)SPECIAL INSTRUCTIONS:

REF: High Pressure Safety Injection pumps and
Low Pressure Safety Injection pumps & R²
Values.

1. I model 8x20WD LPSI Pump
= 1.5 lbs-ft²

2. I model 4x90-9 HPSI Pump
= 1.2 lbs-ft²

Request

Thomas H. Brown

LOCATION: THIRD FLOOR BENTLEY BUILDING
AUTOMATIC ANSWER NUMBER (201) 859-8528

T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 8 31 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 8 31 PM
 T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

```

=====
FEEDER FROM      FEEDER TO      QTY VOLTS      LENGTH      FEEDER DESCRIPTION
NO NAME          NO NAME        /PH  L-L          SIZE TYPE  DUCT  INSUL
=====
  1 SYSTEM        200 161KV APL  1  161000.  1000. FT
  IMPEDANCE:      3.1131 + J19.4200 OHMS/M FEET

2001 2A1          2003 2A3        1   4160.  1000. FT
  IMPEDANCE:      .0047 + J .1600 OHMS/M FEET

2001 2A1          2902 ST2-A      1   4160.  1000. FT
  IMPEDANCE:      .0000 + J .0000 OHMS/M FEET

2002 2A2          2004 2A4        1   4160.  1000. FT
  IMPEDANCE:      .0047 + J .1600 OHMS/M FEET

2002 2A2          2902 ST2-A      1   4160.  1000. FT
  IMPEDANCE:      .0000 + J .0000 OHMS/M FEET

2006 A1           2008 A3         1   4160.  1000. FT
  IMPEDANCE:      .0000 + J .0000 OHMS/M FEET

2007 A2           2009 A4         1   4160.  1000. FT
  IMPEDANCE:      .0000 + J .0000 OHMS/M FEET

2901 ST2-CLR      2902 ST2-A      1   4160.  1000. FT
  IMPEDANCE:      .0005 + J .0220 OHMS/M FEET

2902 ST2-A        2006 A1         1   4160.  1000. FT
  IMPEDANCE:      .0000 + J .0000 OHMS/M FEET

2902 ST2-A        2007 A2         1   4160.  1000. FT
  IMPEDANCE:      .0000 + J .0000 OHMS/M FEET

=====
SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS
Calculated From Largest 3-PHASE Fault Contribution
=====
  
```

DATE:23 JUL 92 TIME: 8 31 PM
 T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * PERCENT | SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|---------------------------|---------------------|----------------|--------------|-----------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: | 4055. 1.2315 + J | 142. 7.6110 | | 3005 2B5 PERCENT | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: | 4055. 1.2438 + J | 142. 7.9432 | | 3006 2B6 PERCENT | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: | 4055. 1.2396 + J | 142. 8.0046 | | 3105 B5 PERCENT | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: | 4055. 1.2532 + J | 142. 8.0126 | | 3106 B6 PERCENT | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME: 8 31 PM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * * | BRANCH DATA | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|-------------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE:23 JUL 92 TIME: 8 31 PM
 T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

B R A N C H L O A D D A T A

| FROM BUS | / | TO BUS | BR. TYPE | CONSTANT KVA | KVA %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | FLOW %PF DIR. |
|---------------|---|-----------|-------------|-----------------|------------|-------------------|-----|-------------------|------------------|
| ===== | | | | | | | | | |
| 1 SYSTEM | | | | | | | | | |
| 200 161KV APL | | | FEEDER | 125 | -82.0 | | | | |
| 2002 2A2 | | | | | | | | | |
| 2004 2A4 | | | FEEDER | 125 | -82.0 | | | | |
| 2902 ST2-A | | | FEEDER | 125 | -82.0 | | | | REV |
| 2901 ST2-CLR | | | | | | | | | |
| 2902 ST2-A | | | FEEDER | 125 | -82.0 | | | | |
| 200 161KV APL | | | | | | | | | |
| 2901 ST2-CLR | | | TRANS. | 125 | -82.0 | | | | |
| 2004 2A4 | | | | | | | | | |
| 3006 2B6 | | | TRANS. | 125 | -82.0 | | | | |

DATE:23 JUL 92 TIME: 8 31 PM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

| * NO * | NAME | * KW | * KVAR | * LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2003 | 2A3 | 2013. | 1058. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 900. | 490. | CONSTANT KVA LOAD |
| 3006 | 2B6 | 399. | 1957. | CONSTANT Z LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 8 31 PM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 2274.45 KVA | |
| CONVERGENCE CRITERIA: | .114 KVA | |
| LARGEST BUS MISMATCH | 2003 2A3 | 139.791 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 15.080 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 1.956 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .249 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .031 KVA |

DATE:23 JUL 92 TIME: 8 31 PM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9
----- VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 33 VOLTAGE DROP: 848. %VD: .53
PROJECTED POWER FLOW: 7125. KW 5838. KVAR 9212. KVA PF: .77 LAGGING
LOSSES THRU FEEDER: 10. KW 65. KVAR 66. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 33 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 7125. KW 5838. KVAR 9212. KVA PF: .77 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158735 %VD: 1.4
----- VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 33 VOLTAGE DROP: 848. %VD: .53
PROJECTED POWER FLOW: 7115. KW 5773. KVAR 9163. KVA PF: .78 LAGGING
LOSSES THRU FEEDER: 10. KW 65. KVAR 66. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 33
PROJECTED POWER FLOW: 7115. KW 5774. KVAR 9163. KVA PF: .78 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4087 %VD: 1.8
----- VOLTAGE ANGLE: -2.2 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 482 VOLTAGE DROP: 70. %VD: 1.69
PROJECTED POWER FLOW: 2931. KW 1751. KVAR 3414. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 3. KW 112. KVAR 112. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 482 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2931. KW 1751. KVAR 3414. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 8 31 PM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00

PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4087 %VD: 1.8
----- VOLTAGE ANGLE: -2.2 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 256 VOLTAGE DROP: 69. %VD: 1.67
PROJECTED POWER FLOW: 430. KW 1763. KVAR 1815. KVA PF: .24 LAGGING
LOSSES THRU FEEDER: 1. KW 32. KVAR 32. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 256 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 430. KW 1763. KVAR 1815. KVA PF: .24 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4017 %VD: 3.4
----- VOLTAGE ANGLE: -3.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 2013. KW 1058. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 482 VOLTAGE DROP: 70. %VD: 1.69
PROJECTED POWER FLOW: 2928. KW 1639. KVAR 3356. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 3. KW 112. KVAR 112. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 156 VOLTAGE DROP: 120. %VD: 2.89
PROJECTED POWER FLOW: 915. KW 581. KVAR 1084. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 14.7 KW 91.1 KVAR 92.3 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4017 %VD: 3.4
----- VOLTAGE ANGLE: -2.4 DEGREES
LOAD FROM: 2002 2A2 FEEDER AMPS: 256 VOLTAGE DROP: 69. %VD: 1.67
PROJECTED POWER FLOW: 429. KW 1732. KVAR 1784. KVA PF: .24 LAGGING
LOSSES THRU FEEDER: 1. KW 32. KVAR 32. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 256 VOLTAGE DROP: 496. %VD: 11.915
PROJECTED POWER FLOW: 429. KW 1732. KVAR 1784. KVA PF: .24 LAGGING
LOSSES THRU TRANSF: 40.3 KW 257.6 KVAR 260.7 KVA

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4087 %VD: 1.8
----- VOLTAGE ANGLE: -2.2 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 8 31 PM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD FROM: 2902 ST2-A FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4087 %VD: 1.8
----- VOLTAGE ANGLE: -2.2 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4087 %VD: 1.8
----- VOLTAGE ANGLE: -2.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 152 VOLTAGE DROP: 108. %VD: 2.60
PROJECTED POWER FLOW: 935. KW 533. KVAR 1077. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.1 KW 91.3 KVAR 92.4 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4087 %VD: 1.8
----- VOLTAGE ANGLE: -2.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3106 B6 TRANSF AMPS: 90 VOLTAGE DROP: 23. %VD: .56
PROJECTED POWER FLOW: 552. KW 315. KVAR 635. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.0 KW 31.9 KVAR 32.2 KVA

DATE:23 JUL 92 TIME: 8 31 PM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4117 %VD: 1.0
----- VOLTAGE ANGLE: -1.7 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1258 VOLTAGE DROP: 30. %VD: .72
PROJECTED POWER FLOW: 7102. KW 5474. KVAR 8967. KVA PF: .79 LAGGING
LOSSES THRU FEEDER: 2. KW 104. KVAR 104. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1258
PROJECTED POWER FLOW: 7102. KW 5474. KVAR 8967. KVA PF: .79 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4087 %VD: 1.8
----- VOLTAGE ANGLE: -2.2 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 482 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2931. KW 1751. KVAR 3414. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 256 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 430. KW 1763. KVAR 1815. KVA PF: .24 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1258 VOLTAGE DROP: 30. %VD: .72
PROJECTED POWER FLOW: 7100. KW 5369. KVAR 8902. KVA PF: .80 LAGGING
LOSSES THRU FEEDER: 2. KW 104. KVAR 104. KVA

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 450 %VD: 6.3\$
----- VOLTAGE ANGLE: -7.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 900. KW 490. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 1316 VOLTAGE DROP: 14. %VD: 2.89
PROJECTED POWER FLOW: 900. KW 490. KVAR 1025. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 14.7 KW 91.1 KVAR 92.3 KVA

DATE:23 JUL 92 TIME: 8 31 PM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 406 %VD: 15.3\$

PROJECTED SPECIAL BUS LOAD: 286. KW 1403. KVAR
NET BRANCH DIVERSITY LOAD: 103. KW 72. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 2166 VOLTAGE DROP: 57. %VD:11.91\$
PROJECTED POWER FLOW: 388. KW 1474. KVAR 1525. KVA PF: .25 LAGGING
LOSSES THRU TRANSF: 40.3 KW 257.6 KVAR 260.7 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 459 %VD: 4.4

PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1285 VOLTAGE DROP: 12. %VD: 2.60
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.1 KW 91.3 KVAR 92.4 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 469 %VD: 2.3

PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 758 VOLTAGE DROP: 3. %VD: .56
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.0 KW 31.9 KVAR 32.2 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
103. KW 1084. KVAR

WARNING STUDY CONTAINS 4 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 10 37 AM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME:10 37 AM
 T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER DESCRIPTION SIZE TYPE DUCT INSUL |
|--|----------------------|------------|--------------|-------------|--|
| 1 SYSTEM | 200 161KV APL | 1 | 161000. | 1000. FT | |
| IMPEDANCE: | 3.1131 + J19.4200 | | | OHMS/M FEET | |
| 2001 2A1 | 2003 2A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J .1600 | | | OHMS/M FEET | |
| 2001 2A1 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |
| 2002 2A2 | 2004 2A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J .1600 | | | OHMS/M FEET | |
| 2002 2A2 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |
| 2006 A1 | 2008 A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |
| 2007 A2 | 2009 A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |
| 2901 ST2-CLR | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0005 + J .0220 | | | OHMS/M FEET | |
| 2902 ST2-A | 2006 A1 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |
| 2902 ST2-A | 2007 A2 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |
| ===== | | | | | |
| SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS | | | | | |
| Calculated From Largest 3-PHASE Fault Contribution | | | | | |
| ===== | | | | | |

DATE:23 JUL 92 TIME:10 37 AM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

TRANSFORMER DATA

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * PERCENT | SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|--|--------------|------------|--------------|-----------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: 1.2315 + J 7.6110 | 4055. | 142. | | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: 1.2438 + J 7.9432 | 4055. | 142. | | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: 1.2396 + J 8.0046 | 4055. | 142. | | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: 1.2532 + J 8.0126 | 4055. | 142. | | 3106 B6 | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME:10 37 AM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * * | BRANCH DATA | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|-------------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE:23 JUL 92 TIME:10 37 AM
 T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

B R A N C H L O A D D A T A

| FROM BUS | / | TO BUS | BR. TYPE | CONSTANT KVA | KVA %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | %PF | FLOW DIR. |
|---------------|---|-----------|-------------|-----------------|------------|-------------------|-----|-------------------|-----|--------------|
| 1 SYSTEM | | | | | | | | | | |
| 200 | | 161KV APL | FEEDER | 272 | -84.0 | | | | | |
| 2001 2A1 | | | | | | | | | | |
| 2003 | | 2A3 | FEEDER | 272 | -84.0 | | | | | |
| 2902 | | ST2-A | FEEDER | 272 | -84.0 | | | | | REV |
| 2901 ST2-CLR | | | | | | | | | | |
| 2902 | | ST2-A | FEEDER | 272 | -84.0 | | | | | |
| 200 161KV APL | | | | | | | | | | |
| 2901 | | ST2-CLR | TRANS. | 272 | -84.0 | | | | | |
| 2003 2A3 | | | | | | | | | | |
| 3005 | | 2B5 | TRANS. | 272 | -84.0 | | | | | |

DATE:23 JUL 92 TIME:10 37 AM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

| * NO * | NAME | * KW | * KVAR | * LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 319. | 1562. | CONSTANT Z LOAD |
| 3006 | 2B6 | 850. | 463. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME:10 37 AM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|------------|
| LARGEST LOAD: | 1735.66 KVA | |
| CONVERGENCE CRITERIA: | .087 KVA | |
| LARGEST BUS MISMATCH | 3006 2B6 | 89.043 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 11.792 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 1.449 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .175 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .021 KVA |

DATE:23 JUL 92 TIME:10 37 AM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9

VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 31 VOLTAGE DROP: 767. %VD: .48
PROJECTED POWER FLOW: 5664. KW 5248. KVAR 8482. KVA PF: .79 LAGGING
LOSSES THRU FEEDER: 9. KW 55. KVAR 56. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 31 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 6664. KW 5248. KVAR 8482. KVA PF: .79 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158816 %VD: 1.4

VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 31 VOLTAGE DROP: 767. %VD: .48
PROJECTED POWER FLOW: 6655. KW 5193. KVAR 8442. KVA PF: .79 LAGGING
LOSSES THRU FEEDER: 9. KW 55. KVAR 56. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3WYFMR AMPS: 31
PROJECTED POWER FLOW: 6655. KW 5193. KVAR 8442. KVA PF: .79 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4101 %VD: 1.4

VOLTAGE ANGLE: -2.1 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 231 VOLTAGE DROP: 62. %VD: 1.48
PROJECTED POWER FLOW: 505. KW 1564. KVAR 1643. KVA PF: .31 LAGGING
LOSSES THRU FEEDER: 1. KW 26. KVAR 26. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 231 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 505. KW 1564. KVAR 1643. KVA PF: .31 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME:10 37 AM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4101 %VD: 1.4
----- VOLTAGE ANGLE: -2.1 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 393 VOLTAGE DROP: 58. %VD: 1.38
PROJECTED POWER FLOW: 2399. KW 1433. KVAR 2794. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 2. KW 74. KVAR 74. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 393 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2399. KW 1433. KVAR 2794. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4039 %VD: 2.9
----- VOLTAGE ANGLE: -2.3 DEGREES
LOAD FROM: 2001 2A1 FEEDER AMPS: 231 VOLTAGE DROP: 62. %VD: 1.48
PROJECTED POWER FLOW: 504. KW 1538. KVAR 1618. KVA PF: .31 LAGGING
LOSSES THRU FEEDER: 1. KW 26. KVAR 26. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 231 VOLTAGE DROP: 409. %VD: 9.84\$
PROJECTED POWER FLOW: 504. KW 1538. KVAR 1618. KVA PF: .31 LAGGING
LOSSES THRU TRANSF: 32.5 KW 200.9 KVAR 203.5 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4043 %VD: 2.8
----- VOLTAGE ANGLE: -3.4 DEGREES
PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 393 VOLTAGE DROP: 58. %VD: 1.38
PROJECTED POWER FLOW: 2397. KW 1358. KVAR 2755. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 2. KW 74. KVAR 74. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 146 VOLTAGE DROP: 113. %VD: 2.71
PROJECTED POWER FLOW: 863. KW 546. KVAR 1021. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 13.1 KW 83.4 KVAR 84.4 KVA

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4101 %VD: 1.4
----- VOLTAGE ANGLE: -2.1 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 366 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME:10 37 AM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD FROM: 2902 ST2-A FEEDER AMPS: 366 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4101 %VD: 1.4
----- VOLTAGE ANGLE: -2.1 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 221 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 221 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4101 %VD: 1.4
----- VOLTAGE ANGLE: -2.1 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 366 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 151 VOLTAGE DROP: 107. %VD: 2.57
PROJECTED POWER FLOW: 935. KW 533. KVAR 1076. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.0 KW 90.6 KVAR 91.7 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4101 %VD: 1.4
----- VOLTAGE ANGLE: -2.1 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 221 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3106 B6 TRANSF AMPS: 89 VOLTAGE DROP: 23. %VD: .54
PROJECTED POWER FLOW: 552. KW 315. KVAR 635. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 4.9 KW 31.6 KVAR 32.0 KVA

DATE:23 JUL 92 TIME:10 37 AM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00

PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4128 %VD: .8

VOLTAGE ANGLE: -1.6 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1158 VOLTAGE DROP: 27. %VD: .65
PROJECTED POWER FLOW: 6645. KW 4939. KVAR 8279. KVA PF: .80 LAGGING
LOSSES THRU FEEDER: 2. KW 88. KVAR 89. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1158
PROJECTED POWER FLOW: 6645. KW 4939. KVAR 8279. KVA PF: .80 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4101 %VD: 1.4

VOLTAGE ANGLE: -2.1 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 231 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 505. KW 1564. KVAR 1643. KVA PF: .31 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 393 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2399. KW 1433. KVAR 2794. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 366 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 221 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1158 VOLTAGE DROP: 27. %VD: .65
PROJECTED POWER FLOW: 6643. KW 4850. KVAR 8225. KVA PF: .81 LAGGING
LOSSES THRU FEEDER: 2. KW 88. KVAR 89. KVA

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 419 %VD: 12.7\$

VOLTAGE ANGLE: -3.6 DEGREES
PROJECTED SPECIAL BUS LOAD: 243. KW 1189. KVAR
NET BRANCH DIVERSITY LOAD: 228. KW 148. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 1954 VOLTAGE DROP: 47. %VD: 9.84\$
PROJECTED POWER FLOW: 471. KW 1337. KVAR 1418. KVA PF: .33 LAGGING
LOSSES THRU TRANSF: 32.5 KW 200.9 KVAR 203.5 KVA

DATE:23 JUL 92 TIME:10 37 AM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 454 %VD: 5.5\$

PROJECTED SPECIAL BUS LOAD: 850. KW 463. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1232 VOLTAGE DROP: 13. %VD: 2.71
PROJECTED POWER FLOW: 850. KW 463. KVAR 968. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 13.1 KW 83.4 KVAR 84.4 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 461 %VD: 4.0

PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1280 VOLTAGE DROP: 12. %VD: 2.57
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.0 KW 90.6 KVAR 91.7 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 471 %VD: 2.0

PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 756 VOLTAGE DROP: 3. %VD: .54
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 4.9 KW 31.6 KVAR 32.0 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
89. KW 904. KVAR

WARNING STUDY CONTAINS 4 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 8 52 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

LAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 8 52 PM
 T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

| ===== | | ===== | | ===== | | ===== | | ===== | |
|--|----------------------|------------|--------------|-------------|---------------------|---------------------|-------|-------|--|
| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER SIZE TYPE | DESCRIPTION DUCT | INSUL | | |
| ===== | | ===== | | ===== | | ===== | | ===== | |
| 1 SYSTEM | 200 161KV APL | 1 | 161000. | 1000. FT | | | | | |
| IMPEDANCE: | 3.1131 + J19.4200 | | | OHMS/M FEET | | | | | |
| 2001 2A1 | 2003 2A3 | 1 | 4160. | 1000. FT | | | | | |
| IMPEDANCE: | .0047 + J .1600 | | | OHMS/M FEET | | | | | |
| 2003 2A1 | 2902 ST2-A | 1 | 4160. | 1000. FT | | | | | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | | | | | |
| 2002 2A2 | 2004 2A4 | 1 | 4160. | 1000. FT | | | | | |
| IMPEDANCE: | .0047 + J .1600 | | | OHMS/M FEET | | | | | |
| 2002 2A2 | 2902 ST2-A | 1 | 4160. | 1000. FT | | | | | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | | | | | |
| 2006 A1 | 2008 A3 | 1 | 4160. | 1000. FT | | | | | |
| IMPEDANCE: | .0300 + J .0000 | | | OHMS/M FEET | | | | | |
| 2007 A2 | 2009 A4 | 1 | 4160. | 1000. FT | | | | | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | | | | | |
| 2901 ST2-CLR | 2902 ST2-A | 1 | 4160. | 1000. FT | | | | | |
| IMPEDANCE: | .0005 + J .0220 | | | OHMS/M FEET | | | | | |
| 2902 ST2-A | 2006 A1 | 1 | 4160. | 1000. FT | | | | | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | | | | | |
| 2902 ST2-A | 2007 A2 | 1 | 4160. | 1000. FT | | | | | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | | | | | |
| ===== | | | | | | | | | |
| SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .0000000000 + J .0000000000 OHMS | | | | | | | | | |
| Calculated From Largest 3-PHASE Fault Contribution | | | | | | | | | |
| ===== | | | | | | | | | |

DATE:23 JUL 92 TIME: 8 52 PM
 T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PPI FLA | * SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|--|--------------|------------|-------------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: 1.2315 + J 7.6110 PERCENT | 4055. | 142. | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: 1.2438 + J 7.9432 PERCENT | 4055. | 142. | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: 1.2396 + J 8.0046 PERCENT | 4055. | 142. | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: 1.2532 + J 8.0126 PERCENT | 4055. | 142. | 3106 B6 | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME: 8 52 PM
 T=4.5 SECONDS, ST #2 Unit 2 MSLS Unit 3 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS | * BRANCH | % IMPEDANCE | | NOMINAL KVA |
|---------------------------|------|-----------|---------|-----------|-------------|--------|----------------|
| | | | L-L | * DATA | R | X | |
| PRIMARY | 200 | 161KV APL | 161000. | * PRI-SEC | .2000 + J | 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * PRI-TER | .1900 + J | 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * SEC-TER | .3700 + J | 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE:23 JUL 92 TIME: 8 52 PM
T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9913, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BRANCH LOAD DATA

```
=====
FROM / TO BR. CONSTANT KVA CONSTANT Z CONSTANT I FLOW
BUS / BUS TYPE KVA %PF KVA %PF KVA %PF DIR.
=====
```

DATE:23 JUL 92 TIME: 8 52 PM
T=4.5 SECONDS, ST #2 Unit 2 MSLP Unit 1 LOOP
SYSTEM VOLT=0.9312, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

| * NO * | NAME | * KW | * KVAR | * LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2003 | 2A3 | 2013. | 1058. | CONSTANT KVA LOAD |
| 2004 | 2A4 | 1228. | 4968. | CONSTANT Z LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 900. | 490. | CONSTANT KVA LOAD |
| 3006 | 2B6 | 356. | 288. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 8 52 PM
T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 5117.52 KVA | |
| CONVERGENCE CRITERIA: | .256 KVA | |
| LARGEST BUS MISMATCH | 2003 2A3 | 216.125 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 21.684 KVA |
| LARGEST BUS MISMATCH: | 3077 2B5 | 3.014 KVA |
| LARGEST BUS MISMATCH: | 3003 2B5 | .406 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .054 KVA |

DATE:23 JUL 92 TIME: 8 52 PM
T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9

VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 44 VOLTAGE DROP: 1274. %VD: .79
PROJECTED POWER FLOW: 8117. KW 9186. KVAR 12259. KVA PF: .66 LAGGING
LOSSES THRU FEEDER: 18. KW 115. KVAR 116. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 44 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 8117. KW 9186. KVAR 12259. KVA PF: .66 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158309 %VD: 1.7

VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 44 VOLTAGE DROP: 1274. %VD: .79
PROJECTED POWER FLOW: 8099. KW 9072. KVAR 12161. KVA PF: .67 LAGGING
LOSSES THRU FEEDER: 18. KW 115. KVAR 116. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 44
PROJECTED POWER FLOW: 8099. KW 9072. KVAR 12161. KVA PF: .67 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4008 %VD: 3.6

VOLTAGE ANGLE: -2.5 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 493 VOLTAGE DROP: 72. %VD: 1.73
PROJECTED POWER FLOW: 2932. KW 1760. KVAR 3420. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 3. KW 116. KVAR 117. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 493 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2932. KW 1760. KVAR 3420. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 8 52 PM
T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4008 %VD: 3.6

LOAD TO: 2004 2A4 FEEDER AMPS: 711 VOLTAGE ANGLE: -2.5 DEGREES
PROJECTED POWER FLOW: 1401. KW 4736. KVAR 4938. KVA PF: .28 %VD: 4.58\$
LOSSES THRU FEEDER: 7. KW 243. KVAR 243. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 711 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1401. KW 4736. KVAR 4938. KVA PF: .28 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3936 %VD: 5.4\$

PROJECTED SPECIAL BUS LOAD: 2013. KW 1056. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 493 VOLTAGE ANGLE: -4.2 DEGREES
PROJECTED POWER FLOW: 2929. KW 1643. KVAR 3358. KVA PF: .87 %VD: 1.73
LOSSES THRU FEEDER: 3. KW 116. KVAR 117. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 159 VOLTAGE DROP: 128. %VD: 3.07
PROJECTED POWER FLOW: 915. KW 595. KVAR 1087. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 15.4 KW 95.4 KVAR 96.6 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3818 %VD: 8.2\$

PROJECTED SPECIAL BUS LOAD: 1034. KW 4185. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 711 VOLTAGE ANGLE: -3.3 DEGREES
PROJECTED POWER FLOW: 1393. KW 4493. KVAR 4704. KVA PF: .30 %VD: 4.58\$
LOSSES THRU FEEDER: 7. KW 243. KVAR 243. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 72 VOLTAGE DROP: 27. %VD: .66
PROJECTED POWER FLOW: 359. KW 308. KVAR 473. KVA PF: .76 LAGGING
LOSSES THRU TRANSF: 3.1 KW 20.1 KVAR 20.3 KVA

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4008 %VD: 3.6

LOAD TO: 2008 A3 FEEDER AMPS: 375 VOLTAGE ANGLE: -2.5 DEGREES
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2605. KVA PF: .90 %VD: .00
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 8 52 PM
T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD FROM: 2902 ST2-A FEEDER AMPS: 375 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2605. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4008 %VD: 3.6

VOLTAGE ANGLE: -2.5 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 227 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 227 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4008 %VD: 3.6

VOLTAGE ANGLE: -2.5 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 375 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2605. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 155 VOLTAGE DROP: 115. %VD: 2.78
PROJECTED POWER FLOW: 936. KW 537. KVAR 1079. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.8 KW 95.4 KVAR 96.5 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4008 %VD: 3.6

VOLTAGE ANGLE: -2.5 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 227 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3106 B6 TRANSF AMPS: 92 VOLTAGE DROP: 28. %VD: .68
PROJECTED POWER FLOW: 552. KW 316. KVAR 636. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.2 KW 33.2 KVAR 33.6 KVA

DATE:23 JUL 92 TIME: 8 52 PM
T=4.5 SECONDS, ST #2 Unit 2 MS1B Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4055 %VD: 2.5

VOLTAGE ANGLE: -1.9 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1674 VOLTAGE DROP: 47. %VD: 1.13
PROJECTED POWER FLOW: 8077. KW 8541. KVAR 11755. KVA PF: .69 LAGGING
LOSSES THRU FEEDER: 4. KW 185. KVAR 185. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3WXFMR AMPS: 1674
PROJECTED POWER FLOW: 8077. KW 8541. KVAR 11755. KVA PF: .69 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4008 %VD: 3.6

VOLTAGE ANGLE: -2.5 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 493 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2932. KW 1760. KVAR 3420. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 711 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1401. KW 4736. KVAR 4938. KVA PF: .28 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 375 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2605. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 227 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1674 VOLTAGE DROP: 47. %VD: 1.13
PROJECTED POWER FLOW: 8073. KW 8356. KVAR 11619. KVA PF: .69 LAGGING
LOSSES THRU FEEDER: 4. KW 185. KVAR 185. KVA

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 439 %VD: 8.5\$

VOLTAGE ANGLE: -8.3 DEGREES
PROJECTED SPECIAL BUS LOAD: 900. KW 490. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 1346 VOLTAGE DROP: 15. %VD: 3.07
PROJECTED POWER FLOW: 900. KW 490. KVAR 1025. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 15.4 KW 95.4 KVAR 96.6 KVA

DATE:23 JUL 92 TIME: 8 52 PM
T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 437 %VD: 8.95

PROJECTED SPECIAL BUS LOAD: 356. KW 288. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 604 VOLTAGE DROP: 3. %VD: .66
PROJECTED POWER FLOW: 356. KW 238. KVAR 458. KVA PF: .78 LAGGING
LOSSES THRU TRANSF: 3.1 KW 20.1 KVAR 20.3 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 449 %VD: 6.45

PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1313 VOLTAGE DROP: 13. %VD: 2.78
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.8 KW 95.4 KVAR 96.5 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 459 %VD: 4.3

PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 774 VOLTAGE DROP: 3. %VD: .68
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.2 KW 33.2 KVAR 33.6 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
93. KW 1434. KVAR

WARNING STUDY CONTAINS 7 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 1 59 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 1 59 PM
 T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER DESCRIPTION SIZE TYPE DUCT INSUL |
|--|----------------------|------------|--------------|----------|--|
| 1 SYSTEM | 260 161KV APL | 1 | 161000. | 1000. FT | |
| IMPEDANCE: | 3.1131 + J19.4200 | | OHMS/M | FEET | |
| 2001 2A1 | 2003 2A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J .1600 | | OHMS/M | FEET | |
| 2001 2A1 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2002 2A2 | 2004 2A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J .1600 | | OHMS/M | FEET | |
| 2002 2A2 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2006 A1 | 2008 A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2007 A2 | 2009 A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2901 ST2-CLR | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0005 + J .0220 | | OHMS/M | FEET | |
| 2902 ST2-A | 2006 A1 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2902 ST2-A | 2007 A2 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| ===== | | | | | |
| SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS | | | | | |
| Calculated From Largest 3-PHASE Fault Contribution | | | | | |
| ===== | | | | | |

DATE:23 JUL 92 TIME: 1 59 PM
T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * NO NAME | SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|---------------------------|---------------------|----------------|--------------|-----------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: | 4055. 1.2315 + J | 142. 7.6110 | | 3005 2B5 PERCENT | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: | 4055. 1.2438 + J | 142. 7.9432 | | 3006 2B6 PERCENT | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: | 4055. 1.2396 + J | 142. 8.0046 | | 3105 B5 PERCENT | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: | 4055. 1.2532 + J | 142. 8.0126 | | 3106 B6 PERCENT | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME: 1 59 PM
T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * DATA | BRANCH DATA | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|-------------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE:23 JUL 92 TIME: 1 59 PM
T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BRANCH LOAD DATA

```
=====
FROM / TO BR. CONSTANT KVA CONSTANT Z CONSTANT I FLOW
BUS / BUS TYPE KVA %PF KVA %PF KVA %PF DIR.
=====
```


DATE:23 JUL 92 TIME: 1 59 PM
T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

| * NO * | NAME | * KW | * KVAR | LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2003 | 2A3 | 1228. | 4968. | CONSTANT Z LOAD |
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 443. | 338. | CONSTANT KVA LOAD |
| 3006 | 2B6 | 850. | 463. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 1 59 PM
T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***

=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOP SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 5117.52 KVA | |
| CONVERGENCE CRITERIA: | .256 KVA | |
| LARGEST BUS MISMATCH | 2004 2A4 | 151.409 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 18.012 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 2.378 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .306 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .039 KVA |

DATE:23 JUL 92 TIME: 1 59 PM
T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9
----- VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 42 VOLTAGE DROP: 1228. %VD: .76
PROJECTED POWER FLOW: 7672. KW 8874. KVAR 11731. KVA PF: .65 LAGGING
LOSSES THRU FEEDER: 17. KW 105. KVAR 106. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 42 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 7672. KW 8874. KVAR 11731. KVA PF: .65 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158355 %VD: 1.6
----- VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 42 VOLTAGE DROP: 1228. %VD: .76
PROJECTED POWER FLOW: 7655. KW 8769. KVAR 11640. KVA PF: .66 LAGGING
LOSSES THRU FEEDER: 17. KW 105. KVAR 106. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 42
PROJECTED POWER FLOW: 7655. KW 8769. KVAR 11641. KVA PF: .66 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4016 %VD: 3.5
----- VOLTAGE ANGLE: -2.4 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 725 VOLTAGE DROP: 193. %VD: 4.64\$
PROJECTED POWER FLOW: 1492. KW 4813. KVAR 5039. KVA PF: .30 LAGGING
LOSSES THRU FEEDER: 7. KW 252. KVAR 252. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 725 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1492. KW 4813. KVAR 5039. KVA PF: .30 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE: 23 JUL 92 TIME: 1 59 PM
 T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00

PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4016 %VD: 3.5
 ----- VOLTAGE ANGLE: -2.4 DEGREES

LOAD TO: 2004 2A4 FEEDER AMPS: 402 VOLTAGE DROP: 59. %VD: 1.42
 PROJECTED POWER FLOW: 2400. KW 1440. KVAR 2799. KVA PF: .86 LAGGING
 LOSSES THRU FEEDER: 2. KW 78. KVAR 78. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 402 VOLTAGE DROP: 0. %VD: .00
 PROJECTED POWER FLOW: 2400. KW 1440. KVAR 2799. KVA PF: .86 LAGGING
 LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3823 %VD: 8.15
 ----- VOLTAGE ANGLE: -3.2 DEGREES

PROJECTED SPECIAL BUS LOAD: 1037. KW 4195. KVAR
 LOAD FROM: 2001 2A1 FEEDER AMPS: 725 VOLTAGE DROP: 193. %VD: 4.645
 PROJECTED POWER FLOW: 1484. KW 45. KVAR 4797. KVA PF: .31 LAGGING
 LOSSES THRU FEEDER: 7. KW 252. KVAR 252. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 87 VOLTAGE DROP: 46. %VD: 1.11
 PROJECTED POWER FLOW: 448. KW 367. KVAR 579. KVA PF: .77 LAGGING
 LOSSES THRU TRANSF: 4.6 KW 28.7 KVAR 29.1 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3957 %VD: 4.9
 ----- VOLTAGE ANGLE: -3.8 DEGREES

PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR
 LOAD FROM: 2002 2A2 FEEDER AMPS: 402 VOLTAGE DROP: 59. %VD: 1.42
 PROJECTED POWER FLOW: 2398. KW 1362. KVAR 2758. KVA PF: .87 LAGGING
 LOSSES THRU FEEDER: 2. KW 78. KVAR 78. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 149 VOLTAGE DROP: 121. %VD: 2.90
 PROJECTED POWER FLOW: 864. KW 550. KVAR 1024. KVA PF: .84 LAGGING
 LOSSES THRU TRANSF: 13.7 KW 87.5 KVAR 88.6 KVA

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4016 %VD: 3.5
 ----- VOLTAGE ANGLE: -2.4 DEGREES

LOAD TO: 2008 A3 FEEDER AMPS: 374 VOLTAGE DROP: 0. %VD: .00
 PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2604. KVA PF: .90 LAGGING
 LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 1 59 PM
 T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Rad Train Sequencing
 ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

 VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
 VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
 PER UNIT DRIVING VOLTAGE = .9912

LOAD FROM: 2902 ST2-A FEEDER AMPS: 374 VOLTAGE DROP: 0. %VD: .00
 PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2604. KVA PF: .90 LAGGING
 LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4016 %VD: 3.5

 VOLTAGE ANGLE: -2.4 DEGREES
 LOAD TO: 2009 A4 FEEDER AMPS: 226 VOLTAGE DROP: 0. %VD: .00
 PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
 LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 226 VOLTAGE DROP: 0. %VD: .00
 PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
 LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4016 %VD: 3.5

 VOLTAGE ANGLE: -2.4 DEGREES
 PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
 LOAD FROM: 2006 A1 FEEDER AMPS: 374 VOLTAGE DROP: 0. %VD: .00
 PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2604. KVA PF: .90 LAGGING
 LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 155 VOLTAGE DROP: 115. %VD: 2.76
 PROJECTED POWER FLOW: 936. KW 537. KVAR 1079. KVA PF: .87 LAGGING
 LOSSES THRU TRANSF: 14.7 KW 95.0 KVAR 96.1 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4016 %VD: 3.5

 VOLTAGE ANGLE: -2.4 DEGREES
 PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
 LOAD FROM: 2007 A2 FEEDER AMPS: 226 VOLTAGE DROP: 0. %VD: .00
 PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
 LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3106 B6 TRANSF AMPS: 91 VOLTAGE DROP: 28. %VD: .67
 PROJECTED POWER FLOW: 552. KW 316. KVAR 636. KVA PF: .87 LAGGING
 LOSSES THRU TRANSF: 5.2 KW 33.1 KVAR 33.5 KVA

DATE:23 JUL 92 TIME: 1 59 PM
T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4061 %VD: 2.4

VOLTAGE ANGLE: -1.8 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1601 VOLTAGE DROP: 46. %VD: 1.10
PROJECTED POWER FLOW: 7635. KW 8283. KVAR 11265. KVA PF: .68 LAGGING
LOSSES THRU FEEDER: 4. KW 169. KVAR 169. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1601
PROJECTED POWER FLOW: 7635. KW 8283. KVAR 11265. KVA PF: .68 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4016 %VD: 3.5

VOLTAGE ANGLE: -2.4 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 725 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1492. KW 4813. KVAR 5039. KVA PF: .30 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 402 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2400. KW 1440. KVAR 2799. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 374 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 226 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1601 VOLTAGE DROP: 46. %VD: 1.10
PROJECTED POWER FLOW: 7632. KW 8114. KVAR 11139. KVA PF: .69 LAGGING
LOSSES THRU FEEDER: 4. KW 169. KVAR 169. KVA

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 436 %VD: 9.2\$

VOLTAGE ANGLE: -5.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 443. KW 338. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 738 VOLTAGE DROP: 5. %VD: 1.11
PROJECTED POWER FLOW: 443. KW 338. KVAR 557. KVA PF: .80 LAGGING
LOSSES THRU TRANSF: 4.6 KW 28.7 KVAR 29.1 KVA

DATE:23 JUL 92 TIME: 1 59 PM
T=4.5 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODFLED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRAN ` = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .912

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 443 %VD: 7.85

VOLTAGE ANGLE: -7.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 850. KW 463. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1263 VOLTAGE DROP: 14. %VD: 2.90
PROJECTED POWER FLOW: 850. KW 463. KVAR 968. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 13.7 KW 87.5 KVAR 88.6 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 450 %VD: 6.25

VOLTAGE ANGLE: -6.6 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1310 VOLTAGE DROP: 13. %VD: 2.76
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.7 KW 95.0 KVAR 96.1 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 460 %VD: 4.1

VOLTAGE ANGLE: -4.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 773 VOLTAGE DROP: 3. %VD: .67
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.2 KW 33.1 KVAR 33.5 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
89. KW 1334. KVAR

WARNING STUDY CONTAINS 6 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Rec Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 11 32 AM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME:11 32 AM
 T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENERGY OPERATIONS INC.

F E E D E R D A T A

| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER DESCRIPTION SIZE TYPE DUCT INSUL |
|--|----------------------|------------|--------------|----------|--|
| 1 SYSTEM | 200 161KV APL | 1 | 161000. | 1000. FT | |
| IMPEDANCE: | 3.1131 + J19.4200 | | OHMS/M | FEET | |
| 2001 2A1 | 2003 2A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J .1600 | | OHMS/M | FEET | |
| 2001 2A1 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2002 2A2 | 2004 2A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J .1600 | | OHMS/M | FEET | |
| 2002 2A2 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2006 A1 | 2008 A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2007 A2 | 2009 A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2901 ST2-CLR | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0005 + J .0220 | | OHMS/M | FEET | |
| 2902 ST2-A | 2006 A1 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2902 ST2-A | 2007 A2 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| ===== | | | | | |
| SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS | | | | | |
| Calculated From Largest 3-PHASE Fault Contribution | | | | | |
| ===== | | | | | |

DATE: 23 JUL 92 TIME: 11 32 AM
T-10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * NO NAME | SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|---------------------------|---------------------|----------------|--------------|-----------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: | 4055. 1.2315 + J | 142. 7.6110 | | 3005 2B5 PERCENT | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: | 4055. 1.2438 + J | 142. 7.9432 | | 3006 2B6 PERCENT | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: | 4055. 1.2396 + J | 142. 8.0046 | | 3105 B5 PERCENT | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: | 4055. 1.2532 + J | 142. 8.0126 | | 3106 B6 PERCENT | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME:11 32 AM
T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * BRANCH DATA | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|---------------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | |

DATE:23 JUL 92 TIME:11 32 AM
 T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

BRANCH LOAD DATA

| FROM BUS | / | TO BUS | BR. TYPE | CONSTANT KVA | KVA %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | FLOW %PF DIR. |
|---------------|---|-----------|-------------|-----------------|------------|-------------------|-----|-------------------|------------------|
| ===== | | | | | | | | | |
| 1 SYSTEM | | | | | | | | | |
| 200 161KV APL | | | FEEDER | 724 | -88.0 | | | | |
| 2002 2A2 | | | | | | | | | |
| 2004 2A4 | | | FEEDER | 724 | -88.0 | | | | |
| 2902 ST2-A | | | FEEDER | 724 | -88.0 | | | | REV |
| 2901 ST2-CLR | | | | | | | | | |
| 2902 ST2-A | | | FEEDER | 724 | -88.0 | | | | |
| 200 161KV APL | | | | | | | | | |
| 2901 ST2-CLR | | | TRANS. | 724 | -88.0 | | | | |

DATE:23 JUL 92 TIME:11 32 AM
T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

| * NO * | NAME | * KW | * KVAR | * LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2003 | 2A3 | 2013. | 1058. | CONSTANT KVA LOAD |
| 2004 | 2A4 | 789. | 3586. | CONSTANT Z LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 900. | 490. | CONSTANT KVA LOAD |
| 3006 | 2B6 | 356. | 288. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME:11 32 AM
T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 3671.77 KVA | |
| CONVERGENCE CRITERIA: | .184 KVA | |
| LARGEST BUS MISMATCH | 2003 2A3 | 195.318 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 20.461 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 2.858 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .386 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .051 KVA |

DATE:23 JUL 92 TIME:11 32 AM
T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTREPRENEUR OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9
----- VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 43 VOLTAGE DROP: 1175. %VD: .73
PROJECTED POWER FLOW: 8397. KW 8326. KVAR 11825. KVA PF: .71 LAGGING
LOSSES THRU FEEDER: 17. KW 107. KVAR 108. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 43 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 8397. KW 8326. KVAR 11825. KVA PF: .71 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158408 %VD: 1.6
----- VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 43 VOLTAGE DROP: 1175. %VD: .73
PROJECTED POWER FLOW: 8380. KW 8219. KVAR 11738. KVA PF: .71 LAGGING
LOSSES THRU FEEDER: 17. KW 107. KVAR 108. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 43
PROJECTED POWER FLOW: 8380. KW 8220. KVAR 11738. KVA PF: .71 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4028 %VD: 3.2
----- VOLTAGE ANGLE: -2.6 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 490 VOLTAGE DROP: 72. %VD: 1.72
PROJECTED POWER FLOW: 2932. KW 1758. KVAR 3418. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 3. KW 115. KVAR 115. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 490 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2932. KW 1758. KVAR 3418. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME:11 32 AM
T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4028 %VD: 3.2

VOLTAGE ANGLE: -2.6 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 614 VOLTAGE DROP: 158. %VD: 3.79
PROJECTED POWER FLOW: 1684. KW 3936. KVAR 4282. KVA PF: .39 LAGGING
LOSSES THRU FEEDER: 5. KW 181. KVAR 181. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 614 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1684. KW 3936. KVAR 4282. KVA PF: .39 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3957 %VD: 4.9

VOLTAGE ANGLE: -4.3 DEGREES
PROJECTED SPECIAL BUS LOAD: 2013. KW 1058. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 490 VOLTAGE DROP: 72. %VD: 1.72
PROJECTED POWER FLOW: 2928. KW 1643. KVAR 3357. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 3. KW 115. KVAR 115. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 158 VOLTAGE DROP: 126. %VD: 3.03
PROJECTED POWER FLOW: 915. KW 585. KVAR 1086. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 15.3 KW 94.3 KVAR 95.5 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3871 %VD: 7.05

VOLTAGE ANGLE: -3.6 DEGREES
PROJECTED SPECIAL BUS LOAD: 683. KW 3104. KVAR
NET BRANCH DIVERSITY LOAD: 637. KW 344. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 614 VOLTAGE DROP: 158. %VD: 3.79
PROJECTED POWER FLOW: 1679. KW 3756. KVAR 4114. KVA PF: .41 LAGGING
LOSSES THRU FEEDER: 5. KW 181. KVAR 181. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 71 VOLTAGE DROP: 24. %VD: .58
PROJECTED POWER FLOW: 359. KW 307. KVAR 473. KVA PF: .76 LAGGING
LOSSES THRU TRANSF: 3.1 KW 19.5 KVAR 19.7 KVA

DATE:23 JUL 92 TIME:11 32 AM
T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4028 %VD: 3.2
----- VOLTAGE ANGLE: -2.6 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 373 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2307. KW 1149. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 373 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2307. KW 1149. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4028 %VD: 3.2
----- VOLTAGE ANGLE: -2.6 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 225 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 225 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4028 %VD: 3.2
----- VOLTAGE ANGLE: -2.6 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 373 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1149. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 155 VOLTAGE DROP: 114. %VD: 2.73
PROJECTED POWER FLOW: 936. KW 536. KVAR 1078. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.6 KW 94.3 KVAR 95. KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4028 %VD: 3.2
----- VOLTAGE ANGLE: -2.6 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 225 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME:11 32 AM
T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Rec Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD TO: 3106 B6 TRANSF AMPS: 91 VOLTAGE DROP: 27. %VD: .65
PROJECTED POWER FLOW: 552. KW 316. KVAR 636. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.1 KW 32.8 KVAR 33.2 KVA

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4071 %VD: 2.1
----- VOLTAGE ANGLE: -2.0 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1614 VOLTAGE DROP: 42. %VD: 1.02
PROJECTED POWER FLOW: 8360. KW 7725. KVAR 11383. KVA PF: .73 LAGGING
LOSSES THRU FEEDER: 4. KW 172. KVAR 172. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1614
PROJECTED POWER FLOW: 8360. KW 7725. KVAR 11383. KVA PF: .73 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4028 %VD: 3.2
----- VOLTAGE ANGLE: -2.6 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 490 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2932. KW 1758. KVAR 3418. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 614 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1684. KW 3936. KVAR 4282. KVA PF: .39 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 373 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1149. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 225 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1614 VOLTAGE DROP: 42. %VD: 1.02
PROJECTED POWER FLOW: 8356. KW 7554. KVAR 11264. KVA PF: .74 LAGGING
LOSSES THRU FEEDER: 4. KW 172. KVAR 172. KVA

DATE:23 JUL 92 TIME:11 32 AM
T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 442 %VD: 7.9\$
----- VOLTAGE ANGLE: -8.3 DEGREES
PROJECTED SPECIAL BUS LOAD: 900. KW 490. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 1339 VOLTAGE DROP: 15. %VD: 3.03
PROJECTED POWER FLOW: 900. KW 490. KVAR 1025. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 15.3 KW 94.3 KVAR 95.5 KVA

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 444 %VD: 7.5\$
----- VOLTAGE ANGLE: -5.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 356. KW 288. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 596 VOLTAGE DROP: 3. %VD: .58
PROJECTED POWER FLOW: 356. KW 288. KVAR 458. KVA PF: .78 LAGGING
LOSSES THRU TRANSF: 3.1 KW 19.5 KVAR 19.7 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 452 %VD: 5.9\$
----- VOLTAGE ANGLE: -6.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1306 VOLTAGE DROP: 13. %VD: 2.73
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.6 KW 94.3 KVAR 95.4 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 462 %VD: 3.8
----- VOLTAGE ANGLE: -5.1 DEGREES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 770 VOLTAGE DROP: 3. %VD: .65
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.1 KW 32.8 KVAR 33.2 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
88. KW 1310. KVAR

WARNING STUDY CONTAINS 4 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 2 18 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 2 18 PM
 T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

| FEEDE NO | FROM NAME | FEEDE TO NAME | QTY /PH | VOLTS L-L | LENG TH | FEEDE R SIZE | DESCR PTION TYPE | DUCT | INSUL |
|--|--------------|---------------------|------------|--------------|------------|--------------------|------------------------|------|-------------|
| 1 | SYSTEM | 200 161KV APL | 1 | 161000. | 1000. | FT | | | |
| | IMPEDANCE: | 3.1131 + J19.4200 | | | | | | | OHMS/M FEET |
| 2001 | 2A1 | 2003 2A3 | 1 | 4160. | 1000. | FT | | | |
| | IMPEDANCE: | .0047 + J .1600 | | | | | | | OHMS/M FEET |
| 2001 | 2A1 | 2902 ST2-A | 1 | 4160. | 1000. | FT | | | |
| | IMPEDANCE: | .0000 + J .0000 | | | | | | | OHMS/M FEET |
| 2002 | 2A2 | 2004 2A4 | 1 | 4160. | 1000. | FT | | | |
| | IMPEDANCE: | .0047 + J .1600 | | | | | | | OHMS/M FEET |
| 2002 | 2A2 | 2902 ST2-A | 1 | 4160. | 1000. | FT | | | |
| | IMPEDANCE: | .0000 + J .0000 | | | | | | | OHMS/M FEET |
| 2006 | A1 | 2008 A3 | 1 | 4160. | 1000. | FT | | | |
| | IMPEDANCE: | .0000 + J .0000 | | | | | | | OHMS/M FEET |
| 2007 | A2 | 2009 A4 | 1 | 4160. | 1000. | FT | | | |
| | IMPEDANCE: | .0000 + J .0000 | | | | | | | OHMS/M FEET |
| 2901 | ST2-CLR | 2902 ST2-A | 1 | 4160. | 1000. | FT | | | |
| | IMPEDANCE: | .0005 + J .0220 | | | | | | | OHMS/M FEET |
| 2902 | ST2-A | 2006 A1 | 1 | 4160. | 1000. | FT | | | |
| | IMPEDANCE: | .0000 + J .0000 | | | | | | | OHMS/M FEET |
| 2902 | ST2-A | 2007 A2 | 1 | 4160. | 1000. | FT | | | |
| | IMPEDANCE: | .0000 + J .0000 | | | | | | | OHMS/M FEET |
| SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS Calculated From Largest 3-PHASE Fault Contribution | | | | | | | | | |

DATE:23 JUL 92 TIME: 2 18 PM
T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VCLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * NO NAME | SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|---------------------------|---------------------------|------------|--------------|-----------------------------|--------------|------------|----------------|
| 2003 2A3 | 4055. | 142. | 3005 2B5 | | 480. | 1203. | 1000.0 |
| IMPEDANCE: | 1.2315 + J 7.6110 PERCENT | | | | | | |
| 2004 2A4 | 4055. | 142. | 3006 2B6 | | 480. | 1203. | 1000.0 |
| IMPEDANCE: | 1.2438 + J 7.9432 PERCENT | | | | | | |
| 2008 A3 | 4055. | 142. | 3105 B5 | | 480. | 1203. | 1000.0 |
| IMPEDANCE: | 1.2396 + J 8.0046 PERCENT | | | | | | |
| 2009 A4 | 4055. | 142. | 3106 B6 | | 480. | 1203. | 1000.0 |
| IMPEDANCE: | 1.2532 + J 8.0126 PERCENT | | | | | | |

DATE:23 JUL 92 TIME: 2 18 PM
 T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | | NO | NAME | VOLTS L-L | * * | BRANCH DATA | % R | IMPEDANCE X | NOMINAL KVA |
|---------------------------|------|---------|------|-----------|--------|-------------|-----------|----------------|----------------|
| PRIMARY | 200 | 161KV | APL | 161000. | * | PRI-SEC | .2000 + J | 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | | 6900. | * | PRI-TER | .1900 + J | 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | | 4160. | * | SEC-TER | .3700 + J | 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | | | |

DATE:23 JUL 92 TIME: 2 18 PM
T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

B R A N C H L O A D D A T A

| FROM / TO | | BR. | CONSTANT KVA | | CONSTANT Z | | CONSTANT I | | FLOW |
|---------------|-----------|--------|--------------|-------|------------|-----|------------|-----|------|
| BUS | / BUS | TYPE | KVA | %PF | KVA | %PF | KVA | %PF | DIR. |
| 1 SYSTEM | | | | | | | | | |
| 200 | 161KV APL | FEEDER | 724 | -88.0 | | | | | |
| 2001 2A1 | | | | | | | | | |
| 2003 | 2A3 | FEEDER | 724 | -88.0 | | | | | |
| 2902 | ST2-A | FEEDER | 724 | -88.0 | | | | | REV |
| 2901 ST2-CLR | | | | | | | | | |
| 2902 | ST2-A | FEEDER | 724 | -88.0 | | | | | |
| 200 161KV APL | | | | | | | | | |
| 2901 | ST2-CLR | TRANS. | 724 | -88.0 | | | | | |

DATE:23 JUL 92 TIME: 2 18 PM
T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

```
=====
* NO * NAME * KW * KVAR * LOAD/GENERATION
=====
```

| | | | | |
|------|-----|-------|-------|-------------------|
| 2003 | 2A3 | 789. | 3586. | CONSTANT Z LOAD |
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 443. | 338. | CONSTANT KVA LOAD |
| 3006 | 2B6 | 850. | 463. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 2 18 PM
T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***

=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 3671.77 KVA | |
| CONVERGENCE CRITERIA: | .184 KVA | |
| LARGEST BUS MISMATCH | 2004 2A4 | 135.391 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 16.940 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 2.251 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .290 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .037 KVA |

DATE:23 JUL 92 TIME: 2 18 PM
T=10 SECONDS, ST #2 Unit 2 MSLF Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9

VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 41 VOLTAGE DROP: 1128. %VD: .70
PROJECTED POWER FLOW: 7952. KW 8012. KVAR 11288. KVA PF: .70 LAGGING
LOSSES THRU FEEDER: 16. KW 97. KVAR 98. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 41 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 7952. KW 8012. KVAR 11288. KVA PF: .70 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158455 %VD: 1.6

VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 41 VOLTAGE DROP: 1128. %VD: .70
PROJECTED POWER FLOW: 7936. KW 7914. KVAR 11208. KVA PF: .71 LAGGING
LOSSES THRU FEEDER: 16. KW 97. KVAR 98. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 41
PROJECTED POWER FLOW: 7936. KW 7915. KVAR 11208. KVA PF: .71 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4036 %VD: 3.0

VOLTAGE ANGLE: -2.5 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 627 VOLTAGE DROP: 161. %VD: 3.86
PROJECTED POWER FLOW: 1775. KW 4011. KVAR 4386. KVA PF: .40 LAGGING
LOSSES THRU FEEDER: 6. KW 189. KVAR 189. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 627 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1775. KW 4011. KVAR 4386. KVA PF: .40 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 2 18 PM
T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00

PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4036 %VD: 3.0
----- VOLTAGE ANGLE: -2.5 DEGREES

LOAD TO: 2004 2A4 FEEDER AMPS: 400 VOLTAGE DROP: 59. %VD: 1.41
PROJECTED POWER FLOW: 2400. KW 1438. KVAR 2798. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 2. KW 77. KVAR 77. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 400 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2400. KW 1438. KVAR 2798. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3875 %VD: 6.85
----- VOLTAGE ANGLE: -3.5 DEGREES

PROJECTED SPECIAL BUS LOAD: 685. KW 3112. KVAR

NET BRANCH DIVERSITY LOAD: 637. KW 344. KVAR

LOAD FROM: 2001 2A1 FEEDER AMPS: 627 VOLTAGE DROP: 161. %VD: 3.86
PROJECTED POWER FLOW: 1769. KW 3822. KVAR 4211. KVA PF: .42 LAGGING
LOSSES THRU FEEDER: 6. KW 189. KVAR 189. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 86 VOLTAGE DROP: 43. %VD: 1.03
PROJECTED POWER FLOW: 447. KW 366. KVAR 578. KVA PF: .77 LAGGING
LOSSES THRU TRANSF: 4.5 KW 27.8 KVAR 28.2 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3977 %VD: 4.4
----- VOLTAGE ANGLE: -3.8 DEGREES

PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR

LOAD FROM: 2002 2A2 FEEDER AMPS: 400 VOLTAGE DROP: 59. %VD: 1.41
PROJECTED POWER FLOW: 2397. KW 1361. KVAR 2757. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 2. KW 77. KVAR 77. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 149 VOLTAGE DROP: 119. %VD: 2.86
PROJECTED POWER FLOW: 864. KW 549. KVAR 1024. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 13.5 KW 86.5 KVAR 87.6 KVA

DATE: 23 JUL 92 TIME: 2 18 PM
T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4036 %VD: 3.0

VOLTAGE ANGLE: -2.5 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 372 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1149. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 372 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1149. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4036 %VD: 3.0

VOLTAGE ANGLE: -2.5 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 225 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 225 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4036 %VD: 3.0

VOLTAGE ANGLE: -2.5 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 372 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1149. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 154 VOLTAGE DROP: 113. %VD: 2.71
PROJECTED POWER FLOW: 936. KW 536. KVAR 1078. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.5 KW 93.9 KVAR 95.1 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4036 %VD: 3.0

VOLTAGE ANGLE: -2.5 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 225 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 2 18 PM
T=10 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 442 %VD: 7.9\$

VOLTAGE ANGLE: -5.4 DEGREES
PROJECTED SPECIAL BUS LOAD: 443. KW 338. KVAR
LOAD FROM: 20G3 2A3 TRANSF AMPS: 727 VOLTAGE DROP: 5. %VD: 1.03
PROJECTED POWER FLOW: 443. KW 338. KVAR 557. KVA PF: .80 LAGGING
LOSSES THRU TRANSF: 4.5 KW 27.8 KVAR 28.2 KVA

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 445 %VD: 7.3\$

VOLTAGE ANGLE: -7.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 850. KW 463. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1255 VOLTAGE DROP: 14. %VD: 2.86
PROJECTED POWER FLOW: 850. KW 463. KVAR 968. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 13.5 KW 86.5 KVAR 87.6 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 453 %VD: 5.7\$

VOLTAGE ANGLE: -6.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1303 VOLTAGE DROP: 13. %VD: 2.71
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.5 KW 93.9 KVAR 95.1 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 463 %VD: 3.6

VOLTAGE ANGLE: -4.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 769 VOLTAGE DROP: 3. %VD: .64
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.1 KW 32.7 KVAR 33.1 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
83. KW 1211. KVAR

WARNING STUDY CONTAINS 4 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 9 33 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 9 33 PM
 T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER DESCRIPTION SIZE TYPE DUCT INSUL |
|------------------------|----------------------|------------|--------------|----------|--|
| 1 SYSTEM | 200 161KV APL | 1 | 161000. | 1000. FT | |
| IMPEDANCE: | 3.1131 + J19.4200 | | OHMS/M | FEET | |
| 2001 2A1 | 2003 2A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J .1600 | | OHMS/M | FEET | |
| 2001 2A1 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2002 2A2 | 2004 2A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J .1600 | | OHMS/M | FEET | |
| 2002 2A2 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2006 A1 | 2008 A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2007 A2 | 2009 A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 29J1 ST2-CLR | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0005 + J .0220 | | OHMS/M | FEET | |
| 2902 ST2-A | 2006 A1 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2902 ST2-A | 2007 A2 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |

SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS
 Calculated From Largest 3-PHASE Fault Contribution

DATE:23 JUL 92 TIME: 9 33 PM
 T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * PERCENT | SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|---------------------------|---------------------|----------------|--------------|-----------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: | 4055. 1.2315 + J | 142. 7.6110 | PERCENT | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: | 4055. 1.2438 + J | 142. 7.9432 | PERCENT | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: | 4055. 1.2596 + J | 142. 8.0046 | PERCENT | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: | 4055. 1.2532 + J | 142. 8.0126 | PERCENT | 3106 B6 | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME: 9 33 PM
 T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * * | BRANCH DATA | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|-------------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE: 23 JUL 92 TIME: 9 5 PM
 T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

B R A N C H L O A D D A T A

| FROM BUS | TO BUS | BR. TYPE | CONSTANT KVA | KVA %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | %PF | FLOW DIR. |
|---------------|-----------|-------------|-----------------|------------|-------------------|-----|-------------------|-----|--------------|
| 1 SYSTEM | | | | | | | | | |
| 200 | 161KV APL | FEEDER | 724 | -88.0 | | | | | |
| 2002 2A2 | | | | | | | | | |
| 2004 | 2A4 | FEEDER | 724 | -88.0 | | | | | |
| 2902 | ST2-A | FEEDER | 724 | -88.0 | | | | | REV |
| 2901 ST2-CLR | | | | | | | | | |
| 2902 | ST2-A | FEEDER | 724 | -88.0 | | | | | |
| 200 161KV APL | | | | | | | | | |
| 2901 | ST2-CLR | TRANS. | 724 | -88.0 | | | | | |

DATE:23 JUL 92 TIME: 9 33 PM
T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

| * NO * | NAME | * KW | * KVAR | * LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2003 | 2A3 | 2012. | 1058. | CONSTANT KVA LOAD |
| 2004 | 2A4 | 1526. | 6569. | CONSTANT Z LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 900. | 490. | CONSTANT KVA LOAD |
| 3006 | 2B6 | 356. | 288. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 9 33 PM
T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TCF SIZE: 58

| | | |
|-----------------------|-------------|--------------|
| LARGEST LOAD: | 6743.92 KVA | |
| CONVERGENCE CRITERIA: | .337 KVA | |
| LARGEST BUS MISMATCH | 2003 2A3 | 25t .446 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 26.302 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 3.853 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .543 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .075 KVA |

DATE:23 JUL 92 TIME: 9 33 PM
T=15 SECONDS, ST #2 Unit 2 MSL Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA. BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9
----- VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 52 VOLTAGE DROP: 1520. %VD: .94
PROJECTED POWER FLOW: 8954. KW 11077. KVAR 14243. KVA PF: .63 LAGGING
LOSSES THRU FEEDER: 25. KW 155. KVAR 157. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 52 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 8954. KW 11077. KVAR 14243. KVA PF: .63 LAGGING
LOSSES THRU FEEDER: 0. KW . KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158063 %VD: 1.8
----- VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 52 VOLTAGE DROP: 1520. %VD: .94
PROJECTED POWER FLOW: 8930. KW 10922. KVAR 14108. KVA PF: .63 LAGGING
LOSSES THRU FEEDER: 25. KW 155. KVAR 157. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 52
PROJECTED POWER FLOW: 8930. KW 10922. KVAR 14108. KVA PF: .63 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3964 %VD: 4.7
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 499 VOLTAGE DROP: 73. %VD: 1.75
PROJECTED POWER FLOW: 2933. KW 1765. KVAR 3423. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 3. KW 119. KVAR 119. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 499 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2933. KW 1765. KVAR 3423. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 9 33 PM
T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3964 %VD: 4.7
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 977 VOLTAGE DROP: 257. %VD: 6.18\$
PROJECTED POWER FLOW: 2221. KW 6327. KVAR 6706. KVA PF: .33 LAGGING
LOSSES THRU FEEDER: 13. KW 458. KVAR 458. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 977 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2221. KW 6327. KVAR 6706. KVA PF: .33 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3891 %VD: 6.5\$
----- VOLTAGE ANGLE: -4.5 DEGREES
PROJECTED SPECIAL BUS LOAD: 2013. KW 1058. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 499 VOLTAGE DROP: 73. %VD: 1.75
PROJECTED POWER FLOW: 2929. KW 1546. KVAR 3360. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 3. KW 119. KVAR 119. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 161 VOLTAGE DROP: 132. %VD: 3.18
PROJECTED POWER FLOW: 916. KW 588. KVAR 1088. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 15.8 KW 97.9 KVAR 99.2 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3707 %VD: 10.9\$
----- VOLTAGE ANGLE: -4.1 DEGREES
PROJECTED SPECIAL BUS LOAD: 1212. KW 5216. KVAR
NET BRANCH DIVERSITY LOAD: 637. KW 344. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 977 VOLTAGE DROP: 257. %VD: 6.18\$
PROJECTED POWER FLOW: 2208. KW 5869. KVAR 6271. KVA PF: .35 LAGGING
LOSSES THRU FEEDER: 13. KW 458. KVAR 458. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 74 VOLTAGE DROP: 34. %VD: .83
PROJECTED POWER FLOW: 359. KW 309. KVAR 474. KVA PF: .76 LAGGING
LOSSES THRU TRANSF: 3.3 KW 21.4 KVAR 21.6 KVA

DATE:23 JUL 92 TIME: 9 33 PM
T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3964 %VD: 4.7
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 380 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1153. KVAR 2606. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 380 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1153. KVAR 2606. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3964 %VD: 4.7
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 229 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 711. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 229 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 711. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3964 %VD: 4.7
----- VOLTAGE ANGLE: -2.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 380 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1153. KVAR 2606. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 157 VOLTAGE DROP: 120. %VD: 2.88
PROJECTED POWER FLOW: 936. KW 540. KVAR 1081. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 15.1 KW 97.8 KVAR 99.0 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3964 %VD: 4.7
----- VOLTAGE ANGLE: -2.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 229 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 711. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 9 33 PM
T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .912

LOAD TO: 3106 B6 TRANSF AMPS: 93 VOLTAGE DROP: 31. %VD: .75
PROJECTED POWER FLOW: 552. KW 317. KVAR 637. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.3 KW 34.0 KVAR 34.4 KVA

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4021 %VD: 3.4
----- VOLTAGE ANGLE: -2.1 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1944 VOLTAGE DROP: 57. %VD: 1.36
PROJECTED POWER FLOW: 8900. KW 10205. KVAR 13541. KVA PF: .66 LAGGING
LOSSES THRU FEEDER: 5. KW 249. KVAR 250. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1944
PROJECTED POWER FLOW: 8900. KW 10205. KVAR 13541. KVA PF: .66 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3964 %VD: 4.7
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 499 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2933. KW 1765. KVAR 3423. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 977 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2222. KW 6327. KVAR 6706. KVA PF: .33 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 380 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1153. KVAR 2606. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 229 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1407. KW 711. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1944 VOLTAGE DROP: 57. %VD: 1.36
PROJECTED POWER FLOW: 8895. KW 9956. KVAR 13350. KVA PF: .67 LAGGING
LOSSES THRU FEEDER: 5. KW 249. KVAR 250. KVA

DATE:23 JUL 92 TIME: 9 33 PM
T=15 SECONDS ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3003 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 434 %VD: 9.6\$

VOLTAGE ANGLE: -8.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 900. KW 490. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 1364 VOLTAGE DROP: 15. %VD: 3.18
PROJECTED POWER FLOW: 900. KW 490. KVAR 1025. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 15.8 KW 97.9 KVAR 99.2 KVA

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 424 %VD: 11.7\$

VOLTAGE ANGLE: -5.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 356. KW 288. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 624 VOLTAGE DROP: 4. %VD: .83
PROJECTED POWER FLOW: 356. KW 288. KVAR 458. KVA PF: .78 LAGGING
LOSSES THRU TRANSF: 3.3 KW 21.4 KVAR 21.6 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 444 %VD: 7.6\$

VOLTAGE ANGLE: -7.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1330 VOLTAGE DROP: 14. %VD: 2.88
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 15.1 KW 97.8 KVAR 99.0 KVA

LOAD BUS: B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 454 %VD: 5.5\$

VOLTAGE ANGLE: -5.3 DEGREES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 784 VOLTAGE DROP: 4. %VD: .75
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.3 KW 34.0 KVAR 34.4 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
116. KW 1949. KVAR

WARNING STUDY CONTAINS 8 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
E.FERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 2 41 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DPOP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 2 41 PM
 T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENERGY OPERATIONS INC.

F E E D E R D A T A

=====

| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER DESCRIPTION SIZE TYPE DUCT INSUL |
|------------------------|----------------------|------------|--------------|--------|--|
|------------------------|----------------------|------------|--------------|--------|--|

=====

| | | | | | |
|--------------|---------------|---|---------|-------|-------------|
| 1 SYSTEM | 200 161KV APL | 1 | 161000. | 1000. | FT |
| IMPEDANCE: | 3.1131 + J | | 19.4200 | | OHMS/M FEET |
| 2001 2A1 | 2003 2A3 | 1 | 4160. | 1000. | FT |
| IMPEDANCE: | .0047 + J | | .1600 | | OHMS/M FEET |
| 2001 2A1 | 2902 ST2-A | 1 | 4160. | 1000. | FT |
| IMPEDANCE: | .0000 + J | | .0000 | | OHMS/M FEET |
| 2002 2A2 | 2004 2A4 | 1 | 4160. | 1000. | FT |
| IMPEDANCE: | .0047 + J | | .1600 | | OHMS/M FEET |
| 2002 2A2 | 2902 ST2-A | 1 | 4160. | 1000. | FT |
| IMPEDANCE: | .0000 + J | | .0000 | | OHMS/M FEET |
| 2006 A1 | 2008 A3 | 1 | 4160. | 1000. | FT |
| IMPEDANCE: | .0000 + J | | .0000 | | OHMS/M FEET |
| 2007 A2 | 2009 A4 | 1 | 4160. | 1000. | FT |
| IMPEDANCE: | .0000 + J | | .0000 | | OHMS/M FEET |
| 2901 ST2-CLR | 2902 ST2-A | 1 | 4160. | 1000. | FT |
| IMPEDANCE: | .0005 + J | | .0220 | | OHMS/M FEET |
| 2902 ST2-A | 2006 A1 | 1 | 4160. | 1000. | FT |
| IMPEDANCE: | .0000 + J | | .0000 | | OHMS/M FEET |
| 2902 ST2-A | 2007 A2 | 1 | 4160. | 1000. | FT |
| IMPEDANCE: | .0000 + J | | .0000 | | OHMS/M FEET |

=====

SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS
 Calculated From Largest 3-PHASE Fault Contribution

=====

DATE: 23 JUL 92 TIME: 2 41 PM
 T=15 SECONDS, ST #2 Unit 2 MSLR Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * PERCENT | SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|--|--------------|------------|--------------|-----------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: 1.055 + J 7.6110 | 4005. | 142. | PERCENT | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: 1.2438 + J 7.9432 | 4055. | 142. | PERCENT | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: 1.2396 + J 8.0046 | 4055. | 142. | PERCENT | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: 1.2532 + J 8.0126 | 4055. | 142. | PERCENT | 3106 B6 | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME: 2 41 PM
 T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * * | BRANCH DATA | % R | IMPEDANCE X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|-------------|-----------|----------------|----------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J | 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J | 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J | 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | | |

DATE:23 JUL 92 TIME: 2 41 PM
 T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

B R A N C H L O A D D A T A

| FROM BUS | / | TO BUS | BR. TYPE | CONSTANT KVA | KVA %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | %PF | FLOW DIR. |
|---------------|---|-----------|-------------|-----------------|------------|-------------------|-----|-------------------|-----|--------------|
| ===== | | | | | | | | | | |
| 1 SYSTEM | | | | | | | | | | |
| 200 | | 161KV APL | FEEDER | 724 | -88.0 | | | | | |
| 2001 2A1 | | | | | | | | | | |
| 2003 | | 2A3 | FEEDER | 724 | -88.0 | | | | | |
| 2902 | | ST2-A | FEEDER | 724 | -88.0 | | | | | REV |
| 2901 ST2-CLR | | | | | | | | | | |
| 2902 | | ST2-A | FEEDER | 724 | -88.0 | | | | | |
| 200 161KV APL | | | | | | | | | | |
| 2901 | | ST2-CLR | TRANS. | 724 | -88.0 | | | | | |
| ===== | | | | | | | | | | |

DATE:23 JUL 92 TIME: 2 41 PM
T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

| * NO * | NAME | * KW | * KVAR | LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2003 | 2A3 | 1566. | 6201. | CONSTANT Z LOAD |
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 443. | 338. | CONSTANT KVA LOAD |
| 3006 | 2B6 | 850. | 463. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 2 41 PM
T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9^o12, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 6395.68 KVA | |
| CONVERGENCE CRITERIA: | .320 KVA | |
| LARGEST BUS MISMATCH | 2004 2A4 | 177.151 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 21.544 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 2.990 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .400 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .043 KVA |

DATE:23 JUL 92 TIME: 2 41 PM
T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9
----- VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 49 VOLTAGE DROP: 1436. %VD: .89
PROJECTED POWER FLOW: 8551. KW 10448. KVAR 13501. KVA PF: .63 LAGGING
LOSSES THRU FEEDER: 22. KW 139. KVAR 141. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 49 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 8551. KW 10448. KVAR 13501. KVA PF: .63 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158147 %VD: 1.8
----- VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 49 VOLTAGE DROP: 1436. %VD: .89
PROJECTED POWER FLOW: 8529. KW 10309. KVAR 13380. KVA PF: .64 LAGGING
LOSSES THRU FEEDER: 22. KW 139. KVAR 141. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 49
PROJECTED POWER FLOW: 8529. KW 10309. KVAR 13380. KVA PF: .64 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3979 %VD: 4.4
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 954 VOLTAGE DROP: 248. %VD: 5.97\$
PROJECTED POWER FLOW: 2357. KW 6135. KVAR 6572. KVA PF: .36 LAGGING
LOSSES THRU FEEDER: 13. KW 437. KVAR 437. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 954 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2357. KW 6135. KVAR 6572. KVA PF: .36 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 2 41 PM
T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3979 %VD: 4.4
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 406 VOLTAGE DROP: 60. %VD: 1.44
PROJECTED POWER FLOW: 2400. KW 1444. KVAR 2801. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 2. KW 79. KVAR 79. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 406 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2400. KW 1444. KVAR 2801. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3730 %VD: 10.3\$
----- VOLTAGE ANGLE: -4.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 1259. KW 4986. KVAR
NET BRANCH DIVERSITY LOAD: 637. KW 344. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 954 VOLTAGE DROP: 248. %VD: 5.97\$
PROJECTED POWER FLOW: 2344. KW 5698. KVAR 6161. KVA PF: .38 LAGGING
LOSSES THRU FEEDER: 13. KW 437. KVAR 437. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 90 VOLTAGE DROP: 53. %VD: 1.27
PROJECTED POWER FLOW: 448. KW 368. KVAR 580. KVA PF: .77 LAGGING
LOSSES THRU TRANSF: 4.9 KW 30.2 KVAR 30.6 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3919 %VD: 5.8\$
----- VOLTAGE ANGLE: -4.1 DEGREES
PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 406 VOLTAGE DROP: 60. %VD: 1.44
PROJECTED POWER FLOW: 2398. KW 1364. KVAR 2759. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 2. KW 79. KVAR 79. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 151 VOLTAGE DROP: 124. %VD: 2.99
PROJECTED POWER FLOW: 864. KW 552. KVAR 1025. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 14.0 KW 89.4 KVAR 90.5 KVA

DATE:23 JUL 92 TIME: 2 41 PM
T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3979 %VD: 4.4
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 378 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1152. KVAR 2605. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2912 ST2-A FEEDER AMPS: 378 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1152. KVAR 2605. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3979 %VD: 4.4
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 228 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 711. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 228 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 711. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3979 %VD: 4.4
----- VOLTAGE ANGLE: -2.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 378 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1152. KVAR 2605. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 157 VOLTAGE DROP: 118. %VD: 2.84
PROJECTED POWER FLOW: 936. KW 539. KVAR 1080. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 15.0 KW 97.0 KVAR 98.2 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3979 %VD: 4.4
----- VOLTAGE ANGLE: -2.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 228 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 711. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 2 41 PM
T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD TO: 3106 B6 TRANSF AMPS: 92 VOLTAGE DROP: 30. %VD: .73
PROJECTED POWER FLOW: 552. KW 317. KVAR 637. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.3 KW 33.7 KVAR 34.1 KVA

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4032 %VD: 3.1
----- VOLTAGE ANGLE: -2.0 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1843 VOLTAGE DROP: 53. %VD: 1.29
PROJECTED POWER FLOW: 8502. KW 9665. KVAR 12873. KVA PF: .66 LAGGING
LOSSES THRU FEEDER: 5. KW 224. KVAR 224. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1843
PROJECTED POWER FLOW: 8502. KW 9665. KVAR 12873. KVA PF: .66 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3979 %VD: 4.4
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 954 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2357. KW 6135. KVAR 6572. KVA PF: .36 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 406 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2400. KW 1444. KVAR 2801. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 378 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1152. KVAR 2605. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 228 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 711. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1843 VOLTAGE DROP: 53. %VD: 1.29
PROJECTED POWER FLOW: 8497. KW 9441. KVAR 12702. KVA PF: .67 LAGGING
LOSSES THRU FEEDER: 5. KW 224. KVAR 224. KVA

DATE:23 JUL 92 TIME: 2 41 PM
T=15 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 424 %VD: 11.6\$

VOLTAGE ANGLE: -6.1 DEGREES
PROJECTED SPECIAL BUS LOAD: 443. KW 338. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 758 VOLTAGE DROP: 6. %VD: 1.27
PROJECTED POWER FLOW: 443. KW 338. KVAR 557. KVA PF: .80 LAGGING
LOSSES THRU TRANSF: 4.9 KW 30.2 KVAR 30.6 KVA

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 438 %VD: 8.8\$

VOLTAGE ANGLE: -8.1 DEGREES
PROJECTED SPECIAL BUS LOAD: 850. KW 463. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1276 VOLTAGE DROP: 14. %VD: 2.99
PROJECTED POWER FLOW: 850. KW 463. KVAR 968. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 14.0 KW 89.4 KVAR 90.5 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 445 %VD: 7.2\$

VOLTAGE ANGLE: -7.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1324 VOLTAGE DROP: 14. %VD: 2.84
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 15.0 KW 97.0 KVAR 98.2 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 456 %VD: 5.1\$

VOLTAGE ANGLE: -5.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 780 VOLTAGE DROP: 3. %VD: .73
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.3 KW 33.7 KVAR 34.1 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
108. KW 1773. KVAR

WARNING STUDY CONTAINS 8 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 11 40 AM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME:11 40 AM
 T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER DESCRIPTION SIZE TYPE DUCT INSUL |
|--|------------------------------------|------------|--------------|----------|--|
| 1 SYSTEM IMPEDANCE: | 200 161KV APL 3.1131 + J19.4200 | 1 | 161000. | 1000. FT | |
| 2001 2A1 IMPEDANCE: | 2003 2A3 .0047 + J | 1 | 4160. | 1000. FT | |
| 2001 2A1 IMPEDANCE: | 2902 ST2-A .0000 + J | 1 | 4160. | 1000. FT | |
| 2002 2A2 IMPEDANCE: | 2004 2A4 .0047 + J | 1 | 4160. | 1000. FT | |
| 2002 2A2 IMPEDANCE: | 2902 ST2-A .0000 + J | 1 | 4160. | 1000. FT | |
| 2006 A1 IMPEDANCE: | 2008 A3 .0000 + J | 1 | 4160. | 1000. FT | |
| 2007 A2 IMPEDANCE: | 2009 A4 .0000 + J | 1 | 4160. | 1000. FT | |
| 2901 ST2-CLR IMPEDANCE: | 2902 ST2-A .0005 + J | 1 | 4160. | 1000. FT | |
| 2902 ST2-A IMPEDANCE: | 2006 A1 .0000 + J | 1 | 4160. | 1000. FT | |
| 2902 ST2-A IMPEDANCE: | 2007 A2 .0000 + J | 1 | 4160. | 1000. FT | |
| ===== | | | | | |
| SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS | | | | | |
| Calculated From Largest 3-PHASE Fault Contribution | | | | | |
| ===== | | | | | |

DATE:23 JUL 92 TIME:11 40 AM
T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|--|--------------|------------|-------------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: 1.2315 + J 7.6110 PERCENT | 4055. | 142. | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: 1.2438 + J 7.9432 PERCENT | 4055. | 142. | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: 1.2396 + J 8.0046 PERCENT | 4055. | 142. | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: 1.2532 + J 8.0126 PERCENT | 4055. | 142. | 3106 B6 | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME:11 40 AM
 T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * * | BRANCH DATA | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|-------------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE:23 JUL 92 TIME:11 40 AM
 T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

B R A N C H L O A D D A A

| FROM BUS | / TO / BUS | BR. TYPE | CONSTANT KVA KVA | KVA %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | %PF | FLOW DIR. |
|---------------|---------------|-------------|---------------------|------------|-------------------|-----|-------------------|-----|--------------|
| ===== | | | | | | | | | |
| 1 SYSTEM | | | | | | | | | |
| 200 161KV APL | | FEEDER | 1585 | -86.1 | | | | | |
| 2002 2A2 | | | | | | | | | |
| 2004 2A4 | | FEEDER | 1585 | -86.1 | | | | | |
| 2902 ST2-A | | FEEDER | 1585 | -86.1 | | | | | REV |
| 2901 ST2-CLR | | | | | | | | | |
| 2902 ST2-A | | FEEDER | 1585 | -86.1 | | | | | |
| 200 161KV APL | | | | | | | | | |
| 2901 ST2-CLR | | TRANS. | 1585 | -86.1 | | | | | |
| 2004 2A4 | | | | | | | | | |
| 3006 2B6 | | TRANS. | 458 | -77.9 | | | | | |

DATE:23 JUL 92 TIME:11 40 AM
T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

```
=====
* NO * NAME * KW * KVAR * LOAD/GENERATION
=====
```

| | | | | |
|------|-----|-------|-------|-------------------|
| 2003 | 2A3 | 2013. | 1058. | CONSTANT KVA LOAD |
| 2004 | 2A4 | 737. | 2983. | CONSTANT Z LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 900. | 490. | CONSTANT KVA LOAD |
| 3006 | 2B6 | 212. | 1040. | CONSTANT Z LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME:11 40 AM
T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 3072.70 KVA | |
| CONVERGENCE CRITERIA: | .154 KVA | |
| LARGEST BUS MISMATCH | 2003 2A3 | 207.619 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 22.383 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 3.245 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .451 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .061 KVA |

DATE:23 JUL 92 TIME:11 40 AM
T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9
----- VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 46 VOLTAGE DROP: 1262. %VD: .78
PROJECTED POWER FLOW: 8891. KW 8964. KVAR 12626. KVA PF: .70 LAGGING
LOSSES THRU FEEDER: 19. KW 122. KVAR 123. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 46 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 8891. KW 8964. KVAR 12626. KVA PF: .70 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158321 %VD: 1.7
----- VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 46 VOLTAGE DROP: 1262. %VD: .78
PROJECTED POWER FLOW: 8872. KW 8842. KVAR 12526. KVA PF: .71 LAGGING
LOSSES THRU FEEDER: 19. KW 122. KVAR 123. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 46
PROJECTED POWER FLOW: 8872. KW 8843. KVAR 12526. KVA PF: .71 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4013 %VD: 3.5
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 492 VOLTAGE DROP: 72. %VD: 1.73
PROJECTED POWER FLOW: 2932. KW 1760. KVAR 3419. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 3. KW 116. KVAR 116. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 492 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2932. KW 1760. KVAR 3419. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME:11 40 AM
T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4013 %VD: 3.5

LOAD TO: 2004 2A4 FEEDER AMPS: 714 VOLTAGE ANGLE: -2.8 DEGREES
PROJECTED POWER FLOW: 2173. KW 4463. KVAR 4964. KVA PF: .44 LAGGING
LOSSES THRU FEEDER: 7. KW 245. KVAR 245. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 714 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2173. KW 4463. KVAR 4964. KVA PF: .44 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3941 %VD: 5.3\$

PROJECTED SPECIAL BUS LOAD: 2013. KW 1058. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 492 VOLTAGE ANGLE: -4.5 DEGREES
PROJECTED POWER FLOW: 2928. KW 1643. KVAR 3358. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 3. KW 116. KVAR 116. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 159 VOLTAGE DROP: 128. %VD: 3.07
PROJECTED POWER FLOW: 915. KW 585. KVAR 1087. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 15.4 KW 95.1 KVAR 96.3 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3834 %VD: 7.8\$

PROJECTED SPECIAL BUS LOAD: 626. KW 2533. KVAR
NET BRANCH DIVERSITY LOAD: 1009. KW 517. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 714 VOLTAGE ANGLE: -4.0 DEGREES
PROJECTED POWER FLOW: 2165. KW 4219. KVAR 4742. KVA PF: .46 LAGGING
LOSSES THRU FEEDER: 7. KW 245. KVAR 245. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 193 VOLTAGE DROP: 336. %VD: 8.07\$
PROJECTED POWER FLOW: 530. KW 1168. KVAR 1283. KVA PF: .41 LAGGING
LOSSES THRU TRANSF: 22.9 KW 146. KVAR 148.0 KVA

DATE:23 JUL 92 TIME:11 40 AM
T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4013 %VD: 3.5
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 375 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 375 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4013 %VD: 3.5
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 226 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 226 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4013 %VD: 3.5
----- VOLTAGE ANGLE: -2.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 375 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 155 VOLTAGE DROP: 115. %VD: 2.76
PROJECTED POWER FLOW: 936. KW 537. KVAR 1079. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.7 KW 95.1 KVAR 96.3 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4013 %VD: 3.5
----- VOLTAGE ANGLE: -2.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 226 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME:11 40 AM
T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD TO: 3106 B6 TRANSF AMPS: 92 VOLTAGE DROP: 28. %VD: .67
PROJECTED POWER FLOW: 552. KW 316. KVAR 636. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.2 KW 33.1 KVAR 33.5 KVA

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4059 %VD: 2.4
----- VOLTAGE ANGLE: -2.1 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1724 VOLTAGE DROP: 46. %VD: 1.10
PROJECTED POWER FLOW: 8849. KW 8279. KVAR 12118. KVA PF: .73 LAGGING
LOSSES THRU FEEDER: 4. KW 196. KVAR 196. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1724
PROJECTED POWER FLOW: 8849. KW 8279. KVAR 12118. KVA PF: .73 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4013 %VD: 3.5
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 492 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2932. KW 1760. KVAR 3419. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 714 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2173. KW 4463. KVAR 4964. KVA PF: .44 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 375 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 226 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1724 VOLTAGE DROP: 46. %VD: 1.10
PROJECTED POWER FLOW: 8844. KW 8083. KVAR 11982. KVA PF: .74 LAGGING
LOSSES THRU FEEDER: 4. KW 196. KVAR 196. KVA

DATE:23 JUL 92 TIME:11 40 AM
T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOADING REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 440 %VD: 8.3\$

VOLTAGE ANGLE: -8.5 DEGREES
PROJECTED SPECIAL BUS LOAD: 900. KW 470. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 1345 VOLTAGE DROP: 15. %VD: 3.07
PROJECTED POWER FLOW: 900. KW 490. KVAR 1025. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 15.4 KW 95.1 KVAR 96.3 KVA

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 404 %VD: 15.9\$

VOLTAGE ANGLE: -6.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 150. KW 735. KVAR
NET BRANCH DIVERSITY LOAD: 357. KW 287. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1632 VOLTAGE DROP: 39. %VD: 8.07\$
PROJECTED POWER FLOW: 507. KW 1022. KVAR 1141. KVA PF: .44 LAGGING
LOSSES THRU TRANSF: 22.9 KW 146.2 KVAR 148.0 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 450 %VD: 6.3\$

VOLTAGE ANGLE: -7.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1311 VOLTAGE DROP: 13. %VD: 2.76
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.7 KW 95.1 KVAR 96.3 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 460 %VD: 4.2

VOLTAGE ANGLE: -5.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 773 VOLTAGE DROP: 3. %VD: .67
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.2 KW 33.1 KVAR 33.5 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
116. KW 1611. KVAR

WARNING STUDY CONTAINS 9 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 3 18 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 3 18 PM
 T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

```

=====
FEEDER FROM      FEEDER TO      QTY VOLTS      LENGTH      FEEDER DESCRIPTION
NO NAME          NO NAME        /PH  L-L
=====
1 SYSTEM         200 161KV APL  1  161000.  1000. FT
  IMPEDANCE:     3.1131 + J19.4200 OHMS/M FEET

2001 2A1         2003 2A3       1    4160.  1000. FT
  IMPEDANCE:     .0047 + J .1600 OHMS/M FEET

2001 2A1         2902 ST2-A     1    4160.  1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET

2002 2A2         2004 2A4       1    4160.  1000. FT
  IMPEDANCE:     .0047 + J .1600 OHMS/M FEET

2002 2A2         2902 ST2-A     1    4160.  1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET

2006 A1          2008 A3        1    4160.  1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET

2007 A2          2009 A4        1    4160.  1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET

2901 ST2-CLR     2902 ST2-A     1    4160.  1000. FT
  IMPEDANCE:     .0005 + J .0220 OHMS/M FEET

2902 ST2-A       2006 A1        1    4160.  1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET

2902 ST2-A       2007 A2        1    4160.  1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET
  
```

```

=====
SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS
Calculated From Largest 3-PHASE Fault Contribution
=====
  
```

DATE:23 JUL 92 TIME: 3 18 PM
T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|---------------------------|---------------------|----------------|-------------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: | 4055. 1.2315 + J | 142. 7.6110 | 3005 2B5 PERCENT | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: | 4055. 1.2438 + J | 142. 7.9432 | 3006 2B6 PERCENT | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: | 4055. 1.2396 + J | 142. 8.0046 | 3105 B5 PERCENT | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: | 4055. 1.2532 + J | 142. 8.0126 | 3106 B6 PERCENT | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME: 3 18 PM
 T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * * | BRANCH DATA | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|-------------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE:23 JUL 92 TIME: 3 18 PM
 T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

B R A N C H L O A D D A T A

| FROM BUS | / TO BUS | BR. TYPE | CONSTANT KVA KVA | KVA %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | FLOW %PF DIR. |
|---------------|-------------|-------------|---------------------|------------|-------------------|-----|-------------------|------------------|
| 1 SYSTEM | | | | | | | | |
| 200 | 161KV APL | FEEDER | 1684 | -86.0 | | | | |
| 2001 2A1 | | | | | | | | |
| 2003 | 2A3 | FEEDER | 1684 | -86.0 | | | | |
| 2902 | ST2-A | FEEDER | 1684 | -85.0 | | | | REV |
| 2901 ST2-CLR | | | | | | | | |
| 2902 | ST2-A | FEEDER | 1684 | -86.0 | | | | |
| 200 161KV APL | | | | | | | | |
| 2901 | ST2-CLR | TRANS. | 1684 | -86.0 | | | | |
| 2003 2A3 | | | | | | | | |
| 3005 | 2B5 | TRANS. | 557 | -79.0 | | | | |

DATE:23 JUL 92 TIME: 3 18 PM
T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

| * NO * | NAME | * KW | * KVAR | LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2003 | 2A3 | 777. | 2615. | CONSTANT Z LOAD |
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 212. | 1040. | CONSTANT Z LOAD |
| 3006 | 2B6 | 850. | 463. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 3 18 PM
T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 2727.99 KVA | |
| CONVERGENCE CRITERIA: | .136 KVA | |
| LARGEST BUS MISMATCH | 3005 2B5 | 146.006 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 18.096 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 2.499 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .332 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .043 KVA |

DATE:23 JUL 92 TIME: 3 18 PM
T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9
----- VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 43 VOLTAGE DROP: 1176. %VD: .73
PROJECTED POWER FLOW: 8483. KW 8320. KVAR 11882. KVA PF: .71 LAGGING
LOSSES THRU FEEDER: 17. KW 108. KVAR 109. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 43 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 8483. KW 8320. KVAR 11882. KVA PF: .71 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158407 %VD: 1.6
----- VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 43 VOLTAGE DROP: 1176. %VD: .73
PROJECTED POWER FLOW: 8466. KW 8212. KVAR 11795. KVA PF: .72 LAGGING
LOSSES THRU FEEDER: 17. KW 108. KVAR 109. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 43
PROJECTED POWER FLOW: 8466. KW 8213. KVAR 11795. KVA PF: .72 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4360 LOAD VOLTAGE: 4028 %VD: 3.2
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 692 VOLTAGE DROP: 170. %VD: 4.09\$
PROJECTED POWER FLOW: 2302. KW 4242. KVAR 4826. KVA PF: .48 LAGGING
LOSSES THRU FEEDER: 7. KW 230. KVAR 230. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 692 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2302. KW 4242. KVAR 4826. KVA PF: .48 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 3 18 PM
 T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00

PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4028 %VD: 3.2
 ----- VOLTAGE ANGLE: -2.7 DEGREES

LOAD TO: 2004 2A4 FEEDER AMPS: 401 VOLTAGE DROP: 59. %VD: 1.41
 PROJECTED POWER FLOW: 2400. KW 1439. KVAR 2798. KVA PF: .86 LAGGING
 LOSSES THRU FEEDER: 2. KW 77. KVAR 77. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 401 VOLTAGE DROP: 0. %VD: .00
 PROJECTED POWER FLOW: 2400. KW 1439. KVAR 2798. KVA PF: .86 LAGGING
 LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3858 %VD: 7.35
 ----- VOLTAGE ANGLE: -4.0 DEGREES

PROJECTED SPECIAL BUS LOAD: 668. KW 2249. KVAR

NET BRANCH DIVERSITY LOAD: 1009. KW 517. KVAR

LOAD FROM: 2001 2A1 FEEDER AMPS: 692 VOLTAGE DROP: 170. %VD: 4.095
 PROJECTED POWER FLOW: 2295. KW 4012. KVAR 4622. KVA PF: .50 LAGGING
 LOSSES THRU FEEDER: 7. KW 230. KVAR 230. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 208 VOLTAGE DROP: 345. %VD: 8.305
 PROJECTED POWER FLOW: 618. KW 1246. KVAR 1390. KVA PF: .44 LAGGING
 LOSSES THRU TRANSF: 26.3 KW 162.5 KVAR 164.6 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3970 %VD: 4.6
 ----- VOLTAGE ANGLE: -4.0 DEGREES

PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR

LOAD FROM: 2002 2A2 FEEDER AMPS: 401 VOLTAGE DROP: 59. %VD: 1.41
 PROJECTED POWER FLOW: 2398. KW 1362. KVAR 2757. KVA PF: .87 LAGGING
 LOSSES THRU FEEDER: 2. KW 77. KVAR 77. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 149 VOLTAGE DROP: 119. %VD: 2.87
 PROJECTED POWER FLOW: 864. KW 550. KVAR 1024. KVA PF: .84 LAGGING
 LOSSES THRU TRANSF: 13.6 KW 86.9 KVAR 87.9 KVA

DATE:23 JUL 92 TIME: 3 18 PM
T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4028 %VD: 3.2
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 373 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1149. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 373 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1149. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4028 %VD: 3.2
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 225 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 225 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4028 %VD: 3.2
----- VOLTAGE ANGLE: -2.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 373 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1149. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 155 VOLTAGE DROP: 114. %VD: 2.73
PROJECTED POWER FLOW: 936. KW 536. KVAR 1078. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.6 KW 94.3 KVAR 95.4 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4028 %VD: 3.2
----- VOLTAGE ANGLE: -2.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 225 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE: 23 JUL 92 TIME: 3 18 PM
T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD TO: 3106 B6 TRANSF AMPS: 91 VOLTAGE DROP: 27. %VD: .65
PROJECTED POWER FLOW: 552. KW 316. KVAR 636. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.1 KW 32.8 KVAR 33.2 KVA

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4071 %VD: 2.1
----- VOLTAGE ANGLE: -2.0 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1622 VOLTAGE DROP: 42. %VD: 1.02
PROJECTED POWER FLOW: 8445. KW 7714. KVAR 11438. KVA PF: .74 LAGGING
LOSSES THRU FEEDER: 4. KW 174. KVAR 174. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1622
PROJECTED POWER FLOW: 8445. KW 7714. KVAR 11438. KVA PF: .74 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4029 %VD: 3.2
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 692 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2302. KW 4242. KVAR 4826. KVA PF: .48 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 401 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2400. KW 1439. KVAR 2798. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 373 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1149. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 225 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1622 VOLTAGE DROP: 42. %VD: 1.02
PROJECTED POWER FLOW: 8441. KW 7540. KVAR 11319. KVA PF: .75 LAGGING
LOSSES THRU FEEDER: 4. KW 174. KVAR 174. KVA

DATE:23 JUL 92 TIME: 3 18 PM
T=18.2 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00

PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 405 %VD: 15.5\$

VOLTAGE ANGLE: -6.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 151. KW 742. KVAR
NET BRANCH DIVERSITY LOAD: 440. KW 342. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 1758 VOLTAGE DROP: 40. %VD: 8.30\$
PROJECTED POWER FLOW: 591. KW 1083. KVAR 1234. KVA PF: .48 LAGGING
LOSSES THRU TRANSF: 26.3 KW 162.5 KVAR 164.6 KVA

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 444 %VD: 7.4\$

VOLTAGE ANGLE: -7.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 850. KW 463. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1258 VOLTAGE DROP: 14. %VD: 2.87
PROJECTED POWER FLOW: 850. KW 463. KVAR 968. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 13.6 KW 86.9 KVAR 87.9 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 452 %VD: 5.9\$

VOLTAGE ANGLE: -6.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1306 VOLTAGE DROP: 13. %VD: 2.73
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.6 KW 94.3 KVAR 95.4 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 462 %VD: 3.8

VOLTAGE ANGLE: -5.1 DEGREES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 770 VOLTAGE DROP: 3. %VD: .65
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.1 KW 32.8 KVAR 33.2 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
110. KW 1463. KVAR

WARNING STUDY CONTAINS 8 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 3 31 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1993

DATE:23 JUL 92 TIME: 3 31 PM
 T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER DESCRIPTION SIZE TYPE DUCT INSUL |
|--|----------------------|------------|--------------|----------|--|
| 1 SYSTEM | 200 161KV APL | 1 | 161000. | 1000. FT | |
| IMPEDANCE: | 3.1131 + J19.4200 | | | | OHMS/M FEET |
| 2001 2A1 | 2003 2A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J | .1600 | | | OHMS/M FEET |
| 2001 2A1 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | | OHMS/M FEET |
| 2002 2A2 | 2004 2A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J | .1600 | | | OHMS/M FEET |
| 2002 2A2 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | | OHMS/M FEET |
| 2006 A1 | 2008 A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | | OHMS/M FEET |
| 2007 A2 | 2009 A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | | OHMS/M FEET |
| 2901 ST2-CLR | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0005 + J | .0220 | | | OHMS/M FEET |
| 2902 ST2-A | 2006 A1 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | | OHMS/M FEET |
| 2902 ST2-A | 2007 A2 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | | OHMS/M FEET |
| ===== | | | | | |
| SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS | | | | | |
| Calculated From Largest 3-PHASE Fault Contribution | | | | | |
| ===== | | | | | |

DATE:23 JUL 92 TIME: 3 31 PM
T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|--|--------------|------------|-------------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: 1.2315 + J 7.6110 PERCENT | 4055. | 142. | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: 1.2438 + J 7.9432 PERCENT | 4055. | 142. | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: 1.2396 + J 8.0046 PERCENT | 4055. | 142. | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: 1.2532 + J 8.0126 PERCENT | 4055. | 142. | 3106 B6 | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME: 3 31 PM
T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-J | * * | BRANCH DATA | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|-------------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE:23 JUL 92 TIME: 3 31 PM
 T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

B R A N C H L O A D D A T A

| FROM BUS | / TO BUS | BR. TYPE | CONSTANT KVA | KVA %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | %PF | FLOW DIR. |
|---------------|-------------|-------------|-----------------|------------|-------------------|-----|-------------------|-----|--------------|
| ===== | | | | | | | | | |
| 1 SYSTEM | | | | | | | | | |
| 200 161KV APL | | FEEDER | 1814 | -85.7 | | | | | |
| 2002 2A2 | | | | | | | | | |
| 2004 2A4 | | FEEDER | 1814 | -85.7 | | | | | |
| 2902 ST2-A | | FEEDER | 1814 | -85.7 | | | | | REV |
| 2901 ST2-CLR | | | | | | | | | |
| 2902 ST2-A | | FEEDER | 1814 | -85.7 | | | | | |
| 200 161KV APL | | | | | | | | | |
| 2901 ST2-CLR | | TRANS. | 1814 | -85.7 | | | | | |
| 2004 2A4 | | | | | | | | | |
| 3006 2B6 | | TRANS. | 458 | -77.9 | | | | | |

DATE:23 JUL 92 TIME: 3 31 PM
T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

| * NO * | NAME | * KW | * KVAR | * LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2003 | 2A3 | 2013. | 1058. | CONSTANT KVA LOAD |
| 2004 | 2A4 | 673. | 2721. | CONSTANT Z LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 900. | 490. | CONSTANT KVA LOAD |
| 3006 | 2B6 | 220. | 1075. | CONSTANT Z LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 3 31 PM
T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

< PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES >>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 2802.99 KVA | |
| CONVERGENCE CRITERIA: | .140 KVA | |
| LARGEST BUS MISMATCH | 2003 2A3 | 205.907 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 22.427 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 3.275 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .458 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .063 KVA |

DATE:23 JUL 92 TIME: 3 31 PM
T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9
----- VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 46 VOLTAGE DROP: 1258. %VD: .78
PROJECTED POWER FLOW: 9034. KW 8913. KVAR 12691. KVA PF: .71 LAGGING
LOSSES THRU FEEDER: 20. KW 123. KVAR 124. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 46 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 9034. KW 8913. KVAR 12691. KVA PF: .71 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158325 %VD: 1.7
----- VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 46 VOLTAGE DROP: 1258. %VD: .78
PROJECTED POWER FLOW: 9014. KW 8790. KVAR 12591. KVA PF: .72 LAGGING
LOSSES THRU FEEDER: 20. KW 123. KVAR 124. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 46
PROJECTED POWER FLOW: 9014. KW 8791. KVAR 12591. KVA PF: .72 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4015 %VD: 3.5
----- VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 492 VOLTAGE DROP: 72. %VD: 1.73
PROJECTED POWER FLOW: 2932. KW 1759. KVAR 3419. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 3. KW 116. KVAR 116. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 492 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2932. KW 1759. KVAR 3419. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 3 31 PM
T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4015 %VD: 3.5
----- VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 716 VOLTAGE DROP: 177. %VD: 4.26\$
PROJECTED POWER FLOW: 2314. KW 4404. KVAR 4975. KVA PF: .47 LAGGING
LOSSES THRU FEEDER: 7. KW 246. KVAR 246. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 716 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2314. KW 4404. KVAR 4975. KVA PF: .47 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3943 %VD: 5.2\$
----- VOLTAGE ANGLE: -4.5 DEGREES
PROJECTED SPECIAL BUS LOAD: 2013. KW 1058. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 492 VOLTAGE DROP: 72. %VD: 1.73
PROJECTED POWER FLOW: 2929. KW 1643. KVAR 3358. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 3. KW 116. KVAR 116. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 159 VOLTAGE DROP: 127. %VD: 3.06
PROJECTED POWER FLOW: 915. KW 585. KVAR 1086. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 15.4 KW 95.0 KVAR 96.2 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3837 %VD: 7.8\$
----- VOLTAGE ANGLE: -4.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 573. KW 2315. KVAR
NET BRANCH DIVERSITY LOAD: 1199. KW 647. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 716 VOLTAGE DROP: 177. %VD: 4.26\$
PROJECTED POWER FLOW: 2307. KW 4159. KVAR 4756. KVA PF: .49 LAGGING
LOSSES THRU FEEDER: 7. KW 246. KVAR 246. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 197 VOLTAGE DROP: 346. %VD: 8.31\$
PROJECTED POWER FLOW: 536. KW 1196. KVAR 1311. KVA PF: .41 LAGGING
LOSSES THRU TRANSF: 23.9 KW 152.5 KVAR 154.3 KVA

DATE:23 JUL 92 TIME: 3 31 PM
T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4015 %VD: 3.5
----- VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 375 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 375 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4015 %VD: 3.5
----- VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 226 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 226 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4015 %VD: 3.5
----- VOLTAGE ANGLE: -2.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 375 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 155 VOLTAGE DROP: 115. %VD: 2.76
PROJECTED POWER FLOW: 936. KW 537. KVAR 1079. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.7 KW 95.1 KVAR 96.2 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4015 %VD: 3.5
----- VOLTAGE ANGLE: -2.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 226 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE: 23 JUL 92 TIME: 3 31 PM
T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD TO: 3106 B6 TRANSF AMPS: 92 VOLTAGE DROP: 28. %VD: .67
PROJECTED POWER FLOW: 552. KW 316. KVAR 636. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.2 KW 33.1 KVAR 33.5 KVA

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4060 %VD: 2.4
----- VOLTAGE ANGLE: -2.2 DEGREES

LOAD TO: 2902 ST2-A FEEDER AMPS: 1733 VOLTAGE DROP: 45. %VD: 1.09
PROJECTED POWER FLOW: 8991. KW 8222. KVAR 12183. KVA PF: .74 LAGGING
LOSSES THRU FEEDER: 4. KW 198. KVAR 198. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1733
PROJECTED POWER FLOW: 8991. KW 8222. KVAR 12183. KVA PF: .74 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4015 %VD: 3.5
----- VOLTAGE ANGLE: -2.9 DEGREES

LOAD TO: 2001 2A1 FEEDER AMPS: 492 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2932. KW 1759. KVAR 3419. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 716 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2314. KW 4404. KVAR 4975. KVA PF: .47 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 375 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 226 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1733 VOLTAGE DROP: 45. %VD: 1.09
PROJECTED POWER FLOW: 8986. KW 8023. KVAR 12047. KVA PF: .75 LAGGING
LOSSES THRU FEEDER: 4. KW 198. KVAR 198. KVA

DATE:23 JUL 92 TIME: 3 31 PM
T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 440 %VD: 8.35

VOLTAGE ANGLE: -8.5 DEGREES
PROJECTED SPECIAL BUS LOAD: 900. KW 490. KVAR
LOAD FROM: 2003 2/3 TRANSF AMPS: 1344 VOLTAGE DROP: 15. %VD: 3.06
PROJECTED POWER FLOW: 900. KW 490. KVAR 1025. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 15.4 KW 95.0 KVAR 96.2 KVA

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 403 %VD: 16.15

VOLTAGE ANGLE: -6.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 155. KW 757. KVAR
NET BRANCH DIVERSITY LOAD: 357. KW 287. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1666 VOLTAGE DROP: 40. %VD: 8.315
PROJECTED POWER FLOW: 512. KW 1044. KVAR 1163. KVA PF: .44 LAGGING
LOSSES THRU TRANSF: 23.9 KW 152.5 KVAR 154.3 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 450 %VD: 6.35

VOLTAGE ANGLE: -7.1 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1311 VOLTAGE DROP: 13. %VD: 2.76
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.7 KW 95.1 KVAR 96.2 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 460 %VD: 4.2

VOLTAGE ANGLE: -5.3 DEGRFES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 773 VOLTAGE DROP: 3. %VD: .67
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.2 KW 33.1 KVAR 33.5 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
117. KW 1627. KVAR

WARNING STUDY CONTAINS 9 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 10 13 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME:10 13 PM
 T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER DESCRIPTION SIZE TYPE DUCT INSUL |
|--|----------------------|------------|--------------|----------|--|
| 1 SYSTEM | 200 161. V APL | 1 | 161000. | 1000. FT | |
| IMPEDANCE: | 3.1131 + J19.4200 | | | | OHMS/M FEET |
| 2001 2A1 | 2003 2A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J | .1600 | | | OHMS/M FEET |
| 2001 2A1 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | | OHMS/M FEET |
| 2002 2A2 | 2004 2A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J | .1600 | | | OHMS/M FEET |
| 2002 2A2 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | | OHMS/M FEET |
| 2006 A1 | 2008 A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | | OHMS/M FEET |
| 2007 A2 | 2009 A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | | OHMS/M FEET |
| 2901 ST2-CLR | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0005 + J | .0220 | | | OHMS/M FEET |
| 2902 ST2-A | 2006 A1 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | | OHMS/M FEET |
| 2902 ST2-A | 2007 A2 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | | OHMS/M FEET |
| ===== | | | | | |
| SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS | | | | | |
| Calculated From Largest 3-PHASE Fault Contribution | | | | | |
| ===== | | | | | |

DATE:23 JUL 92 TIME:10 13 PM
 T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * NO NAME | SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|--|--------------|------------|--------------|-----------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: 1.2315 + J 7.6110 PERCENT | 4055. | 142. | | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: 1.2438 + J 7.9432 PERCENT | 4055. | 142. | | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: 1.2396 + J 8.0046 PERCENT | 4055. | 142. | | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: 1.2532 + J 8.0126 PERCENT | 4055. | 142. | | 3106 B6 | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME:10 13 PM
 T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * * | BRANCH DATA | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|-------------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE:23 JUL 92 TIME:10 13 PM
 T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

B R A N C H L O A D D A T A

```

=====
FROM / TO BR. CONSTANT KVA CONSTANT Z CONSTANT I FLOW
BUS / BUS TYPE KVA %PF KVA %PF KVA %PF DIR.
=====
1 SYSTEM
  200 161KV APL FEEDER 1914 -85.6
2001 2A1
  2003 2A3 FEEDER 1914 -85.6
  2902 ST2-A FEEDER 1914 -85.6 REV
2901 ST2-CLR
  2902 ST2-A FEEDER 1914 -65.6
  200 161KV APL
  2901 ST2-CLR TRANS. 1914 -85.6
2003 2A3
  3005 2B5 TRANS. 557 -79.0
  
```

DATE:23 JUL 92 TIME:10 13 PM
T=22.7 SECONDS, ST #? Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9917, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIO'S INC.

B U S S P E C I A L S T U D Y D A T A

```
=====
* NO * NAME * KW * KVAR * LOAD/GENERATION
=====
```

| | | | | |
|------|-----|-------|-------|-------------------|
| 2003 | 2A3 | 673. | 3721. | CO**STANT Z LOAD |
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 720. | 1075. | CONSTANT Z LOAD |
| 3006 | 2B6 | 850. | 463. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME:10 13 PM
T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 2802.99 KVA | |
| CONVERGENCE CRITERIA: | .140 KVA | |
| LARGEST BUS MISMATCH | 2003 2A3 | 186.793 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 18.804 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 2.634 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .354 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .047 KVA |

DATE:23 JUL 92 TIME:10 13 PM
T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLCW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9
----- VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 44 VOLTAGE DROP: 1212. %VD: .75
PROJECTED POWER FLOW: 8586. KW 8605. KVAR 12156. KVA PF: .71 LAGGING
LOSSES THRU FEEDER: 18. KW 113. KVAR 114. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 44 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 8586. KW 8605. KVAR 12156. KVA PF: .71 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158371 %VD: 1.6
----- VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 44 VOLTAGE DROP: 1212. %VD: .75
PROJECTED POWER FLOW: 8568. KW 8493. KVAR 12064. KVA PF: .71 LAGGING
LOSSES THRU FEEDER: 18. KW 113. KVAR 114. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3WXPFR AMPS: 44
PROJECTED POWER FLOW: 8568. KW 8493. KVAR 12064. KVA PF: .71 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4022 %VD: 3.3
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2003 1A3 FEEDER AMPS: 731 VOLTAGE DROP: 180. %VD: 4.345
PROJECTED POWER FLOW: 2403. KW 4490. KVAR 5092. KVA PF: .47 LAGGING
LOSSES THRU FEEDER: 7. KW 257. KVAR 257. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 731 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2403. KW 4490. KVAR 5092. KVA PF: .47 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME:10 13 PM
T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DRO1 AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4022 %VD: 3.3
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 402 VOLTAGE DROP: 59. %VD: 1.42
PROJECTED POWER FLOW: 2400. KW 1440. KVAR 2799. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 2. KW 77. KVAR 78. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 402 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2400. KW 1440. KVAR 2799. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3841 %VD: 7.75
----- VOLTAGE ANGLE: -4.1 DEGREES
PROJECTED SPECIAL BUS LOAD: 574. KW 2320. KVAR
NET BRANCH DIVERSITY LOAD: 1199. KW 647. KVAR

LOAD FROM: 2001 2A1 FEEDER AMPS: 731 VOLTAGE DROP: 180. %VD: 4.345
PROJECTED POWER FLOW: 2395. KW 4233. KVAR 4864. KVA PF: .49 LAGGING
LOSSES THRU FEEDER: 7. KW 257. KVAR 257. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 212 VOLTAGE DROP: 354. %VD: 8.525
PROJECTED POWER FLOW: 622. KW 1265. KVAR 1410. KVA PF: .44 LAGGING
LOSSES THRU TRANSF: 27.3 KW 168.6 KVAR 170.8 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3963 %VD: 4.7
----- VOLTAGE ANGLE: -4.1 DEGREES

PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 402 VOLTAGE DROP: 59. %VD: 1.42
PROJECTED POWER FLOW: 2398. KW 1362. KVAR 2758. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 2. KW 77. KVAR 78. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 149 VOLTAGE DROP: 120. %VD: 2.89
PROJECTED POWER FLOW: 864. KW 550. KVAR 1024. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 13.7 KW 87.2 KVAR 88.3 KVA

DATE:23 JUL 92 TIME:10 13 PM
T=22.7 SECONDS, ST #2 Unit 2 MSLR Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4022 %VD: 3.3
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 374 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 374 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4022 %VD: 3.3
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 226 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 226 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4022 %VD: 3.3
----- VOLTAGE ANGLE: -2.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 374 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 155 VOLTAGE DROP: 114. %VD: 2.74
PROJECTED POWER FLOW: 936. KW 537. KVAR 1079. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.7 KW 94.7 KVAR 95.8 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4022 %VD: 3.3
----- VOLTAGE ANGLE: -2.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 226 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME:10 13 PM
T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD TO: 3106 B6 TRANSF AMPS: 91 VOLTAGE DROP: 27. %VD: .66
PROJECTED POWER FLOW: 552. KW 316. KVAR 636. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.2 KW 33.0 KVAR 33.4 KVA

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4066 %VD: 2.3
----- VOLTAGE ANGLE: -2.1 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1660 VOLTAGE DROP: 44. %VD: 1.05
PROJECTED POWER FLOW: 8546. KW 7971. KVAR 11686. KVA PF: .73 LAGGING
LOSSES THRU FEEDER: 4. KW 182. KVAR 182. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1660
PROJECTED POWER FLOW: 8546. KW 7971. KVAR 11686. KVA PF: .73 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4022 %VD: 3.3
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 731 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2403. KW 4490. KVAR 5092. KVA PF: .47 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 402 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2400. KW 1440. KVAR 2799. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 ... FEEDER AMPS: 374 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1150. KVAR 2604. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 226 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1660 VOLTAGE DROP: 44. %VD: 1.05
PROJECTED POWER FLOW: 8542. KW 7789. KVAR 11560. KVA PF: .74 LAGGING
LOSSES THRU FEEDER: 4. KW 182. KVAR 182. KVA

DATE:23 JUL 92 TIME:10 13 PM
T=22.7 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 402 %VD: 16.2\$
----- VOLTAGE ANGLE: -6.3 DEGREES
PROJECTED SPECIAL BUS LOAD: 155. KW 755. KVAR
NET BRANCH DIVERSITY LOAD: 440. KW 342. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 1790 VOLTAGE DROP: 41. %VD: 8.52\$
PROJECTED POWER FLOW: 595. KW 1097. KVAR 1248. KVA PF: .48 LAGGING
LOSSES THRU TRANSF: 27.3 KW 168.6 KVAR 170.8 KVA

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 443 %VD: 7.6\$
----- VOLTAGE ANGLE: -8.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 850. KW 463. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1260 VOLTAGE DROP: 14. %VD: 2.89
PROJECTED POWER FLOW: 850. KW 463. KVAR 968. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 13.7 KW 87.2 KVAR 88.3 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 451 %VD: 6.1\$
----- VOLTAGE ANGLE: -6.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1308 VOLTAGE DROP: 13. %VD: 2.74
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.7 KW 94.7 KVAR 95.8 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 461 %VD: 4.0
----- VOLTAGE ANGLE: -5.1 DEGREES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 771 VOLTAGE DROP: 3. %VD: .66
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.2 KW 33.0 KVAR 33.4 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
114. KW 1534. KVAR

WARNING STUDY CONTAINS 8 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

DATE: 23 JUL 9
TIME: 3 48 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAIPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 3 48 PM
 T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

=====

| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER SIZE TYPE | DESCRIPTION DUCT INSUL |
|------------------------|----------------------|------------|--------------|--------|---------------------|---------------------------|
|------------------------|----------------------|------------|--------------|--------|---------------------|---------------------------|

=====

| | | | | | | |
|--------------|-------------------|-------|---------|-------------|--|--|
| 1 SYSTEM | 200 161KV APL | 1 | 161000. | 1000. FT | | |
| IMPEDANCE: | 3.1131 + J19.4200 | | | OHMS/M FEET | | |
| 2001 2A1 | 2003 2A3 | 1 | 4160. | 1000. FT | | |
| IMPEDANCE: | .0047 + J | .1600 | | OHMS/M FEET | | |
| 2001 2A1 | 2902 ST2-A | 1 | 4160. | 1000. FT | | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | | |
| 2002 2A2 | 2004 2A4 | 1 | 4160. | 1000. FT | | |
| IMPEDANCE: | .0047 + J | .1600 | | OHMS/M FEET | | |
| 2002 2A2 | 2902 ST2-A | 1 | 4160. | 1000. FT | | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | | |
| 2006 A1 | 2008 A3 | 1 | 4160. | 1000. FT | | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | | |
| 2007 A2 | 2009 A4 | 1 | 4160. | 1000. FT | | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | | |
| 2901 ST2-CLR | 2902 ST2-A | 1 | 4160. | 1000. FT | | |
| IMPEDANCE: | .0005 + J | .0220 | | OHMS/M FEET | | |
| 2902 ST2-A | 2006 A1 | 1 | 4160. | 1000. FT | | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | | |
| 2902 ST2-A | 2007 A2 | 1 | 4160. | 1000. FT | | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | | |

=====

SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS
 Calculated From Largest 3-PHASE Fault Contribution

=====

DATE:23 JUL 92 TIME: 3 48 PM
T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

TRANSFORMER DATA

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|--|--------------|------------|-------------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: 1.2315 + J 7.6110 PERCENT | 4055. | 142. | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: 1.2438 + J 7.9432 PERCENT | 4055. | 142. | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: 1.2396 + J 8.0046 PERCENT | 4055. | 142. | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: 1.2532 + J 8.0126 PERCENT | 4055. | 142. | 3106 B6 | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME: 3 48 PM
T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * * | BRANCH DATA | % IMPEDANCE R X | NOMINAL KVA |
|-----------|------|-----------|-----------|--------|-------------|------------------|-------------|
| PRIMARY | 200 | 161KV AFL | 161000. | * | PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SLCONDARY | 1200 | H BUCES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |

PRIMARY FIXED TAP: -2.5 %

DATE:23 JUL 92 TIME: 3 48 PM
 T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

BRANCH LOAD DATA

| FROM BUS | / | TO BUS | BR. TYPE | CONSTANT KVA | KVA | %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | %PF | FLOW DIR. |
|---------------|---|-----------|-------------|-----------------|-----|-------|-------------------|-----|-------------------|-----|--------------|
| ===== | | | | | | | | | | | |
| 1 SYSTEM | | | | | | | | | | | |
| 200 | | 161KV APL | FEEDER | 494 | | -80.0 | | | | | |
| 2002 2A2 | | | | | | | | | | | |
| 2004 | | 2A4 | FEEDER | 494 | | -80.0 | | | | | |
| 2902 | | ST2-A | FEEDER | 494 | | -80.0 | | | | | REV |
| 2901 ST2-CLR | | | | | | | | | | | |
| 2902 | | ST2-A | FEEDER | 494 | | -80.0 | | | | | |
| 200 161KV APL | | | | | | | | | | | |
| 2901 | | ST2-CLR | TRANS. | 494 | | -80.0 | | | | | |
| 2004 2A4 | | | | | | | | | | | |
| 3006 | | 2B6 | TRANS. | 494 | | -80.0 | | | | | |

DATE:23 JUL 92 TIME: 3 48 PM
 T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

```
=====
* NO * NAME * KW * KVAR * LOAD/GENERATION
=====
2003 2A3 2013. 1058. CONSTANT KVA LOAD
2004 2A4 1534. 72. CONSTANT KVA LOAD
2008 A3 1401. 613. CONSTANT KVA LOAD
2009 A4 851. 394. CONSTANT KVA LOAD
3005 2B5 900. 490. CONSTANT KVA LOAD
3006 2B6 149. 728. CONSTANT Z LOAD

3105 B5 921. 442. CONSTANT KVA LOAD
3106 B6 547. 283. CONSTANT KVA LOAD
=====
```

DATE:23 JUL 92 TIME: 3 48 PM
T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | | |
|-----------------------|---------|-----|-------------|
| LARGEST LOAD: | 2274.45 | KVA | |
| CONVERGENCE CRITERIA: | .114 | KVA | |
| LARGEST BUS MISMATCH | 2003 | 2A3 | 143.615 KVA |
| LARGEST BUS MISMATCH | 3005 | 2B5 | 16.490 KVA |
| LARGEST BUS MISMATCH | 3005 | 2B5 | 2.297 KVA |
| LARGEST BUS MISMATCH | 3005 | 2B5 | .311 KVA |
| LARGEST BUS MISMATCH | 3005 | 2B3 | .041 KVA |

DATE:23 JUL 92 TIME: 3 48 PM
T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BAIANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9
----- VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 39 VOLTAGE DROP: 913. %VD: .57
PROJECTED POWER FLOW: 8773. KW 6118. KVAR 10696. KVA PF: .82 LAGGING
LOSSES THRU FEEDER: 14. KW 87. KVAR 88. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 39 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 8773. KW 6118. KVAR 10696. KVA PF: .82 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158670 %VD: 1.4
----- VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 39 VOLTAGE DROP: 913. %VD: .57
PROJECTED POWER FLOW: 8759. KW 6030. KVAR 10635. KVA PF: .82 LAGGJ'
LOSSES THRU FEEDER: 14. KW 87. KVAR 88. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 39
PROJECTED POWER FLOW: 8759. KW 6031. KVAR 10635. KVA PF: .82 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4080 %VD: 1.9
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 483 VOLTAGE DROP: 70. %VD: 1.69
PROJECTED POWER FLOW: 2931. KW 1752. KVAR 3415. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 3. KW 112. KVAR 112. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 483 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2931. KW 1752. KVAR 3415. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 3 48 PM
T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4080 %VD: 1.9
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 395 VOLTAGE DROP: 75. %VD: 1.81
PROJECTED POWER FLOW: 2069. KW 1878. KVAR 2795. KVA PF: .74 LAGGING
LOSSES THRU FEEDER: 2. KW 75. KVAR 75. KVA

LOAD FROM: 2002 ST2-A FEEDER AMPS: 395 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2069. KW 1878. KVAR 2795. KVA PF: .74 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4010 %VD: 3.6
----- VOLTAGE ANGLE: -4.4 DEGREES
PROJECTED SPECIAL BUS LOAD: 2013. KW 1058. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 483 VOLTAGE DROP: 70. %VD: 1.69
PROJECTED POWER FLOW: 2928. KW 1639. KVAR 3356. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 3. KW 112. KVAR 112. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 156 VOLTAGE DROP: 121. %VD: 2.91
PROJECTED POWER FLOW: 915. KW 581. KVAR 1084. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 14.8 KW 91.5 KVAR 92.6 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4005 %VD: 3.7
----- VOLTAGE ANGLE: -3.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 395 VOLTAGE DROP: 75. %VD: 1.81
PROJECTED POWER FLOW: 2067. KW 1803. KVAR 2743. KVA PF: .75 LAGGING
LOSSES THRU FEEDER: 2. KW 75. KVAR 75. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 162 VOLTAGE DROP: 254. %VD: 6.10\$
PROJECTED POWER FLOW: 532. KW 991. KVAR 1125. KVA PF: .47 LAGGING
LOSSES THRU TRANSF: 16.1 KW 103.1 KVAR 104.4 KVA

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4080 %VD: 1.9
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 3 48 PM
T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD FROM: 2902 ST2-A FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4080 %VD: 1.9
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4080 %VD: 1.9
----- VOLTAGE ANGLE: -2.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 152 VOLTAGE DROP: 109. %VD: 2.62
PROJECTED POWER FLOW: 935. KW 534. KVAR 1077. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.2 KW 91.7 KVAR 92.8 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4080 %VD: 1.9
----- VOLTAGE ANGLE: -2.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3106 B6 TRANSF AMPS: 90 VOLTAGE DROP: 24. %VD: .57
PROJECTED POWER FLOW: 552. KW 315. KVAR 636. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.0 KW 32.0 KVAR 32.4 KVA

DATE: 23 JUL 92 TIME: 3 48 PM
 T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

 VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
 VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
 PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4111 %VD: 1.2

 VOLTAGE ANGLE: -2.1 DEGREES
 LOAD TO: 2902 ST2-A FEEDER AMPS: 1460 VOLTAGE DROP: 31. %VD: .74
 PROJECTED POWER FLOW: 8743. KW 5626. KVAR 10397. KVA PF: .84 LAGGING
 LOSSES THRU FEEDER: 3. KW 141. KVAR 141. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1460
 PROJECTED POWER FLOW: 8743. KW 5626. KVAR 10397. KVA PF: .84 LAGGING
 XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4080 %VD: 1.9

 VOLTAGE ANGLE: -2.8 DEGREES
 LOAD TO: 2001 2A1 FEEDER AMPS: 483 VOLTAGE DROP: 0. %VD: .00
 PROJECTED POWER FLOW: 2931. KW 1752. KVAR 3415. KVA PF: .86 LAGGING
 LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 395 VOLTAGE DROP: 0. %VD: .00
 PROJECTED POWER FLOW: 2069. KW 1878. KVAR 2795. KVA PF: .74 LAGGING
 LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
 PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2602. KVA PF: .90 LAGGING
 LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
 PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
 LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1460 VOLTAGE DROP: 31. %VD: .74
 PROJECTED POWER FLOW: 8740. KW 5486. KVAR 10319. KVA PF: .85 LAGGING
 LOSSES THRU FEEDER: 3. KW 141. KVAR 141. KVA

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 449 %VD: 6.55

 VOLTAGE ANGLE: -8.3 DEGREES
 PROJECTED SPECIAL BUS LOAD: 0.00 KW 490. KVAR
 LOAD FROM: 2003 2A3 TRANSF AMPS: 13.9 VOLTAGE DROP: 14. %VD: 2.91
 PROJECTED POWER FLOW: 900. KW 490. KVAR 1025. KVA PF: .88 LAGGING
 LOSSES THRU TRANSF: 14.8 KW 91.5 KVAR 92.6 KVA

DATE:23 JUL 92 TIME: 3 48 PM
T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 433 %VD: 9.8\$
----- VOLTAGE ANGLE: -5.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 121. KW 592. KVAR
NET BRANCH DIVERSITY LOAD: 395. KW 276. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1371 VOLTAGE DROP: 29. %VD: 6.10\$
PROJECTED POWER FLOW: 516. KW 888. KVAR 1027. KVA PF: .50 LAGGING
LOSSES THRU TRANSF: 16.1 KW 103.1 KVAR 104.4 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 458 %VD: 4.5
----- VOLTAGE ANGLE: -6.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1287 VOLTAGE DROP: 13. %VD: 2.62
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.2 KW 91.7 KVAR 92.8 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 468 %VD: 2.5
----- VOLTAGE ANGLE: -5.1 DEGREES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 760 VOLTAGE DROP: 3. %VD: .57
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.0 KW 32.0 KVAR 32.4 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
89. KW 1137. KVAR

WARNING STUDY CONTAINS 4 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 4 5 -M

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 4 5 -M
 T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLTM=3.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIICNS INC.

F E E D E R D A T A

```

=====
FEEDER FROM      FEEDER TO      QTY  VOLTS  LENGTH  FEEDER DESCRIPTION
NO NAME          NO NAME        /PH   L-L      FEEDER DESCRIPTION
=====
1 SYSTEM          200 161KV APL  1  161000. 1000. FT
IMPEDANCE:       3.1131 + J19.4200 OHMS/M FEET

2001 2A1          2003 2A3       1   4160.  1000. FT
IMPEDANCE:       .0047 + J .1600 OHMS/M FEET

2001 2A1          2902 ST2-A     1   4160.  1000. FT
IMPEDANCE:       .0000 + J .0000 OHMS/M FEET

2002 2A2          20J4 2A4       1   4160.  1000. FT
IMPEDANCE:       .0047 + J .1600 OHMS/M FEET

2002 2A2          2902 ST2-A     1   4160.  1000. FT
IMPEDANCE:       .0000 + J .0000 OHMS/M FEET

2006 A1           2008 A3        1   4160.  1000. FT
IMPEDANCE:       .0000 + J .0000 OHMS/M FEET

2007 A2           2009 A4        1   4160.  1000. FT
IMPEDANCE:       .0000 + J .0000 OHMS/M FEET

2901 ST2-CLR      2902 ST2-A     1   4160.  1000. FT
IMPEDANCE:       .0005 + J .0220 OHMS/M FEET

2902 ST2-A        2006 A1        1   4160.  1000. FT
IMPEDANCE:       .0000 + J .0000 OHMS/M FEET

2902 ST2-A        2007 A2        1   4160.  1000. FT
IMPEDANCE:       .0000 + J .0000 OHMS/M FEET
=====

```

```

=====
SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS
Calculated From Largest 3-PHASE Fault Contribution
=====

```

DATE: 23 JUL 92 TIME: 4 5 -M
 T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

TRANSFORMER DATA

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * PERCENT | SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|--|--------------|------------|--------------|-----------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: 1.2315 + J 7.6110 | 4055. | 142. | PERCENT | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: 1.2438 + J 7.9432 | 4055. | 142. | PERCENT | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: 1.2396 + J 8.0046 | 4055. | 142. | PERCENT | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: 1.2532 + J 8.0126 | 4055. | 142. | PERCENT | 3106 B6 | 480. | 1203. | 1000.0 |

DATE: 23 JUL 92 TIME: 4 5 -M
 T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * DATA | BRANCH | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|---------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE:23 JUL 92 TIME: 4 5 -M
 T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

B R A N C H L O A D D A T A

| FROM BUS | / TO BUS | BR. TYPE | CONSTANT KVA KVA | CONSTANT Z %PF | CONSTANT I KVA | CONSTANT I %PF | FLOW DIR. |
|---------------|-------------|-------------|---------------------|-------------------|-------------------|-------------------|--------------|
| ===== | | | | | | | |
| 1 SYSTEM | | | | | | | |
| 200 161KV APL | | FEEDER | 593 | -81.0 | | | |
| 2001 2A1 | | | | | | | |
| 2003 2A3 | | FEEDER | 593 | -81.0 | | | |
| 2902 ST2-A | | FEEDER | 593 | -81.0 | | | REV |
| 2901 ST2-CLR | | | | | | | |
| 2902 ST2-A | | FEEDER | 593 | -81.0 | | | |
| 200 161KV APL | | | | | | | |
| 2901 ST2-CLR | | TRANS. | 593 | -81.0 | | | |
| 2003 2A3 | | | | | | | |
| 3005 2B5 | | TRANS. | 593 | -81.0 | | | |

DATE: 23 JUL 92 TIME: 4 5 -M
T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

BUS SPECIAL STUDY DATA

| * NO * | NAME | * KW | * KVAR | * LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2003 | 2A3 | 1535. | 813. | CONSTANT FVA LOAD |
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 149. | 728. | CONSTANT Z LOAD |
| 3006 | 2B6 | 850. | 463. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 4 5 -M
T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 1737.01 KVA | |
| CONVERGENCE CRITERIA: | .087 KVA | |
| LARGEST BUS MISMATCH | 2003 2A3 | 111.430 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 13.492 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 1.804 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .234 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .030 KVA |

DATE:23 JUL 92 TIME: 4 5 -M
T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9

VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 37 VOLTAGE DROP: 867. %VD: .54
PROJECTED POWER FLOW: 8326. KW 5807. KVAR 10151. KVA PF: .82 LAGGING
LOSSES THRU FEEDER: 13. KW 79. KVAR 80. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 37 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 8326. KW 5807. KVAR 10151. KVA PF: .82 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158716 %VD: 1.4

VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 37 VOLTAGE DROP: 867. %VD: .54
PROJECTED POWER FLOW: 8314. KW 5728. KVAR 10096. KVA PF: .82 LAGGING
LOSSES THRU FEEDER: 13. KW 79. KVAR 80. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 37
PROJECTED POWER FLOW: 8314. KW 5729. KVAR 10096. KVA PF: .82 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4087 %VD: 1.7

VOLTAGE ANGLE: -2.6 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 411 VOLTAGE DROP: 78. %VD: 1.87
PROJECTED POWER FLOW: 2157. KW 1949. KVAR 2907. KVA PF: .74 LAGGING
LOSSES THRU FEEDER: 2. KW 81. KVAR 81. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 411 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2157. KW 1949. KVAR 2907. KVA PF: .74 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE: 23 JUL 92 TIME: 4 5 -M
T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4087 %VD: 1.7

VOLTAGE ANGLE: -2.6 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 395 VOLTAGE DROP: 58. %VD: 1.39
PROJECTED POWER FLOW: 2399. KW 1434. KVAR 2795. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 2. KW 75. KVAR 75. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 395 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2399. KW 1434. KVAR 2795. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4009 %VD: 3.6

VOLTAGE ANGLE: -3.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 1535. KW 813. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 411 VOLTAGE DROP: 78. %VD: 1.87
PROJECTED POWER FLOW: 2155. KW 1868. KVAR 2852. KVA PF: .76 LAGGING
LOSSES THRU FEEDER: 2. KW 81. KVAR 81. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 176 VOLTAGE DROP: 263. %VD: 6.335
PROJECTED POWER FLOW: 620. KW 1055. KVAR 1223. KVA PF: .51 LAGGING
LOSSES THRU TRANSF: 18.9 KW 116.5 KVAR 116.0 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4030 %VD: 3.1

VOLTAGE ANGLE: -3.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 395 VOLTAGE DROP: 58. %VD: 1.39
PROJECTED POWER FLOW: 2397. KW 1359. KVAR 2756. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 2. KW 75. KVAR 75. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 146 VOLTAGE DROP: 114. %VD: 2.74
PROJECTED POWER FLOW: 863. KW 547. KVAR 1022. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 13.2 KW 84.0 KVAR 85.0 KVA

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4087 %VD: 1.7

VOLTAGE ANGLE: -2.6 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE: 23 JUL 92 TIME: 4 5 -M
T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD FROM: 2902 ST2-A FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4087 %VD: 1.7
----- VOLTAGE ANGLE: -2.6 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4087 %VD: 1.7
----- VOLTAGE ANGLE: -2.6 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 513. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 152 VOLTAGE DROP: 108. %VD: 2.60
PROJECTED POWER FLOW: 935. KW 533. KVAR 1076. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.1 KW 91.3 KVAR 92.4 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4087 %VD: 1.7
----- VOLTAGE ANGLE: -2.6 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3106 B6 TRANSF AMPS: 90 VOLTAGE DROP: 23. %VD: .56
PROJECTED POWER FLOW: 552. KW 315. KVAR 635. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.0 KW 31.8 KVAR 32.2 KVA

DATE:23 JUL 92 TIME: 4 5 -M
T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4117 %VD: 1.0

VOLTAGE ANGLE: -2.0 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1386 VOLTAGE DROP: 29. %VD: .71
PROJECTED POWER FLOW: 8299. KW 5364. KVAR 9881. KVA PF: .84 LAGGING
LOSSES THRU FEEDER: 3. KW 127. KVAR 127. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1386
PROJECTED POWER FLOW: 8299. KW 5364. KVAR 9881. KVA PF .84 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4087 %VD: 1.7

VOLTAGE ANGLE: -2.6 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 411 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2157. KW 1949. KVAR 2907. KVA PF: .74 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 395 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2399. KW 1434. KVAR 2795. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1386 VOLTAGE DROP: 29. %VD: .71
PROJECTED POWER FLOW: 8296. KW 5238. KVAR 9811. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 3. KW 127. KVAR 127. KVA

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 432 %VD: 9.9\$

VOLTAGE ANGLE: -6.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 121. KW 590. KVAR
NET BRANCH DIVERSITY LOAD: 480. KW 348. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 1488 VOLTAGE DROP: 30. %VD: 6.33\$
PROJECTED POWER FLOW: 601. KW 938. KVAR 1114. KVA PF: .54 LAGGING
LOSSES THRU TRANSF: 18.9 KW 116.5 KVAR 118.0 KVA

DATE:23 JUL 92 TIME: 4 5 -M
T=50 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DRCP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00

PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 452 %VD: 5.95

PROJECTED SPECIAL BUS LOAD: 850 KW 463. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1237 VOLTAGE DROP: 13. %VD: 2.74
PROJECTED POWER FLOW: 850. KW 463. KVAR 968. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 13.2 KW 84.0 KVAR 85.0 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 459 %VD: 4.3

PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1285 VOLTAGE DROP: 12. %VD: 2.60
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.1 KW 91.3 KVAR 92.4 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 469 %VD: 2.3

PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 758 VOLTAGE DROP: 3. %VD: .56
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.0 KW 31.8 KVAR 32.2 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
86. KW 1049. KVAR

WARNING STUDY CONTAINS 4 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 4 10 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE: 23 JUL 92 TIME: 4 10 PM
 T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER DESCRIPTION SIZE TYPE DUCT INSUL |
|--|----------------------|------------|--------------|-------------|--|
| 1 SYSTEM | 200 161KV APL | 1 | 161000. | 1000. FT | |
| IMPEDANCE: | 3.1131 + J19.4200 | | | OHMS/M FEET | |
| 2001 2A1 | 2003 2A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J | .1600 | | OHMS/M FEET | |
| 2001 2A1 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | |
| 2002 2A2 | 2004 2A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J | .1600 | | OHMS/M FEET | |
| 2002 2A2 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | |
| 2006 A1 | 2008 A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | |
| 2007 | 2009 A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | |
| 2901 ST2-CLR | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0005 + J | .0220 | | OHMS/M FEET | |
| 2902 ST2-A | 2006 A1 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | |
| 2902 ST2-A | 2007 A2 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | |
| ===== | | | | | |
| SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS | | | | | |
| Calculated From Largest 3-PHASE Fault Contribution | | | | | |
| ===== | | | | | |

DATE:23 JUL 92 TIME: 4 10 PM
 T-60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|--|--------------|------------|-------------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: 1.2315 + J 7.6110 PERCENT | 4055. | 142. | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: 1.2438 + J 7.9432 PERCENT | 4055. | 142. | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: 1.2396 + J 8.0046 PERCENT | 4055. | 142. | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: 1.2532 + J 8.0126 PERCENT | 4055. | 142. | 3106 B6 | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME: 4 10 PM
T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * * | BRANCH DATA | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|-------------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE:23 JUL 92 TIME: 4 10 PM
 T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

B R A N C H L O A D D A T A

| FROM BUS | / TO BUS | BR. TYPE | CONSTANT KVA | KVA %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | %PF | FLOW DIR. |
|---------------|-------------|-------------|-----------------|------------|-------------------|-----|-------------------|-----|--------------|
| 1 SYSTEM | | | | | | | | | |
| 200 | 161KV APL | FEEDER | 494 | -80.0 | | | | | |
| 2002 2A2 | | | | | | | | | |
| 2004 | 2A4 | FEEDER | 494 | -80.0 | | | | | |
| 2902 | ST2-A | FEEDER | 494 | -80.0 | | | | | REV |
| 2901 ST2-CLR | | | | | | | | | |
| 2902 | ST2-A | FEEDER | 494 | -80.0 | | | | | |
| 200 161KV APL | | | | | | | | | |
| 2901 | ST2-CLR | TRANS. | 494 | -80.0 | | | | | |
| 2004 2A4 | | | | | | | | | |
| 3006 | 2B6 | TRANS. | 494 | -80.0 | | | | | |

LATE:23 JUL 92 TIME: 4 10 PM
T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BUS SPECIAL STUDY DATA

| * NO * | NAME | * KW | * KVAR | * LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2003 | 2A3 | 2013. | 1058. | CONSTANT KVA LOAD |
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 900. | 490. | CONSTANT KVA LOAD |
| 3006 | 2B6 | 297. | 1456. | CONSTANT Z LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 4 10 PM
T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELLED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOP SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 2274.45 KVA | |
| CONVERGENCE CRITERIA: | .114 KVA | |
| LARGEST BUS MISMATCH | 2003 2A3 | 157.704 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 18.146 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 2.600 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .359 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .048 KVA |

DATE:23 JUL 92 TIME: 4 10 PM
T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9
----- VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 40 VOLTAGE DROP: 997. %VD: .62
PROJECTED POWER FLOW: 8888. KW 6788. KVAR 11184. KVA PF: .79 LAGGING
LOSSES THRU FEEDER: 15. KW 95. KVAR 97. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 40 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 8888. KW 6788. KVAR 11184. KVA PF: .79 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158586 %VD: 1.5
----- VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 40 VOLTAGE DROP: 997. %VD: .62
PROJECTED POWER FLOW: 8873. KW 6693. KVAR 11114. KVA PF: .80 LAGGING
LOSSES THRU FEEDER: 15. KW 95. KVAR 97. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 40
PROJECTED POWER FLOW: 8873. KW 6693. KVAR 11115. KVA PF: .80 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4064 %VD: 2.3
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 485 VOLTAGE DROP: 71. %VD: 1.70
PROJECTED POWER FLOW: 2932. KW 1753. KVAR 3416. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 3. KW 113. KVAR 113. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 485 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2932. KW 1753. KVAR 3416. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 4 10 PM
 T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00

PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A7 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4054 %VD: 2.3
 ----- VOLTAGE ANGLE: -2.8 DEGREES

LOAD TO: 2004 2A4 FEEDER AMPS: 470 VOLTAGE DROP: 100. %VD: 2.39
 PROJECTED POWER FLOW: 2181. KW 2487. KVAR 3302. KVA PF: .66 LAGGING
 LOSSES THRU FEEDER: 3. KW 106. KVAR 106. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 470 VOLTAGE DROP: 0. %VD: .00
 PROJECTED POWER FLOW: 2181. KW 2437. KVAR 3308. KVA PF: .66 LAGGING
 LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3993 %VD: 4.0
 ----- VOLTAGE ANGLE: -4.4 DEGREES

PROJECTED SPECIAL BUS LOAD: 2013. KW 1058. KVAR
 LOAD FROM: 2001 2A1 FEEDER AMPS: 485 VOLTAGE DROP: 71. %VD: 1.70
 PROJECTED POWER FLOW: 2928. KW 1640. KVAR 3356. KVA PF: .87 LAGGING
 LOSSES THRU FEEDER: 3. KW 113. KVAR 113. KVA

LOAD TO: 3005 235 TRANSF AMPS: 157 VOLTAGE DROP: 122. %VD: 2.94
 PRCTJCTED POWER FLOW: 915. KW 582. KVAR 1084. KVA PF: .84 LAGGING
 LOSSES THRU TRANSF: 14.9 KW 92.3 KVAR 93.5 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3965 %VD: 4.7
 ----- VOLTAGE ANGLE: -4.0 DEGREES

PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR
 LOAD FROM: 2002 2A2 FEEDER AMPS: 470 VOLTAGE DROP: 100. %VD: 2.39
 PROJECTED POWER FLOW: 2178. KW 2381. KVAR 3227. KVA PF: .67 LAGGING
 LOSSES THRU FEEDER: 3. KW 106. KVAR 103. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 247 VOLTAGE DROP: 459. %VD: 11.04\$
 PROJECTED POWER FLOW: 644. KW 1569. KVAR 1696. KVA PF: .38 LAGGING
 LOSSES THRU TRANSF: 37.4 KW 239.1 KVAR 242.0 KVA

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4064 %VD: 2.3
 ----- VOLTAGE ANGLE: -2.8 DEGREES

LOAD TO: 2008 A3 FEEDER AMPS: 370 VOLTAGE DROP: 0. %VD: .00
 PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2603. KVA PF: .90 LAGGING
 LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 4 10 PM
T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD FROM: 2902 ST2-A FEEDER AMPS: 370 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2603. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4064 %VD: 2.3
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4064 %VD: 2.3
----- VOLTAGE ANGLE: -2.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 370 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2603. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 P5 TRANSF AMPS: 153 VOLTAGE DROP: 110. %VD: 2.65
PROJECTED POWER FLOW: 935. KW 534. KVAR 1077. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.3 KW 92.5 KVAR 93.6 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4064 %VD: 2.3
----- VOLTAGE ANGLE: -2.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3106 B6 TRANSF AMPS: 90 VOLTAGE DROP: 25. %VD: .60
PROJECTED POWER FLOW: 552. KW 315. KVAR 636. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.0 KW 32.2 KVAR 32.6 KVA

DATE:23 JUL 92 TIME: 4 10 PM
T=60 SECONDS, ST #2 Unit 2 MSLE Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00

PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4099 %VD: 1.5

LOAD TO: 2902 ST2-A FEEDER AMPS: 1527 VOLTAGE ANGLE: -2.1 DEGREES
PROJECTED POWER FLOW: 8855. KW 6251. KVAR 10839. KVA PF: .82 %VD: .82
LOSSES THRU FEEDER: 3. KW 154. KVAR 154. KVA LAGGING

LOAD FROM: 200 161KV AFL AND: 1200 H BUSES 3W XFMR AMPS: 1527
PROJECTED POWER FLOW: 8855. KW 6251. KVAR 10839. KVA PF: .82 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4064 %VD: 2.3

LOAD TO: 2001 2A1 FEEDER AMPS: 485 VOLTAGE ANGLE: -2.8 DEGREES
PROJECTED POWER FLOW: 2932. KW 1753. KVAR 3416. KVA PF: .86 %VD: .00
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA LAGGING

LOAD TO: 2002 2A2 FEEDER AMPS: 470 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2181. KW 2487. KVAR 3308. KVA PF: .66 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 370 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2603. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1527 VOLTAGE DROP: 34. %VD: .82
PROJECTED POWER FLOW: 8852. KW 6097. KVAR 10748. KVA PF: .82 LAGGING
LOSSES THRU FEEDER: 3. KW 154. KVAR 154. KVA

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 447 %VD: 6.9\$

PROJECTED SPECIAL BUS LOAD: 900. KW 490. KVAR
LOAD FROM: 200 2A3 TRANSF AMPS: 1324 VOLTAGE ANGLE: -8.3 DEGREES
PROJECTED POWER FLOW: 900. KW 490. KVAR 1025. KVA PF: .88 %VD: 2.94
LOSSES THRU TRANSF: 14.9 KW 92.3 KVAR 93.5 KVA LAGGING

DATE:23 JUL 92 TIME: 4 10 PM
T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 404 %VD: 15.7\$

PROJECTED SPECIAL BUS LOAD: 211. KW 1034. KVAR
NET BRANCH DIVERSITY LOAD: 395. KW 296. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 2087 VOLTAGE DROP: 53. %VD:11.04\$
PROJECTED POWER FLOW: 606. KW 1330. KVAR 1462. KVA PF: .41 LAGGING
LOSSES THRU TRANSF: 37.4 KW 239.1 KVAR 242.0 KVA

LOAD BUS. 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 456 %VD: 5.0

PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1293 VOLTAGE DROP: 13. %VD: 2.65
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.3 KW 92.5 KVAR 93.6 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 466 %VD: 2.9

PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 763 VOLTAGE DROP: 3. %VD: .60
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.0 KW 32.2 KVAR 32.6 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
115. KW 1366. KVAR

WARNING STUDY CONTAINS 4 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 10 38 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME:10 38 PM
 T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER DESCRIPTION SIZE TYPE DUCT INSUL |
|--|------------------------------------|------------|--------------|----------|--|
| 1 SYSTEM IMPEDANCE: | 200 161KV APL 3.1131 + J19.4200 | 1 | 161000. | 1000. FT | OHMS/M FEET |
| 2001 2A1 IMPEDANCE: | 2003 2A3 .0047 + J | 1 | 4160. | 1000. FT | .1600 OHMS/M FEET |
| 2001 2A1 IMPEDANCE: | 2902 ST2-A .0000 + J | 1 | 4160. | 1000. FT | .0000 OHMS/M FEET |
| 2002 2A2 IMPEDANCE: | 2004 2A4 .0047 + J | 1 | 4160. | 1000. FT | .1600 OHMS/M FEET |
| 2002 2A2 IMPEDANCE: | 2902 ST2-A .0000 + J | 1 | 4160. | 1000. FT | .0000 OHMS/M FEET |
| 2006 A1 IMPEDANCE: | 2008 A3 .0000 + J | 1 | 4160. | 1000. FT | .0000 OHMS/M FEET |
| 2007 A2 IMPEDANCE: | 2009 A4 .0000 + J | 1 | 4160. | 1000. FT | .0000 OHMS/M FEET |
| 2901 ST2-CLR IMPEDANCE: | 2902 ST2-A .0005 + J | 1 | 4160. | 1000. FT | .0220 OHMS/M FEET |
| 2902 ST2-A IMPEDANCE: | 2006 A1 .0000 + J | 1 | 4160. | 1000. FT | .0000 OHMS/M FEET |
| 2902 ST2-A IMPEDANCE: | 2007 A2 .0000 + J | 1 | 4160. | 1000. FT | .0000 OHMS/M FEET |
| ===== | | | | | |
| SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS | | | | | |
| Calculated From Largest 3-PHASE Fault Contribution | | | | | |
| ===== | | | | | |

DATE:23 JUL 92 TIME:10 38 PM
 T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * PERCENT | SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|--|--------------|------------|--------------|-----------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: 1.2315 + J 7.6110 | 4055. | 142. | | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: 1.2438 + J 7.9432 | 4055. | 142. | | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: 1.2396 + J 8.0046 | 4055. | 142. | | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: 1.2532 + J 8.0126 | 4055. | 142. | | 3106 B6 | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME:10 38 PM
 T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * * | BRANCH DATA | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|-------------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J 4.7300 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 29C1 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE:23 JUL 92 TIME:10 38 PM
 T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

BRANCH LOAD DATA

| FROM BUS | / TO BUS | BR. TYPE | CONSTANT KVA KVA | KVA %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | %PF | FLOW DIR. |
|---------------|-------------|-------------|---------------------|------------|-------------------|-----|-------------------|-----|--------------|
| 1 SYSTEM | | | | | | | | | |
| 200 | 161KV APL | FEEDER | 593 | -81.0 | | | | | |
| 2001 2A1 | | | | | | | | | |
| 2003 | 2A3 | FEEDER | 593 | -81.0 | | | | | |
| 2902 | ST2-A | FEEDER | 593 | -81.0 | | | | | REV |
| 2901 ST2-CLR | | | | | | | | | |
| 2902 | ST2-A | FEEDER | 593 | -81.0 | | | | | |
| 200 161KV APL | | | | | | | | | |
| 2901 | ST2-CLR | TRANS. | 593 | -81.0 | | | | | |
| 2003 2A3 | | | | | | | | | |
| 3005 | 2B5 | TRANS. | 593 | -81.0 | | | | | |

DATE:23 JUL 92 TIME:10 38 PM
T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Re: Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

```
=====
* NO * NAME * KW * KVAR * LOAD/GENERATION
=====
```

| | | | | |
|------|-----|-------|-------|-------------------|
| 2003 | 2A3 | 1535. | 813. | CONSTANT KVA LOAD |
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 297. | 1456. | CONSTANT Z LOAD |
| 3006 | 2B6 | 850. | 463. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

```
=====
```

DATE:23 JUL 92 TIME:10 38 PM
T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 1737.01 KVA | |
| CONVERGENCE CRITERIA: | .087 KVA | |
| LARGEST BUS MISMATCH | 3005 2B5 | 157.271 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 15.023 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 2.077 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .277 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .036 KVA |

DATE:23 JUL 92 TIME:10 38 PM
T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9

VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 39 VOLTAGE DROP: 951. %VD: .59
PROJECTED POWER FLOW: 8443. KW 6482. KVAR 10644. KVA PF: .79 LAGGING
LOSSES THRU FEEDER: 14. KW 86. KVAR 88. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 39 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 8443. KW 6482. KVAR 10644. KVA PF: .79 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158632 %VD: 1.5

VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 39 VOLTAGE DROP: 951. %VD: .59
PROJECTED POWER FLOW: 8429. KW 6396. KVAR 10581. KVA PF: .80 LAGGING
LOSSES THRU FEEDER: 14. KW 86. KVAR 88. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 39
PROJECTED POWER FLOW: 8429. KW 6396. KVAR 10581. KVA PF: .80 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4072 %VD: 2.1

VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 486 VOLTAGE DROP: 102. %VD: 2.46
PROJECTED POWER FLOW: 2271. KW 2565. KVAR 3426. KVA PF: .66 LAGGING
LOSSES THRU FEEDER: 3. KW 113. KVAR 113. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 486 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2271. KW 2565. KVAR 3426. KVA PF: .66 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME:10 38 PM
T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4072 %VD: 2.1

VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 396 VOLTAGE DROP: 58. %VD: 1.40
PROJECTED POWER FLOW: 2399. KW 1435. KVAR 2796. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 2. KW 75. KVAR 75. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 396 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2399. KW 1435. KVAR 2796. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3969 %VD: 4.6

VOLTAGE ANGLE: -3.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 1535. KW 813. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 486 VOLTAGE DROP: 102. %VD: 2.46
PROJECTED POWER FLOW: 2268. KW 2451. KVAR 3339. KVA PF: .68 LAGGING
LOSSES THRU FEEDER: 3. KW 113. KVAR 113. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 261 VOLTAGE DROP: 462. %VD: 11.11\$
PROJECTED POWER FLOW: 733. KW 1638. KVAR 1795. KVA PF: .41 LAGGING
LOSSES THRU TRANSF: 41.4 KW 255.9 KVAR 259.2 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4013 %VD: 3.5

VOLTAGE ANGLE: -4.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 396 VOLTAGE DROP: 58. %VD: 1.40
PROJECTED POWER FLOW: 2397. KW 1360. KVAR 2756. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 2. KW 75. KVAR 75. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 147 VOLTAGE DROP: 115. %VD: 2.77
PROJECTED POWER FLOW: 863. KW 548. KVAR 1022. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 13.3 KW 84.8 KVAR 85.8 KVA

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4072 %VD: 2.1

VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 369 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2603. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME:10 38 PM
T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD FROM: 2902 ST2-A FEEDER AMPS: 369 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2603. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4072 %VD: 2.1

VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4071 %VD: 2.1

VOLTAGE ANGLE: -2.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 369 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2603. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 153 VOLTAGE DROP: 110. %VD: 2.64
PROJECTED POWER FLOW: 935. KW 534. KVAR 1077. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.3 KW 92.1 KVAR 93.2 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4072 %VD: 2.1

VOLTAGE ANGLE: -2.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3106 B6 TRANSF AMPS: 90 VOLTAGE DROP: 24. %VD: .59
PROJECTED POWER FLOW: 552. KW 315. KVAR 636. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.0 KW 32.1 KVAR 32.5 KVA

DATE:23 JUL 92 TIME:10 38 PM
T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4104 %VD: 1.3

VOLTAGE ANGLE: -2.0 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1453 VOLTAGE DROP: 33. %VD: .79
PROJECTED POWER FLOW: 8413. KW 5995. KVAR 10330. KVA PF: .81 LAGGING
LOSSES THRU FEEDER: 3. KW 139. KVAR 139. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1453
PROJECTED POWER FLOW: 8413. KW 5995. KVAR 10330. KVA PF: .81 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4072 %VD: 2.1

VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 486 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2271. KW 2565. KVAR 3426. KVA PF: .66 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 396 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2399. KW 1435. KVAR 2796. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 369 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2603. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1453 VOLTAGE DROP: 33. %VD: .79
PROJECTED POWER FLOW: 8410. KW 5856. KVAR 10248. KVA PF: .82 LAGGING
LOSSES THRU FEEDER: 3. KW 139. KVAR 139. KVA

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 405 %VD: 15.75

VOLTAGE ANGLE: -6.4 DEGREES
PROJECTED SPECIAL BUS LOAD: 211. KW 1035. KVAR
NET BRANCH DIVERSITY LOAD: 480. KW 348. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 2205 VOLTAGE DROP: 53. %VD: 11.115
PROJECTED POWER FLOW: 691. KW 1382. KVAR 1546. KVA PF: .45 LAGGING
LOSSES THRU TRANSF: 41.4 KW 255.9 KVAR 259.2 KVA

DATE:23 JUL 92 TIME:10 38 PM
T=60 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 450 %VD: 6.3\$

VOLTAGE ANGLE: -7.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 850. KW 463. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1242 VOLTAGE DROP: 13. %VD: 2.77
PROJECTED POWER FLOW: 850. KW 463. KVAR 968. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 13.3 KW 84.8 KVAR 85.8 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 457 %VD: 4.8

VOLTAGE ANGLE: -6.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1290 VOLTAGE DROP: 13. %VD: 2.64
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.3 KW 92.1 KVAR 93.2 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 467 %VD: 2.7

VOLTAGE ANGLE: -5.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 761 VOLTAGE DROP: 3. %VD: .59
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.0 KW 32.1 KVAR 32.5 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
113. KW 1280. KVAR

WARNING STUDY CONTAINS 4 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State Green Train Sequencing
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 4 48 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE: 23 JUL 92 TIME: 4 48 PM
 T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER DESCRIPTION SIZE TYPE DUCT INSUL |
|------------------------|----------------------|------------|--------------|----------|--|
| 1 SYSTEM | 200 161KV APL | 1 | 161000. | 1000. FT | |
| IMPEDANCE: | 3.1131 + J19.4200 | | OHMS/M | FEET | |
| 2001 2A1 | 2003 2A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J .1600 | | OHMS/M | FEET | |
| 2001 2A1 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2002 2A2 | 2004 2A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J .1600 | | OHMS/M | FEET | |
| 2002 2A2 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2006 A1 | 2008 A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2007 A2 | 2009 A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2901 ST2-CLP | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0005 + J .0220 | | OHMS/M | FEET | |
| 2902 ST2-A | 2006 A1 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |
| 2902 ST2-A | 2007 A2 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | OHMS/M | FEET | |

SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS
 Calculated From Largest 3-PHASE Fault Contribution

DATE:23 JUL 92 TIME: 4 48 PM
 T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

```

=====
PRIMARY RECORD          VOLTS      PRI  * SECONDARY RECORD    VOLTS      SEC  NOMINAL
NO NAME                L-L      FLA   NO NAME                L-L      FLA   KVA
=====
2003 2A3                4055.    142. 3005 2B5                480.    1203. 1000.0
IMPEDANCE: 1.2315 + J 7.6110 PERCENT
2004 2A4                4055.    142. 3006 2B6                480.    1203. 1000.0
IMPEDANCE: 1.2438 + J 7.9432 PERCENT
2008 A3                 4055.    142. 3105 B5                 480.    1203. 1000.0
IMPEDANCE: 1.2396 + J 8.0046 PERCENT
2009 A4                 4055.    142. 3106 B6                 480.    1203. 1000.0
IMPEDANCE: 1.2532 + J 8.0126 PERCENT
  
```

DATE: 23 JUL 92 TIME: 4 48 PM
T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * DATA | BRANCH | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|---------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE: 23 JUL 92 TIME: 4 48 PM
 T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

BRANCH LOAD DATA

| FROM BUS | / TO BUS | BR. TYPE | CONSTANT KVA | CONSTANT %PF | CONSTANT Z KVA | CONSTANT I %PF | CONSTANT I KVA | FLOW DIR. |
|---------------|-------------|-------------|-----------------|-----------------|-------------------|-------------------|-------------------|--------------|
| 1 SYSTEM | | | | | | | | |
| 200 | 161KV APL | FEEDER | 568 | -80.0 | | | | |
| 2002 2A2 | | | | | | | | |
| 2004 | 2A4 | FEEDER | 568 | -80.0 | | | | |
| 2902 | ST2-A | FEEDER | 568 | -80.0 | | | | REV |
| 2901 ST2-CLR | | | | | | | | |
| 2902 | ST2-A | FEEDER | 568 | -80.0 | | | | |
| 200 161KV APL | | | | | | | | |
| 2901 | ST2-CLR | TRANS. | 568 | -80.0 | | | | |
| 2004 2A4 | | | | | | | | |
| 3006 | 2B6 | TRANS. | 568 | -80.0 | | | | |

DATE:23 JUL 92 TIME: 4 48 PM
T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOCP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

```
=====
* NO * NAME      * KW   * KVAR * LOAD/GENERATION
=====
```

| | | | | |
|------|-----|-------|-------|-------------------|
| 2003 | 2A3 | 2013. | 1058. | CONSTANT KVA LOAD |
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 900. | 490. | CONSTANT KVA LOAD |
| 3006 | 2B6 | 290. | 1422. | CONSTANT Z LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 4 48 PM
T=70 SECONDS, ST #2 Unit 2 MSL# Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 2274.45 KVA | |
| CONVERGENCE CRITERIA: | .114 KVA | |
| LARGEST BUS MISMATCH | 3006 2B6 | 153.420 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 18.327 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 2.656 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .371 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .051 KVA |

DATE:23 JUL 92 TIME: 4 48 PM
 T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Fed Train Steady State, Green Train Sequencing
 ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

 VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
 VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
 PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9

 VOLTAGE ANGLE: .0 DEGREES
 LOAD TO: 200 161KV APL FEEDER AMPS: 41 VOLTAGE DROP: 1002. %VD: .62
 PROJECTED POWER FLOW: 8944. KW 6826. KVAR 11251. KVA PF: .79 LAGGING
 LOSSES THRU FEEDER: 15. KW 97. KVAR 98. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 41 VOLTAGE DROP: 0. %VD: .00
 PROJECTED POWER FLOW: 8944. KW 6826. KVAR 11251. KVA PF: .79 LAGGING
 LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158581 %VD: 1.5

 VOLTAGE ANGLE: -.3 DEGREES
 LOAD FROM: 1 SYSTEM FEEDER AMPS: 41 VOLTAGE DROP: 1002. %VD: .62
 PROJECTED POWER FLOW: 8928. KW 6730. KVAR 11181. KVA PF: .80 LAGGING
 LOSSES THRU FEEDER: 15. KW 97. KVAR 98. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3WXFMR AMPS: 41
 PROJECTED POWER FLOW: 8928. KW 6730. KVAR 11181. KVA PF: .80 LAGGING
 XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4063 %VD: 2.3

 VOLTAGE ANGLE: -2.8 DEGREES
 LOAD TO: 2003 2A3 FEEDER AMPS: 485 VOLTAGE DROP: 71. %VD: 1.70
 PROJECTED POWER FLOW: 2932. KW 1753. KVAR 3416. KVA PF: .86 LAGGING
 LOSSES THRU FEEDER: 3. KW 113. KVAR 113. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 485 VOLTAGE DROP: 0. %VD: .00
 PROJECTED POWER FLOW: 2932. KW 1753. KVAR 3416. KVA PF: .86 LAGGING
 LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE: 23 JUL 92 TIME: 4 48 PM
T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4063 %VD: 2.3
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 478 VOLTAGE DROP: 101. %VD: 2.42
PROJECTED POWER FLOW: 2235. KW 2517. KVAR 3366. KVA PF: .66 LAGGING
LOSSES THRU FEEDER: 3. KW 110. KVAR 110. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 478 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2235. KW 2517. KVAR 3366. KVA PF: .66 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3993 %VD: 4.0
----- VOLTAGE ANGLE: -4.5 DEGREES
PROJECTED SPECIAL BUS LOAD: 2013. KW 1058. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 485 VOLTAGE DROP: 71. %VD: 1.70
PROJECTED POWER FLOW: 2928. KW 1640. KVAR 3356. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 3. KW 113. KVAR 113. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 157 VOLTAGE DROP: 122. %VD: 2.94
PROJECTED POWER FLOW: 915. KW 582. KVAR 1064. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 14.9 KW 92.3 KVAR 93.5 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3963 %VD: 4.7
----- VOLTAGE ANGLE: -4.1 DEGREES
PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 478 VOLTAGE DROP: 101. %VD: 2.42
PROJECTED POWER FLOW: 2232. KW 2407. KVAR 3283. KVA PF: .68 LAGGING
LOSSES THRU FEEDER: 3. KW 110. KVAR 110. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 254 VOLTAGE DROP: 470. %VD: 11.315
PROJECTED POWER FLOW: 698. KW 1595. KVAR 1741. KVA PF: .40 LAGGING
LOSSES THRU TRANSF: 39.5 KW 252.2 KVAR 255.3 KVA

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4063 %VD: 2.3
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 370 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2603. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 4 48 PM
T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % EUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD FROM: 2902 ST2-A FEEDER AMPS: 370 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2603. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4063 %VD: 2.3
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4063 %VD: 2.3
----- VOLTAGE ANGLE: -2.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 370 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2603. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 153 VOLTAGE DROP: 110. %VD: 2.65
PROJECTED POWER FLOW: 935. KW 534. KVAR 1077. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.3 KW 92.5 KVAR 93.6 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4063 %VD: 2.3
----- VOLTAGE ANGLE: -2.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3106 B6 TRANSF AMPS: 90 VOLTAGE DROP: 25. %VD: .60
PROJECTED POWER FLOW: 552. KW 315. KVAR 636. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.0 KW 32.2 KVAR 32.6 KVA

DATE:23 JUL 92 TIME: 4 48 PM
T=70 SECONDS, Sf #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4098 %VD: 1.5

LOAD TO: 2902 ST2-A FEEDER AMPS: 1536 VOLTAGE ANGLE: -2.2 DEGREES
PROJECTED POWER FLOW: 8910. KW 6283. KVAR 10902. KVA PF: .82 %VD: .83
LOSSES THRU FEEDER: 3. KW 156. KVAR 156. KVA LAGGING

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1536
PROJECTED POWER FLOW: 8910. KW 6283. KVAR 10902. KVA PF: .82 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4063 %VD: 2.3

LOAD TO: 2001 2A1 FEEDER AMPS: 485 VOLTAGE ANGLE: -2.8 DEGREES
PROJECTED POWER FLOW: 2932. KW 1753. KVAR 3416. KVA PF: .86 %VD: .00
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA LAGGING

LOAD TO: 2002 2A2 FEEDER AMPS: 478 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2235. KW 2517. KVAR 3366. KVA PF: .66 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 370 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1149. KVAR 2603. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1536 VOLTAGE DROP: 34. %VD: .83
PROJECTED POWER FLOW: 8906. KW 6127. KVAR 10810. KVA PF: .82 LAGGING
LOSSES THRU FEEDER: 3. KW 156. KVAR 156. KVA

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 447 %VD: 7.0\$

PROJECTED SPECIAL BUS LOAD: 900. KW 490. KVAR
VOLTAGE ANGLE: -8.4 DEGREES
LOAD FROM: 2003 2A3 TRANSF AMPS: 1325 VOLTAGE DROP: 14. %VD: 2.94
PROJECTED POWER FLOW: 900. KW 490. KVAR 1025. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 14.9 KW 92.3 KVAR 93.5 KVA

DATE:23 JUL 92 TIME: 4 48 PM
T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS .NC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 403 %VD: 16.1\$

VOLTAGE ANGLE: -6.5 DEGREES
PROJECTED SPECIAL BUS LOAD: 204. KW 1002. KVAR
NET BRANCH DIVERSITY LOAD: 454. KW 341. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 2143 VOLTAGE DROP: 54. %VD:11.31\$
PROJECTED POWER FLOW: 659. KW 1343. KVAR 1496. KVA PF: .44 LAGGING
LOSSES THRU TRANSF: 39.5 KW 252.2 KVAR 255.3 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 456 %VD: 5.0

VOLTAGE ANGLE: -6.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMI : 1293 VOLTAGE DROP: 13. %VD: 2.65
PROJECTED POWER FLOW: 921. KW 442. VAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 4.3 KW 92.5 KVAR 93.6 KVA

LOAD BUS: 3106 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 466 %VD: 2.9

VOLTAGE ANGLE: -5.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 763 VOLTAGE DROP: 3. %VD: .60
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.0 KW 32.2 KVAR 32.6 KVA

17 EUSES

*** TOTAL SYSTEM LOSSES ***
118. KW 1392. KVAR

WARNING STUDY CONTAINS 4 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 5 11 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 5 11 PM
 T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER DESCRIPTION SIZE TYPE DUCT INSUL |
|------------------------|----------------------|------------|--------------|-------------|--|
| 1 SYSTEM | 200 161KV APL | 1 | 161000. | 1000. FT | |
| IMPEDANCE: | 3.1131 + J19.4200 | | | OHMS/M FEET | |
| 2001 2A1 | 2003 2A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J .1600 | | | OHMS/M FEET | |
| 2001 2A1 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |
| 2002 2A2 | 2004 2A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J .1600 | | | OHMS/M FEET | |
| 2002 2A2 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |
| 2006 A1 | 2008 A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |
| 2007 A2 | 2009 A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |
| 2901 ST2-CLR | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0005 + J .0220 | | | OHMS/M FEET | |
| 2902 ST2-A | 2006 A1 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |
| 2902 ST2-A | 2007 A2 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |

SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS
 Calculated From Largest 3-PHASE Fault Contribution

DATE:23 JUL 92 TIME: 5 11 PM
T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOCP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * NO NAME | SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|--|--------------|------------|--------------|-----------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: 1.2315 + J 7.6110 PERCENT | 4055. | 142. | | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: 1.2438 + J 7.9432 PERCENT | 4055. | 142. | | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: 1.2396 + J 8.0046 PERCENT | 4055. | 142. | | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: 1.2532 + J 8.0126 PERCENT | 4055. | 142. | | 3106 B6 | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME: 5 11 PM
T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * DATA | BRANCH | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|---------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2300 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE:23 JUL 92 TIME: 5 11 PM
 T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

B R A N C H L O A D D A T A

| FROM BUS | / TO BUS | BR. TYPE | CONSTANT KVA KVA | KVA %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | %PF | FLOW DIR. | REV |
|---------------|-------------|-------------|---------------------|------------|-------------------|-----|-------------------|-----|--------------|-----|
| ===== | | | | | | | | | | |
| 1 SYSTEM | | | | | | | | | | |
| 200 | 161KV APL | FEEDER | 667 | -81.0 | | | | | | |
| 2001 2A1 | | | | | | | | | | |
| 2003 | 2A3 | FEEDER | 667 | -81.0 | | | | | | |
| 2902 | ST2-A | FEEDER | 667 | -81.0 | | | | | | REV |
| 2901 ST2-CLR | | | | | | | | | | |
| 2902 | ST2-A | FEEDER | 667 | -81.0 | | | | | | |
| 200 151KV APL | | | | | | | | | | |
| 2901 | ST2-CLR | TRANS. | 667 | -81.0 | | | | | | |
| 2003 2A3 | | | | | | | | | | |
| 3005 | 2B5 | TRANS. | 667 | -81.0 | | | | | | |
| ===== | | | | | | | | | | |

DATE:23 JUL 92 TIME: 5 11 PM
T=70 SECONDS, ST #1 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

| * NO * | NAME | * KW | * KVAR | * LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2003 | 2A3 | 1535. | 813. | CONSTANT KVA LOAD |
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 220. | 1075. | CONSTANT Z LOAD |
| 3006 | 2B6 | 850. | 463. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | 36 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 5 11 PM
T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TQF SIZE: 58

LARGEST LOAD: 1737.01 KVA
CONVERGENCE CRITERIA: .087 KVA
LARGEST BUS MISMATCH 3005 2B5 150.040 KVA
LARGEST BUS MISMATCH 3005 2B5 13.817 KVA
LARGEST BUS MISMATCH 3006 2B6 1.995 KVA
LARGEST BUS MISMATCH 3006 2B6 .267 KVA
LARGEST BUS MISMATCH 3006 2B6 .035 KVA

DATE:23 JUL 92 TIME: 5 11 PM
T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9
----- VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 38 VOLTAGE DROP: 917. %VD: .57
PROJECTED POWER FLOW: 8446. KW 6206. KVAR 10481. KVA PF: .81 LAGGING
LOSSES THRU FEEDER: 13. KW 84. KVAR 85. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 38 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 8446. KW 6206. KVAR 10481. KVA PF: .81 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158666 %VD: 1.4
----- VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 38 VOLTAGE DROP: 917. %VD: .57
PROJECTED POWER FLOW: 8433. KW 6122. KVAR 10421. KVA PF: .81 LAGGING
LOSSES THRU FEEDER: 13. KW 84. KVAR 85. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 38
PROJECTED POWER FLOW: 8433. KW 6122. KVAR 10421. KVA PF: .81 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4078 %VD: 2.0
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2903 2A3 FEEDER AMPS: 459 VOLTAGE DROP: 92. %VD: 2.22
PROJECTED POWER FLOW: 2275. KW 2309. KVAR 3241. KVA PF: .70 LAGGING
LOSSES THRU FEEDER: 3. KW 101. KVAR 101. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 459 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2275. KW 2309. KVAR 3241. KVA PF: .70 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 5 11 PM
T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00

PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4078 %VD: 2.0
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 396 VOLTAGE DROP: 58. %VD: 1.39
PROJECTED POWER FLOW: 2399. KW 1435. KVAR 2796. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 2. KW 75. KVAR 75. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 396 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2399. KW 1435. KVAR 2796. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3986 %VD: 4.2
----- VOLTAGE ANGLE: -3.9 DEGREES
PROJECTED SPFCIAL BUS LOAD: 1535. KW 813. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 459 VOLTAGE DROP: 92. %VD: 2.22
PROJECTED POWER FLOW: 2272. KW 2207. KVAR 3168. KVA PF: .72 LAGGING
LOSSES THRU FEEDER: 3. KW 101. KVAR 101. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 228 VOLTAGE DROP: 381. %VD: 9.15\$
PROJECTED POWER FLOW: 737. KW 1394. KVAR 1577. KVA PF: .47 LAGGING
LOSSES THRU TRANSF: 31.7 KW 196.0 KVAR 198.6 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4020 %VD: 3.4
----- VOLTAGE ANGLE: -4.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 396 VOLTAGE DROP: 58. %VD: 1.39
PROJECTED POWER FLOW: 2397. KW 1359. KVAR 2756. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 2. KW 75. KVAR 75. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 147 VOLTAGE DROP: 115. %VD: 2.76
PROJECTED POWER FLOW: 863. KW 547. KVAR 1022. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 13.2 KW 84.4 KVAR 85.5 KVA

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4078 %VD: 2.0
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 5 11 PM
T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD FROM: 2902 ST2-A FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4078 %VD: 2.0
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4078 %VD: 2.0
----- VOLTAGE ANGLE: -2.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 152 VOLTAGE DROP: 109. %VD: 2.62
PROJECTED POWER FLOW: 935. KW 534. KVAR 1077. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.2 KW 91.8 KVAR 92.9 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4078 %VD: 2.0
----- VOLTAGE ANGLE: -2.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3106 B6 TRANSF AMPS: 90 VOLTAGE DROP: 24. %VD: .58
PROJECTED POWER FLOW: 552. KW 315. KVAR 636. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.0 KW 32.0 KVAR 32.4 KVA

DATE: 23 JUL 92 TIME: 5 11 PM
T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4109 %VD: 1.2

VOLTAGE ANGLE: -2.0 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1431 VOLTAGE DROP: 31. %VD: .76
PROJECTED POWER FLOW: 8417. KW 5734. KVAR 10184. KVA PF: .83 LAGGING
LOSSES THRU FEEDER: 3. KW 135. KVAR 135. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1431
PROJECTED POWER FLOW: 8417. KW 5734. KVAR 10184. KVA PF: .83 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4078 %VD: 2.0

VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 459 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2275. KW 2309. KVAR 3241. KVA PF: .70 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 396 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2399. KW 1435. KVAR 2796. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1431 VOLTAGE DROP: 31. %VD: .76
PROJECTED POWER FLOW: 8414. KW 5599. KVAR 101 KVA PF: .83 LAGGING
LOSSES THRU FEEDER: 3. KW 135. KVAR 135. KVA

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 416 %VD: 13.3%

VOLTAGE ANGLE: -6.5 DEGREES
PROJECTED SPECIAL BUS LOAD: 165. KW 807. KVAR
NET BRANCH DIVERSITY LOAD: 540. KW 391. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 1930 VOLTAGE DROP: 44. %VD: 9.15%
PROJECTED POWER FLOW: 705. KW 1198. KVAR 1391. KVA PF: .51 LAGGING
LOSSES THRU TRANSF: 31.7 KW 196.0 KVAR 198.6 KVA

DATE:23 JUL 92 TIME: 5 11 PM
T=70 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 451 %VD: 6.15

VOLTAGE ANGLE: -7.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 850. KW 463. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1240 VOLTAGE DROP: 13. %VD: 2.76
PROJECTED POWER FLOW: 850. KW 463. KVAR 968. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 13.2 KW 84.4 KVAR 85.5 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 458 %VD: 4.6

VOLTAGE ANGLE: -6.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1288 VOLTAGE DROP: 13. %VD: 2.62
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.2 KW 91.8 KVAR 92.9 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 468 %VD: 2.5

VOLTAGE ANGLE: -5.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 760 VOLTAGE DROP: 3. %VD: .58
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.0 KW 32.0 KVAR 32.4 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
102. KW 1187. KVAR

WARNING STUDY CONTAINS 4 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 5 17 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 5 17 PM
 T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENERGY OPERATIONS INC.

F E E D E R D A T A

| FEEDE NO | FROM NAME | FEEDE TO NAME | QTY /PH | VOLTS L-L | LENGT H | FEEDER DESCRIPTION | | |
|--|--------------|---------------------|------------|--------------|------------|--------------------|------|------------|
| | | | | | | SIZE | TYPE | DUCT INSUL |
| 1 | SYSTEM | 200 161KV APL | 1 | 161000. | 1000. | FT | | |
| | IMPEDANCE: | 3.1131 + J19.4200 | | OHMS/M | FEET | | | |
| 2001 | 2A1 | 2003 2A3 | 1 | 4160. | 1000. | FT | | |
| | IMPEDANCE: | .0047 + J | .1600 | OHMS/M | FEET | | | |
| 2001 | 2A1 | 2902 ST2-A | 1 | 4160. | 1000. | FT | | |
| | IMPEDANCE: | .0000 + J | .0000 | OHMS/M | FEET | | | |
| 2002 | 2A2 | 2004 2A4 | 1 | 4160. | 1000. | FT | | |
| | IMPEDANCE: | .0047 + J | .1600 | OHMS/M | FEET | | | |
| 2002 | 2A2 | 2902 ST2-A | 1 | 4160. | 1000. | FT | | |
| | IMPEDANCE: | .0000 + J | .0000 | OHMS/M | FEET | | | |
| 2006 | A1 | 2008 A3 | 1 | 4160. | 1000. | FT | | |
| | IMPEDANCE: | .0000 + J | .0000 | OHMS/M | FEET | | | |
| 2007 | A2 | 2009 A4 | 1 | 4160. | 1000. | FT | | |
| | IMPEDANCE: | .0000 + J | .0000 | OHMS/M | FEET | | | |
| 2901 | ST2-CLR | 2902 ST2-A | 1 | 4160. | 1000. | FT | | |
| | IMPEDANCE: | .0005 + J | .0220 | OHMS/M | FEET | | | |
| 2902 | ST2-A | 2006 A1 | 1 | 4160. | 1000. | FT | | |
| | IMPEDANCE: | .0000 + J | .0000 | OHMS/M | FEET | | | |
| 2902 | ST2-A | 2007 A2 | 1 | 4160. | 1000. | FT | | |
| | IMPEDANCE: | .0000 + J | .0000 | OHMS/M | FEET | | | |
| ===== | | | | | | | | |
| SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS | | | | | | | | |
| Calculated From Largest 3-PHASE Fault Contribution | | | | | | | | |
| ===== | | | | | | | | |

DATE: 23 JUL 92 TIME: 5 17 PM
T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

TRANSFORMER DATA

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * PERCENT | SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|--|--------------|------------|--------------|-----------------------------|--------------|------------|----------------|
| 2003 273 IMPEDANCE: 1.2315 + J 7.6110 | 4055. | 142. | PERCENT | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: 1.2438 + J 7.9432 | 4055. | 142. | PERCENT | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: 1.2396 + J 8.0046 | 4055. | 142. | PERCENT | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: 1.2532 + J 8.0126 | 4055. | 142. | PERCENT | 3106 B6 | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME: 5 17 PM
T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * * | BRANCH DATA | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|-------------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE:23 JUL 92 TIME: 5 17 PM
 T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

B R A N C H L O A D D A T A

| FROM BUS | / TO BUS | BR. TYPE | CONSTANT KVA KVA | %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | FLOW %PF DIR. |
|---------------|-------------|-------------|---------------------|-------|-------------------|-----|-------------------|------------------|
| 1 SYSTEM | | | | | | | | |
| 200 | 161KV APL | FEEDER | 642 | -80.0 | | | | |
| 2002 2A2 | | | | | | | | |
| 2004 | 2A4 | FEEDER | 642 | -80.0 | | | | |
| 2902 | ST2-A | FEEDER | 642 | -80.0 | | | | REV |
| 2901 ST2-CLR | | | | | | | | |
| 2902 | ST2-A | FEEDER | 642 | -80.0 | | | | |
| 200 161KV APL | | | | | | | | |
| 2901 | ST2-CLR | TRANS. | 642 | -80.0 | | | | |
| 2004 2A4 | | | | | | | | |
| 3006 | 2B6 | TRANS. | 642 | -80.0 | | | | |

DATE:23 JUL 92 TIME: 5 17 PM
 T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

```

=====
* NO * NAME * KW * KVAR * LOAD/GENERATION
=====
2003 2A3            2013.    1058.    CONSTANT KVA LOAD

2004 2A4            1534.     812.    CONSTANT KVA LOAD
2008 A3            1401.     613.    CONSTANT KVA LOAD
2009 A4            851.      394.    CONSTANT KVA LOAD
3005 2B5            900.      490.    CONSTANT KVA LOAD
3006 2B6            194.      950.    CONSTANT Z LOAD

3105 B5            921.      442.    CONSTANT KVA LOAD
3106 B6            547.      283.    CONSTANT KVA LOAD
=====

```

DATE:23 JUL 92 TIME: 5 17 PM
T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***

=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 2274.45 KVA | |
| CONVERGENCE CRITERIA: | .114 KVA | |
| LARGEST BUS MISMATCH | 3006 2B6 | 139.092 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 17.491 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 2.518 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .351 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .048 KVA |

DATE: 23 JUL 92 TIME: 5 17 PM
T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM T=0.9912, Red Train Steady State, Green Train Sequencing
ENTERC ERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE: 161000 LOAD VOLTAGE: 159583 %VD: .9

VOLTAGE ANGLE: .0 DEGREES
200 161KV APL FEEDER AMPS: 40 VOLTAGE DROP: 958. %VD: .60
PROJECTED POWER FLOW: 8931. KW 6466. KVAR 11026. KVA PF: .81 LAGGING
LOSSES THRU FEEDER: 15. KW 93. KVAR 94. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 40 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 8931. KW 6466. KVAR 11026. KVA PF: .81 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE: 161000 LOAD VOLTAGE: 158625 %VD: 1.5

VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 40 VOLTAGE DROP: 958. %VD: .60
PROJECTED POWER FLOW: 8917. KW 6374. KVAR 10960. KVA PF: .81 LAGGING
LOSSES THRU FEEDER: 15. KW 93. KVAR 94. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 40
PROJECTED POWER FLOW: 8917. KW 6374. KVAR 10960. KVA PF: .81 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4072 %VD: 2.1

VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2001 2A3 FEEDER AMPS: 484 VOLTAGE DROP: 71. %VD: 1.70
PROJECTED POWER FLOW: 2931. KW 1752. KVAR 3415. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 3. KW 113. KVAR 113. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 484 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2931. KW 1752. KVAR 3415. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE: 23 JUL 92 TIME: 5 17 PM
T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4072 %VD: 2.1
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 44 VOLTAGE DROP: 88. %VD: 2.10
PROJECTED POWER FLOW: 2225. KW 2186. KVAR 3119. KVA PF: .71 LAGGING
LOSSES THRU FEEDER: 3. KW 94. KVAR 94. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 442 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2225. KW 2186. KVAR 3119. KVA PF: .71 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4001 %VD: 3.8
----- VOLTAGE ANGLE: -4.4 DEGREES
PROJECTED SPECIAL BUS LOAD: 2013. KW 1058. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 484 VOLTAGE DROP: 71. %VD: 1.70
PROJECTED POWER FLOW: 2928. KW 1640. KVAR 3356. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 3. KW 113. KVAR 113. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 156 VOLTAGE DROP: 122. %VD: 2.92
PROJECTED POWER FLOW: 915. KW 582. KVAR 1084. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 14.9 KW 91.9 KVAR 93.1 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3984 %VD: 4.2
----- VOLTAGE ANGLE: -4.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 442 VOLTAGE DROP: 88. %VD: 2.10
PROJECTED POWER FLOW: 2222. KW 2092. KVAR 3052. KVA PF: .73 LAGGING
LOSSES THRU FEEDER: 3. KW 94. KVAR 94. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 211 VOLTAGE DROP: 360. %VD: 8.65\$
PROJECTED POWER FLOW: 688. KW 1280. KVAR 1453. KVA PF: .47 LAGGING
LOSSES THRU TRANSF: 27.2 KW 173.8 KVAR 175.9 KVA

LOAD BUS: 2006 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4072 %VD: 2.1
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 369 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2603. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE: 23 JUL 92 TIME: 5 17 PM
T=83 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD FROM: 2902 ST2-A FEEDER AMPS: 369 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2603. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4072 %VD: 2.1
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4072 %VD: 2.1
----- VOLTAGE ANGLE: -2.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 369 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2603. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 E5 TRANSF AMPS: 153 VOLTAGE DROP: 110. %VD: 2.63
PROJECTED POWER FLOW: 935. KW 534. KVAR 1079. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.3 KW 93.1 KVAR 93.2 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4072 %VD: 2.1
----- VOLTAGE ANGLE: -2.8 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3106 B6 TRANSF AMPS: 90 VOLTAGE DROP: 24. %VD: .59
PROJECTED POWER FLOW: 552. KW 315. KVAR 636. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.0 KW 32.1 KVAR 32.5 KVA

DATE:23 JUL 92 TIME: 5 17 PM
T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOCP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4104 %VD: 1.3
----- VOLTAGE ANGLE: -2.2 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1505 VOLTAGE DROP: 33. %VD: .78
PROJECTED POWER FLOW: 8899. KW 5944. KVAR 10701. KVA PF: .83 LAGGING
LOSSES THRU FEEDER: 3. KW 150. KVAR 150. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1505
PROJECTED POWER FLOW: 8899. KW 5944. KVAR 10701. KVA PF: .83 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4072 %VD: 2.1
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 484 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2931. KW 1752. KVAR 3415. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 442 VOLTAGE DROP: 0. %VD: .00
PROJECTED PCWER FLOW: 2225. KW 2186. KVAR 3119. KVA PF: .71 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 369 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2603. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 223 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1505 VOLTAGE DROP: 33. %VD: .78
PROJECTED POWER FLOW: 8896. KW 5795. KVAR 10616. KVA PF: .84 LAGGING
LOSSES THRU FEEDER: 3. KW 150. KVAR 150. KVA

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 448 %VD: 6.75
----- VOLTAGE ANGLE: -8.3 DEGREES
PROJECTED SPECIAL BUS LOAD: 900. KW 490. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 1322 VOLTAGE DROP: 14. %VD: 2.92
PROJECTED POWER FLOW: 900. KW 490. KVAR 1025. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 14.9 KW 91.9 KVAR 93.1 KVA

DATE: 23 JUL 92 TIME: 5 17 PM
T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 418 %VD: 12.9\$

VOLTAGE ANGLE: -6.6 DEGREES
PROJECTED SPECIAL BUS LOAD: 147. KW 721. KVAR
NET BRANCH DIVERSITY LOAD: 514. KW 385. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1779 VOLTAGE DROP: 42. %VD: 8.65\$
PROJECTED POWER FLOW: 661. KW 1106. KVAR 1289. KVA PF: .51 LAGGING
LOSSES THRU TRANSF: 27.2 KW 173.8 KVAR 175.9 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 457 %VD: 4.8

VOLTAGE ANGLE: -6.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1290 VOLTAGE DROP: 13. %VD: 2.63
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.3 KW 92.1 KVAR 93.2 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 467 %VD: 2.7

VOLTAGE ANGLE: -5.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 761 VOLTAGE DROP: 3. %VD: .59
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.0 KW 32.1 KVAR 32.5 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
103. KW 1268. KVAR

WARNING STUDY CONTAINS 4 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 7 8 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 7 8 PM
 T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER DESCRIPTION SIZE TYPE DUCT INSUL |
|------------------------|----------------------|------------|--------------|-------------|--|
| 1 SYSTEM | 200 161KV APL | 1 | 161000. | 1000. FT | |
| IMPEDANCE: | 3.1131 + J19.4200 | | | OHMS/M FEET | |
| 2001 2A1 | 2003 2A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J | .1600 | | OHMS/M FEET | |
| 2001 2A1 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | |
| 2002 2A2 | 2004 2A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J | .1600 | | OHMS/M FEET | |
| 2002 2A2 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | |
| 2006 A1 | 2008 A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | |
| 2007 A2 | 2009 A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | |
| 2901 ST2-CLR | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0005 + J | .0220 | | OHMS/M FEET | |
| 2902 ST2-A | 2006 A1 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | |
| 2902 ST2-A | 2007 A2 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | | OHMS/M FEET | |

SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS
 Calculated From Largest 3-PHASE Fault Contribution

DATE:23 JUL 92 TIME: 7 8 PM
T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|--|--------------|------------|-------------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: 1.2315 + J 7.6110 PERCENT | 4055. | 142. | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: 1.2438 + J 7.9432 PERCENT | 4055. | 142. | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: 1.2396 + J 8.0046 PERCENT | 4055. | 142. | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: 1.2532 + J 8.0126 PERCENT | 4055. | 142. | 3106 B6 | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME: 7 8 PM
 T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * * | BRANCH DATA | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|--------------|--------|----------------|-------------------------------|----------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE:23 JUL 92 TIME: 7 8 PM
 T=80 SECONDS, CT #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

BRANCH LOAD DATA

| FROM BUS | / TO BUS | BR. TYPE | CONSTANT KVA KVA | %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | FLOW %PF DIR. |
|---------------|-------------|-------------|---------------------|-------|-------------------|-----|-------------------|------------------|
| 1 SYSTEM | | | | | | | | |
| 200 | 161KV APL | FEEDER | 741 | -81.0 | | | | |
| 2001 2A1 | | | | | | | | |
| 2003 | 2A3 | FEEDER | 741 | -81.0 | | | | |
| 2902 | ST2-A | FEEDER | 741 | -81.0 | | | | REV |
| 2901 ST2-CLR | | | | | | | | |
| 2902 | ST2-A | FEEDER | 741 | -81.0 | | | | |
| 200 161KV APL | | | | | | | | |
| 2901 | ST2-CLR | TRANS. | 741 | -81.0 | | | | |
| 2003 2A3 | | | | | | | | |
| 3005 | 2B5 | TRANS. | 741 | -81.0 | | | | |

DATE:23 JUL 92 TIME: 7 8 PM
T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

| * NO * | NAME | * KW | * KVAR | * LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2003 | 2A3 | 1535. | 813. | CONSTANT KVA LOAD |
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 135. | 659. | CONSTANT Z LOAD |
| 3006 | 2B6 | 850. | 463. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 7 8 PM
T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 1737.01 KVA | |
| CONVERGENCE CRITERIA: | .087 KVA | |
| LARGEST BUS MISMATCH | 3005 2B5 | 130.717 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 13.275 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 1.880 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .251 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .033 KVA |

DATE:23 JUL 92 TIME: 7 8 PM
T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9

VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 37 VOLTAGE DROP: 877. %VD: .54
PROJECTED POWER FLOW: 8437. KW 5872. KVAR 10280. KVA PF: .82 LAGGING
LOSSES THRU FEEDER: 13. KW 81. KVAR 82. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 37 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 8437. KW 5872. KVAR 10280. KVA PF: .82 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158706 %VD: 1.4

VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 37 VOLTAGE DROP: 877. %VD: .54
PROJECTED POWER FLOW: 8425. KW 5791. KVAR 10223. KVA PF: .82 LAGGING
LOSSES THRU FEEDER: 13. KW 81. KVAR 82. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 37
PROJECTED POWER FLOW: 8425. KW 5792. KVAR 10223. KVA PF: .82 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4086 %VD: 1.8

VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 427 VOLTAGE DROP: 80. %VD: 1.92
PROJECTED POWER FLOW: 2268. KW 1999. KVAR 3023. KVA PF: .75 LAGGING
LOSSES THRU FEEDER: 3. KW 88. KVAR 88. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 427 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2268. KW 1999. KVAR 3023. KVA PF: .75 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 7 8 PM
T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4086 %VD: 1.8
----- VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 395 VOLTAGE DROP: 58. %VD: 1.39
PROJECTED POWER FLOW: 2399. KW 1434. KVAR 2795. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 2. KW 75. KVAR 75. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 395 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2399. KW 1434. KVAR 2795. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4006 %VD: 3.7
----- VOLTAGE ANGLE: -3.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 1535. KW 813. KVAR

LOAD FROM: 2001 2A1 FEEDER AMPS: 427 VOLTAGE DROP: 80. %VD: 1.92
PROJECTED POWER FLOW: 2265. KW 1911. KVAR 2964. KVA PF: .76 LAGGING
LOSSES THRU FEEDER: 3. KW 88. KVAR 88. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 190 VOLTAGE DROP: 282. %VD: 6.78\$
PROJECTED POWER FLOW: 730. KW 1098. KVAR 1319. KVA PF: .55 LAGGING
LOSSES THRU TRANSF: 22.0 KW 135.7 KVAR 137.4 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4028 %VD: 3.2
----- VOLTAGE ANGLE: -4.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR

LOAD FROM: 2002 2A2 FEEDER AMPS: 395 VOLTAGE DROP: 58. %VD: 1.39
PROJECTED POWER FLOW: 2397. KW 1359. KVAR 2756. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 2. KW 75. KVAR 75. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 146 VOLTAGE DROP: 114. %VD: 2.74
PROJECTED POWER FLOW: 863. KW 547. KVAR 1022. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 13.2 KW 84.1 KVAR 85.1 KVA

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4086 %VD: 1.8
----- VOLTAGE ANGLE: -2.7 DEGREES

LOAD TO: 2008 A3 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2502. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE: 23 JUL 92 TIME: 7 8 PM
T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD FROM: 2902 ST2-A FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4086 %VD: 1.8

VOLTAGE ANGLE: -2.7 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4086 %VD: 1.8

VOLTAGE ANGLE: -2.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 152 VOLTAGE DROP: 108. %VD: 2.60
PROJECTED POWER FLOW: 935. KW 533. KVAR 1077. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.2 KW 91.4 KVAR 92.5 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4086 %VD: 1.8

VOLTAGE ANGLE: -2.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3106 B6 TRANSF AMPS: 90 VOLTAGE DROP: 24. %VD: .57
PROJECTED POWER FLOW: 552. KW 315. KVAR 635. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.0 KW 31.9 KVAR 32.3 KVA

DATE:23 JUL 92 TIME: 7 8 PM
T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4116 %VD: 1.1

LOAD TO: 2902 ST2-A FEEDER AMPS: 1403 VOLTAGE ANGLE: -2.0 DEGREES
PROJECTED POWER FLOW: 8409. KW 5418. KVAR 10003. KVA PF: .84 LAGGING
LOSSES THRU FEEDER: 3. KW 130. KVAR 130. KVA
VOLTAGE DROP: 30. %VD: .71
LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1403
PROJECTED POWER FLOW: 8409. KW 5418. KVAR 10003. KVA PF: .84 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4086 %VD: 1.8

LOAD TO: 2001 2A1 FEEDER AMPS: 427 VOLTAGE ANGLE: -2.7 DEGREES
PROJECTED POWER FLOW: 2268. KW 1999. KVAR 3023. KVA PF: .75 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA
VOLTAGE DROP: 0. %VD: .00

LOAD TO: 2002 2A2 FEEDER AMPS: 395 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2399. KW 1434. KVAR 2795. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1403 VOLTAGE DROP: 30. %VD: .71
PROJECTED POWER FLOW: 8406. KW 5288. KVAR 9931. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 3. KW 130. KVAR 130. KVA

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 430 %VD: 10.5\$

PROJECTED SPECIAL BUS LOAD: 108. KW 528. KVAR
NET BRANCH DIVERSITY LOAD: 600. KW 435. KVAR
VOLTAGE ANGLE: -6.6 DEGREES
LOAD FROM: 2003 2A3 TRANSF AMPS: 1606 VOLTAGE DROP: 33. %VD: 6.78\$
PROJECTED POWER FLOW: 708. KW 963. KVAR 1195. KVA PF: .59 LAGGING
LOSSES THRU TRANSF: 22.0 KW 135.7 KVAR 137.4 KVA

DATE:23 JUL 92 TIME: 7 8 PM
T=80 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 452 %VD: 5.9\$

PROJECTED SPECIAL BUS LOAD: 850. KW 463. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1237 VOLTAGE DROP: 15. %VD: 2.74
PROJECTED POWER FLOW: 850. KW 463. KVAR 968. KVA PF: .98 LAGGING
LOSSES THRU TRANSF: 10.2 KW 84.1 KVAR 85.1 KVA

LOAD BUS: 3005 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 459 %VD: 4.4

PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1285 VOLTAGE DROP: 13. %VD: 2.60
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.2 KW 91.4 KVAR 92.5 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 469 %VD: 2.3

PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 759 VOLTAGE DROP: 3. %VD: .57
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.0 KW 21.9 KVAR 32.3 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
90. KW 1089. KVAR

WARNING STUDY CONTAINS 4 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=85 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 7 14 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 7 14 PM
 T=85 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

| FEEDE NO | FROM NAME | FEEDE NO | TO NAME | QTY /PH | VOLTS L-L | LENGT H | FEEDE DESCRIPTION | | |
|-------------|--------------|-------------|-------------------|------------|--------------|------------|----------------------|------|---------------|
| | | | | | | | SIZE | TYPE | DUCT INSUL |
| 1 | SYSTEM | 200 | 161KV APL | 1 | 161000. | 1000. | | | FT |
| | IMPEDANCE: | | 3.1131 + J19.4200 | | | | | | OHMS/M FEET |
| 2001 | 2A1 | 2003 | 2A3 | 1 | 4160. | 1000. | | | FT |
| | IMPEDANCE: | | .0047 + J .1600 | | | | | | OHMS/M FEET |
| 2001 | 2A1 | 2902 | ST2-A | 1 | 4160. | 1000. | | | FT |
| | IMPEDANCE: | | .0000 + J .0000 | | | | | | OHMS/M FEET |
| 2002 | 2A2 | 2004 | 2A4 | 1 | 4160. | 1000. | | | FT |
| | IMPEDANCE: | | .0047 + J .1600 | | | | | | OHMS/M FEET |
| 2002 | 2A2 | 2902 | ST2-A | 1 | 4160. | 1000. | | | FT |
| | IMPEDANCE: | | .0000 + J .0000 | | | | | | OHMS/M FEET |
| 2006 | A1 | 2008 | A3 | 1 | 4160. | 1000. | | | FT |
| | IMPEDANCE: | | .0000 + J .0000 | | | | | | OHMS/M FEET |
| 2007 | A2 | 2009 | A4 | 1 | 4160. | 1000. | | | FT |
| | IMPEDANCE: | | .0000 + J .0000 | | | | | | OHMS/M FEET |
| 2901 | ST2-CLR | 2902 | ST2-A | 1 | 4160. | 1000. | | | FT |
| | IMPEDANCE: | | .0005 + J .0220 | | | | | | OHMS/M FEET |
| 2902 | ST2-A | 2006 | A1 | 1 | 4160. | 1000. | | | FT |
| | IMPEDANCE: | | .0000 + J .0000 | | | | | | OHMS/M FEET |
| 2902 | ST2-A | 2007 | A2 | 1 | 4160. | 1000. | | | FT |
| | IMPEDANCE: | | .0000 + J .0000 | | | | | | OHMS/M FEET |

SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS
 Calculated From Largest 3-PHASE Fault Contribution

DATE:23 JUL 92 TIME: 7 14 PM
 T=85 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|--|--------------|------------|-------------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: 1.2315 + J 7.6110 PERCENT | 4055. | 142. | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: 1.2438 + J 7.9432 PERCENT | 4055. | 142. | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: 1.2396 + J 8.0046 PERCENT | 4055. | 142. | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: 1.2532 + J 8.0126 PERCENT | 4055. | 142. | 3106 B6 | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME: 7 14 PM
 T=85 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A (THREE WINDING)

```

=====
BUS          VOLTS *   BRANCH      % IMPEDANCE      NOMINAL
DATA        NO   NAME   L-L   *   DATA          R           X           KVA
=====
PRIMARY     200  161KV A1L  161000. *   PRI-SEC        .2000 + J 4.7800  15000.0
SECONDARY  1200  H BUSES    6900.  *   PRI-TER        .1900 + J 4.6000  12600.0
TERTIARY   2001  ST2-CLR    4160.  *   SEC-TER        .3700 + J 8.000   12600.0
PRIMARY FIXED TAP:  -2.5 %
  
```

DATE: 23 JUL 92 TIME: 7 14 PM
 T=85 SECONDS, ST #2 Unit 2 MSLE Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

BRANCH LOAD DATA

| FROM BUS | / TO BUS | BR. TYPE | CONSTANT KVA KVA | KVA %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | FLOW %PF DIR. |
|---------------|-------------|-------------|---------------------|------------|-------------------|-----|-------------------|------------------|
| 1 SYSTEM | | | | | | | | |
| 200 | 161KV APL | FEEDER | 2473 | -86.0 | | | | |
| 2001 2A1 | | | | | | | | |
| 2003 | 2A3 | FEEDER | 2473 | -86.0 | | | | |
| 2902 | ST2-A | FEEDER | 2473 | -86.0 | | | | REV |
| 2901 ST2-CLR | | | | | | | | |
| 2902 | ST2-A | FEEDER | 2473 | -86.0 | | | | |
| 200 161KV APL | | | | | | | | |
| 2901 | ST2-CLR | TRANS. | 2473 | -86.0 | | | | |
| 2003 2A3 | | | | | | | | |
| 3005 | 2B5 | TRANS. | 741 | -81.0 | | | | |

DATE:23 JUL 92 TIME: 7 14 PM
T=85 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

| * NO * | NAME | * KW | * KVAR | * LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2003 | 2A3 | 1023. | 3961. | CONSTANT Z LOAD |
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 149. | 728. | CONSTANT Z LOAD |
| 3006 | 2B6 | 850. | 463. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 7 14 PM
T=85 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES






<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOP SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 4090.97 KVA | |
| CONVERGENCE CRITERIA: | .205 KVA | |
| LARGEST BUS MISMATCH | 2003 2A3 | 289.293 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 24.329 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 3.240 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .462 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .064 KVA |

1

IMAGE EVALUATION
TEST TARGET (MT-3)



DATE:23 JUL 92 TIME: 7 14 PM
T=85 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9
----- VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 49 VOLTAGE DROP: 1382. %VD: .86
PROJECTED POWER FLOW: 9301. KW 9892. KVAR 13578. KVA PF: .69 LAGGING
LOSSES THRU FEEDER: 23. KW 141. KVAR 142. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 49 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 9301. KW 9892. KVAR 13578. KVA PF: .69 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158200 %VD: 1.7
----- VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 49 VOLTAGE DROP: 1382. %VD: .86
PROJECTED POWER FLOW: 9279. KW 9752. KVAR 13461. KVA PF: .69 LAGGING
LOSSES THRU FEEDER: 23. KW 141. KVAR 142. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 49
PROJECTED POWER FLOW: 9279. KW 9752. KVAR 13461. KVA PF: .69 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3992 %VD: 4.0
----- VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 922 VOLTAGE DROP: 225. %VD: 5.41\$
PROJECTED POWER FLOW: 3107. KW 5569. KVAR 6377. KVA PF: .49 LAGGING
LOSSES THRU FEEDER: 12. KW 408. KVAR 409. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 922 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 3107. KW 5569. KVAR 6377. KVA PF: .49 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 7 14 PM
T=85 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3992 %VD: 4.0

LCAD TO: 2004 2A4 FEEDER AMPS: 405 VOLTAGE DROP: 59. %VD: 1.43
PROJECTED POWER FLOW: 2400. KW 1442. KVAR 2800. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 2. KW 79. KVAR 79. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 405 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2400. KW 1442. KVAR 2800. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3767 %VD: 9.5\$

PROJECTED SPECIAL BUS LOAD: 839. KW 3247. KVAR
NET BRANCH DIVERSITY LOAD: 1529. KW 825. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 922 VOLTAGE DROP: 225. %VD: 5.41\$
PROJECTED POWER FLOW: 3095. KW 5161. KVAR 6018. KVA PF: .51 LAGGING
LOSSES THRU FEEDER: 12. KW 408. KVAR 409. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 201 VOLTAGE DROP: 309. %VD: 7.42\$
PROJECTED POWER FLOW: 728. KW 1089. KVAR 1310. KVA PF: .56 LAGGING
LOSSES THRU TRANSF: 24.5 KW 151.3 KVAR 153.2 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3932 %VD: 5.5\$

PROJECTED SPECIAL BUS LOAD: 1534. KW 912. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 405 VOLTAGE DROP: 59. %VD: 1.43
PROJECTED POWER FLOW: 2398. KW 1364. KVAR 2758. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 2. KW 79. KVAR 79. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 150 VOLTAGE DROP: 123. %VD: 2.96
PROJECTED POWER FLOW: 864. KW 552. KVAR 1025. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 13.9 KW 88.7 KVAR 89.8 KVA

DATE:23 JUL 92 TIME: 7 14 PM
T=85 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3992 %VD: 4.0
----- VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 377 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1151. KVAR 2605. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 377 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1151. KVAR 2605. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3992 %VD: 4.0
----- VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 227 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 227 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3992 %VD: 4.0
----- VOLTAGE ANGLE: -2.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 377 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1151. KVAR 2605. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 156 VOLTAGE DROP: 117. %VD: 2.81
PROJECTED POWER FLOW: 936. KW 538. KVAR 1080. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.9 KW 96.3 KVAR 97.4 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3992 %VD: 4.0
----- VOLTAGE ANGLE: -2.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 227 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 7 14 PM
T=85 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD TO: 3106 B6 TRANSF AMPS: 92 VOLTAGE DROP: 29. %VD: .71
PROJECTED POWER FLOW: 552. KW 316. KVAR 636. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.2 KW 33.5 KVAR 33.9 KVA

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4042 %VD: 2.8
----- VOLTAGE ANGLE: -2.2 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1854 VOLTAGE DROP: 50. %VD: 1.21
PROJECTED POWER FLOW: 9252. KW 9100. KVAR 12978. KVA PF: .71 LAGGING
LOSSES THRU FEEDER: 5. KW 227. KVAR 227. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1854
PROJECTED POWER FLOW: 9252. KW 9100. KVAR 12978. KVA PF: .71 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3992 %VD: 4.0
----- VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 922 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 3107. KW 5569. KVAR 6377. KVA PF: .49 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 405 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2400. KW 1442. KVAR 2800. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 377 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1151. KVAR 2605. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 227 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1854 VOLTAGE DROP: 50. %VD: 1.21
PROJECTED POWER FLOW: 9247. KW 8874. KVAR 12816. KVA PF: .72 LAGGING
LOSSES THRU FEEDER: 5. KW 227. KVAR 227. KVA

DATE:23 JUL 92 TIME: 7 14 PM
T=85 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 399 %VD: 16.9\$

VOLTAGE ANGLE: -7.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 103. KW 503. KVAR
NET BRANCH DIVERSITY LOAD: 600. KW 435. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 1696 VOLTAGE DROP: 36. %VD: 7.42\$
PROJECTED POWER FLOW: 703. KW 938. KVAR 1172. KVA PF: .60 LAGGING
LOSSES THRU TRANSF: 24.5 KW 151.3 KVAR 153.2 KVA

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 440 %VD: 8.4\$

VOLTAGE ANGLE: -8.3 DEGREES
PROJECTED SPECIAL BUS LOAD: 850. KW 463. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1271 VOLTAGE DROP: 14. %VD: 2.96
PROJECTED POWER FLOW: 850. KW 463. KVAR 968. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 13.9 KW 88.7 KVAR 89.8 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 447 %VD: 6.9\$

VOLTAGE ANGLE: -7.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1319 VOLTAGE DROP: 14. %VD: 2.81
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.9 KW 96.3 KVAR 97.4 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 457 %VD: 4.8

VOLTAGE ANGLE: -5.4 DEGREES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 778 VOLTAGE DROP: 3. %VD: .71
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.2 KW 33.5 KVAR 33.9 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
127. KW 1876. KVAR

WARNING STUDY CONTAINS 9 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 7 18 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 7 18 PM
T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

F E E D E R D A T A

```

=====
FEEDER FROM      FEEDER TO      QTY  VOLTS  LENGTH  FEEDER DESCRIPTION
NO NAME          NO NAME        /PH  L-L    FEET    SIZE TYPE DUCT  INSUL
=====
1 SYSTEM          200 161KV APL  1  161000. 1000. FT
IMPEDANCE:      3.1131 + J19.4200 OHMS/M FEET

2001 2A1          2003 2A3        1   4160. 1000. FT
IMPEDANCE:      .0047 + J .1600 OHMS/M FEET

2001 2A1          2902 ST2-A      1   4160. 1000. FT
IMPEDANCE:      .0000 + J .0000 OHMS/M FEET

2002 2A2          2004 2A4        1   4160. 1000. FT
IMPEDANCE:      .0047 + J .1600 OHMS/M FEET

2002 2A2          2902 ST2-A      1   4160. 1000. FT
IMPEDANCE:      .0000 + J .0000 OHMS/M FEET

2006 A1           2008 A3        1   4160. 1000. FT
IMPEDANCE:      .0000 + J .0000 OHMS/M FEET

2007 A2           2009 A4        1   4160. 1000. FT
IMPEDANCE:      .0000 + J .0000 OHMS/M FEET

2901 ST2-CLR      2902 ST2-A      1   4160. 1000. FT
IMPEDANCE:      .0005 + J .0220 OHMS/M FEET

2902 ST2-A        2006 A1        1   4160. 1000. FT
IMPEDANCE:      .0000 + J .0000 OHMS/M FEET

2902 ST2-A        2007 A2        1   4160. 1000. FT
IMPEDANCE:      .0000 + J .0000 OHMS/M FEET

```

```

=====
SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS
Calculated From Largest 3-PHASE Fault Contribution
=====

```

DATE:23 JUL 92 TIME: 7 18 PM
 T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD | | VOLTS | PRI | * SECONDARY RECORD | VOLTS | SEC | NOMINAL |
|----------------|------|-------------------|------|--------------------|-------|------|--------------|
| NO | NAME | L-L | FLA | NO | L-L | FLA | KVA |
| 2003 | 2A3 | 4055. | 142. | 3005 | 2B5 | 480. | 1203. 1000.0 |
| IMPEDANCE: | | 1.2315 + J 7.6110 | | PERCENT | | | |
| 2004 | 2A4 | 4055. | 142. | 3006 | 2B6 | 480. | 1203. 1000.0 |
| IMPEDANCE: | | 1.2438 + J 7.9432 | | PERCENT | | | |
| 2008 | A3 | 4055. | 142. | 3105 | B5 | 480. | 1203. 1000.0 |
| IMPEDANCE: | | 1.2396 + J 8.0046 | | PERCENT | | | |
| 2009 | A4 | 4055. | 142. | 3106 | B6 | 480. | 1203. 1000.0 |
| IMPEDANCE: | | 1.2532 + J 8.0126 | | PERCENT | | | |

DATE:23 JUL 92 TIME: 7 18 PM
 T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOC
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A (T H R E E W I N D I N G)

| BUS DATA | NO | NAME | VOLTS L-L | * DATA | BRANCH | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|---------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE: 23 JUL 92 TIME: 7 18 PM
 T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
 ENTERGY OPERATIONS INC.

BRANCH LOAD DATA

| FROM BUS | / TO BUS | BR. TYPE | CONSTANT KVA | KVA %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | %PF | FLOW DIR. |
|---------------|-------------|-------------|-----------------|------------|-------------------|-----|-------------------|-----|--------------|
| 1 SYSTEM | | | | | | | | | |
| 200 | 161KV APL | FEEDER | 748 | -81.0 | | | | | |
| 2002 2A2 | | | | | | | | | |
| 2004 | 2A4 | FEEDER | 748 | -81.0 | | | | | |
| 2902 | ST2-A | FEEDER | 748 | -81.0 | | | | | REV |
| 2901 ST2-CLR | | | | | | | | | |
| 2902 | ST2-A | FEEDER | 748 | -81.0 | | | | | |
| 200 161KV APL | | | | | | | | | |
| 2901 | ST2-CLR | TRANS. | 748 | -81.0 | | | | | |
| 2004 2A4 | | | | | | | | | |
| 3006 | 2B6 | TRANS. | 748 | -81.0 | | | | | |

DATE:23 JUL 92 TIME: 7 18 PM
T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

| * NO * | NAME | * KW | * KVAR | * LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2003 | 2A3 | 2013. | 1058. | CONSTANT KVA LOAD |
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 900. | 490. | CONSTANT KVA LOAD |
| 3006 | 2B6 | 102. | 499. | CONSTANT Z LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 7 18 PM
T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 2274.45 KVA | |
| CONVERGENCE CRITERIA: | .114 KVA | |
| LARGEST BUS MISMATCH | 2003 2A3 | 142.567 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 16.655 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 2.381 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .332 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .046 KVA |

DATE:23 JUL 92 TIME: 7 18 PM
T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9
----- VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 39 VOLTAGE DROP: 915. %VD: .57
PROJECTED POWER FLOW: 8949. KW 6110. KVAR 10836. KVA PF: .83 LAGGING
LOSSES THRU FEEDER: 14. KW 90. KVAR 91. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 39 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 8949. KW 6110. KVAR 10836. KVA PF: .83 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158668 %VD: 1.4
----- VOLTAGE ANGLE: -.4 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 39 VOLTAGE DROP: 915. %VD: .57
PROJECTED POWER FLOW: 8934. KW 6021. KVAR 10774. KVA PF: .83 LAGGING
LOSSES THRU FEEDER: 14. KW 90. KVAR 91. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 39
PROJECTED POWER FLOW: 8934. KW 6021. KVAR 10774. KVA PF: .83 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4080 %VD: 1.9
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 483 VOLTAGE DROP: 70. %VD: 1.69
PROJECTED POWER FLOW: 2931. KW 1751. KVAR 3415. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 3. KW 112. KVAR 112. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 483 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2931. KW 1751. KVAR 3415. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 7 18 PM
T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4080 %VD: 1.9
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 412 VOLTAGE DROP: 74. %VD: 1.79
PROJECTED POWER FLOW: 2244. KW 1855. KVAR 2911. KVA PF: .77 LAGGING
LOSSES THRU FEEDER: 2. KW 81. KVAR 81. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 412 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2244. KW 1855. KVAR 2911. KVA PF: .77 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4010 %VD: 3.6
----- VOLTAGE ANGLE: -4.4 DEGREES
PROJECTED SPECIAL BUS LOAD: 2013. KW 1058. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 483 VOLTAGE DROP: 70. %VD: 1.69
PROJECTED POWER FLOW: 2928. KW 1639. KVAR 3356. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 3. KW 112. KVAR 112. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 156 VOLTAGE DROP: 121. %VD: 2.91
PROJECTED POWER FLOW: 915. KW 581. KVAR 1084. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 14.8 KW 91.4 KVAR 92.6 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4006 %VD: 3.7
----- VOLTAGE ANGLE: -4.1 DEGREES
PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 412 VOLTAGE DROP: 74. %VD: 1.79
PROJECTED POWER FLOW: 2241. KW 1773. KVAR 2858. KVA PF: .78 LAGGING
LOSSES THRU FEEDER: 2. KW 81. KVAR 81. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 172 VOLTAGE DROP: 250. %VD: 6.025
PROJECTED POWER FLOW: 707. KW 961. KVAR 1193. KVA PF: .59 LAGGING
LOSSES THRU TRANSF: 18.2 KW 115.9 KVAR 117.3 KVA

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4080 %VD: 1.9
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 7 18 PM
T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00

PER UNIT DRIVING VOLTAGE = .9912

LOAD FROM: 2902 ST2-A FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4080 %VD: 1.9

VOLTAGE ANGLE: -2.8 DEGREES

LOAD TO: 2009 A4 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4080 %VD: 1.9

VOLTAGE ANGLE: -2.8 DEGREES

PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR

LOAD FROM: 2006 A1 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 152 VOLTAGE DROP: 109. %VD: 2.62
PROJECTED POWER FLOW: 935. KW 534. KVAR 1077. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.2 KW 91.7 KVAR 92.8 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4080 %VD: 1.9

VOLTAGE ANGLE: -2.8 DEGREES

PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR

LOAD FROM: 2007 A2 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3106 B6 TRANSF AMPS: 90 VOLTAGE DROP: 24. %VD: .57
PROJECTED POWER FLOW: 552. KW 315. KVAR 636. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.0 KW 32.0 KVAR 32.4 KVA

DATE: 23 JUL 92 TIME: 7 18 PM
T=0 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4111 %VD: 1.2
----- VOLTAGE ANGLE: -2.2 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1479 VOLTAGE DROP: 31. %VD: .74
PROJECTED POWER FLOW: 8917. KW 5606. KVAR 10533. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 3. KW 144. KVAR 144. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1479
PROJECTED POWER FLOW: 8917. KW 5606. KVAR 10533. KVA PF: .85 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4080 %VD: 1.9
----- VOLTAGE ANGLE: -2.8 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 483 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2931. KW 1752. KVAR 3415. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 412 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2244. KW 1855. KVAR 2911. KVA PF: .77 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 368 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1147. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1479 VOLTAGE DROP: 31. %VD: .74
PROJECTED POWER FLOW: 8914. KW 5462. KVAR 10454. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 3. KW 144. KVAR 144. KVA

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 449 %VD: 6.55
----- VOLTAGE ANGLE: -8.3 DEGREES
PROJECTED SPECIAL BUS LOAD: 900. KW 490. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 1318 VOLTAGE DROP: 14. %VD: 2.91
PROJECTED POWER FLOW: 900. KW 490. KVAR 1025. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 14.8 KW 91.4 KVAR 92.6 KVA

DATE:23 JUL 92 TIME: 7 18 PM
T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Red Train Steady State, Green Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00

PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 433 %VD: 9.75
----- VOLTAGE ANGLE: -6.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 83. KW 407. KVAR
NET BRANCH DIVERSITY LOAD: 606. KW 439. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1453 VOLTAGE DROP: 29. %VD: 6.025
PROJECTED POWER FLOW: 689. KW 845. KVAR 1091. KVA PF: .63 LAGGING
LOSSES THRU TRANSF: 18.2 KW 115.9 KVAR 117.3 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 458 %VD: 4.5
----- VOLTAGE ANGLE: -6.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1287 VOLTAGE DROP: 13. %VD: 2.62
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.2 KW 91.7 KVAR 92.8 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 468 %VD: 2.5
----- VOLTAGE ANGLE: -5.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 760 VOLTAGE DROP: 3. %VD: .57
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.0 KW 32.0 KVAR 32.4 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
92. KW 1173. KVAR

WARNING STUDY CONTAINS 4 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 7 23 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 7 23 PM
 T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER DESCRIPTION SIZE TYPE DUCT INSUL |
|------------------------|----------------------|------------|--------------|-------------|--|
| 1 SYSTEM | 200 161KV APL | 1 | 161000. | 1000. FT | |
| IMPEDANCE: | 3.1131 + J19.4200 | | | OHMS/M FEET | |
| 2001 2A1 | 2003 2A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J .1600 | | | OHMS/M FEET | |
| 2001 2A1 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |
| 2002 2A2 | 2004 2A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J .1600 | | | OHMS/M FEET | |
| 2002 2A2 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |
| 2006 A1 | 2008 A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |
| 2007 A2 | 2009 A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |
| 2901 ST2-CLR | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0005 + J .0220 | | | OHMS/M FEET | |
| 2902 ST2-A | 2006 A1 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |
| 2902 ST2-A | 2007 A2 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J .0000 | | | OHMS/M FEET | |

SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS
 Calculated From Largest 3-PHASE Fault Contribution

DATE:23 JUL 92 TIME: 7 23 PM
 T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

TRANSFORMER DATA

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|--|--------------|------------|-------------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: 1.2315 + J 7.6110 PERCENT | 4055. | 142. | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: 1.2438 + J 7.9432 PERCENT | 4055. | 142. | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: 1.2396 + J 8.0046 PERCENT | 4055. | 142. | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: 1.2532 + J 8.0126 PERCENT | 4055. | 142. | 3106 B6 | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME: 7 23 PM
T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * DATA | BRANCH DATA | % IMPEDANCE R X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|-------------|------------------|-------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | |

DATE: 23 JUL 92 TIME: 7 23 PM
 T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

BRANCH LOAD DATA

| FROM BUS | / TO BUS | BR. TYPE | CONSTANT KVA KVA | KVA %PF | CONSTANT Z KVA | %PF | CONSTANT I KVA | %PF | FLOW DIR. |
|---------------|-------------|-------------|---------------------|------------|-------------------|-----|-------------------|-----|--------------|
| 1 SYSTEM | | | | | | | | | |
| 200 | 161KV APL | FEEDER | 2529 | -85.9 | | | | | |
| 2001 2A1 | | | | | | | | | |
| 2003 | 2A3 | FEEDER | 2529 | -85.9 | | | | | |
| 2902 | ST2-A | FEEDER | 2529 | -85.9 | | | | | REV |
| 2901 ST2-CLR | | | | | | | | | |
| 2902 | ST2-A | FEEDER | 2529 | -85.9 | | | | | |
| 200 161KV APL | | | | | | | | | |
| 2901 | ST2-CLR | TRANS. | 2529 | -85.9 | | | | | |
| 2003 2A3 | | | | | | | | | |
| 3005 | 2B5 | TRANS. | 796 | -81.0 | | | | | |

DATE:23 JUL 92 TIME: 7 23 PM
T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

```
=====
* NO * NAME * KW * KVAR * LOAD/GENERATION
=====
```

| | | | | |
|------|-----|-------|-------|-------------------|
| 2003 | 2A3 | 1023. | 3961. | CONSTANT Z LOAD |
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 114. | 555. | CONSTANT Z LOAD |
| 3006 | 2B6 | 850. | 463. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 7 23 PM
T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***

=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 4090.97 KVA | |
| CONVERGENCE CRITERIA: | .205 | |
| LARGEST BUS MISMATCH | 2003 2A3 | 284.551 KVA |
| LARGEST BUS MISMATCH | 3005 235 | 26.156 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 3.270 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .463 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .065 KVA |

DATE:23 JUL 92 TIME: 7 23 PM
T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9
----- VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 49 VOLTAGE DROP: 1371. %VD: .85
PROJECTED POWER FLOW: 9324. KW 9792. KVAR 13521. KVA PF: .69 LAGGING
LOSSES THRU FEEDER: 22. KW 139. KVAR 141. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 49 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 9324. KW 9792. KVAR 13521. KVA PF: .69 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158212 %VD: 1.7
----- VOLTAGE ANGLE: -.3 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 49 VOLTAGE DROP: 1371. %VD: .85
PROJECTED POWER FLOW: 9301. KW 9652. KVAR 13405. KVA PF: .69 LAGGING
LOSSES THRU FEEDER: 22. KW 139. KVAR 141. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 49
PROJECTED POWER FLOW: 9301. KW 9653. KVAR 13405. KVA PF: .69 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3994 %VD: 4.0
----- VOLTAGE ANGLE: -3.0 DEGREES
LOAD TO: 2003 2A3 FEED. AMPS: 912 VOLTAGE DROP: 221. %VD: 5.32\$
PROJECTED POWER FLOW: 3130. KW 5478. KVAR 6309. KVA PF: .50 LAGGING
LOSSES THRU FEEDER: 12. KW 399. KVAR 399. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 912 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 3130. KW 5478. KVAR 6309. KVA PF: .50 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 7 23 PM
T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3994 %VD: 4.0
----- VOLTAGE ANGLE: -3.0 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 405 VOLTAGE DROP: 59. %VD: 1.43
PROJECTED POWER FLOW: 2400. KW 1442. KVAR 2800. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 2. KW 79. KVAR 79. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 405 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2400. KW 1442. KVAR 2800. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3773 %VD: 9.35
----- VOLTAGE ANGLE: -4.8 DEGREES

PROJECTED SPECIAL BUS LOAD: 841. KW 3258. KVAR
NET BRANCH DIVERSITY LOAD: 1529. KW 825. KVAR

LOAD FROM: 2001 2A1 FEEDER AMPS: 912 VOLTAGE DROP: 221. %VD: 5.325
PROJECTED POWER FLOW: 3113. KW 5079. KVAR 5959. KVA PF: .52 LAGGING
LOSSES THRU FEEDER: 12. KW 399. KVAR 399. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 191 VOLTAGE DROP: 277. %VD: 6.655
PROJECTED POWER FLOW: 748. KW 996. KVAR 1245. KVA PF: .60 LAGGING
LOSSES THRU TRANSF: 22.1 KW 136.4 KVAR 138.2 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3935 %VD: 5.45
----- VOLTAGE ANGLE: -4.3 DEGREES

PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR

LOAD FROM: 2002 2A2 FEEDER AMPS: 405 VOLTAGE DROP: 59. %VD: 1.43
PROJECTED POWER FLOW: 2398. KW 1364. KVAR 2758. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 2. KW 79. KVAR 79. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 150 VOLTAGE DROP: 123. %VD: 2.95
PROJECTED POWER FLOW: 864. KW 552. KVAR 1025. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 13.9 KW 88.6 KVAR 89.7 KVA

DATE:23 JUL 92 TIME: 7 23 PM
T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00

PER ULIT DRIVING VOLTAGE = .9912

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3994 %VD: 4.0
----- VOLTAGE ANGLE: -3.0 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 377 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1151. KVAR 2605. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 377 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1151. KVAR 2605. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3994 %VD: 4.0
----- VOLTAGE ANGLE: -3.0 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 227 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 227 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3994 %VD: 4.0
----- VOLTAGE ANGLE: -3.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 377 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2337. KW 1151. KVAR 2605. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 156 VOLTAGE DROP: 117. %VD: 2.81
PROJECTED POWER FLOW: 936. KW 538. KVAR 1080. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.9 KW 96.2 KVAR 97.3 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 3994 %VD: 4.0
----- VOLTAGE ANGLE: -3.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 227 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 710. KVAR 1573. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE: 23 JUL 92 TIME: 7 23 PM

T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP

SYSTEM VOLT=0.9912, Greer Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.0

PER UNIT DRIVING VOLTAGE = .9912

| | | |
|---|-----------------|----------------------------|
| LOAD TO: 3106 B6 | TRANSF AMPS: 92 | VOLTAGE DROP: 29. %VD: .70 |
| PROJECTED POWER FLOW: 552. KW 316. KVAR | 636. KVA | PF: .87 LAGGING |
| LOSSES THRU TRANSF: 5.2 KW 33.5 KVAR | 33.9 KVA | |

| | | |
|---|----------------------|-----------------------------|
| LOAD BUS: 2901 ST2-CLR | DESIGN VOLTAGE: 4160 | LOAD VOLTAGE: 4044 %VD: 2.8 |
| | | VOLTAGE ANGLE: -2.2 DEGREES |
| LOAD TO: 2902 ST2-A | FEEDER AMPS: 1846 | VOLTAGE DROP: 50. %VD: 1.20 |
| PROJECTED POWER FLOW: 9275. KW 9006. KVAR | 12928. KVA | PF: .72 LAGGING |
| LOSSES THRU FEEDER: 5. KW 225. KVAR | 225. KVA | |

| | | |
|--|--------------------|-----------------|
| LOAD FROM: 200 161KV AFL AND: 1200 H BUSES | 3W XFMR AMPS: 1846 | |
| PROJECTED POWER FLOW: 9275. KW 9006. KVAR | 12928. KVA | PF: .72 LAGGING |
| | ***XFMR TAPS | -2.5%*** |

| | | |
|---|----------------------|-----------------------------|
| LOAD BUS: 2902 ST2-A | DESIGN VOLTAGE: 4160 | LOAD VOLTAGE: 3994 %VD: 4.0 |
| | | VOLTAGE ANGLE: -3.0 DEGREES |
| LOAD TO: 2001 2A1 | FEEDER AMPS: 912 | VOLTAGE DROP: 0. %VD: .00 |
| PROJECTED POWER FLOW: 3130. KW 5478. KVAR | 6309. KVA | PF: .50 LAGGING |
| LOSSES THRU FEEDER: 0. KW 0. KVAR | 0. KVA | |

| | | |
|---|------------------|---------------------------|
| LOAD TO: 2002 2A2 | FEEDER AMPS: 405 | VOLTAGE DROP: 0. %VD: .00 |
| PROJECTED POWER FLOW: 2400. KW 1442. KVAR | 2800. KVA | PF: .86 LAGGING |
| LOSSES THRU FEEDER: 0. KW 0. KVAR | 0. KVA | |

| | | |
|---|------------------|---------------------------|
| LOAD TO: 2006 A1 | FEEDER AMPS: 377 | VOLTAGE DROP: 0. %VD: .00 |
| PROJECTED POWER FLOW: 2337. KW 1151. KVAR | 2605. KVA | PF: .90 LAGGING |
| LOSSES THRU FEEDER: 0. KW 0. KVAR | 0. KVA | |

| | | |
|--|------------------|---------------------------|
| LOAD TO: 2007 A2 | FEEDER AMPS: 227 | VOLTAGE DROP: 0. %VD: .00 |
| PROJECTED POWER FLOW: 1403. KW 710. KVAR | 1573. KVA | PF: .89 LAGGING |
| LOSSES THRU FEEDER: 0. KW 0. KVAR | 0. KVA | |

| | | |
|---|-------------------|-----------------------------|
| LOAD FROM: 2901 ST2-CLR | FEEDER AMPS: 1846 | VOLTAGE DROP: 50. %VD: 1.20 |
| PROJECTED POWER FLOW: 9270. KW 8782. KVAR | 12769. KVA | PF: .73 LAGGING |
| LOSSES THRU FEEDER: 5. K 225. KVAR | 225. KVA | |

DATE:23 JUL 92 TIME: 7 23 PM
 T=90 SECONDS, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

 VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
 VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
 PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 403 %VD: 16.0\$

 VOLTAGE ANGLE: -8.0 DEGREES
 PROJECTED SPECIAL BUS LOAD: 81. KW 392. KVAR
 NET BRANCH DIVERSITY LOAD: 646. KW 467. KVAR
 LOAD FROM: 2003 2A3 TRANSF AMPS: 1610 VOLTAGE DROP: 32. %VD: 6.65\$
 PROJECTED POWER FLOW: 726. KW 859. KVAR 1125. KVA PF: .65 LAGGING
 LOSSES THRU TRANSF: 22.1 KW 136.4 KVAR 133.2 KVA

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 440 %VD: 8.4\$

 VOLTAGE ANGLE: -8.3 DEGREES
 PROJECTED SPECIAL BUS LOAD: 850. KW 463. KVAR
 LOAD FROM: 2004 2A4 TRANSF AMPS: 1271 VOLTAGE DROP: 14. %VD: 2.95
 PROJECTED POWER FLOW: 850. KW 463. KVAR 968. KVA PF: .88 LAGGING
 LOSSES THRU TRANSF: 13.9 KW 88.6 KVAR 89.7 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 447 %VD: 6.8\$

 VOLTAGE ANGLE: -7.2 DEGREES
 PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
 LOAD FROM: 2008 A3 TRANSF AMPS: 1318 VOLTAGE DROP: 13. %VD: 2.81
 PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
 LOSSES THRU TRANSF: 14.9 KW 96.2 KVAR 97.3 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 457 %VD: 4.7

 VOLTAGE ANGLE: -5.4 DEGREES
 PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
 LOAD FROM: 2009 A4 TRANSF AMPS: 777 VOLTAGE DROP: 3. %VD: .70
 PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
 LOSSES THRU TRANSF: 5.2 KW 33.5 KVAR 33.9 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
 124. KW 1843. KVAR

WARNING STUDY CONTAINS 9 VOLTAGE CRITERIA VIOLATIONS
 VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train SS W/Swing Loads
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 1 11 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 1 11 PM
 T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train SS W/Swing Loads
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

```

=====
FEEDER FROM      FEEDER TO      QTY VOLTS      LENGTH      FEEDER DESCRIPTION
NO NAME          NO NAME        /PH  L-L
=====
1 SYSTEM         200 161KV APL  1  161000.  1000. FT
  IMPEDANCE:     3.1131 + J19.4200 OHMS/M FEET

2001 2A1         2003 2A3       1   4160.  1000. FT
  IMPEDANCE:     .0047 + J .1600 OHMS/M FEET

2001 2A1         2902 ST2-A     1   4160.  1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET

2002 2A2         2004 2A4       1   4160.  1000. FT
  IMPEDANCE:     .0047 + J .1600 OHMS/M FEET

2002 2A2         2902 ST2-A     1   4160.  1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET

2006 A1          2008 A3        1   4160.  1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET

2007 A2          2009 A4        1   4160.  1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET

2901 ST2-CLR     2902 ST2-A     1   4160.  1000. FT
  IMPEDANCE:     .0005 + J .0220 OHMS/M FEET

2902 ST2-A       2006 A1        1   4160.  1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET

2902 ST2-A       2007 A2        1   4160.  1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET
=====
  
```

```

=====
SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS
Calculated From Largest 3-PHASE Fault Contribution
=====
  
```

DATE: 23 JUL 92 TIME: 1 11 PM
 T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train SS W/Swing Loads
 ENTERGY OPERATIONS INC.

TRANSFORMER DATA

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * PERCENT | SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|--|--------------|------------|--------------|-----------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: 1.2315 + J 7.6110 | 4055. | 142. | PERCENT | 3005 2B5 | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: 1.2438 + J 7.9432 | 4055. | 142. | PERCENT | 3006 2B6 | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: 1.2396 + J 8.0046 | 4055. | 142. | PERCENT | 3105 B5 | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: 1.2532 + J 8.0126 | 4055. | 142. | PERCENT | 3106 B6 | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME: 1 11 PM
 T=Steady State, ST #2 Unit 2 MS1 ; Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train SS W/Swing Loads
 ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * * | BRANCH DATA | % k | IMPEDANCE X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|-------------|-----------|----------------|----------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J | 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J | 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J | 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | | |

DATE: 21 JUL 92 TIME: 1 11 PM
Steady state, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOL = 0.9912, Green Train Steady State, Red Train SS W/Swing Loads
WILLIAMS CORPORATION INC.

BRANCH LOAD DATA

| FROM BUS | TO BUS | BR. TYPE | CONSTANT KVA KVA | CONSTANT Z %PF | CONSTANT I KVA | FLOW %PF DIR. |
|-------------|-----------|-------------|---------------------|-------------------|-------------------|------------------|
|-------------|-----------|-------------|---------------------|-------------------|-------------------|------------------|

DATE: 23 JUL 92 TIME: 1 11 PM
T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train SS W/Swing Loads
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

| * NO * | NAME | * KW | * KVAR | LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2003 | 2A3 | 2013. | 1058. | CONSTANT KVA LOAD |
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 961. | 533. | CONSTANT KVA LOAD |
| 3006 | 2B6 | 850. | 463. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE:23 JUL 92 TIME: 1 11 PM
T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train SS W/Swing Loads
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | | |
|-----------------------|---------|-----|-------------|
| LARGEST LOAD: | 2274.10 | KVA | |
| CONVERGENCE CRITERIA: | .114 | KVA | |
| LARGEST BUS MISMATCH | 2003 | 2A3 | 136.699 KVA |
| LARGEST BUS MISMATCH | 3005 | 2B5 | 18.899 KVA |
| LARGEST BUS MISMATCH | 3005 | 2B5 | 2.801 KVA |
| LARGEST BUS MISMATCH | 3005 | 2B5 | .410 KVA |
| LARGEST BUS MISMATCH | 3005 | 2B5 | .060 KVA |

DATE:23 JUL 92 TIME: 1 11 PM
T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train SS W/Swing Loads
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:159583 %VD: .9

VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 39 VOLTAGE DROP: 875. %VD: .54
PROJECTED POWER FLOW: 9167. KW 5750. KVAR 10821. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 14. KW 89. KVAR 90. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 39 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 9167. KW 5750. KVAR 10821. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:158708 %VD: 1.4

VOLTAGE ANGLE: -.4 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 39 VOLTAGE DROP: 875. %VD: .54
PROJECTED POWER FLOW: 9153. KW 5661. KVAR 10762. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 14. KW 89. KVAR 90. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 39
PROJECTED POWER FLOW: 9153. KW 5661. KVAR 10762. KVA PF: .85 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4089 %VD: 1.7

VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 494 VOLTAGE DROP: 73. %VD: 1.75
PROJECTED POWER FLOW: 2994. KW 1814. KVAR 3501. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 3. KW 117. KVAR 117. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 494 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2994. KW 1814. KVAR 3501. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 1 11 PM
T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train SS W/Swing Loads
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4089 %VD: 1.7
----- VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 395 VOLTAGE DROP: 58. %VD: 1.39
PROJECTED POWER FLOW: 2399. KW 1434. KVAR 2795. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 2. KW 75. KVAR 75. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 395 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2399. KW 1434. KVAR 2795. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4016 %VD: 3.5
----- VOLTAGE ANGLE: -4.5 DEGREES
PROJECTED SPECIAL BUS LOAD: 2013. KW 1058. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 494 VOLTAGE DROP: 73. %VD: 1.75
PROJECTED POWER FLOW: 2991. KW 1697. KVAR 3439. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 3. KW 117. KVAR 117. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 168 VOLTAGE DROP: 141. %VD: 3.33
PROJECTED POWER FLOW: 978. KW 639. KVAR 1168. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 17.1 KW 105.9 KVAR 107.3 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4031 %VD: 3.1
----- VOLTAGE ANGLE: -4.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 395 VOLTAGE DROP: 58. %VD: 1.39
PROJECTED POWER FLOW: 2397. KW 1359. KVAR 2755. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 2. KW 75. KVAR 75. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 146 VOLTAGE DROP: 114. %VD: 2.74
PROJECTED POWER FLOW: 863. KW 547. KVAR 1022. KVA PF: .34 LAGGING
LOSSES THRU TRANSF: 13.1 KW 83.9 KVAR 85.0 KVA

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4089 %VD: 1.7
----- VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 367 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 1 11 PM
I=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train SS W/Swing Loads
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD FROM: 2902 ST2-A FEEDER AMPS: 367 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4089 %VD: 1.7

VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4089 %VD: 1.7

VOLTAGE ANGLE: -2.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 367 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 152 VOLTAGE DROP: 108. %VD: 2.60
PROJECTED POWER FLOW: 935. KW 533. KVAR 1076. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.1 KW 91.2 KVAR 92.3 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4089 %VD: 1.7

VOLTAGE ANGLE: -2.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3106 B6 TRANSF AMPS: 90 VOLTAGE DROP: 23. %VD: .56
PROJECTED POWER FLOW: 552. KW 315. KVAR 635. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.0 KW 31.8 KVAR 32.2 KVA

DATE:23 JUL 92 TIME: 1 11 PM
T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train SS W/Swing Loads
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4117 %VD: 1.0
----- VOLTAGE ANGLE: -2.2 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1477 VOLTAGE DROP: 29. %VD: .69
PROJECTED POWER FLOW: 9136. KW 5247. KVAR 10536. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 3. KW 144. KVAR 144. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1477
PROJECTED POWER FLOW: 9136. KW 5247. KVAR 10536. KVA PF: .87 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4089 %VD: 1.7
----- VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 494 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2994. KW 1814. KVAR 3501. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 395 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2399. KW 1434. KVAR 2795. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 367 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1477 VOLTAGE DROP: 29. %VD: .69
PROJECTED POWER FLOW: 9133. KW 5103. KVAR 10462. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 3. KW 144. KVAR 144. KVA

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 447 %VD: 6.95
----- VOLTAGE ANGLE: -8.7 DEGREES
PROJECTED SPECIAL BUS LOAD: 961. KW 533. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 1419 VOLTAGE DROP: 16. %VD: 3.38
PROJECTED POWER FLOW: 961. KW 533. KVAR 1099. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 17.1 KW 105.9 KVAR 107.3 KVA

DATE:23 JUL 92 TIME: 1 11 PM
T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train SS W/Swing Loads
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 452 %VD: 5.8\$

VOLTAGE ANGLE: -8.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 850. KW 463. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 1236 VOLTAGE DROP: 13. %VD: 2.74
PROJECTED POWER FLOW: 850. KW 463. KVAR 968. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 13.1 KW 83.9 KVAR 85.0 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 459 %VD: 4.3

VOLTAGE ANGLE: -7.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR
LOAD FROM: 2008 A3 TRANSF AMPS: 1284 VOLTAGE DROP: 12. %VD: 2.60
PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING
LOSSES THRU TRANSF: 14.1 KW 91.2 KVAR 92.3 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 469 %VD: 2.3

VOLTAGE ANGLE: -5.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR
LOAD FROM: 2009 A4 TRANSF AMPS: 758 VOLTAGE DROP: 3. %VD: .56
PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING
LOSSES THRU TRANSF: 5.0 KW 31.8 KVAR 32.2 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***
90. KW 1152. KVAR

WARNING STUDY CONTAINS 2 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 7 27 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 7 27 PM
 T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VCLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

F E E D E R D A T A

```

=====
FEEDER FROM      FEEDER TO      QTY VOLTS      LENGTH      FEEDER DESCRIPTION
NO NAME          NO NAME        /PH  L-L
=====
1 SYSTEM         200 161KV APL  1  161000.  1000. FT
  IMPEDANCE:     3.1131 + J19.4200 OHMS/M FFET
2001 2A1         2003 2A3       1   4160.   1000. FT
  IMPEDANCE:     .0047 + J .1600 OHMS/M FEET
2001 2A1         2902 ST2-A     1   4160.   1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET
2002 2A2         2004 2A4       1   4160.   1000. FT
  IMPEDANCE:     .0047 + J .1600 OHMS/M FEET
2002 2A2         2902 ST2-A     1   4160.   1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET
2006 A1          2008 A3        1   4160.   1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET
2007 A2          2009 A4        1   4160.   1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET
2901 ST2-CLR     2902 ST2-A     1   4160.   1000. FT
  IMPEDANCE:     .0005 + J .0220 OHMS/M FEET
2902 ST2-A       2006 A1        1   4160.   1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET
2902 ST2-A       2007 A2        1   4160.   1000. FT
  IMPEDANCE:     .0000 + J .0000 OHMS/M FEET
=====
  
```

```

=====
SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS
Calculated From Largest 3-PHASE Fault Contribution
=====
  
```

DATE:23 JUL 92 TIME: 7 27 PM
T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

T R A N S F O R M E R D A T A

| PRIMARY RECORD NO NAME | VOLTS L-L | PRI FLA | * SECONDARY RECORD NO NAME | VOLTS L-L | SEC FLA | NOMINAL KVA |
|---------------------------|---------------------|----------------|-------------------------------|--------------|------------|----------------|
| 2003 2A3 IMPEDANCE: | 4055. 1.2315 + J | 142. 7.6110 | 3005 2B5 PERCENT | 480. | 1203. | 1000.0 |
| 2004 2A4 IMPEDANCE: | 4055. 1.2438 + J | 142. 7.9432 | 3006 2B6 PERCENT | 480. | 1203. | 1000.0 |
| 2008 A3 IMPEDANCE: | 4055. 1.2396 + J | 142. 8.0046 | 3105 B5 PERCENT | 480. | 1203. | 1000.0 |
| 2009 A4 IMPEDANCE: | 4055. 1.2532 + J | 142. 8.0126 | 3106 B6 PERCENT | 480. | 1203. | 1000.0 |

DATE:23 JUL 92 TIME: 7 27 PM
 T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
 SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
 ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * * | BRANCH DATA | % R | IMPEDANCE X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|-------------|-----------|----------------|----------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J | 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J | 4.6000 | 12600.0 |
| TERTIARY | 2901 | ST2-CLR | 4160. | * | SEC-TER | .3700 + J | 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | | |

DATE:23 JUL 92 TIME: 7 27 PM
T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BRANCH LOAD DATA

| FROM | TO | BR. | CONSTANT KVA | CONSTANT Z | CONSTANT I | FLOW |
|------|-----|------|--------------|------------|------------|----------|
| BUS | BUS | TYPE | KVA | %PF | KVA | %PF DIR. |

DATE:23 JUL 92 TIME: 7 27 PM
T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

| * NO * | NAME | * KW | * KVAR | * LOAD/GENERATION |
|--------|------|-------|--------|-------------------|
| 2003 | 2A3 | 2013. | 1058. | CONSTANT KVA LOAD |
| 2004 | 2A4 | 1534. | 812. | CONSTANT KVA LOAD |
| 2008 | A3 | 1401. | 613. | CONSTANT KVA LOAD |
| 2009 | A4 | 851. | 394. | CONSTANT KVA LOAD |
| 3005 | 2B5 | 900. | 490. | CONSTANT KVA LOAD |
| 3006 | 2B6 | 911. | 505. | CONSTANT KVA LOAD |
| 3105 | B5 | 921. | 442. | CONSTANT KVA LOAD |
| 3106 | B6 | 547. | 283. | CONSTANT KVA LOAD |

DATE: 2 JUL 92 TIME: 7 27 PM
T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***

=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : .9912
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODEL TV : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOP SIZE: 38

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 2274.10 KVA | |
| CONVERGENCE CRITERIA: | .114 KVA | |
| LARGEST BUS MISMATCH | 2002 2A3 | 134.711 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 16.433 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | 2.394 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .346 KVA |
| LARGEST BUS MISMATCH | 3006 2B6 | .050 KVA |

DATE: 23 JUL 92 TIME: 7 27 PM
T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 1 SYSTEM DESIGN VOLTAGE: 161000 LOAD VOLTAGE: 159583 %VD: .9
----- VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 39 VOLTAGE DROP: 875. %VD: .54
PROJECTED POWER FLOW: 9167. KW 5747. KVAR 10820. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 14. KW 89. KVAR 90. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 39 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 9167. KW 5747. KVAR 10820. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE: 161000 LOAD VOLTAGE: 158708 %VD: 1.4
----- VOLTAGE ANGLE: -.4 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 39 VOLTAGE DROP: 875. %VD: .54
PROJECTED POWER FLOW: 9153. KW 5658. KVAR 10760. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 14. KW 89. KVAR 90. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 39
PROJECTED POWER FLOW: 9153. KW 5658. KVAR 10761. KVA PF: .85 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4089 %VD: 1.7
----- VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2003 2A3 FEEDER AMPS: 482 VOLTAGE DROP: 70. %VD: 1.69
PROJECTED POWER FLOW: 2931. KW 1751. KVAR 3414. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 3. KW 112. KVAR 112. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 482 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2931. KW 1751. KVAR 3414. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE: 23 JUL 92 TIME: 7 27 PM
T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4089 %VD: 1.7
----- VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 407 VOLTAGE DROP: 60. %VD: 1.45
PROJECTED POWER FLOW: 2463. KW 1495. KVAR 2881. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 2. KW 79. KVAR 79. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 407 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2463. KW 1495. KVAR 2881. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4018 %VD: 3.4
----- VOLTAGE ANGLE: -4.5 DEGREES
PROJECTED SPECIAL BUS LOAD: 2013. KW 1058. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 482 VOLTAGE DROP: 70. %VD: 1.69
PROJECTED POWER FLOW: 2928. KW 1639. KVAR 3355. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 3. KW 112. KVAR 112. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 156 VOLTAGE DROP: 120. %VD: 2.89
PROJECTED POWER FLOW: 915. KW 581. KVAR 1084. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 14.7 KW 91.0 KVAR 92.2 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4028 %VD: 3.2
----- VOLTAGE ANGLE: -4.2 DEGREES
PROJECTED SPECIAL BUS LOAD: 1534. KW 812. KVAR
LOAD FROM: 2002 2A2 FEEDER AMPS: 407 VOLTAGE DROP: 60. %VD: 1.45
PROJECTED POWER FLOW: 2460. KW 1415. KVAR 2835. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 2. KW 79. KVAR 79. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 158 VOLTAGE DROP: 135. %VD: 3.24
PROJECTED POWER FLOW: 926. KW 603. KVAR 1106. KVA PF: .84 LAGGING
LOSSES THRU TRANSF: 15.4 KW 98.4 KVAR 99.6 KVA

LOAD BUS: 2006 A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4089 %VD: 1.7
----- VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2008 A3 FEEDER AMPS: 367 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 7 27 PM
T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DRCP MODELED
VOLTAGE DROP CRITLRIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD FROM: 2902 ST2-A FEEDER AMPS: 367 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2007 A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4089 %VD: 1.7
----- VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2009 A4 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2008 A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4089 %VD: 1.7
----- VOLTAGE ANGLE: -2.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 1401. KW 613. KVAR
LOAD FROM: 2006 A1 FEEDER AMPS: 367 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3105 B5 TRANSF AMPS: 152 VOLTAGE DROP: 108. %VD: 2.60
PROJECTED POWER FLOW: 935. KW 533. KVAR 1076. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 14.1 KW 91.2 KVAR 92.3 KVA

LOAD BUS: 2009 A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4089 %VD: 1.7
----- VOLTAGE ANGLE: -2.9 DEGREES
PROJECTED SPECIAL BUS LOAD: 851. KW 394. KVAR
LOAD FROM: 2007 A2 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 3106 B6 TRANSF AMPS: 90 VOLTAGE DROP: 23. %VD: .56
PROJECTED POWER FLOW: 552. KW 315. KVAR 635. KVA PF: .87 LAGGING
LOSSES THRU TRANSF: 5.0 KW 31.8 KVAR 32.2 KVA

DATE: 23 JUL 92 TIME: 7 27 PM
T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
INTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4117 %VD: 1.0
----- VOLTAGE ANGLE: -2.2 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 1477 VOLTAGE DROP: 29. %VD: .69
PROJECTED POWER FLOW: 9136. KW 5244. KVAR 10534. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 3. KW 144. KVAR 144. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 1477
PROJECTED POWER FLOW: 9136. KW 5244. KVAR 10534. KVA PF: .87 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4089 %VD: 1.7
----- VOLTAGE ANGLE: -2.9 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 482 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2931. KW 1751. KVAR 3414. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 407 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2463. KW 1495. KVAR 2881. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2006 A1 FEEDER AMPS: 367 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2336. KW 1146. KVAR 2602. KVA PF: .90 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: 222 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 1403. KW 709. KVAR 1572. KVA PF: .89 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 1477 VOLTAGE DROP: 29. %VD: .69
PROJECTED POWER FLOW: 9133. KW 5100. KVAR 10460. KVA PF: .87 LAGGING
LOSSES THRU FEEDER: 3. KW 144. KVAR 144. KVA

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 450 %VD: 6.35
----- VOLTAGE ANGLE: -8.4 DEGREES
PROJECTED SPECIAL BUS LOAD: 900. KW 490. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 1315 VOLTAGE DROP: 14. %VD: 2.89
PROJECTED POWER FLOW: 900. KW 490. KVAR 1025. KVA PF: .88 LAGGING
LOSSES THRU TRANSF: 14.7 KW 91.0 KVAR 92.2 KVA

DATE:23 JUL 92 TIME: 7 27 PM
T=Steady State, ST #2 Unit 2 MSLB Unit 1 LOOP
SYSTEM VOLT=0.9912, Green Train Steady State, Red Train Sequencing
ENTERGY OPERATIONS INC

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00

PER UNIT DRIVING VOLTAGE = .9912

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 449 %VD: 6.45

VOLTAGE ANGLE: -8.3 DEGREES

PROJECTED SPECIAL BUS LOAD: 911. KW 505. KVAR

LOAD FROM: 2004 2A4 TRANSF AMPS: 1338 VOLTAGE DROP: 16. %VD: 3.24

PROJECTED POWER FLOW: 911. KW 505. KVAR 1042. KVA PF: .87 LAGGING

LOSSES THRU TRANSF: 15.4 KW 98.4 KVAR 99.6 KVA

LOAD BUS: 3105 B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 459 %VD: 4.3

VOLTAGE ANGLE: -7.0 DEGREES

PROJECTED SPECIAL BUS LOAD: 921. KW 442. KVAR

LOAD FROM: 2008 A3 TRANSF AMPS: 1284 VOLTAGE DROP: 12. %VD: 2.60

PROJECTED POWER FLOW: 921. KW 442. KVAR 1022. KVA PF: .90 LAGGING

LOSSES THRU TRANSF: 14.1 KW 91.2 KVAR 92.3 KVA

LOAD BUS: 3106 B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 469 %VD: 2.3

VOLTAGE ANGLE: -5.2 DEGREES

PROJECTED SPECIAL BUS LOAD: 547. KW 283. KVAR

LOAD FROM: 2009 A4 TRANSF AMPS: 758 VOLTAGE DROP: 3. %VD: .56

PROJECTED POWER FLOW: 547. KW 283. KVAR 616. KVA PF: .89 LAGGING

LOSSES THRU TRANSF: 5.0 KW 31.8 KVAR 32.2 KVA

17 BUSES

*** TOTAL SYSTEM LOSSES ***

89. KW 1150. KVAR

WARNING STUDY CONTAINS 2 VOLTAGE CRITERIA VIOLATIONS
VIOLATIONS DENOTED BY (\$) AT BUS AND BRANCH %VD LOCATIONS

Minimum Loading Conditions (Unit 2 Outage)
SYSTEM VOLT=1.05
ENTERGY OPERATIONS INC.

DATE: 23 JUL 92
TIME: 7 36 PM

ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL
INTERPRETATION AND APPLICATION BY A REGISTERED
ENGINEER ONLY

DAPPER (LOAD FLOW AND VOLTAGE DROP MINI/MICRO VERSION 3.5 LEVEL 2.1)
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1983

DATE:23 JUL 92 TIME: 7 36 PM
 Minimum Loading Conditions (Unit 2 Outage)
 SYSTEM VOLT=1.05
 ENTERGY OPERATIONS INC.

Attachment 69
 Calc 92-E-0065-01
 Page 2 of 11

PAGE 2

F E E D E R D A T A

| FEEDER FROM NO NAME | FEEDER TO NO NAME | QTY /PH | VOLTS L-L | LENGTH | FEEDER DESCRIPTION SIZE TYPE DUCT INSUL |
|------------------------|----------------------|------------|--------------|----------|--|
| 1 SYSTEM | 200 161KV APL | 1 | 161000. | 1000. FT | |
| IMPEDANCE: | .2592 + J | .2592 | OHMS/M | FEET | |
| 2001 2A1 | 2003 2A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J | .1600 | OHMS/M | FEET | |
| 2001 2A1 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | OHMS/M | FEET | |
| 2002 2A2 | 2004 2A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0047 + J | .1600 | OHMS/M | FEET | |
| 2002 2A2 | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | OHMS/M | FEET | |
| 2006 A1 | 2008 A3 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | OHMS/M | FEET | |
| 2007 A2 | 2009 A4 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | OHMS/M | FEET | |
| 2901 ST2-CLR | 2902 ST2-A | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0005 + J | .0220 | OHMS/M | FEET | |
| 2902 ST2-A | 2006 A1 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | OHMS/M | FEET | |
| 2902 ST2-A | 2007 A2 | 1 | 4160. | 1000. FT | |
| IMPEDANCE: | .0000 + J | .0000 | OHMS/M | FEET | |

SOURCE BUS THEVENIN EQUIVALENT IMPEDANCE: .000000000 + J .000000000 OHMS
 Calculated From Largest 3-PHASE Fault Contribution

DATE:23 JUL 92 TIME: 7 36 PM
Minimum Loading Conditions (Unit 2 Outage)
SYSTEM VOLT=1.05
ENTERGY OPERATIONS INC.

Attachment 69
Calc 92-E-0065-01
Page 3 of 11

PAGE 3

TRANSFORMER DATA

```
=====
PRIMARY RECORD      VOLTS      PRI * SECONDARY RECORD      VOLTS      SEC      NOMINAL
NO NAME            L-L        FLA   NO NAME            L-L        FLA      KVA
=====
2003 2A3           4055.      142.  3005 2B5           480.      1203.   1000.0
IMPEDANCE: 1.2315 + J 7.6110 PERCENT
2004 2A4           4055.      142.  3006 2B6           480.      1203.   1000.0
IMPEDANCE: 1.2438 + J 7.9432 PERCENT
2008 A3            4055.      142.  3105 B5           480.      1203.   1000.0
IMPEDANCE: 1.2396 + J 8.0046 PERCENT
2009 A4            4055.      142.  3106 B6           480.      1203.   1000.0
IMPEDANCE: 1.2532 + J 8.0126 PERCENT
=====
```

DATE:23 JUL 92 TIME: 7 36 PM
 Minimum Loading Conditions (Unit 2 Outage)
 SYSTEM VOLT=1.05
 ENTERGY OPERATIONS INC.

TRANSFORMER DATA (THREE WINDING)

| BUS DATA | NO | NAME | VOLTS L-L | * * | BRANCH DATA | % R | IMPEDANCE X | NOMINAL KVA |
|---------------------------|------|-----------|-----------|--------|-------------|-----------|----------------|----------------|
| PRIMARY | 200 | 161KV APL | 161000. | * | PRI-SEC | .2000 + J | 4.7800 | 15000.0 |
| SECONDARY | 1200 | H BUSES | 6900. | * | PRI-TER | .1900 + J | 4.6000 | 12600.0 |
| TERTIARY | 2901 | S22-CLR | 4770. | * | SEC-TER | .3700 + J | 8.9000 | 12600.0 |
| PRIMARY FIXED TAP: -2.5 % | | | | | | | | |

DATE:23 JUL 92 TIME: 7 36 PM
Minimum Loading Conditions (Unit 2 Outage)
SYSTEM VOLT=1.05
ENTERGY OPERATIONS INC.

BRANCH LOAD DATA

```
=====
FROM / TO BR. CONSTANT KVA CONSTANT Z CONSTANT I FLOW
BUS / BUS TYPE KVA %PF KVA %PF KVA %PF DIR.
=====
```

DATE:23 JUL 92 TIME: 7 36 PM
Minimum Loading Conditions (Unit 2 Outage)
SYSTEM VOLT=1.05
ENTERGY OPERATIONS INC.

B U S S P E C I A L S T U D Y D A T A

```
=====
* NO *   NAME   *   KW   *   KVAR *   LOAD/GENERATION
=====
2001 2A1            913.      495.    CONSTANT KVA LOAD
2003 2A3            831.      467.    CONSTANT KVA LOAD
3005 2B5            361.      252.    CONSTANT KVA LOAD
3006 2B6            361.      252.    CONSTANT KVA LOAD
=====
```


DATE:23 JUL 92 TIME: 7 36 PM
Minimum Loading Conditions (Unit 2 Ou+age)
SYSTEM VOLT=1.05
ENTERGY OPERATIONS INC.

*** SOLUTION COMMENTS ***
=====

SOLUTION PARAMETERS

PER UNIT DRIVING VOLTAGE : 1.0500
BRANCH VOLTAGE CRITERIA : 4.00 %
BUS VOLTAGE CRITERIA : 5.00 %
EXACT(ITERATIVE) SOLUTION : YES
TRANSFORMERS MODELED : YES

<<PERCENT VOLTAGE DROPS ARE BASED ON NOMINAL DESIGN VOLTAGES>>

TOF SIZE: 58

| | | |
|-----------------------|-------------|-------------|
| LARGEST LOAD: | 1038.55 KVA | |
| CONVERGENCE CRITERIA: | .052 KVA | |
| LARGEST BUS MISMATCH | 2001 2A1 | 146.964 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | 3.117 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .138 KVA |
| LARGEST BUS MISMATCH | 3005 2B5 | .006 KVA |

DATE:23 JUL 92 TIME: 7 36 PM
Minimum Loading Conditions (Unit 2 Outage)
SYSTEM VOLT=1.05
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL PUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00

PER UNIT DRIVING VOLTAGE = 1.0500

LOAD PUS: 1 SYSTEM DESIGN VOLTAGE:161000 LOAD VOLTAGE:169050 %VD: -5.0

VOLTAGE ANGLE: .0 DEGREES
LOAD TO: 200 161KV APL FEEDER AMPS: 10 VOLTAGE DROP: 6. %VD: .00
PROJECTED POWER FLOW: 2472. KW 1546. KVAR 2916. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: **** SOURCE FEEDER AMPS: 10 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2472. KW 1546. KVAR 2916. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 200 161KV APL DESIGN VOLTAGE:161000 LOAD VOLTAGE:169044 %VD: -5.0

VOLTAGE ANGLE: .0 DEGREES
LOAD FROM: 1 SYSTEM FEEDER AMPS: 10 VOLTAGE DROP: 6. %VD: .00
PROJECTED POWER FLOW: 2472. KW 1546. KVAR 2916. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 1200 H BUSES AND: 2901 ST2-CLR 3W XFMR AMPS: 10
PROJECTED POWER FLOW: 2472. KW 1547. KVAR 2916. KVA PF: .85 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 1200 H BUSES *** NO LOAD SPECIFIED ***

LOAD BUS: 2001 2A1 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4449 %VD: -6.9

VOLTAGE ANGLE: -.6 DEGREES
PROJECTED SPECIAL BUS LOAD: 913. KW 495. KVAR
LOAD TO: 2003 2A3 FEEDER AMPS: 183 VOLTAGE DROP: 28. %VD: .67
PROJECTED POWER FLOW: 1195. KW 748. KVAR 1409. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 0. KW 16. KVAR 16. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 318 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2108. KW 1243. KVAR 2447. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

DATE:23 JUL 92 TIME: 7 36 PM
Minimum Loading Conditions (Unit 2 Outage)
SYSTEM VOLT=1.05
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED

VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00

PER UNIT DRIVING VOLTAGE = 1.0500

LOAD BUS: 2002 2A2 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4449 %VD: -6.9
----- VOLTAGE ANGLE: -.6 DEGREES
LOAD TO: 2004 2A4 FEEDER AMPS: 58 VOLTAGE DROP: 10. %VD: .24
PROJECTED POWER FLOW: 363. KW 267. KVAR 451. KVA PF: .81 LAGGING
LOSSES THRU FEEDER: 0. KW 2. KVAR 2. KVA

LOAD FROM: 2902 ST2-A FEEDER AMPS: 58 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 363. KW 267. KVAR 451. KVA PF: .81 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD BUS: 2003 2A3 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4421 %VD: -6.3
----- VOLTAGE ANGLE: -1.1 DEGREES
PROJECTED SPECIAL BUS LOAD: 831. KW 467. KVAR
LOAD FROM: 2001 2A1 FEEDER AMPS: 183 VOLTAGE DROP: 28. %VD: .67
PROJECTED POWER FLOW: 1194. KW 732. KVAR 1401. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 0. KW 16. KVAR 16. KVA

LOAD TO: 3005 2B5 TRANSF AMPS: 59 VOLTAGE DROP: -21. %VD: -.52
PROJECTED POWER FLOW: 363. KW 265. KVAR 449. KVA PF: .81 LAGGING
LOSSES THRU TRANSF: 2.1 KW 12.9 KVAR 13.1 KVA

LOAD BUS: 2004 2A4 DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4439 %VD: -6.7
----- VOLTAGE ANGLE: -.8 DEGREES
LOAD FROM: 2002 2A2 FEEDER AMPS: 58 VOLTAGE DROP: 10. %VD: .24
PROJECTED POWER FLOW: 363. KW 265. KVAR 450. KVA PF: .81 LAGGING
LOSSES THRU FEEDER: 0. KW 2. KVAR 2. KVA

LOAD TO: 3006 2B6 TRANSF AMPS: 58 VOLTAGE DROP: -19. %VD: -.45
PROJECTED POWER FLOW: 363. KW 265. KVAR 450. KVA PF: .81 LAGGING
LOSSES THRU TRANSF: 2.1 KW 13.4 KVAR 13.6 KVA

LOAD BUS: 2006 A1

*** NO LOAD SPECIFIED ***

DATE:23 JUL 92 TIME: 7 36 PM
Minimum Loading Conditions (Unit 2 Outage)
SYSTEM VOLT=1.05
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = 1.0500

LOAD BUS: 2007 A2 *** NO LOAD SPECIFIED ***

LOAD BUS: 2008 A3 *** NO LOAD SPECIFIED ***

LOAD BUS: 2009 A4 *** NO LOAD SPECIFIED ***

LOAD BUS: 2901 ST2-CLR DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4457 %VD: -7.1
----- VOLTAGE ANGLE: -.4 DEGREES
LOAD TO: 2902 ST2-A FEEDER AMPS: 376 VOLTAGE DROP: 8. %VD: .19
PROJECTED POWER FLOW: 2471. KW 1519. KVAR 2901. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 0. KW 9. KVAR 9. KVA

LOAD FROM: 200 161KV APL AND: 1200 H BUSES 3W XFMR AMPS: 376
PROJECTED POWER FLOW: 2471. KW 1519. KVAR 2901. KVA PF: .85 LAGGING
XFMR TAPS -2.5%

LOAD BUS: 2902 ST2-A DESIGN VOLTAGE: 4160 LOAD VOLTAGE: 4449 %VD: -6.9
----- VOLTAGE ANGLE: -.6 DEGREES
LOAD TO: 2001 2A1 FEEDER AMPS: 318 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 2108. KW 1243. KVAR 2447. KVA PF: .86 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2002 2A2 FEEDER AMPS: 58 VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 363. KW 267. KVAR 451. KVA PF: .81 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2006 A1 FEEDER AMPS: VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 0. KW 0. KVAR 0. KVA PF: .00 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD TO: 2007 A2 FEEDER AMPS: VOLTAGE DROP: 0. %VD: .00
PROJECTED POWER FLOW: 0. KW 0. KVAR 0. KVA PF: .00 LAGGING
LOSSES THRU FEEDER: 0. KW 0. KVAR 0. KVA

LOAD FROM: 2901 ST2-CLR FEEDER AMPS: 376 VOLTAGE DROP: 8. %VD: .19
PROJECTED POWER FLOW: 2471. KW 1510. KVAR 2896. KVA PF: .85 LAGGING
LOSSES THRU FEEDER: 0. KW 9. KVAR 9. KVA

DATE:23 JUL 92 TIME: 7 36 PM
Minimum Loading Conditions (Unit 2 Outage)
SYSTEM VOLT=1.05
ENTERGY OPERATIONS INC.

BALANCED VOLTAGE DROP AND LOAD FLOW ANALYSIS (SPECIAL BUS LOAD REPORT)

VOLTAGE EFFECT ON LOADS MODELED TRANSFORMER VOLTAGE DROP MODELED
VOLTAGE DROP CRITERIA: BRANCH = 4.00 % BUS = 5.00
PER UNIT DRIVING VOLTAGE = 1.0500

LOAD BUS: 3005 2B5 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 513 %VD: -6.8
----- VOLTAGE ANGLE: -2.3 DEGREES
PROJECTED SPECIAL BUS LOAD: 361. KW 252. KVAR
LOAD FROM: 2003 2A3 TRANSF AMPS: 496 VOLTAGE DROP: -2. %VD: -.52
PROJECTED POWER FLOW: 361. KW 252. KVAR 440. KVA PF: .82 LAGGING
LOSSES THRU TRANSF: 2.1 KW 12.9 KVAR 13.1 KVA

LOAD BUS: 3006 2B6 DESIGN VOLTAGE: 480 LOAD VOLTAGE: 514 %VD: -7.2
----- VOLTAGE ANGLE: -2.0 DEGREES
PROJECTED SPECIAL BUS LOAD: 361. KW 252. KVAR
LOAD FROM: 2004 2A4 TRANSF AMPS: 494 VOLTAGE DROP: -2. %VD: -.45
PROJECTED POWER FLOW: 361. KW 252. KVAR 440. KVA PF: .82 LAGGING
LOSSES THRU TRANSF: 2.1 KW 13.4 KVAR 13.6 KVA

LOAD BUS: 3105 B5 *** NO LOAD SPECIFIED ***

LOAD BUS: 3106 B6 *** NO LOAD SPECIFIED ***

17 BUSES

*** TOTAL SYSTEM LOSSES ***
6. KW 80. KVAR