		1200				-					-														-	-			-
(9-83)														API	UCLEAR REGULATORY COMMISSION APPROVED OMB NO 3150-0104 EXPIRES 8/31/85														
FACILITY	CILITY NAME (1)															DOC	KET	NUMB	BER (2	21	PAGE (3)								
	- · D · · · · · · · · · · · · · · · · ·															0	5	0 1	0	0	2 15	1	0	1 0	OF 0	1			
Eng.		ed S	Saf	ety	Fe	atur	res A	ctu	ation	- Rea	actor	Т	rip	/M	G Set	ts	De-	ene	rgiz	zed			- 1						
EVENT DATE (5) LER NUMBER (6)										-	PORT DA		T	OTHER FACILITIES IN VI							VOL	DLVED (8)							
MONTH	MONTH DAY		R	YEAR		SEQUENTIAL NUMBER			REVISION	MONTH	DAY	Y	YEAR		N/A			MES				0 5 0 0							
0 1	2 9	8	5	8 5	-	0	0 4		00	0 2	2 8	8	15	5	N/A									5 10				1	_
OPI	ERATING	1	7	HIS RI	EPOR	T IS SI	JBMITTE	D PU	RSUANT	TO THE RE	EQUIRE	HEN'	TS O	F 10	CFR 8: 10	Check	one o	or more	of th	e foile	owing	(11)							
	ODE (9)	0	7 0	20	0.402(b) 0.406(a)(1)(i) 0.406(a)(1)(ii)				20.405(c) 50.38(c)(1) 50.36(c)(2)						50.73(a)(2)(iv) 50.73(a)(2)(v) 50.73(a)(2)(vii) 50.73(a)(2)(viii)(A)						73.71(b) 73.71(c) OTHER (Specify in Abstract below and in Text, NRC Form 366.4)								
			F	20	0.405((a)(1)(iii (a)(1)(iv (a)(1)(v)	w)	50.73(a)(2)(i) 60.73(a)(2)(ii) 50.73(a)(2)(iii)					50.73(a)(2)(viii)(B) 50.73(a)(2)(x)																
										LICENSEE	CONTAC	T FC	OR TH	HIS L	ER (12)						_			HONE					
R.	L. Teu	ıteb	er	g, R	egi	ulat	ion a	nd	Comp	oliance	e Eng	gin	eei	,			J.				01	DE						9 1	10
						co	MPLETE	ONE	LINE FOR	R EACH CO	MPONE	IT F	AILU	REC	DESCRIBER	DIN	THIS	REPO	RT (1	3)									
CAUSE	SYSTEM	cor	MPON	VENT		MANUFAC REPORTABLE TO NPRDS				E			CAUSE SY		SYSTEM	STEM COMPONENT		NENT	MANUFAC- TURER				REPORTABLE TO NPROS						
		_1	1	1																1	1	1							
		1	1	1		1									1			1		1	1	1							
						S	UPPLEME	NTA	L REPORT	EXPECTE	D (14)			_										N	TON	н	DAY	YE	EAR

ABSTRACT (Limit to 1400 spaces i.e. approximately fifteen single-space typewritten lines) (16)

Event: On January 29, 1985, at 11:14 a.m.,

YES III yes complete EXPECTED SUBMISSION DATE

Event: On January 29, 1985, at 11:14 a.m., while Unit 3 was at 100% power and Unit 4 was proceeding from hot shutdown to cold shutdown conditions under administrative controls, the non-licensed Operations personnel who had been instructed to remove the A and B MG sets of Unit 4 from service, inadvertently entered the Unit 3 motor control center room and removed A and B MG sets for Unit 3 from service instead. Since the MG sets supply power to the control rod system, isolating this power source resulted in the de-energization of the control rod drive mechanisms which allowed the control rods to drop to full insertion, i.e., a reactor trip. Following the reactor trip, Off-Normal Operating Procedure 0208.1, Shutdown Resulting from Reactor Trip or Turbine Trip, was initiated. A post-trip review was performed and all equipment functioned as designed upon actuation of the Reactor Protection System Features. The USNRC was notified of a Significant Event pursuant to 10CFR50.72(B)(2)(ii) via the ENS at 12:50 p.m. The health and safety of the public were not affected. Similar Occurrences: LER 250-84-003, 250-84-005, 250-84-014, 250-85-003, 251-84-008, and 251-84-021.

X NO

<u>Cause of Event:</u> The reactor trip was the result of personnel oversight when the Unit 3 MG sets were inadvertently removed from service rather than those for Unit 4. Room markings distinguishing Unit 3's from Unit 4's motor control center rooms had recently been removed for installation of new Appendix R fire doors and painting of these doors.

Corrective Actions: The licensed and non-licensed personnel involved were individually counseled concerning this event. The room markings were reposted. The rod drive MG sets control cabinets' identification was enhanced. Although removing the MG sets from service on a shutdown unit is not a critical evolution, the consequences of performing the evolution on the opposite unit must be considered. Instructions were issued to Operations personnel concerning the use of qualified personnel on critical evolutions. The event will be reviewed in operator requalification class.

IE22



PR 2 8 1985

L-85-86

U. S. Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

Gentlemen:

Re: Reportable Event 85-04

Turkey Point Unit 3

Date of Event: January 29, 1985 Engineered Safety Feature Actuation -Reactor Trip/MG Sets De-Energized

The attached Licensee Event Report is being submitted pursuant to the requirements of 10 CFR to provide notification of the subject event.

Very truly yours,

J. W. Williams, Jr.
Group Vice President
Nuclear Energy

JWW/SAV/js

Attachment

cc: Dr. J. Nelson Grace

Harold F. Reis, Esquire

File 933.1 PNS-LI-85-84-1

IEZZ ...