

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) LaSalle County Station Unit 2	DOCKET NUMBER (2) 0 5 0 0 0 3 7 4	PAGE (3) 1 OF 0 3
--	--------------------------------------	----------------------

TITLE (4)
Unsecured High Radiation Area

EVENT DATE (6)			LER NUMBER (8)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)										
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)								
1	0	9	8	4	0	7	0	0	1	0	3	1	8	4	0	5	0	0	0

OPERATING MODE (9) 1

POWER LEVEL (10) 1 0 0

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)

20.402(b)	20.405(e)	90.73(a)(2)(iv)	73.71(b)
20.406(a)(1)(i)	90.38(a)(1)	90.73(a)(2)(v)	73.71(e)
20.406(a)(1)(ii)	90.38(a)(2)	90.73(a)(2)(vi)	OTHER (Specify in Abstract below and in Text, NRC Form 388A)
20.406(a)(1)(iii)	<input checked="" type="checkbox"/> 90.73(a)(2)(i)	90.73(a)(2)(vii)(A)	
20.406(a)(1)(iv)	90.73(a)(2)(ii)	90.73(a)(2)(vii)(B)	
20.406(a)(1)(v)	90.73(a)(2)(iii)	90.73(a)(2)(viii)	

LICENSEE CONTACT FOR THIS LER (12)

NAME L. R. Aldrich, extension 238	TELEPHONE NUMBER AREA CODE: 815 357 7676 1
--------------------------------------	---

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC
A	Z	Z 9 9 9	Z 9 9 9	N					

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)

MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

Upon notification of a security alarm at 1725 on October 9, 1984, a Radiation Chemistry Technician (RCT) was dispatched to door #128, the entrance to the Unit 2 Main Steam Tunnel located on the 687 elevation of the Auxiliary Building. The RCT found the door to be unsecured and held open by the ventilation flow. The RCT closed and secured the door. A review of the security computer card history reports for door #128 indicated that a contractor employee entered the area at 1642 and exited at 1655. The security door alarm annunciated at 1656. The contractor employee was counseled by the RCT about his responsibility for securing high radiation area doors. In addition, during the week of November 5, 1984, the Training Department will be training the onsite contractor personnel on high radiation area access procedures.

8411190216 841031
PDR ADOCK 05000374
S PDR

IE22
11

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) LaSalle County Station Unit 2	DOCKET NUMBER (2) 0500037484	LER NUMBER (8)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
		84	070	00	02	OF	03

TEXT (If more space is required, use additional NRC Form 386A's) (17)

I. EVENT DESCRIPTION

Upon notification of a security alarm at 1725 on October 9, 1984, a Radiation Chemistry Technician (RCT) was dispatched to Door #128, the entrance to the Unit 2 main steam tunnel located on the 687 elevation of the Auxiliary Building. The RCT found the door to be unsecured and unattended, being held open by the high ventilation flow. Contrary to Technical Specification 6.1.1, the high radiation area was unsecured and unattended.

II. CAUSE

A review of the security computer card history reports for door #128 on October 9, 1984, indicated that a contractor employee entered the area at 1642 and exited at 1655. The door was not secured properly and the security alarm annunciated at 1656. The high ventilation flow inward toward the main steam tunnel prevented the door from properly latching.

III. PROBABLE CONSEQUENCES OF OCCURRENCE

Review of the dosimetry data for the period in question indicates that no unauthorized radiation exposure greater than 50 mrem occurred. The door was unsecured for approximately 39 minutes.

IV. CORRECTIVE ACTION

Upon discovery of the unsecured door, the RCT closed and secured the door. The Security door alarm cleared at 1736. The contractor employee was counseled by the RCT about his responsibility for securing high radiation doors. During the week of November 5, 1984, the Training Department will be training the onsite contractor personnel on high radiation area access procedures. In addition, the Training Department instructors will be emphasizing the high radiation area access procedures and employee responsibilities during future Nuclear General Employee Training (NGET) and annual retraining classes. (AIR 1-84-67167)

V. PREVIOUS OCCURRENCES

During the year 1984 to date, eight (8) previous events of a similar nature have occurred. These events are documented in the following LER's.

373/84-025
373/84-036
373/84-034
373/84-042
374/84-022
374/84-044
374/84-038
374/84-049

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) LaSalle County Station Unit 2	DOCKET NUMBER (2) 0 5 0 0 0 3 7 4 8 4	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
		84	070	00	03	OF	03

TEXT (If more space is required, use additional NRC Form 366A's) (17)

VI. NAME AND TELEPHONE NUMBER OF PREPARER

L. R. Aldrich, 815/357-6761, extension 238.



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

October 31, 1984

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Dear Sir:

Reportable Occurrence Report #84-070-00, Docket #050-374 is being submitted to your office in accordance with 10CFR 50.73.

G. J. Diederich

for G. J. Diederich
Superintendent
LaSalle County Station

GJD/MLD/kg

Enclosure

xc: NRC, Regional Director
INPO-Records Center
File/NRC

IE22
11