


TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. #1 • DALLAS, TEXAS 75201

BILLY R. CLEMENTS
VICE PRESIDENT NUCLEAR OPERATIONS

February 25, 1985
TXX-4423



Mr. D.R. Hunter, Chief
Reactor Project Branch 2
U.S. Nuclear Regulatory Commission
Office of Inspection & Enforcement
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76012

Docket Nos.: 50-445
50-446

COMANCHE PEAK STEAM ELECTRIC STATION
ERF COMPUTER TERMINATION POINTS
QA FILE: CP-85-06, SDAR-167
FILE NO.: 10110

Dear Mr. Hunter:

On February 1, 1985 we verbally notified your Mr. D. Hunnicutt of a deficiency regarding termination points that have been found to be cracked or broken.

We are continuing our evaluation and anticipate completion by March 26, 1985.

Very truly yours,

A handwritten signature in cursive script that reads "Billy R. Clements".

BRC:tlg

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8503110088 850225
PDR ADOCK 05000445
S PDR

52-27
1/0