

July 29, 1992
LIC-92-225R

Omaha Public Power District
444 South 16th Street Mall
Omaha, Nebraska 68102-2247
402/636-2000

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, DC 20555

Reference: Docket No. 50-285

Gentlemen:

SUBJECT: Omaha Public Power District (OPPD) Response to NRC Bulletin No. 92-01, "Failure Of Thermo-Lag 330 Fire Barrier System To Maintain Cabling In Wide Cable Trays And Small Conduits Free From Fire Damage"

NRC Bulletin No. 92-01 requested that licensees provide a written notification stating whether or not Thermo-Lag 330 fire barrier systems are installed in their facilities.

The Fort Calhoun Station (FCS) Safe Shutdown Analysis (EA-FC-89-055, Revision 1) was reviewed to identify areas where credit is taken for 1-hour or 3-hour fire wrap systems. EA-FC-89-055 takes credit only for a single 1-hour fire wrap system located in the lower electrical penetration room (Fire Area 34A). Documentation associated with the modification that installed the 1-hour fire wrap in Fire Area 34A identifies it as a 3M brand Interam E50A flexible wrap system. Thus, no Thermo-Lag 330 fire barriers are installed at FCS and therefore the compensatory actions requested by NRC Bulletin No. 92-01 are not applicable to OPPD.

If you should have any questions, please contact me.

Sincerely,

for *W. G. Gates*
W. G. Gates
Division Manager
Nuclear Operations

WGG/sel

c: LeBoeuf, Lamb, Leiby & MacRae
J. L. Milligan, NRC Regional Administrator, Region IV
R. P. Mullikin, NRC Senior Resident Inspector
S. D. Bloom, NRC Acting Project Manager

9208030180 920729
PDR ADOCK 05000285
PDR

IE49
1/0