

Measurement

Penalties incurred due to repairs
or adjustments prior to the CILRT 0.133

"As Found" Type A test results 0.180

Appendix J acceptance criteria for the "as found" condition of the
containment = 0.75 La = 0.1875 wt %/day.

4. Open Items

Open items are matters which have been discussed with the licensee, which will be reviewed further by the inspector, and which involve some action on the part of the NRC or licensee or both. An open item disclosed during this inspection is discussed in Paragraph 2.a.(1).

5. Exit Interview

The inspector met with licensee representatives (denoted in Paragraph 1) at the conclusion of the inspection on September 28, 1984 and summarized the scope and findings of the inspection activities.