



ARKANSAS POWER & LIGHT COMPANY

POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

January 18, 1985

ØCANØ185Ø1


Mr. Richard P. Denise, Director  
Division of Resident Reactor Projects  
and Engineering Programs  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76011

SUBJECT: Arkansas Nuclear One - Units 1 & 2  
Docket Nos. 50-313 and 50-368  
License Nos. DPR-51 and NPF-6  
Response to Inspection Reports  
50-313/84-31 and 50-368/84-31

Gentlemen:

The subject reports have been reviewed. A response to the "Notice of Violation" is attached.

Very truly yours,

  
J. Ted Enos  
Manager, Licensing

JTE:RJS:ds

Attachment

cc: Mr. Richard C. DeYoung  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Mr. Norman M. Haller, Director  
Office of Management & Program Analysis  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

8503110264 850305  
PDR ADOCK 05000368  
Q PDR

## NOTICE OF VIOLATION

Based on the results of an NRC inspection conducted during the period of November 1-23, 1984, and in accordance with the NRC Enforcement Policy (10CFR Part 2, Appendix C), 47 FR 8583, dated March 8, 1984, the following violation was identified:

### Control of Combustibles

Unit 2 Technical Specification 6.8.1 requires that, "Written procedures shall be established, implemented, and maintained covering ... f. Fire Protection Program Implementation.

Administrative Procedure 1000.47, "Control of Combustibles," Revision 0, has been established in accordance with this Technical Specification.

Step 6.4.1 of this procedure requires that transient combustibles should not exceed the limits specified in Attachment 2.

Attachment 2 of this procedure permits no more than 5 pounds of ordinary combustibles in the Unit 2 elevation 317 general access area (Fire Zone 2006-LL).

Contrary to the above, on November 19, 1984, the NRC inspectors found an excessive amount of combustibles located in the Unit 2 elevation 317 general access area. The combustibles consisted of many bags of contaminated trash awaiting segregation and compacting.

This is Severity Level V Violation. (Supplement I.E.) (368/8431-01)

### RESPONSE

Upon notification by the NRC inspectors, a fire watch was promptly posted in the area, and full compliance with the procedure was achieved. The cognizant supervisor responsible for placing the combustibles in the area was counselled by the Safety and Fire Prevention Coordinator. In addition, Arkansas Power & Light Company is aware that the combustible limits in the Control of Combustibles procedures are very conservative. An evaluation of each zone included in the procedure is planned in order to determine more realistic limits based on actual conditions of the area.