

(c) for each percent that the magnitude of  $q_t - q_b$  exceeds -17 percent, the  $\Delta T$  trip setpoint shall be automatically reduced by an equivalent of 2.0 percent of rated power.

(5) Overpower  $\Delta T \left( \frac{1}{1+\tau_3 S} \right)$

$$\leq \Delta T_o \left( K_4 - K_5 \left( \frac{\tau_5 S}{\tau_5 S + 1} \right) \left( \frac{1}{1+\tau_4 S} \right) T - K_6 (T-T') - f(\Delta I) \right)$$

where

$\Delta T_o$  = indicated  $\Delta T$  at rated power, °F

T = average temperature, °F

T' = 574.2°F

$K_4 \leq$  1.089 of rated power

$K_5$  = 0.0262 for increasing %

= 0.0 for decreasing T

$K_6$  = 0.00123 for  $T \geq T'$

= 0.0 for  $T < T'$

$\tau_5$  = 10 sec

f ( $\Delta I$ ) as defined in (4) above,

$\tau_3$  = 2 sec for Rosemont or equivalent RTD

= 0 sec for Sostman or equivalent RTD

$\tau_4$  = 2 sec for Rosemont or equivalent RTD

= 0 sec for Sostman or equivalent RTD

(6) Undervoltage -  $\geq 75$  percent of normal voltage

(7) Indicated reactor coolant flow per loop -  $\geq 90$  percent of normal indicated loop flow

(8) Reactor coolant pump motor breaker open

(a) Low frequency set point  $\geq 57.5$  cps

(b) Low voltage set point  $\geq 75$  percent of normal voltage.

- (3)\* Low pressurizer pressure -  $\geq 1865$  psig for operation at 2250 psia primary system pressure  
 $\geq 1790$  psig for operation at 2000 psia primary system pressure

(4) Overtemperature  $\Delta T \left( \frac{1}{1+\tau_3 S} \right)$

$$\leq \Delta T_o \left( K_1 - K_2 \left( T \left( \frac{1}{1+\tau_4 S} \right) - T^1 \right) \left( \frac{1+\tau_1 S}{1+\tau_2 S} \right) + K_3 (P-P^1) - f(\Delta I) \right)$$

where

$\Delta T_o$  = indicated  $\Delta T$  at rated power, °F

$T$  = average temperature, F°

$T^1$  = 574.2 °F

$P$  = pressurizer pressure, psig

$P^1$  = 2235 psig

\* $K_1$   $\leq 1.117$  for operation at 2250 psia primary system pressure

$\leq 1.30$  for operation at 2000 psia primary system pressure

$K_2$  = 0.0150

$K_3$  = 0.000791

$\tau_1$  = 25 sec

$\tau_2$  = 3 sec

$\tau_3$  = 2 sec for Rosemont or equivalent RTD

= 0 sec for Sostman or equivalent RTD

$\tau_4$  = 2 sec for Rosemont or equivalent RTD

= 0 sec for Sostman or equivalent RTD

and  $f(\Delta I)$  is an even function of the indicated difference between top and bottom detectors of the power-range nuclear ion chambers; with gains to be selected based on measured instrument response during plant startup tests, where  $q_t$  and  $q_b$  are the percent power in the top and bottom halves of the core respectively, and  $q_t + q_b$  is total core power in percent of rated power, such that:

(a) for  $q_t - q_b$  within -17, +5 percent,  $f(\Delta I) = 0$ .

(b) for each percent that the magnitude of  $q_t - q_b$  exceeds +5 percent, the  $\Delta T$  trip set point shall be automatically reduced by an equivalent of 2.0 percent of rated power.

\* Appropriate safety analyses shall be performed prior to shifting operation from one primary system pressure to the other.