



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

METROPOLITAN EDISON COMPANY

JERSEY CENTRAL POWER AND LIGHT COMPANY

PENNSYLVANIA ELECTRIC COMPANY

GPU NUCLEAR CORPORATION

DOCKET NO. 50-289

THREE MILE ISLAND NUCLEAR STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 102
License No. DPR-50

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by GPU Nuclear Corporation, et al (the licensees) dated June 4, 1984, as supplemented August 8, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8411190605 841031
PDR ADOCK 05000289
P PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.c.(2) of Facility Operating License No. DPR-50 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 102, are hereby incorporated in the license. GPU Nuclear Corporation shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 31, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 102

FACILITY OPERATING LICENSE NO. DPR-50

DOCKET NO. 50-289

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

Remove

3-41

4-3

6-22

6-23

Insert

3-41

4-3

6-22

6-23

3.6 REACTOR BUILDING

Applicability

Applies to the containment integrity of the reactor building.

Objective

To assure containment integrity

Specifications

- 3.6.1 Containment integrity, as defined in Section 1.7, shall be maintained whenever all three of the following conditions exist:
- Reactor coolant pressure is 300 psig or greater.
 - Reactor coolant temperature is 200°F or greater.
 - Nuclear Fuel is in the core.
- 3.6.2 Containment integrity shall be maintained when both the reactor coolant system is open to the containment atmosphere and a shutdown margin exists that is less than that for a refueling shutdown.
- 3.6.3 Positive reactivity insertions which would result in a reduction in shutdown margin to less than 1% $\Delta k/k$ shall not be made by control rod motion or boron dilution unless containment integrity is being maintained.
- 3.6.4 The reactor shall not be critical when the reactor building internal pressure exceeds 2.0 psig or 1.0 psi vacuum.
- 3.6.5 Prior to criticality following refueling shutdown, a check shall be made to confirm that all manual containment isolation valves which should be closed are closed and are conspicuously marked.
- 3.6.6 If, while the reactor is critical, a reactor building isolation valve is determined to be inoperable in a position other than the required position, the other reactor building isolation valve in the line shall be tested to insure operability. If the inoperable valve is not restored within 48 hours, the operable valve will be closed or the reactor shall be brought to the cold shutdown condition within an additional 24 hours.
- 3.6.7 The hydrogen recombiner shall be operable during REACTOR CRITICAL, HOT STANDBY and POWER OPERATION. With the hydrogen recombiner inoperable, restore the recombiner to operable status or bring the reactor to HOT SHUTDOWN within seven (7) days.

TABLE 4.1-1
INSTRUMENT SURVEILLANCE REQUIREMENTS

<u>CHANNEL DESCRIPTION</u>	<u>CHECK</u>	<u>IESI</u>	<u>CALIBRATE</u>	<u>REMARKS</u>
1. Protection Channel Coincidence Logic	NA	M	NA	Includes independent testing of shunt trip and undervoltage trip features. (1) When reactor power is greater than 15%. (2) When above 15% reactor power run a heat balance check once per shift. Heat Balance calibration shall be performed whenever heat balance exceeds indicated neutron power by more than two percent. (1) When reactor power is greater than 60% verify imbalance using incore instrumentation. (2) When above 15% reactor power calculate axial offset upper and lower chambers after each startup if not done within the previous seven days. (1) When in service. (1) When in service.
2. Control Rod Drive Trip Breaker	NA	M	NA	
3. Power Range Amplifier	D(1)	NA	(2)	
4. Power Range Channel	S	M	M(1)(2)	
5. Intermediate Range Channel	S(1)	P	NA	
6. Source Range Channel	S(1)	P	NA	
7. Reactor Coolant Temperature Channel	S	M	R	
8. High Reactor Coolant Pressure Channel	S	M	R	
9. Low Reactor Coolant Pressure Channel.	S	M	R	

- c. documentation that the changes have been reviewed and approved pursuant to 6.8.2.

2. Shall become effective upon review and approval by GPUNC Management.

6.14 OFFSITE DOSE CALCULATION MANUAL (ODCM)

- 6.14.1 The ODCM shall be approved by the Commission prior to implementation.

- 6.14.2 GPU Nuclear Corporation initiated changes to the ODCM:

1. Shall be submitted to the NRC in the Semiannual Radioactive Effluent Release Report for the period in which the changes were made. This submittal shall contain:
 - a. sufficiently detailed information to justify the changes without benefit of additional or supplemental information;
 - b. a determination that the changes did not reduce the accuracy or reliability of dose calculations or setpoint determinations; and
 - c. documentation that the changes have been reviewed and approved pursuant to 6.8.2.
2. Shall become effective upon review and approval by GPUNC Management.

6.15 Deleted

6.16 POST-ACCIDENT SAMPLING PROGRAMS NUREG 0737 (II.B.3, II.F.1.2)

Programs which will ensure the capability to accurately sample and analyze vital areas under accident conditions have been implemented.

The following programs have been established:

1. Iodine and Particulate Sampling
2. Reactor Coolant Sampling
3. Containment Atmosphere Sampling

Each program shall be maintained and shall include the following:

1. Training of personnel,
2. Procedures, and
3. Provisions for maintenance of sampling and analysis equipment.

6.17 MAJOR CHANGES TO RADIOACTIVE WASTE TREATMENT SYSTEMS

6.17.1 GPU Nuclear Corporation initiated safety related changes to the radioactive waste system (liquid, gaseous and solid):

1. Shall be reported to the Commission in the Annual Report (Specification 6.9.1B) for the period in which the evaluation was reviewed. The discussion of each change shall contain:
 - a. A summary of the evaluation that led to the determination that the change could be made in accordance with 10 CFR 50.59;
 - b. Sufficient detailed information to totally support the reason for the change without benefit of additional or supplemental information;
 - c. A detailed description of the equipment, components and processes involved and the interfaces with other plant systems;
 - d. An evaluation of the change which shows the predicted releases of radioactive materials in liquid and gaseous effluents and/or quantity of solid waste that differ from those previously predicted in the license application and amendments thereto;
 - e. An evaluation of the change which shows the expected maximum exposures to individuals in the unrestricted area and to the general population that differ from those previously estimated in the license application and amendments thereto;
 - f. A comparison of the predicted releases of radioactive materials, in liquid and gaseous effluents and in solid waste, to the actual releases for the period prior to when the changes are to be made;
 - g. An estimate of the exposure to plant operating personnel as a result of the change; and
 - h. Documentation of the fact that the change was reviewed and