

NUREG-0020
Vol. 8, No. 9
September 1984

LICENSED OPERATING REACTORS

STATUS SUMMARY REPORT
DATA AS OF 08-31-83

UNITED STATES NUCLEAR REGULATORY COMMISSION



B411200011 841031
PDR NUREG
0020 R PDR

Available from

NRC/GPO Sales Program

Superintendent of Documents
Government Printing Office
Washington, D. C. 20402

A year's subscription consists of 12 issues for
this publication.

Single copies of this publication
are available from National Technical
Information Service, Springfield, VA 22161

Microfiche of single copies are
available from NRC/GPO Sales Program:
Washington, D. C. 20555

NUREG-0020
Vol. 8, No. 9
September 1984

LICENSED OPERATING REACTORS

STATUS SUMMARY REPORT

DATA AS OF 08-31-83

Manuscript Completed: October 1984
Date Published: October 1984

OFFICE OF RESOURCE MANAGEMENT
U.S. NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555



AUTHORIZATION AND CLEARANCE

The U.S. Nuclear Regulatory Commission's Office of Resource Management publishes this month status report "as part of the reporting requirements in Section 50.36 of 10 CFR Part 50 under GAO Clearance Number B-180225, with an expiration date of September 30, 1981," as stated in the October 3, 1978 letter from John M. Lovelady, Assistant Director, General Government Division, U.S. General Accounting Office, to J.M. Felton, Director, Division of Rules and Records, U.S. Nuclear Regulatory Commission

*Extended to April 30, 1985 by OMB Directive 3150-0011.

STATEMENT OF PURPOSE

The U.S. Nuclear Regulatory Commission's monthly LICENSED OPERATING REACTORS Status Summary Report provides data on the operation of nuclear units as timely and accurately as possible. This information is collected by the Office of Resource Management, from the Headquarters Staff of NRC's Office of Inspection and Enforcement, from NRC's Regional Offices, and from utilities. Since all of the data concerning operation of the units is provided by the utility operators less than two weeks after the end of the month, necessary corrections to published information are shown on the ERRATA page.

This report is divided into three sections: the first contains monthly highlights and statistics for commercial operating units, and errata from previously reported data; the second is a compilation of detailed information on each unit, provided by NRC Regional Offices, IE Headquarters and the Utilities; and the third section is an appendix for miscellaneous information such as spent fuel storage capability, reactor years of experience and non-power reactors in the United States.

The percentage computations, Items 20 through 24 in Section 2, the vendor capacity factors on page 1-7, and actual vs. potential energy production on Page 1-2 are computed using actual data for the period of consideration. The percentages listed in power generation on Page 1-2 are computed as an arithmetic average. The factors for the life-span of each unit (the "Cumulative" column) are reported by the utility and are not entirely re-computed by NRC. Utility power production data is checked for consistency with previously submitted statistics.

It is hoped this status report proves informative and helpful to all agencies and individuals interested in analyzing trends in the nuclear industry which might have safety implications, or in maintaining an awareness of the U.S. energy situation as a whole.

T A B L E O F C O N T E N T S

	PAGE
GLOSSARY	ii
INDEX TO LICENSED UNITS	vii
<u>SECTION 1 - CURRENT DATA SUMMARIES</u>	
MONTHLY HIGHLIGHTS OF COMMERCIAL NUCLEAR POWER UNITS	1-2
Licensed Power Reactors	1-2
Power Generation	1-2
Actual vs. Potential Energy Production	1-2
Outage Data	1-2
Reasons for Shutdown	1-3
Derated Units	1-3
Shutdowns Greater Than 72 Hours Each	1-3
UNIT AVAILABILITY, CAPACITY, AND FORCED OUTAGE RATE PLOT	1-4
AVERAGE DAILY POWER LEVEL FOR ALL COMMERCIAL OPERATING UNITS	1-5
AVERAGE CAPACITY FACTORS BY VENDOR	
Vendor Plot	1-6
Statistics	1-7
MEMORANDA - SPECIAL INFORMATION	1-8
ERRATA - CORRECTIONS TO PREVIOUSLY REPORTED DATA	1-9
<u>SECTION 2 - OPERATING POWER REACTORS</u>	
ARKANSAS 1 THROUGH ZION 2	2-002 through 2-386
For each reactor:	
Operating Status	
Average Daily Power Level (MWe) Plot	
Unit Shutdowns/Reductions Summary	
Facility Data	
Inspection Status	
Licensee Reports	
<u>SECTION 3 - APPENDIX</u>	
STATUS OF SPENT FUEL STORAGE CAPABILITY	3-2
REACTOR-YEARS OF OPERATION	3-4
NON-POWER REACTORS IN THE U.S.	3-5

G L O S S A R Y

AVERAGE DAILY POWER LEVEL (MWe)	The net electrical energy generated during the day (measured from 0001 to 2400 hours inclusive) in megawatts hours, divided by 24 hours.
LICENSED THERMAL POWER (MWt)	The maximum thermal power of the reactor authorized by the NRC, expressed in megawatts.
DATE OF COMMERCIAL OPERATION	Date unit was declared by utility owner to be available for the regular production of electricity; usually related to satisfactory completion of qualification tests as specified in the purchase contract and to accounting policies and practices of utility.
DESIGN ELECTRICAL RATING (DER) (NET MWe)	The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design.
FORCED OUTAGE	An outage required to be initiated no later than the weekend following discovery of an offnormal condition.
FORCED OUTAGE HOURS	The clock hours during the report period that a unit is unavailable due to forced outages.
GROSS ELECTRICAL ENERGY GENERATED (MWH)	Electrical output of the unit during the report period as measured at the output terminals of the turbine generator, in megawatts hours.
GROSS HOURS	The clock hours from the beginning of a specified situation until its end. For outage durations, the clock hours during which the unit is not in power production.
GROSS THERMAL ENERGY GENERATED (MWH)	The thermal energy produced by the unit during the report period as measured or computed by the licensee in megawatt hours.
HOURS GENERATOR ON-LINE	Also, "Unit Service Hours." The total clock hours in the report period during which the unit operated with breakers closed to the station bus. These hours added to the total outage hours experienced by the unit during the report period, shall equal the hours in the report period.
HOURS IN REPORTING PERIOD	For units in power ascension at the end of the period, the gross hours from the beginning of the period or the first electrical production, whichever comes last, to the end of the period. For units in commercial operation at the end of the period, the gross hours from the beginning of the period or of commercial operation, whichever comes last, to the end of the period or decommissioning, whichever comes first.

G L O S S A R Y (continued)

HOURS REACTOR CRITICAL	The total clock hours in the report period during which the reactor sustained a controlled chain reaction.
MAXIMUM DEPENDABLE CAPACITY (GROSS) (MDC Gross) (Gross MWe)	Dependable main-unit gross capacity, winter or summer, whichever is smaller. The dependable capacity varies because the unit efficiency varies during the year due to cooling water temperature variations. It is the gross electrical output as measured at the output terminals of the turbine generator during the most restrictive seasonal conditions (usually summer).
MAXIMUM DEPENDABLE CAPACITY (NET) (MDC Net) (Net MWe)	Maximum Dependable Capacity (Gross) less the normal station service loads.
NAMEPLATE RATING (Gross MWe)	The nameplate power designation of the generator in megavolt amperes (MVA) times the nameplate power factor of the generator. NOTE: The nameplate rating of the generator may not be indicative of the maximum or dependable capacity, since some other item of equipment of a lesser rating (e.g., turbine) may limit unit output.
NET ELECTRICAL ENERGY GENERATED	Gross electrical output of the unit measured at the output terminals of the turbine generator during the reporting period, minus the normal station service electrical energy utilization. If this quantity is less than zero, a negative number should be recorded.
OUTAGE	A situation in which no electrical production takes place.
OUTAGE DATE	As reported on Appendix D of Reg. Guide 1.16, the date of the start of the outage. If continued from a previous month, report the same outage date but change "Method of Shutting Down Reactor" to "4 (continuations)" and add a note: "Continued from previous month."
OUTAGE DURATION	The Total clock hours of the outage measured from the beginning of the report period or the outage, whichever comes last, to the end of the report period or the outage, whichever comes first.
OUTAGE NUMBER	A number unique to the outage assigned by the licensee. The same number is reported each month in which the outage is in progress. One format is "76-05" for the fifth outage to occur in 1976.
PERIOD HOURS	See "Hours in Reporting Period."
POWER REDUCTION	A reduction in the Average Daily Power Level of more than 20% from the previous day. All power reductions are defined as outage of zero hours durations for the purpose of computing unit service and availability factors, and forced outage rate.

G L O S S A R Y (continued)

REACTOR AVAILABLE HOURS	The Total clock hours in the report period during which the reactor was critical or was capable of being made critical. (Reactor Reserve Shutdown Hours + Hours Reactor Critical.)
REACTOR AVAILABILITY FACTOR	$\frac{\text{Reactor Available Hours} \times 100}{\text{Period Hours}}$
REACTOR RESERVE SHUTDOWN	The cessation of criticality in the reactor for administrative or other similar reasons when operation could have been continued.
REACTOR RESERVE SHUTDOWN HOURS	The total clock hours in the report period that the reactor is in reserve shutdown mode. NOTE: No credit is given for NRC imposed shutdowns.
REACTOR SERVICE FACTOR	$\frac{\text{Hours Reactor Critical} \times 100}{\text{Period Hours}}$
REPORT PERIOD	Usually, the preceding calendar month. Can also be the preceding calendar year, (Year-to-Date), or the life-span of a unit (cumulative).
RESTRICTED POWER LEVEL	Maximum net electrical generation to which the unit is restricted during the report period due to the state of equipment, external conditions, administrative reasons, or a direction by NRC.
SCHEDULED OUTAGE	Planned removal of a unit from service for refueling, inspection, training, or maintenance. Those outages which do not fit the definition of "Forced Outage" perforce are "Scheduled Outages."
STARTUP AND POWER ASCENSION TEST PHASE	Period following initial criticality during which the unit is tested at successive higher levels, culminating with operation at full power for a sustained period and completion of warranty runs. Following this phase, the utility generally considers the unit to be available for commercial operation.
UNIT	The set of equipment uniquely associated with the reactor, including turbine generators, and ancillary equipment, considered as a single electrical energy production facility.
UNIT AVAILABLE HOURS	The total clock hours in the report period during which the unit operated on-line or was capable of such operation. (Unit Reserve Shutdown Hours + Hours Generator On-Line.)

G L O S S A R Y (continued)

UNIT AVAILABILITY FACTOR	$\frac{\text{Unit Available Hours} \times 100}{\text{Period Hours}}$
UNIT CAPACITY FACTORS	
- Using Licensed Thermal Power	$\frac{\text{Gross Thermal Energy Generated} \times 100}{\text{Period Hours} \times \text{LIC. Thermal Power}}$
- Using Nameplate Rating	$\frac{\text{Gross Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{Nameplate Rating}}$
- Using DER	$\frac{\text{Net Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{DER}}$
- Using MDC Gross	$\frac{\text{Gross Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{MDC Gross}}$
- Using MDC Net	$\frac{\text{Net Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{MDC Net}}$
NOTE: if MDC GROSS and/or MDC NET have not been determined, the DER is substituted for this quantity for Unit Capacity Factor calculations.	
UNIT FORCED OUTAGE RATE	$\frac{\text{Forced Outage Hours}}{\text{Unit Service Hours} + \text{Forced Outage Hours}}$
UNIT RESERVE SHUTDOWN	The removal of the unit from on-line operation for economic or other similar reasons when operation could have been continued.
UNIT RESERVE SHUTDOWN HOURS	The total clock hours in the report period during which the unit was in reserve shutdown mode.
UNIT SERVICE FACTOR	$\frac{\text{Unit Service Hours} \times 100}{\text{Period Hours}}$
UNIT SERVICE HOURS	See "Hours Generator On-Line."

NOTE:

At the end of each statement in the Enforcement Summary for any given facility may be found numbers in parentheses. These numbers are related to the inspection, e.g., 8111 (the 11th inspection of the plant in 1981); and the severity level, e.g., 4 (severity level IV). Violations are ranked by severity levels from I through V with level I being the most serious. The severity level is used in the determination of any resulting enforcement action. Gray Book lists severity level by Arabic numbers corresponding to the Roman numerals. Details on the various severity levels and enforcement actions can be found in Appendix C to 10 CFR Part 2 published in the Federal Register of March 9, 1982 pages 9987 through 9995, and as corrected April 14, 1982.

INDEX TO OPERATING POWER REACTORS

	PAGE		PAGE
ARKANSAS 1	2-002	NORTH ANNA 1	2-190
ARKANSAS 2	2-006	NORTH ANNA 2	2-194
BEAVER VALLEY 1	2-010	OCONEE 1	2-198
BIG ROCK POINT 1	2-014	OCONEE 2	2-202
BROWNS FERRY 1	2-018	OCONEE 3	2-206
BROWNS FERRY 2	2-024	OYSTER CREEK 1	2-210
BROWNS FERRY 3	2-030	PALISADES	2-214
BRUNSWICK 1	2-036	PEACH BOTTOM 2	2-218
BRUNSWICK 2	2-042	PEACH BOTTOM 3	2-224
CALVERT CLIFFS 1	2-046	PILGRIM 1	2-228
CALVERT CLIFFS 2	2-052	POINT BEACH 1	2-234
COOK 1	2-056	POINT BEACH 2	2-238
COOK 2	2-060	PRAIRIE ISLAND 1	2-242
COOPER STATION	2-064	PRAIRIE ISLAND 2	2-246
CRYSTAL RIVER 3	2-068	QUAD CITIES 1	2-250
DAVIS-BESSE 1	2-072	QUAD CITIES 2	2-254
DRESDEN 2	2-076	RANCHO SECO 1	2-260
DRESDEN 3	2-080	ROBINSON 2	2-266
DUANE ARNOLD	2-084	SALEM 1	2-272
FARLEY 1	2-088	SALEM 2	2-278
FARLEY 2	2-094	SAN ONOFRE 1	2-284
FITZPATRICK	2-100	SAN ONOFRE 2	2-290
FORT CALHOUN 1	2-104	SAN ONOFRE 3	2-296
FORT ST VRAIN	2-108	SEQUOYAH 1	2-302
GINNA	2-114	SEQUOYAH 2	2-308
HADDAM NECK	2-120	ST LUCIE 1	2-312
HATCH 1	2-124	ST LUCIE 2	2-316
HATCH 2	2-128	SUMMER 1	2-320
INDIAN POINT 2	2-134	SURRY 1	2-326
INDIAN POINT 3	2-138	SURRY 2	2-330
KEWAUNEE	2-142	SUSQUEHANNA 1	2-334
LA CROSSE	2-146	SUSQUEHANNA 2	2-338
LASALLE 1	2-150	THREE MILE ISLAND 1	2-342
LASALLE 2	2-154	TROJAN	2-348
MAINE YANKEE	2-160	TURKEY POINT 3	2-352
MCGUIRE 1	2-166	TURKEY POINT 4	2-358
MCGUIRE 2	2-170	VERMONT YANKEE 1	2-364
MILLSTONE 1	2-174	WASHINGTON NUCLEAR 2	2-368
MILLSTONE 2	2-178	YANKEE-ROWE 1	2-374
MONTICELLO	2-182	ZION 1	2-378
NINE MILE POINT 1	2-186	ZION 2	2-382

SECTION 1

**CURRENT
DATA
SUMMARIES**

MONTHLY HIGHLIGHTS

***** 79 IN COMMERCIAL OPERATION 62,118 CAPACITY MWe (Net) --Based upon maximum dependable
 * LICENSED * (a) 3 IN POWER ASCENSION. 3,201 capacity; design elec. rating
 * POWER * --- used if MDC not determined
 * REACTORS * (b) 82 LICENSED TO OPERATE 65,319 TOTAL
 ***** (c) 3 LICENSED FOR FUEL LOADING
 AND LOW POWER TESTING

MDC NET		DER		DATE	DER
(a) LASALLE 2	1036	(b) Excludes these plants	1. DRESDEN 1	06/16/82	1250
WASH. NUC. 2	1100	licensed for operation	2. HUMBOLDT BAY	04/19/84	1084
SUSQUEHANNA 2	1065	which are shut down	3. TMI 2	06/11/84	1188
		indefinitely			

		REPORT MONTH	PREVIOUS MONTH	YEAR-TO-DATE
*****	1. GROSS ELECTRICAL (MWHE)	30,184,531	28,811,822	224,314,256
* POWER *	2. NET ELECTRICAL (MWHE)	28,742,464	27,430,862	213,260,960
* GENERATION *	3. AVG. UNIT SERVICE FACTOR (%)	68.2	64.2	63.3
*****	4. AVG. UNIT AVAILABILITY FACTOR (%)	68.2	64.2	63.3
	5. AVG. UNIT CAPACITY FACTOR (MDC) (%)	62.1	58.8	58.7
	6. AVG. UNIT CAPACITY FACTOR (DER) (%)	60.6	57.4	57.3
	7. FORCED OUTAGE RATE (%)	12.4	13.1	10.1

			% OF POTENTIAL PRODUCTION
*****	1. ENERGY ACTUALLY PRODUCED DURING THIS REPORT PERIOD.	28,742,464 NET	62.2
* ACTUAL VS. *	2. ENERGY NOT PRODUCED DUE TO SCHEDULED OUTAGES (NET).	8,979,422 MWhe	19.4
* POTENTIAL *	3. ENERGY NOT PRODUCED DUE TO FORCED OUTAGES (NET)	5,750,086 MWhe	12.4
* ENERGY *	4. ENERGY NOT PRODUCED FOR OTHER REASONS (NET)	2,743,819 MWhe	5.9
* PRODUCTION *			
*****	POTENTIAL ENERGY PRODUCTION IN THIS PERIOD BY UNITS IN COMMERCIAL OPERATION (Using Maximum Dependable Capacity Net)	46,215,792 MWhe	100.0% TOTAL
	5. ENERGY NOT PRODUCED DUE TO NRC-REQUIRED OUTAGES	786,216 MWhe	
	6. ENERGY NOT PRODUCED DUE TO NRC RESTRICTED POWER LEVELS.	0 MWhe	0 UNIT(S) WITH NRC RESTRICTION

		NUMBER	HOURS	PERCENT OF CLOCK TIME	MWHE LOST PRODUCTION
*****	1. FORCED OUTAGES DURING REPORT PERIOD	63	7,205.0	12.3	5,750,086
* OUTAGE *	2. SCHEDULED OUTAGES DURING REPORT PERIOD.	21	11,490.3	19.5	8,979,422
* DATA *					
*****	TOTAL	84	18,695.3	31.8	14,729,509

MWHE LOST PRODUCTION = Down time X maximum dependable capacity net

MONTHLY HIGHLIGHTS


REASONS FOR SHUTDOWNS		NUMBER	HOURS LOST
A - Equipment Failure		48	5,215.8
B - Maintenance or Test		7	1,958.8
C - Refueling		14	9,481.3
D - Regulatory Restriction		2	937.4
E - Operator Training & License Examination		0	0.0
F - Administrative		0	0.0
G - Operational Error		4	154.5
H - Other		9	947.5
TOTAL		84	18,695.3

DERATED FORT ST VRAIN MDC (MWe Net) 330 POWER LIMIT (MWe Net) 280 TYPE Self-imposed

UNIT	REASON	UNIT	REASON	UNIT	REASON	UNIT	REASON
ARKANSAS 2	A	BROWNS FERRY 1	B	BROWNS FERRY 3	C	BRUNSWICK 2	C
CALVERT CLIFFS 2	A	COOK 1	B	FITZPATRICK	A	FORT ST VRAIN	A
HADDAM NECK	C	HATCH 2	H	INDIAN POINT 2	C	LA CROSSE	A,A
MCGUIRE 2	A,A	MONTICELLO	C	NORTH ANNA 1	C	NORTH ANNA 2	C
OYSTER CREEK 1	C	PALISADES	A	PEACH BOTTOM 2	C	PILGRIM 1	C
QUAD CITIES 1	C	RANCHO SECO 1	A	ROBINSON 2	C	SALEM 1	A
SALEM 2	A	SAN ONOFRE 1	B	SAN ONOFRE 3	D	SEQUOYAH 2	A
THREE MILE ISLAND 1	D	TROJAN	C	TURKEY POINT 4	G	VERMONT YANKEE 1	C
YANKEE-ROWE 1	A	ZION 1	B				

Unit Availability, Capacity, Forced Outage

Avg. Unit Percentage as of 08-31-84




AVERAGE DAILY POWER LEVEL FOR ALL COMMERCIALY OPERATING UNITS

This chart depicts the average daily power level for the units in commercial operation during the month.

The straight line on the graph labelled "SUM OF MDC" is plotted at the value shown by summing the separate maximum dependable capacities of the commercially operating units (in Net MWe). The plot shown below the line is calculated by summing the separate average daily power levels of the same units for each day of the month.

The scale on the left vertical axis runs in 1,000 MWe increments from 0 to 55,000 MWe (Net). The right vertical axis shows the percentage in 10% increments, up to 100% of the "SUM OF MDC".


It should be recognized that the 100% line would be obtainable only if all of the commercially operating units operated at 100% capacity, 24 hours per day, for the entire month. In other words, since any power generator must occasionally shut down to refuel and/or perform needed maintenance, and also since 100% capacity production is not always required by power demands, the 100% line is a theoretical goal and not a practical one.



AUGUST 1984

Vendor Average Capacity Factors

As of 08-31-84



NOTE: This display of average capacity factors provides a general performance comparison of plants supplied by the four nuclear steam supply system vendors. One must be careful when drawing conclusions regarding the reasons for the performance levels indicated, since plant performance may be affected by unspecified factors such as: (1) various plant designs and models are included for each vendor; (2) turbine/generators and (3) different architect/engineers are also involved.

AVERAGE CAPACITY FACTORS BY VENDORS

***** CFMDC	CFMDC	CFMDC	CFMDC
* GENERAL * 64.4 BROWNS FERRY 1	60.9 BROWNS FERRY 2	0.0 BROWNS FERRY 3	85.0 BRUNSWICK 1
* ELECTRIC * 0.0 BRUNSWICK 2	72.0 COOPER STATION	87.5 DRESDEN 2	76.1 DRESDEN 3
***** 94.2 DUANE ARNOLD	70.1 FITZPATRICK	73.7 HATCH 1	0.0 HATCH 2
84.4 LASALLE 1	79.2 MILLSTONE 1	0.0 MONTICELLO	94.5 NINE MILE POINT 1
0.0 OYSTER CREEK 1	0.0 PEACH BOTTOM 2	90.5 PEACH BOTTOM 3	0.0 PILGRIM 1
23.9 QUAD CITIES 1	92.4 QUAD CITIES 2	97.0 SUSQUEHANNA 1	40.8 VERMONT YANKEE 1
***** CFMDC	CFMDC	CFMDC	CFMDC
* BABCOCK & * 80.4 ARKANSAS 1	94.4 CRYSTAL RIVER 3	87.5 DAVIS-BESSE 1	98.5 OCONEE 1
* WILCOX * 96.3 OCONEE 2	91.0 OCONEE 3	34.7 RANCHO SECO 1	0.0 THREE MILE ISLAND 1
***** CFMDC	CFMDC	CFMDC	CFMDC
* COMBUSTION * 89.8 ARKANSAS 2	90.8 CALVERT CLIFFS 1	83.8 CALVERT CLIFFS 2	97.8 FORT CALHOUN 1
* ENGINEERING * 102.1 MAINE YANKEE	95.0 MILLSTONE 2	8.0 PALISADES	87.4 SAN ONOFRE 2
***** 64.2 SAN ONOFRE 3	97.4 ST LUCIE 1	98.0 ST LUCIE 2	
***** CFMDC	CFMDC	CFMDC	CFMDC
* WESTINGHOUSE* 95.1 BEAVER VALLEY 1	53.9 COOK 1	91.6 COOK 2	101.7 FARLEY 1
***** 97.9 FARLEY 2	98.3 GINNA	0.0 HADDAM NECK	0.0 INDIAN POINT 2
80.1 INDIAN POINT 3	102.0 KEWAUNEE	89.1 MCGUIRE 1	23.0 MCGUIRE 2
0.0 NORTH ANNA 1	5.8 NORTH ANNA 2	102.2 POINT BEACH 1	100.5 POINT BEACH 2
93.0 PRAIRIE ISLAND 1	83.8 PRAIRIE ISLAND 2	0.0 ROBINSON 2	0.0 SALEM 1
70.2 SALEM 2	0.0 SAN ONOFRE 1	83.9 SEQUOYAH 1	60.5 SEQUOYAH 2
89.3 SUMMER 1	70.9 SURRY 1	89.8 SURRY 2	0.0 TROJAN
93.4 TURKEY POINT 3	81.9 TURKEY POINT 4	56.7 YANKEE-ROWE 1	3.0 ZION 1
91.9 ZION 2			

 * OTHER INFO *

Units excluded are:
 BIG ROCK POINT
 DRESDEN 1
 FORT ST VRAIN
 HUMBOLDT BAY
 LACROSSE
 THREE MILE ISLAND 2

Capacity factor in this page, denoted as CFMDC, is a function of the net maximum dependable capacity. See the corresponding definition in the glossary. The vendor averages are computed by the formula:

Net Electrical Energy Produced by Vendor x 100%

 Potential Electrical Production by Vendor in this Month

	GE BWRs	West PWRs	Comb PWRs	B&W PWRs	ALL PWRs
NET ELECTRICAL PRODUCTION.....	7,767,662	11,592,778	5,633,767	3,698,712	20,925,257
MDC NET.....	19,226	26,641	9,049	6,760	42,450
CFMDC.....	54.3	58.5	83.7	73.5	66.3

MEMORANDA

THE FOLLOWING UNITS USE WEIGHTED AVERAGES TO CALCULATE CAPACITY FACTORS:

ITEM 22

BIG ROCK POINT 1
CALVERT CLIFFS 1 & 2
FARLEY 1
FITZPATRICK
FORT CALHOUN 1
INDIAN POINT 2*
KEWAUNEE
OYSTER CREEK 1
POINT BEACH 1 & 2
THREE MILE ISLAND 1
TURKEY POINT 3 & 4

ITEM 22 & 23

GINNA
HADDAM NECK (CONNECTICUT YANKEE)
MAINE YANKEE
MILLSTONE 2
OCONEE 1, 2, & 3
YANKEE-ROWE 1

*COMPUTED SINCE 7/1/74, THE DATE OF COMPLETION OF A 100 DAY - 100% POWER OPERATION TEST.

THE FOLLOWING UNITS USE THE DATE OF FIRST ELECTRICAL GENERATION INSTEAD OF COMMERCIAL OPERATION,
FOR THEIR CUMULATIVE DATA:

ITEMS 20 THROUGH 24

COOK 1 & 2
BEAVER VALLEY 1
SAN ONOFRE 1

ITEM 24 ONLY

BIG ROCK POINT 1

E R R A T A
CORRECTIONS TO PREVIOUSLY REPORTED DATA

NOTE: THESE CHANGES ARE REFLECTED IN THE DATA CONTAINED IN THE CURRENT REPORT

REVISED MONTHLY HIGHLIGHTS

NONE

SECTION 2

**OPERATING
POWER
REACTORS**

1. Docket: 50-313 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: K. L. MORTON (501) 964-3155

4. Licensed Thermal Power (MWt): 2568

5. Nameplate Rating (Gross MWe): 1003 X 0.9 = 903

6. Design Electrical Rating (Net MWe): 850

7. Maximum Dependable Capacity (Gross MWe): 883

8. Maximum Dependable Capacity (Net MWe): 836

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>85,050.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,224.4</u>	<u>57,659.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>5,044.0</u>
15. Hrs Generator On-Line	<u>697.8</u>	<u>5,160.4</u>	<u>56,410.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>817.5</u>
17. Gross Therm Ener (MWH)	<u>1,592,306</u>	<u>12,320,448</u>	<u>134,240,745</u>
18. Gross Elec Ener (MWH)	<u>526,110</u>	<u>4,122,675</u>	<u>44,261,040</u>
19. Net Elec Ener (MWH)	<u>499,901</u>	<u>3,938,255</u>	<u>42,196,642</u>
20. Unit Service Factor	<u>93.8</u>	<u>88.1</u>	<u>66.3</u>
21. Unit Avail Factor	<u>93.7</u>	<u>88.1</u>	<u>67.3</u>
22. Unit Cap Factor (MDC Net)	<u>80.4</u>	<u>80.5</u>	<u>59.3</u>
23. Unit Cap Factor (DER Net)	<u>79.0</u>	<u>79.1</u>	<u>58.4</u>
24. Unit Forced Outage Rate	<u>6.2</u>	<u>1.2</u>	<u>15.4</u>
25. Forced Outage Hours	<u>46.2</u>	<u>61.0</u>	<u>10,239.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING & MAINT: 10/12/84 THROUGH 12/22/85

27. If Currently Shutdown Estimated Startup Date: N/A

* ARKANSAS 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ARKANSAS 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * ARKANSAS 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-03	08/11/84	F	46.2	A	1		AB	SEAL	THE UNIT WENT TO HOT STANDBY TO REPAIR A LEAKING RCP SEAL PRESSURE SENSING LINE. REPAIRS WERE COMPLETED, AND THE UNIT RETURNED TO NORMAL OPERATION.

 * SUMMARY *

 ARKANSAS 1 OPERATED WITH 1 OUTAGE FOR EQUIPMENT REPAIR.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* ARKANSAS 1 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ARKANSAS
COUNTY.....POPE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...6 MI WNW OF
RUSSELLVILLE, AR
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 6, 1974
DATE ELEC ENER 1ST GENER...AUGUST 17, 1974
DATE COMMERCIAL OPERATE...DECEMBER 19, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...DARDANELLE RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ARKANSAS POWER & LIGHT
CORPORATE ADDRESS.....NINTH & LOUISIANA STREETS
LITTLE ROCK, ARKANSAS 72203
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....B. JOHNSON
LICENSING PROJ MANAGER.....G. VISSING
DOCKET NUMBER.....50-313
LICENSE & DATE ISSUANCE...DPR-51, MAY 21, 1974
PUBLIC DOCUMENT ROOM...#...ARKANSAS TECH UNIVERSITY
RUSSELLVILLE, ARKANSAS 72801

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED JUNE 19-22, 1984 (84-20)

ROUTINE, UNANNOUNCED INSPECTION OF THE SECURITY PROGRAM AUDIT, PHYSICAL BARRIERS - PROTECTED AREA, PHYSICAL BARRIERS - VITAL AREA, ASSESSMENT AIDS, ACCESS CONTROL - PERSONNEL, ACCESS CONTROL - PACKAGES, AND ACCESS CONTROL - VEHICLES.

WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED JUNE 25-29, 1984 (84-21)

ROUTINE, ANNOUNCED INSPECTION OF THE LICENSEE'S CHEMISTRY AND RADIOCHEMISTRY PROGRAM INCLUDING REVIEW OF ORGANIZATION, TRAINING, AUDITS OF CHEMISTRY/RADIOCHEMISTRY ACTIVITIES, ADMINISTRATIVE AND ANALYTICAL PROCEDURES, INSTRUMENT CALIBRATION AND QUALITY CONTROL OF ANALYTICAL MEASUREMENTS, RADIO-CHEMISTRY CONFIRMATORY MEASUREMENTS OF SELECTED PLANT RADIO-ACTIVE EFFLUENT SAMPLES, AND WHOLE BODY COUNTING CONFIRMATORY MEASUREMENTS.

WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

ENFORCEMENT SUMMARY

CONTRARY TO CRITERION VII OF APPENDIX B TO 10 CFR PART 50 AND PARAGRAPHS 5.0 AND 6.1.4 OF ARKANSAS POWER & LIGHT COMPANY PROCEDURE NO. 1033.01, QUALITY CONTROL STAFF REVIEW OF RECEIVED MATERIALS DOCUMENTATION DID NOT ASSURE CONFORMANCE TO PROCUREMENT REQUIREMENTS AS EVIDENCED BY: 1. ACCEPTANCE OF FASTENER CERTIFICATIONS FROM CARDINAL INDUSTRIAL PRODUCTS CORPORATION WHICH DID NOT COMPLY WITH THE MECHANICAL TEST, CHEMICAL ANALYSIS, AND HEAT TREATMENT DOCUMENTATION REQUIREMENTS OF THE PURCHASE ORDER; 2. ACCEPTANCE OF SUB-TIER VENDOR FASTENER CERTIFICATIONS FROM SOUTHERN BOLT & FASTENER CORPORATION WHICH DID NOT COMPLY WITH THE QUALITY ASSURANCE AND HEAT TREATMENT DOCUMENTATION REQUIREMENTS OF THE PURCHASE ORDER. CONTRARY TO CRITERION VII OF APPENDIX B TO 10 CFR PART 50 AND PARAGRAPHS 5.0 AND 6.1.4 OF ARKANSAS POWER & LIGHT COMPANY PROCEDURE NO. 1033.01, QUALITY CONTROL STAFF REVIEW OF RECEIVED MATERIALS DOCUMENTATION DID NOT ASSURE CONFORMANCE TO PROCUREMENT REQUIREMENTS AS EVIDENCED BY: 1. ACCEPTANCE OF FASTENER CERTIFICATIONS FROM CARDINAL INDUSTRIAL PRODUCTS CORPORATION WHICH DID NOT COMPLY WITH THE MECHANICAL TEST, CHEMICAL ANALYSIS, AND HEAT TREATMENT DOCUMENTATION REQUIREMENTS OF THE PURCHASE ORDER; 2. ACCEPTANCE OF SUB-TIER VENDOR FASTENER CERTIFICATIONS FROM SOUTHERN BOLT & FASTENER CORPORATION WHICH DID NOT COMPLY WITH THE QUALITY ASSURANCE AND HEAT TREATMENT DOCUMENTATION REQUIREMENTS OF THE PURCHASE ORDER.
(8335 J)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

POWER LIMITED TO ABOUT 90% DUE TO ELEVATED 'A' STEAM GENERATOR WATER LEVEL.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

POWER OPERATION

LAST IE SITE INSPECTION DATE: JUNE 25-29, 1984

INSPECTION REPORT NO: 50-313/84-21

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	---------------	----------------	---------

NONE

1. Docket: 50-368 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: LINDY BRAMLETT (501) 964-3145

4. Licensed Thermal Power (MWt): 2815

5. Nameplate Rating (Gross MWe): 943

6. Design Electrical Rating (Net MWe): 912

7. Maximum Dependable Capacity (Gross MWe): 897

8. Maximum Dependable Capacity (Net MWe): 858

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>38,879.0</u>
13. Hours Reactor Critical	<u>656.6</u>	<u>4,876.6</u>	<u>26,549.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,430.1</u>
15. Hrs Generator On-Line	<u>656.6</u>	<u>4,715.2</u>	<u>25,665.5</u>
16. Unic Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>75.0</u>
17. Gross Therm Ener (MWH)	<u>1,803,614</u>	<u>12,123,739</u>	<u>64,673,279</u>
18. Gross Elec Ener (MWH)	<u>599,561</u>	<u>4,935,313</u>	<u>21,052,264</u>
19. Net Elec Ener (MWH)	<u>573,046</u>	<u>3,849,217</u>	<u>20,055,557</u>
20. Unit Service Factor	<u>88.3</u>	<u>80.5</u>	<u>66.0</u>
21. Unit Avail Factor	<u>88.3</u>	<u>80.5</u>	<u>66.2</u>
22. Unit Cap Factor (MDC Net)	<u>89.8</u>	<u>76.6</u>	<u>60.1</u>
23. Unit Cap Factor (DER Net)	<u>84.5</u>	<u>72.1</u>	<u>56.6</u>
24. Unit Forced Outage Rate	<u>11.7</u>	<u>7.6</u>	<u>18.3</u>
25. Forced Outage Hours	<u>87.4</u>	<u>388.6</u>	<u>5,767.1</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 09/03/84

 * ARKANSAS 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ARKANSAS 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* ARKANSAS 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
8408	08/28/84	F	87.4	A	3	2-84248	ZZ	ZZZZZZ	THE UNIT TRIPPED DUE TO A DROPPED CEA. THE UNIT THEN WENT TO CSD TO REPAIR A FAULTY RCP SEAL AND A LEAKING STEAM GENERATOR MANWAY.

* SUMMARY *

ARKANSAS 2 OPERATED WITH 1 OUTAGE FOR EQUIPMENT REPAIR.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

ARKANSAS 2 #

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ARKANSAS
COUNTY.....POPE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...6 MI WNW OF
RUSSELLVILLE, AR
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 5, 1978
DATE ELEC ENER 1ST GENER...DECEMBER 26, 1978
DATE COMMERCIAL OPERATE...MARCH 26, 1980
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER....DARDANELLE RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ARKANSAS POWER & LIGHT
CORPORATE ADDRESS.....NINTH & LOUISIANA STREETS
LITTLE ROCK, ARKANSAS 72203
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....W. JOHNSON
LICENSING PROJ MANAGER.....R. LEE
DOCKET NUMBER.....50-368
LICENSE & DATE ISSUANCE...NPF-6, SEPTEMBER 1, 1978
PUBLIC DOCUMENT ROOM.....ARKANSAS TECH UNIVERSITY
RUSSELLVILLE, ARKANSAS 72801

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED ON JUNE 19-22, 1984 (84-20)

ROUTINE, UNANNOUNCED INSPECTION OF THE SECURITY PROGRAM AUDIT, PHYSICAL BARRIERS - PROTECTED AREA, PHYSICAL BARRIERS - VITAL AREA, ASSESSMENT AIDS, ACCESS CONTROL - PERSONNEL, ACCESS CONTROL - PACKAGES, AND ACCESS CONTROL - VEHICLES.

WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION CONDUCTED JUNE 25-29, 1984 (84-21)

ROUTINE, ANNOUNCED INSPECTION OF THE LICENSEE'S CHEMISTRY AND RADIOCHEMISTRY PROGRAM INCLUDING REVIEW OF ORGANIZATION, TRAIN-ING, AUDITS OF CHEMISTRY/RADIOCHEMISTRY ACTIVITIES, ADMINISTRATIVE AND ANALYTICAL PROCEDURES, INSTRUMENT CALIBRATION AND QUALITY CONTROL OF ANALYTICAL MEASUREMENTS, RADIOCHEMISTRY CONFIRMATORY MEASUREMENTS OF SELECTED PLANT RADIOACTIVE EFFLUENT SAMPLES, AND WHOLE BODY COUNTING CONFIRMATORY MEASUREMENTS.

WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

```
*****  
* ARKANSAS 2 *  
*****
```

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

POWER OPERATION

LAST IE SITE INSPECTION DATE: JUNE 25-29, 1984

INSPECTION REPORT NO: 50-368/84-21

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-013/00	6-17-84	7-17-84	REACTOR TRIP DUE TO DROPPED CONTROL ELEMENT ASSEMBLY (CEA)
84-014/00	6-18-84	7-17-84	REACTOR TRIP DUE TO HIGH STEAM GENERATOR LEVEL
84-015/00	3-2-84	7-23-84	BREACH OF FIRE BARRIER
84-016/00	6-21-84	7-23-84	INOPERABLE FIRE BARRIER - FIRE BARRIER DAMPERS

1. Docket: 50-334 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. L. HOLTZ (412) 643-1369

4. Licensed Thermal Power (MWt): 2660

5. Nameplate Rating (Gross MWe): 1026 X 0.9 = 923

6. Design Electrical Rating (Net MWe): 835

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 810

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>73,079.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,501.3</u>	<u>36,384.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>4,482.7</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,329.1</u>	<u>35,108.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,949,986</u>	<u>13,475,781</u>	<u>81,065,313</u>
18. Gross Elec Ener (MWH)	<u>610,000</u>	<u>4,329,500</u>	<u>25,758,440</u>
19. Net Elec Ener (MWH)	<u>573,090</u>	<u>4,072,635</u>	<u>23,961,433</u>
20. Unit Service Factor	<u>100.0</u>	<u>91.0</u>	<u>50.4</u>
21. Unit Avail Factor	<u>100.0</u>	<u>91.0</u>	<u>50.4</u>
22. Unit Cap Factor (MDC Net)	<u>95.1</u>	<u>85.9</u>	<u>44.1</u>
23. Unit Cap Factor (DER Net)	<u>92.2</u>	<u>83.3</u>	<u>42.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>3.5</u>	<u>27.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>195.0</u>	<u>17,872.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING & MAINTENANCE - 10/13/84 - 73 DAYS

27. If Currently Shutdown Estimated Startup Date: N/A

* BEAVER VALLEY 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BEAVER VALLEY 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* BEAVER VALLEY 1 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

BEAVER VALLEY 1 OPERATED ROUTINELY WITH NO OUTAGES OR REDUCTIONS DURING AUGUST.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System & Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BEAVER VALLEY 1 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....BEAVER
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI E OF
E. LIVERPOOL, OH
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 10, 1976
DATE ELEC ENER 1ST GENER...JUNE 14, 1976
DATE COMMERCIAL OPERATE...OCTOBER 1, 1976
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...OHIO RIVER
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUQUESNE LIGHT
CORPORATE ADDRESS.....ONE OXFORD CENTRE, 301 GRANT STREET
PITTSBURGH, PENNSYLVANIA 15279
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....W. TROSKOSKI
LICENSING PROJ MANAGER.....P. TAM
DOCKET NUMBER.....50-334
LICENSE & DATE ISSUANCE...DPR-66, JULY 2, 1976
PUBLIC DOCUMENT ROOM.....B.F. JONES MEMORIAL LIBRARY
633 FRANKLIN AVENUE
ALIQUIPPA, PA 15001

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50 APPENDIX B AND OQA PROGRAM SECTION A.2.2.11, TEST CONTROL, PROCEDURES USED TO PERFORM STATION BATTERY SERVICE TESTS DID NOT CONTAIN ACCEPTANCE CRITERIA CORRESPONDING TO THE DESIGN REQUIREMENTS OF THE DC SYSTEM. CONTRARY TO STATION ADMINISTRATIVE PROCEDURES, REQUIRED BY TS 6.8.1 AND REG GUIDE 1.33, THE SCOPE OF EQUIPMENT CLEARANCE PERMIT 495226 WAS EXPANDED TO INCLUDE WORK ON ADJOINING.
(8415 4)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* BEAVER VALLEY 1 *

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

1. Docket: 50-155 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: LINDA BALCH (616) 547-6537

4. Licensed Thermal Power (Mwt): 240

5. Nameplate Rating (Gross MWe): 70.6 X 0.85 = 60

6. Design Electrical Rating (Net MWe): 72

7. Maximum Dependable Capacity (Gross MWe): 69

8. Maximum Dependable Capacity (Net MWe): 64

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>187,842.0</u>
13. Hours Reactor Critical	<u>724.2</u>	<u>4,119.3</u>	<u>131,829.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>717.1</u>	<u>4,053.7</u>	<u>129,346.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>116,993</u>	<u>737,691</u>	<u>24,223,582</u>
18. Gross Elec Ener (MWH)	<u>37,692</u>	<u>239,270</u>	<u>7,654,879</u>
19. Net Elec Ener (MWH)	<u>35,371</u>	<u>225,410</u>	<u>7,237,622</u>
20. Unit Service Factor	<u>96.4</u>	<u>69.2</u>	<u>68.9</u>
21. Unit Avail Factor	<u>96.4</u>	<u>69.2</u>	<u>68.9</u>
22. Unit Cap Factor (MDC Net)	<u>74.3</u>	<u>60.2</u>	<u>57.4*</u>
23. Unit Cap Factor (DER Net)	<u>66.0</u>	<u>53.5</u>	<u>53.5</u>
24. Unit Forced Outage Rate	<u>3.6</u>	<u>21.1</u>	<u>16.7</u>
25. Forced Outage Hours	<u>26.9</u>	<u>1,081.3</u>	<u>10,981.6</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* B I G R O C K P O I N T 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BIG ROCK POINT 1



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * BIG ROCK POINT 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-06	08/02/84	F	0.0	A	5		HA	INSTRU	POWER REDUCTION TO REMOVE TURBINE GENERATOR FROM SERVICE FOR IPR REPAIRS.
84-07	08/03/84	F	26.9	A	1	84-12	HE	VALVEX	AFTER REMOVING TURBINE FROM SERVICE FOR IPR REPAIRS, TURBINE BYPASS VALVE WENT CLOSED LEADING TO SUBSEQUENT REACTOR SCRAM. PROCEDURAL CHANGES HAVE BEEN MADE TO CONTROL BYPASS MANUALLY WHEN AT LOW POWER LEVELS.

 * SUMMARY *

 BIG ROCK POINT 1 OPERATED WITH 1 OUTAGE AND 1 REDUCTION, EACH DUE TO EQUIPMENT FAILURE DURING AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BIG ROCK POINT 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MICHIGAN

COUNTY.....CHARLEVOIX

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...4 MI NE OF
CHARLEVOIX, MICH

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...SEPTEMBER 27, 1962

DATE ELEC ENER 1ST GENER...DECEMBER 8, 1962

DATE COMMERCIAL OPERATE...MARCH 29, 1963

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER...LAKE MICHIGAN

ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CONSUMERS POWER

CORPORATE ADDRESS.....212 WEST MICHIGAN AVENUE
JACKSON, MICHIGAN 49201

CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....S. GUTHRIE

LICENSING PROJ MANAGER.....R. EMCH
DOCKET NUMBER.....50-155

LICENSE & DATE ISSUANCE...DPR-6, AUGUST 30, 1962

PUBLIC DOCUMENT ROOM.....NORTH CENTRAL MICHIGAN COLLEGE
1515 HOWARD STREET
PETOSKEY, MICHIGAN 49770

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JULY 9-12, (84-08): ROUTINE, UNANNOUNCED INSPECTION OF THE OPERATIONAL RADIATION PROTECTION PROGRAM DURING THE REFUELING AND MAINTENANCE OUTAGE, INCLUDING: PLANNING AND PREPARATION; CHANGES; TRAINING AND QUALIFICATIONS OF NEW PERSONNEL; EXTERNAL EXPOSURE CONTROL; INTERNAL EXPOSURE CONTROL; CONTROL OF RADIOACTIVE MATERIALS AND CONTAMINATION; ALARA PROGRAM; AND OPEN ITEMS. ALSO, AN INCIDENT INVOLVING A LEAK IN A CONDENSATE TANK DEMINERALIZED WATER SUPPLY LINE WAS REVIEWED. THE INSPECTION INVOLVED 44 INSPECTOR-HOURS ON SITE BY TWO NRC INSPECTORS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE PLANT IS OPERATING ROUTINELY.

LAST IE SITE INSPECTION DATE: SEPTEMBER 10-14, 1984

INSPECTION REPORT NO: 84-10

 R E P O R T S F R O M L I C E N S E E

```

=====
NUMBER      DATE OF      DATE OF      SUBJECT
            EVENT        REPORT
-----
84-03      05/30/84    08/16/84    UNMONITORED LIQUID RELEASE TO SOIL.
84-09      07/26/84    08/22/84    TURBINE BYPASS VALVE CLOSING RESULTING IN SCRAM.
84-10      07/27/84    08/22/84    SHORT PERIOD REACTOR PROTECTION SYSTEM TRIP.
=====
    
```

1. Docket: 50-259 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: TED THOM (205) 729-0834

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1065

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>88,417.0</u>
13. Hours Reactor Critical	<u>509.4</u>	<u>5,138.4</u>	<u>54,944.2</u>
14. Rx Reserve Shtdwn Hrs	<u>234.6</u>	<u>700.1</u>	<u>6,484.7</u>
15. Hrs Generator On-Line	<u>494.7</u>	<u>5,012.9</u>	<u>53,730.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,607,170</u>	<u>15,303,209</u>	<u>153,860,888</u>
18. Gross Elec Ener (MWH)	<u>526,390</u>	<u>5,083,220</u>	<u>50,728,840</u>
19. Net Elec Ener (MWH)	<u>510,650</u>	<u>4,908,008</u>	<u>49,233,335</u>
20. Unit Service Factor	<u>66.5</u>	<u>85.6</u>	<u>60.8</u>
21. Unit Avail Factor	<u>66.5</u>	<u>85.6</u>	<u>60.8</u>
22. Unit Cap Factor (MDC Net)	<u>64.4</u>	<u>78.7</u>	<u>52.3</u>
23. Unit Cap Factor (DER Net)	<u>64.4</u>	<u>78.7</u>	<u>52.3</u>
24. Unit Forced Outage Rate	<u>33.5</u>	<u>13.9</u>	<u>23.0</u>
25. Forced Outage Hours	<u>249.3</u>	<u>810.3</u>	<u>16,035.0</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 09/07/84

* BROWNS FERRY 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BROWNS FERRY 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * BROWNS FERRY 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
289	08/21/84	F	249.3	B	1				REACTOR MANUALLY SCRAMMED TO TEST CHECK VALVE FCV-75-26 FOR PROPER SEATING.

***** BROWNS FERRY 1 SHUTDOWN ON AUGUST 21 FOR TESTING.
 * SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BROWNS FERRY 1 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ALABAMA
COUNTY.....LIMESTONE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI NW OF
DECATUR, ALA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...AUGUST 17, 1973
DATE ELEC ENER 1ST GENER...OCTOBER 15, 1973
DATE COMMERCIAL OPERATE...AUGUST 1, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...TENNESSEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....TENNESSEE VALLEY AUTHORITY
CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II
CHAATTANOOGA, TENNESSEE 37401
CONTRACTOR
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. PAULK
LICENSING PROJ MANAGER.....R. CLARK
DOCKET NUMBER.....50-259
LICENSE & DATE ISSUANCE...DPR-33, DECEMBER 20, 1973
PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY
SOUTH AND FORREST
ATHENS, ALABAMA 35611

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 23-27 (84-25): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 11 INSPECTOR-HOURS ON SITE IN THE AREAS OF RADIOACTIVE LIQUID AND GASEOUS EFFLUENTS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION 13-14 (84-28): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 4 INSPECTOR-HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 31 (84-29): THIS SPECIAL, ANNOUNCED INSPECTION INVOLVED 1 INSPECTOR-HOURS ON SITE IN THE AREA OF SECURITY. OF THE ONE AREA INSPECTED, ONE APPARENT VIOLATION WAS FOUND (FAILURE TO CONTROL ACCESS TO THE FUEL HANDLING AREA).

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.2.B.4.C AS IMPLEMENTED BY BROWNS FERRY STANDARD PRACTICE 8.3 AND 17.18 REQUIRES THAT THE PLANT OPERATING REVIEW COMMITTEE REVIEW PROPOSED CHANGES TO SYSTEMS HAVING SAFETY SIGNIFICANCE AND WHICH MAY CONSTITUTE ANY UNREVIEWED SAFETY QUESTION. CONTRARY TO THE ABOVE, THE REQUIREMENT WAS NOT MET IN THAT REVISIONS TO UNREVIEWED SAFETY QUESTION DETERMINATIONS ARE NOT GENERICALLY REVIEWED BY THE PLANT OPERATING REVIEW COMMITTEE AS REQUIRED BY BROWNS FERRY STANDARD PRACTICE 17.18 AND 8.3. SPECIFICALLY, REVISIONS TO SAFETY EVALUATIONS GENERATED FROM THE TVA DESIGN ORGANIZATION ARE NOT REVIEWED TO DETERMINE SPECIAL CONDITIONS OR REQUIREMENTS DELINEATED IN THE REVISIONS. A REVIEW OF ECN 0392 (INSTALLATION OF THE SCRAM DISCHARGE VOLUME AND

ENFORCEMENT SUMMARY

ASSOCIATED INSTRUMENTATION) FOR ALL UNITS INDICATED THAT PLANT SUPERVISORS AND MANAGERS WERE UNAWARE OF SPECIAL TIMING REQUIREMENTS FOR INSTRUMENT RESPONSES, SPECIAL ADMINISTRATIVE PROCEDURES REQUIRED TO BE IMPLEMENTED FOR CERTAIN CONFIGURATION DESIGNS AND QUALIFICATION CRITERIA.
(8346 4)

TECHNICAL SPECIFICATION 6.7.2.A(9) REQUIRES A PROMPT NOTIFICATION UPON DISCOVERY DURING PLANT LIFE OF CONDITIONS NOT SPECIFICALLY CONSIDERED IN THE SAFETY ANALYSIS REPORT OR TECHNICAL SPECIFICATIONS THAT REQUIRE REMEDIAL ACTION OR CORRECTIVE MEASURES TO PREVENT THE EXISTENCE OR DEVELOPMENT OF AN UNSAFE CONDITION. CONTRARY TO THE ABOVE, THIS REQUIREMENT WAS NOT MET IN THAT THE EMERGENCY DIESEL GENERATOR COOLING WATER HEAT EXCHANGERS WERE FOUND IN MARCH 1983 TO HAVE A TUBE-SIDE DESIGN PRESSURE OF 75 PSIG IN A SYSTEM WITH A DESIGN PRESSURE OF 185 PSIG AND KNOWN OPERATING PRESSURES OF APPROXIMATELY 135 PSIG AND NO REPORT HAD BEEN MADE TO DATE. 10 CFR 50, APPENDIX B, CRITERION III REQUIRES THAT DESIGN CONTROL MEASURES SHALL PROVIDE FOR VERIFYING OR CHECKING THE ADEQUACY OF DESIGN, SUCH AS BY THE PERFORMANCE OF DESIGN REVIEWS, BY THE USE OF ALTERNATE OR SIMPLIFIED CALCULATIONAL METHODS OR BY THE PERFORMANCE OF A SUITABLE TESTING PROGRAM. CONTRARY TO THE ABOVE, THIS REQUIREMENT WAS NOT MET IN THAT THE EMERGENCY EQUIPMENT COOLING WATER (EECW) DIESEL GENERATOR HEAT EXCHANGERS HAVE A DESIGN PRESSURE OF 75 PSIG WHICH IS EXCEEDED BY THE EECW NORMAL OPERATING PRESSURE OF 100 TO 120 PSIG AND EMERGENCY OPERATING PRESSURE OF APPROXIMATELY 135 PSIG.
(8355 3)

10 CFR 50, APPENDIX B, CRITERION III REQUIRES THAT MEASURES SHALL BE ESTABLISHED FOR THE IDENTIFICATION AND CONTROL OF DESIGN INTERFACES AND FOR COORDINATION AMONG PARTICIPATING DESIGN ORGANIZATIONS; THAT DESIGN CONTROL MEASURES SHALL PROVIDE FOR VERIFYING OR CHECKING THE ADEQUACY OF DESIGN; AND THAT DESIGN CHANGES, INCLUDING FIELD CHANGES, SHALL BE SUBJECT TO DESIGN CONTROL MEASURES COMMENSURATE WITH THOSE APPLIED TO THE ORIGINAL DESIGN." CONTRARY TO THE ABOVE, ENGINEERING PROCEDURE EN DES-EP 1.48 ISSUED DECEMBER 16, 1983 ALLOWED DECISIONS TO BE MADE FOR A SIGNIFICANT NONCONFORMING CONDITION WITHOUT DESIGN CONTROL MEASURES COMMENSURATE WITH THOSE APPLIED TO THE ORIGINAL DESIGN. IN CONSEQUENCE, SIXTEEN EMERGENCY DIESEL GENERATOR COOLING WATER HEAT EXCHANGERS AND TWELVE RHR PUMP SEAL COOLING HEAT EXCHANGERS WERE NOT TARGETED FOR PROMPT CORRECTIVE ACTION APPLYING THE GUIDANCE FROM EN DES-EP 1.48.
(8401 3)

FAILURE TO CONTROL ACCESS TO A CONTROLLED ACCESS AREA.

(8429 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

INTERGRANULAR STRESS CORROSION CRACKING (IGSCC) PROBLEMS IN RHR, CORE SPRAY AND OTHER PIPING HAS NECESSITATED WELD OVERLAY REPAIRS.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

THE OFFICE OF POWER AND OFFICE OF ENGINEERING, DESIGN AND CONSTRUCTION WERE COMBINED TO FORM THE OFFICE OF POWER AND ENGINEERING, H. G. PARRIS, MANAGER. A SEPARATE OFFICE OF NUCLEAR POWER WAS ESTABLISHED WITH J. P. DARLING, MANAGER, J. P. COFFEY WAS ASSIGNED AS SITE DIRECTOR, BROWNS FERRY REPORTING TO J. P. DARLING.

OTHER ITEMS

PLANT STATUS:

SHUTDOWN FOR TESTING.

LAST IE SITE INSPECTION DATE: JULY 31, 1984 +

INSPECTION REPORT NO: 50-259/84-29 +

R E P O R T S F R O M L I C E N S E E

```
=====
```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-025	06/15/84	07/03/84	ISOLATION BETWEEN TURBINE AND REACTOR BLDG HEAT SYS LINES INADEQUATE, FAILURE TO FOLLOW DESIGN CRITERIA MAIN PROBLEM.
84-026	06/20/84	07/17/84	HIGH DRYWELL LEAKAGE AND SUBSEQUENT MANUAL SCRAM, RECIRCULATION PUMP UPPER SEAL FAILED.
84-028	07/10/84	08/08/84	AUTOMATIC DISCHARGE TRANSFER LOGIC FAILED TO WORK, THIS EVENT WAS RANDOM.

```
=====
```

THIS PAGE INTENTIONALLY LEFT BLANK

1 Docket: 50-260 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: TED THOM (205) 729-0834

4. Licensed Thermal Power (Mwt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1065

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>83,328.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,554.8</u>	<u>55,518.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>300.1</u>	<u>14,200.4</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,504.6</u>	<u>53,997.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,600,550</u>	<u>12,434,765</u>	<u>152,579,810</u>
18. Gross Elec Ener (MWH)	<u>501,660</u>	<u>3,967,580</u>	<u>50,564,868</u>
19. Net Elec Ener (MWH)	<u>482,530</u>	<u>3,849,508</u>	<u>49,108,111</u>
20. Unit Service Factor	<u>100.0</u>	<u>94.0</u>	<u>64.8</u>
21. Unit Avail Factor	<u>100.0</u>	<u>94.0</u>	<u>64.8</u>
22. Unit Cap Factor (MDC Net)	<u>60.9</u>	<u>61.7</u>	<u>55.3</u>
23. Unit Cap Factor (DER Net)	<u>60.9</u>	<u>61.7</u>	<u>55.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.3</u>	<u>23.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>249.4</u>	<u>16,304.4</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
SEPTEMBER 1984 - REFUEL

27. If Currently Shutdown Estimated Startup Date: N/A

* BROWNS FERRY 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BROWNS FERRY 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* BROWNS FERRY 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

* SUMMARY *

BROWNS FERRY 2 OPERATED WITH NO OUTAGES OR REDUCTIONS, ANTICIPATING A SEPTEMBER REFUELING OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BROWNS FERRY 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ALABAMA
COUNTY.....LIMESTONE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI NW OF
DECATUR, ALA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JULY 20, 1974
DATE ELEC ENER 1ST GENER...AUGUST 28, 1974
DATE COMMERCIAL OPERATE...MARCH 1, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...TENNESSEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....TENNESSEE VALLEY AUTHORITY
CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II
CHATTANOOGA, TENNESSEE 37401
CONTRACTOR
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. PAULK
LICENSING PROJ MANAGER....R. CLARK
DOCKET NUMBER.....50-260
LICENSE & DATE ISSUANCE...DPR-52, AUGUST 2, 1974
PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY
SOUTH AND FORREST
ATHENS, ALABAMA 35611

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 23-27 (84-25): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 11 INSPECTOR-HOURS ON SITE IN THE AREAS OF RADIOACTIVE LIQUID AND GASEOUS EFFLUENTS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.
INSPECTION 13-14 (84-28): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 3 INSPECTOR-HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.
INSPECTION JULY 31 (84-29): THIS SPECIAL, ANNOUNCED INSPECTION INVOLVED 1 INSPECTOR-HOURS ON SITE IN THE AREA OF SECURITY. OF THE ONE AREA INSPECTED, ONE APPARENT VIOLATION WAS FOUND (FAILURE TO CONTROL ACCESS TO THE FUEL HANDLING AREA).

ENFORCEMENT SUMMARY

10 CFR 50, APPENDIX B, CRITERION XVI, AS IMPLEMENTED BY TVA TOPICAL REPORT, SECTION 17.2.16, REQUIRES THE LICENSEE TO ESTABLISH MEASURES TO ASSURE CONDITIONS ADVERSE TO QUALITY, SUCH AS FAILURES, MALFUNCTIONS, DEFICIENCIES, DEVIATIONS, DEFECTIVE MATERIAL AND EQUIPMENT, AND NONCONFORMANCES, ARE PROMPTLY IDENTIFIED AND CORRECTED. CONTRARY TO THE ABOVE, FROM MARCH 18, 1983, THROUGH OCTOBER 13, 1983, ONE OF THE UNIT 2 WEST SCRAM DISCHARGE INSTRUMENT VOLUME SCRAM LEVEL SWITCHES (2-LT-85-45A) WAS INOPERABLE MAKING THE NUMBER OF OPERABLE INSTRUMENT CHANNELS LESS THAN TWO. THE LICENSEE HAD INFORMATION AVAILABLE FROM SCRAMS OCCURRING ON MAY 30, SEPTEMBER 18 AND OCTOBER 7, 1983, WHICH INDICATED THAT LEVEL TRANSMITTER 2-LT-85-45A WAS INOPERABLE. 10 CFR 50, APPENDIX

ENFORCEMENT SUMMARY

B, CRITERION III REQUIRES THAT DESIGN CONTROL MEASURES SHALL PROVIDE FOR VERIFYING OR CHECKING THE ADEQUACY OF DESIGN, SUCH AS BY THE PERFORMANCE OF DESIGN REVIEWS, BY THE USE OF ALTERNATE OR SIMPLIFIED CALCULATIONAL METHODS, OR BY THE PERFORMANCE OF A SUITABLE TESTING PROGRAM. DESIGN CONTROL MEASURES SHALL BE APPLIED TO THE DELINEATION OF ACCEPTANCE CRITERIA FOR TESTS. CONTRARY TO THE ABOVE, THE REQUIREMENT WAS NOT MET IN THAT THE POST MODIFICATION TESTING (PMT 110) CONDUCTED TO ASSURE DESIGN ADEQUACY ON THE NEWLY INSTALLED DIFFERENTIAL PRESSURE HIGH LEVEL DETECTORS (ROSEMOUNT 1153DP); (2-LT-85-45A) ON THE UNIT 2 SCRAM RESPONSE TIMING REQUIREMENTS. SUBSEQUENT RESPONSE TIMING TESTS ON 2-LT-85-45-A, CONDUCTED ON OCTOBER 14, 1983, HAS REVEALED INSTRUMENT RESPONSE TIME OF 17-1/2 MINUTES. THIS RESPONSE TIME EXCEEDS ALL SAFETY EVALUATION CRITERIA.
(8346 3)

TECHNICAL SPECIFICATION 6.2.B.4.C AS IMPLEMENTED BY BROWNS FERRY STANDARD PRACTICE 8.3 AND 17.18 REQUIRES THAT THE PLANT OPERATING REVIEW COMMITTEE REVIEW PROPOSED CHANGES TO SYSTEMS HAVING SAFETY SIGNIFICANCE AND WHICH MAY CONSTITUTE ANY UNREVIEWED SAFETY QUESTION. CONTRARY TO THE ABOVE, THE REQUIREMENT WAS NOT MET IN THAT REVISIONS TO UNREVIEWED SAFETY QUESTION DETERMINATIONS ARE NOT GENERALLY REVIEWED BY THE PLANT OPERATING REVIEW COMMITTEE AS REQUIRED BY BROWNS FERRY STANDARD PRACTICE 17.18 AND 8.3. SPECIFICALLY, REVISIONS TO SAFETY EVALUATIONS GENERATED FROM THE TVA DESIGN ORGANIZATION ARE NOT REVIEWED TO DETERMINE SPECIAL CONDITIONS OR REQUIREMENTS DELINEATED IN THE REVISIONS. A REVIEW OF ECN 0392 (INSTALLATION OF THE SCRAM DISCHARGE VOLUME AND ASSOCIATED INSTRUMENTATION) FOR ALL UNITS INDICATED THAT PLANT SUPERVISORS AND MANAGERS WERE UNAWARE OF SPECIAL TIMING REQUIREMENTS FOR INSTRUMENT RESPONSES, SPECIAL ADMINISTRATIVE PROCEDURES REQUIRED TO BE IMPLEMENTED FOR CERTAIN CONFIGURATION DESIGNS AND QUALIFICATION CRITERIA. TECHNICAL SPECIFICATION 4.1.C REQUIRES THAT WHEN IT IS DETERMINED THAT A CHANNEL IS FAILED IN THE UNSAFE CONDITION, THE OTHER RPS CHANNEL THAT MONITORS THE SAME VARIABLE SHALL BE FUNCTIONALLY TESTED IMMEDIATELY BEFORE THE TRIP SYSTEM CONTAINING THE FAILURE IS TRIPPED. CONTRARY TO THE ABOVE, THE REQUIREMENT WAS NOT MET IN THAT ON OCTOBER 13, 1983 THE SCRAM DISCHARGE VOLUME SCRAM LEVEL SWITCH (2-LT-85-45A) WAS DISCOVERED INOPERABLE. THE LICENSEE FAILED TO PERFORM THE REQUIRED FUNCTIONAL TEST TO ENSURE OPERABILITY OF THE REDUNDANT REACTOR PROTECTION SYSTEM (RPS) CHANNEL. TECHNICAL SPECIFICATION 6.7.2.A.9 REQUIRES THAT A PROMPT NOTIFICATION BE MADE UPON DISCOVERY DURING PLANT LIFE OF CONDITIONS NOT SPECIFICALLY CONSIDERED IN THE SAFETY ANALYSIS REPORT OF TECHNICAL SPECIFICATIONS THAT REQUIRE REMEDIAL ACTION OR CORRECTIVE MEASURES TO PREVENT THE EXISTENCE OR DEVELOPMENT OF AN UNSAFE CONDITION. CONTRARY TO THE ABOVE, THE REQUIREMENT WAS NOT MET IN THAT KNOWN DEFICIENCIES EXISTED WITH THE SCRAM DISCHARGE VOLUME PRESSURE TRANSMITTERS (ROSEMOUNT 1153DP) ON UNIT 2 FROM ORIGINAL INSTALLATION, DUE TO EXCESSIVE TIME RESPONSE REQUIRED TO AFFECT THE REACTOR PROTECTION SYSTEM TRIP. PRESSURE TRANSMITTER 2-LT-85-45A EXCEEDED ALL SAFETY EVALUATION CRITERIA. TIME RESPONSE WAS KNOWN BY PLANT PERSONNEL TO BE VARIABLE FROM 15-29 MINUTES FROM THE UNIT'S ORIGINAL INSTALLATION. TVA'S DESIGN ORGANIZATION REDESIGNED THE LEVEL DETECTOR SYSTEM AFTER EVALUATING THE RESPONSE TIMES FOR A REPRESENTATIVE SAMPLE OF THE UNIT 2 LEVEL INSTRUMENTS AS BEING "EXCESSIVE". THIS REDESIGN EFFORT WAS NOT REPORTED AND THE EXACT TIMING OF THE LEVEL TRANSMITTER 2-LT-85-45A WAS NEVER PRECISELY DETERMINED UNTIL OCTOBER 14, 1983.
(8346 4)

TECHNICAL SPECIFICATION 6.7.2.A(9) REQUIRES A PROMPT NOTIFICATION UPON DISCOVERY DURING PLANT LIFE OF CONDITIONS NOT SPECIFICALLY CONSIDERED IN THE SAFETY ANALYSIS REPORT OR TECHNICAL SPECIFICATIONS THAT REQUIRE REMEDIAL ACTION OR CORRECTIVE MEASURES TO PREVENT THE EXISTENCE OR DEVELOPMENT OF AN UNSAFE CONDITION. CONTRARY TO THE ABOVE, THIS REQUIREMENT WAS NOT MET IN THAT THE EMERGENCY DIESEL GENERATOR COOLING WATER HEAT EXCHANGERS WERE FOUND IN MARCH 1983 TO HAVE A TUBE-SIDE DESIGN PRESSURE OF 75 PSIG IN A SYSTEM WITH A DESIGN PRESSURE OF 185 PSIG AND KNOWN OPERATING PRESSURES OF APPROXIMATELY 135 PSIG AND NO REPORT HAD BEEN MADE TO DATE. 10 CFR 50, APPENDIX B, CRITERION III REQUIRES THAT DESIGN CONTROL MEASURES SHALL PROVIDE FOR VERIFYING OR CHECKING THE ADEQUACY OF DESIGN, SUCH AS BY THE PERFORMANCE OF DESIGN REVIEWS, BY THE USE OF ALTERNATE OR SIMPLIFIED CALCULATIONAL METHODS OR BY THE PERFORMANCE OF A SUITABLE TESTING PROGRAM. CONTRARY TO THE ABOVE, THIS REQUIREMENT WAS NOT MET IN THAT THE EMERGENCY EQUIPMENT COOLING WATER (EECW) DIESEL GENERATOR HEAT EXCHANGERS HAVE A DESIGN PRESSURE OF 75 PSIG WHICH IS EXCEEDED BY THE EECW NORMAL OPERATING PRESSURE OF 100 TO 120 PSIG AND EMERGENCY OPERATING PRESSURE OF APPROXIMATELY 135 PSIG.
(8355 3)

10 CFR 50, APPENDIX B, CRITERION III REQUIRES THAT MEASURES SHALL BE ESTABLISHED FOR THE IDENTIFICATION AND CONTROL OF DESIGN INTERFACES AND FOR COORDINATION AMONG PARTICIPATING DESIGN ORGANIZATIONS; THAT DESIGN CONTROL MEASURES SHALL PROVIDE FOR VERIFYING OR CHECKING THE ADEQUACY OF DESIGN; AND THAT DESIGN CHANGES, INCLUDING FIELD CHANGES, SHALL BE SUBJECT TO DESIGN CONTROL MEASURES COMMENSURATE WITH THOSE APPLIED TO THE ORIGINAL DESIGN." CONTRARY TO THE ABOVE, ENGINEERING PROCEDURE EN DES-EP 1.48 ISSUED DECEMBER 16, 1983 ALLOWED DECISIONS TO BE MADE FOR A SIGNIFICANT NONCONFORMING CONDITION WITHOUT DESIGN CONTROL MEASURES

ENFORCEMENT SUMMARY

COMMENSURATE WITH THOSE APPLIED TO THE ORIGINAL DESIGN. IN CONSEQUENCE, SIXTEEN EMERGENCY DIESEL GENERATOR COOLING WATER HEAT EXCHANGERS AND TWELVE RHR PUMP SEAL COOLING HEAT EXCHANGERS WERE NOT TARGETED FOR PROMPT CORRECTIVE ACTION APPLYING THE GUIDANCE FROM EN DES-EP 1.48.
(8401 3)

FAILURE TO CONTROL ACCESS TO A CONTROLLED ACCESS AREA.
(8429 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

THE OFFICE OF POWER AND OFFICE OF ENGINEERING, DESIGN AND CONSTRUCTION WERE COMBINED TO FORM THE OFFICE OF POWER AND ENGINEERING, H. G. PARRIS, MANAGER. A SEPARATE OFFICE OF NUCLEAR POWER WAS ESTABLISHED WITH J. P. DARLING, MANAGER, J. P. COFFEY WAS ASSIGNED AS SITE DIRECTOR, BROWNS FERRY REPORTING TO J. P. DARLING.

PLANT STATUS:

OPERATING AT REDUCED OUTPUT (60%) TO STRETCH CYCLE THRU SEPTEMBER.

LAST IE SITE INSPECTION DATE: JULY 31, 1984 +

INSPECTION REPORT NO: 50-260/84-29 +

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE.			

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-296 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: TED THOM (205) 729-0834

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1065

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>65,783.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>43,088.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,878.1</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>42,194.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>126,285,520</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>41,597,620</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>40,376,156</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>64.1</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>64.1</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>57.6</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>57.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>10.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>5,091.4</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 10/27/84

* BROWNS FERRY 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BROWNS FERRY 3



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* BROWNS FERRY 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
140	09/07/83	S	744.0	C	4				EOC-5 REFUEL OUTAGE CONTINUES.

***** BROWNS FERRY 3 REMAINS SHUTDOWN IN A CONTINUING REFUELING AND MAINTENANCE OUTAGE.
* SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BROWNS FERRY 3 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ALABAMA

COUNTY.....LIMESTONE

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI NW OF
 DECATUR, ALA

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...AUGUST 8, 1976

DATE ELEC ENER 1ST GENER...SEPTEMBER 12, 1976

DATE COMMERCIAL OPERATE...MARCH 1, 1977

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER....TENNESSEE RIVER

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
 RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....TENNESSEE VALLEY AUTHORITY

CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II
 CHATTANOOGA, TENNESSEE 37401

CONTRACTOR
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY

NUC STEAM SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....J. PAULK

LICENSING PROJ MANAGER....R. CLARK
DOCKET NUMBER.....50-296

LICENSE & DATE ISSUANCE...DPR-68, AUGUST 18, 1976

PUBLIC DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY
 SOUTH AND FORREST
 ATHENS, ALABAMA 35611

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 23-27 (84-25): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 10 INSPECTOR-HOURS ON SITE IN THE AREAS OF RADIOACTIVE LIQUID AND GASEOUS EFFLUENTS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION 13-14 (84-28): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 3 INSPECTOR-HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 31 (84-29): THIS SPECIAL, ANNOUNCED INSPECTION INVOLVED 1 INSPECTOR-HOURS ON SITE IN THE AREA OF SECURITY. OF THE ONE AREA INSPECTED, ONE APPARENT VIOLATION WAS FOUND (FAILURE TO CONTROL ACCESS TO THE FUEL HANDLING AREA).

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.2.B.4.C AS IMPLEMENTED BY BROWNS FERRY STANDARD PRACTICE 8.3 AND 17.18 REQUIRES THAT THE PLANT OPERATING REVIEW COMMITTEE REVIEW PROPOSED CHANGES TO SYSTEMS HAVING SAFETY SIGNIFICANCE AND WHICH MAY CONSTITUTE ANY UNREVIEWED SAFETY QUESTION. CONTRARY TO THE ABOVE, THE REQUIREMENT WAS NOT MET IN THAT REVISIONS TO UNREVIEWED SAFETY QUESTION DETERMINATIONS ARE NOT GENERALLY REVIEWED BY THE PLANT OPERATING REVIEW COMMITTEE AS REQUIRED BY BROWNS FERRY STANDARD PRACTICE 17.18 AND 8.3. SPECIFICALLY, REVISIONS TO SAFETY EVALUATIONS GENERATED FROM THE TVA DESIGN ORGANIZATION ARE NOT REVIEWED TO DETERMINE SPECIAL CONDITIONS OR REQUIREMENTS DELINEATED IN THE REVISIONS. A REVIEW OF ECN 0392 (INSTALLATION OF THE SCRAM DISCHARGE VOLUME AND

ENFORCEMENT SUMMARY

ASSOCIATED INSTRUMENTATION) FOR ALL UNITS INDICATED THAT PLANT SUPERVISORS AND MANAGERS WERE UNAWARE OF SPECIAL TIMING REQUIREMENTS FOR INSTRUMENT RESPONSES, SPECIAL ADMINISTRATIVE PROCEDURES REQUIRED TO BE IMPLEMENTED FOR CERTAIN CONFIGURATION DESIGNS AND QUALIFICATION CRITERIA.
(8346 4)

TECHNICAL SPECIFICATION 6.7.2.A(9) REQUIRES A PROMPT NOTIFICATION UPON DISCOVERY DURING PLANT LIFE OF CONDITIONS NOT SPECIFICALLY CONSIDERED IN THE SAFETY ANALYSIS REPORT OR TECHNICAL SPECIFICATIONS THAT REQUIRE REMEDIAL ACTION OR CORRECTIVE MEASURES TO PREVENT THE EXISTENCE OR DEVELOPMENT OF AN UNSAFE CONDITION. CONTRARY TO THE ABOVE, THIS REQUIREMENT WAS NOT MET IN THAT THE EMERGENCY DIESEL GENERATOR COOLING WATER HEAT EXCHANGERS WERE FOUND IN MARCH 1983 TO HAVE A TUBE-SIDE DESIGN PRESSURE OF 75 PSIG IN A SYSTEM WITH A DESIGN PRESSURE OF 185 PSIG AND KNOWN OPERATING PRESSURES OF APPROXIMATELY 135 PSIG AND NO REPORT HAD BEEN MADE TO DATE. 10 CFR 50, APPENDIX B, CRITERION III REQUIRES THAT DESIGN CONTROL MEASURES SHALL PROVIDE FOR VERIFYING OR CHECKING THE ADEQUACY OF DESIGN, SUCH AS BY THE PERFORMANCE OF DESIGN REVIEWS, BY THE USE OF ALTERNATE OR SIMPLIFIED CALCULATIONAL METHODS OR BY THE PERFORMANCE OF A SUITABLE TESTING PROGRAM. CONTRARY TO THE ABOVE, THIS REQUIREMENT WAS NOT MET IN THAT THE EMERGENCY EQUIPMENT COOLING WATER (EECW) DIESEL GENERATOR HEAT EXCHANGERS HAVE A DESIGN PRESSURE OF 75 PSIG WHICH IS EXCEEDED BY THE EECW NORMAL OPERATING PRESSURE OF 100 TO 120 PSIG AND EMERGENCY OPERATING PRESSURE OF APPROXIMATELY 135 PSIG.
(8355 3)

10 CFR 50, APPENDIX B, CRITERION III REQUIRES THAT MEASURES SHALL BE ESTABLISHED FOR THE IDENTIFICATION AND CONTROL OF DESIGN INTERFACES AND FOR COORDINATION AMONG PARTICIPATING DESIGN ORGANIZATIONS; THAT DESIGN CONTROL MEASURES SHALL PROVIDE FOR VERIFYING OR CHECKING THE ADEQUACY OF DESIGN; AND THAT DESIGN CHANGES, INCLUDING FIELD CHANGES, SHALL BE SUBJECT TO DESIGN CONTROL MEASURES COMMENSURATE WITH THOSE APPLIED TO THE ORIGINAL DESIGN." CONTRARY TO THE ABOVE, ENGINEERING PROCEDURE EN DES-EP 1.48 ISSUED DECEMBER 16, 1983 ALLOWED DECISIONS TO BE MADE FOR A SIGNIFICANT NONCONFORMING CONDITION WITHOUT DESIGN CONTROL MEASURES COMMENSURATE WITH THOSE APPLIED TO THE ORIGINAL DESIGN. IN CONSEQUENCE, SIXTEEN EMERGENCY DIESEL GENERATOR COOLING WATER HEAT EXCHANGERS AND TWELVE RHR PUMP SEAL COOLING HEAT EXCHANGERS WERE NOT TARGETED FOR PROMPT CORRECTIVE ACTION APPLYING THE GUIDANCE FROM EN DES-EP 1.48.
(8401 3)

FAILURE TO CONTROL ACCESS TO A CONTROLLED ACCESS AREA.
(8429 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

THE OFFICE OF POWER AND OFFICE OF ENGINEERING, DESIGN AND CONSTRUCTION WERE COMBINED TO FORM THE OFFICE OF POWER AND ENGINEERING, H. G. PARRIS, MANAGER. A SEPARATE OFFICE OF NUCLEAR POWER WAS ESTABLISHED WITH J. P. DARLING, MANAGER, J. P. COFFEY WAS ASSIGNED AS SITE DIRECTOR, BROWNS FERRY REPORTING TO J. P. DARLING.

PLANT STATUS:

Report Period AUG 1984

INSPECTION STATUS - (CONTINUED)

* BROWNS FERRY 3 *

OTHER ITEMS

SHUTDOWN 9/6/83 TO PERFORM IGSCC INSPECTION.

LAST IE SITE INSPECTION DATE: JULY 31, 1984 +

INSPECTION REPORT NO: 50-296/84-29 +

REPORTS FROM LICENSEE

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE.			

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-325 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: FRANCES HARRISON (919) 457-9521

4. Licensed Thermal Power (MWt): 2436

5. Nameplate Rating (Gross MWe): 963 X 0.9 = 867

6. Design Electrical Rating (Net MWe): 821

7. Maximum Dependable Capacity (Gross MWe): 815

8. Maximum Dependable Capacity (Net MWe): 790

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>65,376.0</u>
13. Hours Reactor Critical	<u>704.1</u>	<u>5,233.4</u>	<u>41,631.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,647.1</u>
15. Hrs Generator On-Line	<u>687.1</u>	<u>5,100.8</u>	<u>39,189.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,554,862</u>	<u>11,870,537</u>	<u>80,297,823</u>
18. Gross Elec Ener (MWH)	<u>514,820</u>	<u>3,950,886</u>	<u>26,497,934</u>
19. Net Elec Ener (MWH)	<u>499,334</u>	<u>3,836,161</u>	<u>25,449,992</u>
20. Unit Service Factor	<u>92.4</u>	<u>87.1</u>	<u>59.9</u>
21. Unit Avail Factor	<u>92.4</u>	<u>87.1</u>	<u>59.9</u>
22. Unit Cap Factor (MDC Net)	<u>85.0</u>	<u>82.9</u>	<u>49.3</u>
23. Unit Cap Factor (DER Net)	<u>81.7</u>	<u>79.8</u>	<u>47.4</u>
24. Unit Forced Outage Rate	<u>7.6</u>	<u>10.2</u>	<u>19.6</u>
25. Forced Outage Hours	<u>56.9</u>	<u>579.0</u>	<u>9,498.2</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
LOCAL LEAK RATE TESTING: 10/31/84 - SIX WEEKS

27. If Currently Shutdown Estimated Startup Date: N/A

* BRUNSWICK 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
BRUNSWICK 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * BRUNSWICK 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-057	08/01/84	F	56.9	H	3				REACTOR SCRAM; AUXILIARY OPERATORS USING WALKIE-TALKIES IN REACTOR BLDG. 20 FT. ELEVATION AND -17 FT. ELEVATION IN CS ROOM. CORRECTIVE ACTION: SECURE USE OF RADIOS IN OPERATING UNITS WITH EXCEPTION OF SECURITY.
84-065	08/17/84	S	0.0	B	5				REDUCED POWER FOR ROD IMPROVEMENT.
84-066	08/25/84	S	0.0	B	5				ROD IMPROVEMENT PT-14.1 AND WEEKLY VALVE TESTING AND DEBRIS FILTER BACKWASH.

 * SUMMARY *

 BRUNSWICK 1 OPERATED ROUTINELY DURING AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* BRUNSWICK 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NORTH CAROLINA
COUNTY.....BRUNSWICK
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...3 MI N OF
SOUTHPORT, NC
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...OCTOBER 8, 1976
DATE ELEC ENER 1ST GENER...DECEMBER 4, 1976
DATE COMMERCIAL OPERATE...MARCH 18, 1977
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER....CAPE FEAR RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CAROLINA POWER & LIGHT
CORPORATE ADDRESS.....P. O. BOX 1551
RALEIGH, NORTH CAROLINA 27602
CONTRACTOR
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BROWN & ROOT
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....D. MYERS
LICENSING PROJ MANAGER.....M. GROTHENHUIS
DOCKET NUMBER.....50-325
LICENSE & DATE ISSUANCE...DPR-71, NOVEMBER 12, 1976
PUBLIC DOCUMENT ROOM.....SOUTHPORT-BRUNSWICK COUNTY LIBRARY
108 W. MOORE STREET
SOUTHPORT, NORTH CAROLINA 28461

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 18-20 (84-19): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 11 INSPECTOR-HOURS ON SITE IN THE AREAS OF REVIEW OF SURVEILLANCE TESTING OF REACTOR INSTRUMENTATION ISOLATION VALVES, REVIEW OF SURVEILLANCE TESTING OF SNUBBERS, AND FOLLOWUP OF A PREVIOUSLY IDENTIFIED INSPECTOR FOLLOWUP ITEM. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 15 - AUGUST 15 (84-20): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 75.5 INSPECTOR-HOURS ON THE SITE IN THE AREAS OF SURVEILLANCE, MAINTENANCE, OPERATIONAL SAFETY VERIFICATION, ESF SYSTEM WALKDOWN, IN-OFFICE LICENSEE EVENT REPORTS REVIEW, INDEPENDENT INSPECTION, PLANT TRANSIENTS, PLANT MODIFICATIONS, CALIBRATION AND IEB CLOSEOUTS. OF THE AREAS INSPECTED NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 30 - AUGUST 3 (84-21): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 15 INSPECTOR-HOURS ON SITE (2 HOURS ON BACK-SHIFT) INSPECTING: IMPLEMENTATION OF APPROVED SECURITY PLAN RELATIVE TO PLAN CHANGES AND IMPLEMENTING PROCEDURES; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AREA; PHYSICAL BARRIERS - VITAL AREA; SECURITY SYSTEM POWER SUPPLY; ACCESS CONTROLS - PERSONNEL, PACKAGES, AND VEHICLES; DETECTION AIDS - PROTECTED AREA; AND DETECTION AIDS - VITAL AREAS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH REGULATORY REQUIREMENTS IN THE 11 AREAS INSPECTED.

INSPECTION JULY 18-20 (84-22): THIS SPECIAL, ANNOUNCED INSPECTION INVOLVED 7.5 INSPECTOR-HOURS ON SITE IN THE AREAS OF INSERVICE INSPECTION, OBSERVATION OF WORK ACTIVITIES, INSERVICE INSPECTION, REVIEW OF DATA, AND INDEPENDENT INSPECTION EFFORT. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION SUMMARY

INSPECTION JULY 30 - AUGUST 3 (84-23): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 22 INSPECTOR-HOURS ON SITE IN THE AREA OF PLANT CHEMISTRY. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.8.1.A FOR UNITS ONE AND TWO REQUIRES THAT WRITTEN PROCEDURES SHALL BE ESTABLISHED, IMPLEMENTED, AND MAINTAINED COVERING ADMINISTRATIVE PROCEDURES. CONTRARY TO THE ABOVE, THE ADMINISTRATIVE PROCEDURE COVERING IMPLEMENTATION OF TECHNICAL SPECIFICATION CHANGES, AI 9.1, WAS NOT ADEQUATELY IMPLEMENTED IN THAT "PROCEDURE IDENTIFICATION CHANGE FORMS" WERE NOT ROUTED TO ALL RESPONSIBLE GROUPS. THIS LED TO FOUR NEW SURVEILLANCE REQUIREMENTS ADDED TO THE TECHNICAL SPECIFICATIONS BY AMENDMENTS 68 AND 94 TO THE OPERATING LICENSE OF UNITS ONE AND TWO, TO EXCEED THE REQUIRED MONTHLY PERFORMANCE FREQUENCY. THE AMENDMENT WAS ISSUED MARCH 20, 1984, AND TESTING WAS NOT COMPLETE UNTIL MAY 25, 1984. 10 CFR 50, APPENDIX B, CRITERION V REQUIRES ACTIVITIES AFFECTING QUALITY SHALL BE ACCOMPLISHED IN ACCORDANCE WITH INSTRUCTIONS, PROCEDURES, OR DRAWINGS. CONTRARY TO THE ABOVE, ACTIVITIES AFFECTING QUALITY WERE NOT ACCOMPLISHED IN ACCORDANCE WITH PROCEDURES IN THAT: (A) SURVEILLANCES REQUIRED BY SECTION 7.1 OF QAP-302 "SURVEILLANCE OF TECHNICAL SPECIFICATIONS" WERE NOT ACCOMPLISHED ON ALL TECHNICAL SPECIFICATION CHANGES AS DESCRIBED IN THE PROCEDURE. (B) ON MARCH 12, 1984, THE REQUIRED AUDIT OF SECTION 7.1 OF QAP-302 AS SPECIFIED ON THE PERFORMANCE EVALUATION UNIT CHECKLIST FOR AUDIT QAA-126-4 WAS NOT ACCOMPLISHED. TECHNICAL SPECIFICATION 6.8.1.A FOR UNITS ONE AND TWO REQUIRES THAT WRITTEN PROCEDURES SHALL BE ESTABLISHED, IMPLEMENTED, AND MAINTAINED COVERING ADMINISTRATIVE PROCEDURES. CONTRARY TO THE ABOVE, THE ADMINISTRATIVE PROCEDURE COVERING IMPLEMENTATION OF TECHNICAL SPECIFICATION CHANGES, AI 9.1, WAS NOT ADEQUATELY IMPLEMENTED IN THAT "PROCEDURE IDENTIFICATION CHANGE FORMS" WERE NOT ROUTED TO ALL RESPONSIBLE GROUPS. THIS LED TO FOUR NEW SURVEILLANCE REQUIREMENTS ADDED TO THE TECHNICAL SPECIFICATIONS BY AMENDMENTS 68 AND 94 TO THE OPERATING LICENSE OF UNITS ONE AND TWO, TO EXCEED THE REQUIRED MONTHLY PERFORMANCE FREQUENCY. THE AMENDMENT WAS ISSUED MARCH 20, 1984, AND TESTING WAS NOT COMPLETE UNTIL MAY 25, 1984. 10 CFR 50, APPENDIX B, CRITERION V REQUIRES ACTIVITIES AFFECTING QUALITY SHALL BE ACCOMPLISHED IN ACCORDANCE WITH INSTRUCTIONS, PROCEDURES, OR DRAWINGS. CONTRARY TO THE ABOVE, ACTIVITIES AFFECTING QUALITY WERE NOT ACCOMPLISHED IN ACCORDANCE WITH PROCEDURES IN THAT: (A) SURVEILLANCES REQUIRED BY SECTION 7.1 OF QAP-302 "SURVEILLANCE OF TECHNICAL SPECIFICATIONS" WERE NOT ACCOMPLISHED ON ALL TECHNICAL SPECIFICATION CHANGES AS DESCRIBED IN THE PROCEDURE. (B) ON MARCH 12, 1984, THE REQUIRED AUDIT OF SECTION 7.1 OF QAP-302 AS SPECIFIED ON THE PERFORMANCE EVALUATION UNIT CHECKLIST FOR AUDIT QAA-126-4 WAS NOT ACCOMPLISHED.
(8413 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

ROUTINE OPERATION.

OTHER ITEMS

LAST IE SITE INSPECTION DATE: JULY 30 - AUGUST 3, 1984 +

INSPECTION REPORT NO: 50-325/84-23 +

 R E P O R T S F R O M L I C E N S E E

```
=====
```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-010	06/25/84	07/20/84	TRAIN A OF CBEAF SYSTEM AUTO STARTED DUE TO A FIRE ALARM IN THE CONTROL BUILDING.
84-011	07/11/84	07/31/84	(CBEAF) SYSTEM AUTOMATICALLY STARTED DUE TO A SPURIOUS FIRE ALARM, CAUSE COULD NOT BE DETERMINED.

```
=====
```

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-324 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: FRANCES HARRISON (919) 457-9521

4. Licensed Thermal Power (MWt): 2436

5. Nameplate Rating (Gross MWe): 963 X 0.9 = 867

6. Design Electrical Rating (Net MWe): 821

7. Maximum Dependable Capacity (Gross MWe): 815

8. Maximum Dependable Capacity (Net MWe): 790

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>77,400.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>1,604.3</u>	<u>46,331.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>1,566.9</u>	<u>43,352.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>3,355,120</u>	<u>81,931,834</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>1,110,430</u>	<u>27,220,128</u>
19. Net Elec Ener (MWH)	<u>-6,131</u>	<u>1,048,529</u>	<u>26,076,147</u>
20. Unit Service Factor	<u>.0</u>	<u>26.8</u>	<u>56.0</u>
21. Unit Avail Factor	<u>.0</u>	<u>26.8</u>	<u>56.0</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>22.7</u>	<u>42.6</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>21.8</u>	<u>41.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>2.2</u>	<u>17.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>35.5</u>	<u>9,638.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 10/10/84

* BRUNSWICK 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BRUNSWICK 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* BRUNSWICK 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-020	03/12/84	S	744.0	C	4		RC	FUELXX	REFUELING/MAINTENANCE OUTAGE CONTINUES.

* SUMMARY *

BRUNSWICK 2 REMAINS SHUTDOWN IN A CONTINUING REFUELING/MAINTENANCE OUTAGE.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

* BRUNSWICK 2 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NORTH CAROLINA
COUNTY.....BRUNSWICK
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...3 MI N OF
SOUTHPORT, NC
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MARCH 20, 1975
DATE ELEC ENER 1ST GENER...APRIL 29, 1975
DATE COMMERCIAL OPERATE...NOVEMBER 3, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CAPE FEAR RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CAROLINA POWER & LIGHT
CORPORATE ADDRESS.....411 FAYETTEVILLE STREET
RALEIGH, NORTH CAROLINA 27602
CONTRACTOR
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BROWN & ROOT
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....D. MYERS
LICENSING PROJ MANAGER.....M. GROTEHUIS
DOCKET NUMBER.....50-324
LICENSE & DATE ISSUANCE...DPR-62, DECEMBER 27, 1974
PUBLIC DOCUMENT ROOM.....SOUTHPORT-BRUNSWICK COUNTY LIBRARY
108 W. MOORE STREET
SOUTHPORT, NORTH CAROLINA 28461

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 18-20 (84-19): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 11 INSPECTOR-HOURS ON SITE IN THE AREAS OF REVIEW OF SURVEILLANCE TESTING OF REACTOR INSTRUMENTATION ISOLATION VALVES, REVIEW OF SURVEILLANCE TESTING OF SNUBBERS, AND FOLLOWUP OF A PREVIOUSLY IDENTIFIED INSPECTOR FOLLOWUP ITEM. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 15 - AUGUST 15 (84-20): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 75.5 INSPECTOR-HOURS ON THE SITE IN THE AREAS OF SURVEILLANCE, MAINTENANCE, OPERATIONAL SAFETY VERIFICATION, ESF SYSTEM WALKDOWN, IN-OFFICE LICENSEE EVENT REPORTS REVIEW, INDEPENDENT INSPECTION, PLANT TRANSIENTS, PLANT MODIFICATIONS, CALIBRATION AND IEB CLOSEOUTS. OF THE AREAS INSPECTED NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 30 - AUGUST 3 (84-21): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 15 INSPECTOR-HOURS ON SITE (2 HOURS ON BACK-SHIFT) INSPECTING: IMPLEMENTATION OF APPROVED SECURITY PLAN RELATIVE TO PLAN CHANGES AND IMPLEMENTING PROCEDURES; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AREA; PHYSICAL BARRIERS - VITAL AREA; SECURITY SYSTEM POWER SUPPLY; ACCESS CONTROLS - PERSONNEL, PACKAGES, AND VEHICLES; DETECTION AIDS - PROTECTED AREA; AND DETECTION AIDS - VITAL AREAS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH REGULATORY REQUIREMENTS IN THE 11 AREAS INSPECTED.

INSPECTION JULY 18-20 (84-22): THIS SPECIAL, ANNOUNCED INSPECTION INVOLVED 7.5 INSPECTOR-HOURS ON SITE IN THE AREAS OF INSERVICE INSPECTION, OBSERVATION OF WORK ACTIVITIES, INSERVICE INSPECTION, REVIEW OF DATA, AND INDEPENDENT INSPECTION EFFORT. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* BRUNSWICK 2 *

INSPECTION SUMMARY

INSPECTION JULY 30 - AUGUST 3 (84-23): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 22 INSPECTOR-HOURS ON SITE IN THE AREA OF PLANT CHEMISTRY. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

REFUEL AND MAINTENANCE OUTAGE.

LAST IE SITE INSPECTION DATE: JULY 30 - AUGUST 3, 1984 +

INSPECTION REPORT NO: 50-324/84-23 +

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE.			

=====

1. Docket: 50-317 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: EVELYN BEWLEY (301) 787-5365

4. Licensed Thermal Power (MWt): 2700

5. Nameplate Rating (Gross MWe): 1020 X 0.9 = 918

6. Design Electrical Rating (Net MWe): 845

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 825

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>81,684.0</u>
13. Hours Reactor Critical	<u>703.5</u>	<u>5,052.4</u>	<u>65,019.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,887.9</u>
15. Hrs Generator On-Line	<u>672.4</u>	<u>4,989.5</u>	<u>63,735.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,770,910</u>	<u>13,242,324</u>	<u>157,384,619</u>
18. Gross Elec Ener (MWH)	<u>584,585</u>	<u>4,467,181</u>	<u>51,894,666</u>
19. Net Elec Ener (MWH)	<u>557,184</u>	<u>4,272,263</u>	<u>49,507,229</u>
20. Unit Service Factor	<u>90.4</u>	<u>85.2</u>	<u>78.0</u>
21. Unit Avail Factor	<u>90.4</u>	<u>85.2</u>	<u>78.0</u>
22. Unit Cap Factor (MDC Net)	<u>90.8</u>	<u>88.4</u>	<u>74.3*</u>
23. Unit Cap Factor (DER Net)	<u>88.6</u>	<u>86.4</u>	<u>71.7</u>
24. Unit Forced Outage Rate	<u>9.6</u>	<u>14.8</u>	<u>8.1</u>
25. Forced Outage Hours	<u>71.6</u>	<u>865.5</u>	<u>5,528.3</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 09/15/84

* CALVERT CLIFFS 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

CALVERT CLIFFS 1



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* CALVERT CLIFFS 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-06	08/29/84	F	71.6	A	1		XX	ZZZZZ	REDUCTION OF MAIN CIRCULATING WATER FLOW CAUSED BY IMPINGEMENT OF A LARGE NUMBER OF FISH ON THE TRAVELING SCREENS.

***** CALVERT CLIFFS 1 SHUTDOWN ON AUGUST 29TH FOR MAINTENANCE REPAIRS.
* SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	H-Other	5-Reduced Load	Licensee Event Report
	D-Regulatory Restriction	9-Other	(LER) File (NUREG-0161)
	E-Operator Training		
	& License Examination		

* CALVERT CLIFFS 1 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....MARYLAND
COUNTY.....CALVERT
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI S OF
ANNAPOLIS, MD
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 7, 1974
DATE ELEC ENER 1ST GENER...JANUARY 3, 1975
DATE COMMERCIAL OPERATE...MAY 8, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CHESAPEAKE BAY
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY
LICENSEE.....BALTIMORE GAS & ELEC
CORPORATE ADDRESS.....P.O. BOX 1475
BALTIMORE, MARYLAND 21203
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. FOLEY
LICENSING PROJ MANAGER....D. JAFFE
DOCKET NUMBER.....50-317
LICENSE & DATE ISSUANCE...DPR-53, JULY 31, 1974
PUBLIC DOCUMENT ROOM.....CALVERT COUNTY LIBRARY
FOURTH STREET
PRINCE FREDERICK, MARYLAND 20678

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 3.6.4.1. REQUIRES THE CONTAINMENT ISOLATION VALVES SPECIFIED IN TABLE 3.6-1 T BE OPERABLE WITH THE ISOLATION TIMES SHOWN DURING MODE 1 THROUGH 5 OPERATIONS. TABLE 3.6-1 STATES THAT ISOLATION TIMES ARE "NA" (NOT APPLICABLE) FOR 1-SV-6529 (POST ACCIDENT SAMPLING LIQUID RETURN VALVE TO REACTOR COOLANT DRAIN TANK), 1-SV-6540G AND 1-SV-6570G (HYDROGEN SAMPLE RETURN VALVES), THEREBY REQUIRING THAT THESE VALVES BE MAINTAINED CLOSED. TABLE 3.6-1 IS PERMISSIVE IN THAT IT ALLOWS 1-SV-6529 TO BE OPENED ON AN INTERMITTENT BASIS UNDER ADMINISTRATIVE CONTROL. CONTRARY TO THE ABOVE, ON JANUARY 13, 1984, WITH THE UNIT IN MODE 1 OPERATION, 1-SV-6529 WAS DISCOVERED TO BE WITHOUT ADMINISTRATIVE CONTROL, HAVING APPARENTLY BEEN OPEN SINCE CONTROL FUSES WERE INSTALLED ON JANUARY 3, 1984, AN ACT CONTRARY TO THE ADMINISTRATIVE CONTROLS DETAILED IN NRC AND LICENSEE SAFETY EVALUATIONS. CONTRARY TO THE ABOVE WITH THE UNIT IN MODE 1 OPERATION, VALVES 1-SV-6540G AND 1-SV-6507G WERE OPENED FOR A THREE MINUTE PERIOD (FROM 2:00 P.M. TO 2:03 P.M.). (8401 4)

APPENDIX A, TECHNICAL SPECIFICATION SECTION 6.5.1.6 REQUIRES THAT THE POSRC SHALL BE RESPONSIBLE FOR REVIEW OF ALL PROCEDURES REQUIRED BY SPECIFICATION 6.8 AND CHANGES THERETO. SPECIFICATION 6.8 REQUIRES WRITTEN PROCEDURES RECOMMENDED IN APPENDIX A OF

ENFORCEMENT SUMMARY

REGULATORY GUIDE 1.33, REVISION 2, FEBRUARY 1978. REGULATORY GUIDE 1.33 REQUIRES CHEMICAL AND RADIOCHEMICAL CONTROL PROCEDURES, PROCEDURES FOR SURVEILLANCE TESTS LISTED IN THE TECHNICAL SPECIFICATIONS AND PROCEDURES USED TO DETERMINE RADIOACTIVITY IN LIQUID AND GASEOUS EFFLUENT INCLUDING SAMPLING AND CALIBRATION. CONTRARY TO THE ABOVE, (A) PROCEDURES COVERING REQUIRED SURVEILLANCE TEST FOR REACTOR COOLANT SYSTEM CHEMISTRY: RCP-1-905 WATER CHEMISTRY ANALYSIS DETERMINATION OF DISSOLVED OXYGEN; RCP-1-906 DETERMINATION OF CHLORIDE; RCP-1-907 DETERMINATION OF FLUORIDE; WERE NOT REVIEWED BY POSRC. (B) PROCEDURES COVERING DETERMINATION OF RADIOACTIVITY IN EFFLUENTS INCLUDING CALIBRATION: RCP-1-1001 RADIOCHEMISTRY ANALYSIS DETERMINATION OF GROSS BETA-GAMMA (ALPHA) DEGASSED ACTIVITY; RCP-1-1007 RADIOCHEMISTRY ANALYSIS DETERMINATION OF TRITIUM-ACTIVITY; RCP-1-1010 EVALUATION OF GAMMA SPECTRA; RCP-2-101 CALIBRATION AND OPERATIONAL CHECK OF GE (LI) DETECTOR; RCP-2-302 LIQUID SCINTILLATION SYSTEM; RCP-2-303 WIDEBETA II OPERATION AND CALIBRATION; WERE NOT REVIEWED BY POSRC. OTHER PROCEDURES COVERING ACTIVITIES IN THESE AREAS WERE NOT REVIEWED BY POSRC.
(8409 4)

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, PROCEDURES WERE NOT ESTABLISHED TO ASSURE CONTROL OF PORT MODIFICATION PUNCH LISTS OR TO ASSURE DOCUMENTATION OF SATISFACTORY RESOLUTION OF PUNCH LIST ITEMS.
(8416 5)

FAILURE TO NOTIFY THE COMMISSION WITHIN 90 DAYS OF A CHANGE TO THE SECURITY AND TRAINING AND QUALIFICATION PLAN.
(8417 5)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

* CALVERT CLIFFS 1 *

R E P O R T S F R O M L I C E N S E E

Report Period AUG 1984

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-318 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: EVELYN BEWLEY (310) 787-5365

4. Licensed Thermal Power (MWt): 2700

5. Nameplate Rating (Gross MWe): 1012 X 0.9 = 911

6. Design Electrical Rating (Net MWe): 845

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 825

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>65,039.0</u>
13. Hours Reactor Critical	<u>636.0</u>	<u>3,864.5</u>	<u>53,792.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>958.1</u>
15. Hrs Generator On-Line	<u>630.1</u>	<u>3,755.9</u>	<u>52,871.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,640,770</u>	<u>9,690,259</u>	<u>131,531,952</u>
18. Gross Elec Ener (MWH)	<u>539,510</u>	<u>3,180,698</u>	<u>43,249,984</u>
19. Net Elec Ener (MWH)	<u>514,528</u>	<u>3,034,364</u>	<u>41,238,126</u>
20. Unit Service Factor	<u>84.7</u>	<u>64.1</u>	<u>81.3</u>
21. Unit Avail Factor	<u>84.7</u>	<u>64.1</u>	<u>81.3</u>
22. Unit Cap Factor (MDC Net)	<u>83.8</u>	<u>62.8</u>	<u>77.3*</u>
23. Unit Cap Factor (DER Net)	<u>81.8</u>	<u>61.3</u>	<u>75.0</u>
24. Unit Forced Outage Rate	<u>15.3</u>	<u>9.0</u>	<u>6.1</u>
25. Forced Outage Hours	<u>113.9</u>	<u>370.0</u>	<u>3,415.2</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* CALVERT CLIFFS 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
CALVERT CLIFFS 2



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* CALVERT CLIFFS 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-07	08/09/84	F	113.9	A	1		CB	PUMPXX	LEAK IN 22B REACTOR COOLANT PUMP CONTROL BLEED OFF LINE WELD.

* SUMMARY *

CALVERT CLIFFS 2 OPERATED WITH 1 OUTAGE AND NO REDUCTIONS DURING AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* CALVERT CLIFFS 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MARYLAND
COUNTY.....CALVERT
DIST AND DIRECTION FROM
NEAREST POPULATION CTR....40 MI S OF
ANNAPOLIS, MD
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 30, 1976
DATE ELEC ENER 1ST GENER...DECEMBER 7, 1976
DATE COMMERCIAL OPERATE....APRIL 1, 1977
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER....CHESAPEAKE BAY
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....BALTIMORE GAS & ELEC
CORPORATE ADDRESS.....P.O. BOX 1475
BALTIMORE, MARYLAND 21203
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. FOLEY
LICENSING PROJ MANAGER.....D. JAFFE
DOCKET NUMBER.....50-318
LICENSE & DATE ISSUANCE....DPR-69, NOVEMBER 30, 1976
PUBLIC DOCUMENT ROOM.....CALVERT COUNTY LIBRARY
FOURTH STREET
PRINCE FREDERICK, MARYLAND 20678

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

APPENDIX A, TECHNICAL SPECIFICATION SECTION 6.5.1.6 REQUIRES THAT THE POSRC SHALL BE RESPONSIBLE FOR REVIEW OF ALL PROCEDURES REQUIRED BY SPECIFICATION 6.8 AND CHANGES THERETO. SPECIFICATION 6.8 REQUIRES WRITTEN PROCEDURES RECOMMENDED IN APPENDIX A OF REGULATORY GUIDE 1.33, REVISION 2, FEBRUARY 1978. REGULATORY GUIDE 1.33 REQUIRES CHEMICAL AND RADIOCHEMICAL CONTROL PROCEDURES, PROCEDURES FOR SURVEILLANCE TESTS LISTED IN THE TECHNICAL SPECIFICATIONS AND PROCEDURES USED TO DETERMINE RADIOACTIVITY IN LIQUID AND GASEOUS EFFLUENT INCLUDING SAMPLING AND CALIBRATION. CONTRARY TO THE ABOVE, (A) PROCEDURES COVERING REQUIRED SURVEILLANCE TEST FOR REACTOR COOLANT SYSTEM CHEMISTRY: RCP-1-905 WATER CHEMISTRY ANALYSIS DETERMINATION OF DISSOLVED OXYGEN; RCP-1-906 DETERMINATION OF CHLORIDE; RCP-1-907 DETERMINATION OF FLUORIDE; WERE NOT REVIEWED BY POSRC. (B) PROCEDURES COVERING DETERMINATION OF RADIOACTIVITY IN EFFLUENTS INCLUDING CALIBRATION: RCP-1-1001 RADIOCHEMISTRY ANALYSIS DETERMINATION OF GROSS BETA-GAMMA (ALPHA) DEGASSED ACTIVITY; RCP-1-1007 RADIOCHEMISTRY ANALYSIS DETERMINATION OF TRITIUM-ACTIVITY; RCP-1-1010 EVALUATION OF GAMMA SPECTRA; RCP-2-101 CALIBRATION AND OPERATIONAL CHECK OF GE (LI) DETECTOR; RCP-2-302 LIQUID SCINTILLATION SYSTEM; RCP-2-303 WIDEBETA II OPERATION AND CALIBRATION; WERE NOT REVIEWED BY POSRC. OTHER PROCEDURES COVERING ACTIVITIES IN THESE AREAS WERE NOT REVIEWED BY POSRC.
(8409 4)

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* CALVERT CLIFFS 2 *

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, PROCEDURES WERE NOT ESTABLISHED TO ASSURE CONTROL OF PORT MODIFICATION PUNCH LISTS OR TO ASSURE DOCUMENTATION OF SATISFACTORY RESOLUTION OF PUNCH LIST ITEMS.
(8416 5)

FAILURE TO NOTIFY THE COMMISSION WITHIN 90 DAYS OF A CHANGE TO THE SECURITY AND TRAINING AND QUALIFICATION PLAN.
(8417 5)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

1. Docket: 5.-315 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: W. T. GILLETT (616) 465-5901

4. Licensed Thermal Power (MWt): 3250

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1030

7. Maximum Dependable Capacity (Gross MWe): 1056

8. Maximum Dependable Capacity (Net MWe): 1020

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>84,743.0</u>
13. Hours Reactor Critical	<u>492.3</u>	<u>5,156.9</u>	<u>62,775.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>463.0</u>
15. Hrs Generator On-Line	<u>466.2</u>	<u>5,088.8</u>	<u>61,432.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>321.0</u>
17. Gross Therm Ener (MWH)	<u>1,349,657</u>	<u>15,524,904</u>	<u>179,606,518</u>
18. Gross Elec Ener (MWH)	<u>426,470</u>	<u>5,070,850</u>	<u>58,997,140</u>
19. Net Elec Ener (MWH)	<u>409,192</u>	<u>4,882,790</u>	<u>56,763,130</u>
20. Unit Service Factor	<u>62.7</u>	<u>86.9</u>	<u>74.3</u>
21. Unit Avail Factor	<u>62.7</u>	<u>86.9</u>	<u>74.3</u>
22. Unit Cap Factor (MDC Net)	<u>53.9</u>	<u>81.8</u>	<u>67.4</u>
23. Unit Cap Factor (DER Net)	<u>53.4</u>	<u>81.0</u>	<u>64.6</u>
24. Unit Forced Outage Rate	<u>5.5</u>	<u>7.6</u>	<u>7.8</u>
25. Forced Outage Hours	<u>27.2</u>	<u>418.6</u>	<u>4,499.4</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
REFUELING & MAINTENANCE: 03/01/85 - 4 MOS.

27. If Currently Shutdown Estimated Startup Date: N/A

* COOK 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
COOK 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * COOK 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
225	07/27/84	S	250.6	B	4		ZZ	ZZZZZZ	THE UNIT WAS REMOVED FROM SERVICE TO PERFORM REQUIRED ICE CONDENSER SURVEILLANCE AND TO REPAIR LEAKING PRESSURIZER SAFETY VALVES. THE PRESSURIZER SAFETY VALVES WERE REPLACED WITH REBUILT VALVES. THE UNIT WAS RETURNED TO SERVICE ON 840811.
226	08/14/84	F	27.2	A	3	84-018-00	EF	INSTRU	A REACTOR TRIP WITH TRAIN "A" SAFETY INJECTION OCCURRED FROM 100% POWER DUE TO A FAILURE OF VITAL A.C. INSTRUMENT BUS, CRID IV INVERTER. THE INVERTER FAILURE WAS DUE TO WATER VAPOR LADEN AIR BEING BLOWN INTO THE INVERTER CABINET BY A TEMPORARY VENTILATION BLOWER. THE WATER SOURCE WAS DUE TO A LEAK.
227	08/17/84	F	0.0	H	5		HH	TURBIN	REACTOR POWER WAS REDUCED FROM 100% TO 80% FOR APPROXIMATELY 18 HOURS TO REDUCE THE LOADING OF THE EAST MAIN FEED PUMP TURBINE DUE TO A HIGH VIBRATION PROBLEM ON THE TURBINE INBOARD BEARING.
228	08/23/84	F	0.0	B	5		HH	HTEXCH	REACTOR POWER WAS REDUCED FROM 100% TO 58 TO FIRST REMOVE THE WEST MAIN FEED PUMP TURBINE TO REPAIR CONDENSER TUBE LEAK. ONE TUBE WAS PLUGGED.
229	08/31/84	F	0.0	H	5		HH	TURBIN	REACTOR POWER WAS REDUCED TO 57% TO REMOVE THE EAST MAIN FEED PUMP TURBINE FROM SERVICE TO MAKE ALIGNMENT CHECKS AND REPLACE THE TURBINE INBOARD BEARING WITH A NEW DESIGN (ELLIPTICAL) BEARING.

 * SUMMARY *

 COOK 1 OPERATED WITH 2 OUTAGES AND 3 REDUCTIONS DURING AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MICHIGAN
COUNTY.....BERRIEN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI S OF
BENTON HARBOR, MI
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JANUARY 18, 1975
DATE ELEC ENER 1ST GENER...FEBRUARY 10, 1975
DATE COMMERCIAL OPERATE...AUGUST 27, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....INDIANA & MICHIGAN ELECTRIC
CORPORATE ADDRESS.....1 RIVERSIDE PLAZA
COLUMBUS, OHIO 43216
CONTRACTOR
ARCHITECT/ENGINEER.....AMERICAN ELEC. POWER SERVICE CORP.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....AMERICAN ELEC. POWER SERVICE CORP.
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....E. SWANSON
LICENSING PROJ MANAGER.....D. WIGGINTON
DOCKET NUMBER.....50-315
LICENSE & DATE ISSUANCE...DPR-58, OCTOBER 25, 1974
PUBLIC DOCUMENT ROOM.....MAUDE PRESTON PALENSKE MEMORIAL LIBRARY
500 MARKET STREET
ST. JOSEPH, MICHIGAN 49085

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 4, THROUGH JUNE 8, (84-11): SPECIAL UNANNOUNCED INSPECTION BY A TEAM OF SENIOR RESIDENT INSPECTORS OF PROBLEM ALARMS; SYSTEM WALKDOWN AND PRINT VERIFICATION; SURVEILLANCE; MAINTENANCE; INSERVICE TESTING; WORK CONTROLS, INDEPENDENT VERIFICATION; OPERATIONS REVIEW; CALIBRATION; AND MISCELLANEOUS ISSUES. THE INSPECTION INVOLVED A TOTAL OF 142 INSPECTOR-HOURS BY FOUR NRC INSPECTORS INCLUDING 13 HOURS DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JULY 23-27, (84-14): ROUTINE ANNOUNCED INSPECTION OF LICENSEE EVENT REPORTS; STARTUP TEST RESULTS PACKAGES; UNIT 2 CYCLE 4 CORE POWER DISTRIBUTION LIMITS; AND THE PLANT NUCLEAR SAFETY REVIEW COMMITTEE'S REVIEW OF THE UNIT 2, CYCLE 5 CORE RELOAD ANALYSIS. THE INSPECTION INVOLVED A TOTAL OF 49 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS, INCLUDING 11 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT IS OPERATING ROUTINELY.

LAST IE SITE INSPECTION DATE: SEPTEMBER 1-28, 1984

INSPECTION REPORT NO: 84-19

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-07	05/28/84	08/10/84	DISCOVERY OF ERROR IN DETECTOR CODE.
84-13	07/06/84	07/31/84	FAILURE TO MAINTAIN FIRE WATCH.
84-14	07/16/84	08/15/84	BOTH SAFETY INJECTION PUMPS INOP.
84-15	07/28/84	08/24/84	FAILURE TO COMPLETE DAILY SURVEY OF SPENT FUEL STORAGE AREA.

1. Docket: 50-316 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: W. T. GILLET (616) 465-5901

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1333 X 0.85 = 1133

6. Design Electrical Rating (Net MWe): 1100

7. Maximum Dependable Capacity (Gross MWe): 1100

8. Maximum Dependable Capacity (Net MWe): 1060

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>58,439.0</u>
13. Hours Reactor Critical	<u>697.9</u>	<u>2,881.6</u>	<u>40,666.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>693.2</u>	<u>2,805.7</u>	<u>39,605.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,341,526</u>	<u>9,163,987</u>	<u>127,616,955</u>
18. Gross Elec Ener (MWH)	<u>748,680</u>	<u>2,988,240</u>	<u>41,214,670</u>
19. Net Elec Ener (MWH)	<u>722,391</u>	<u>2,884,206</u>	<u>39,737,559</u>
20. Unit Service Factor	<u>93.2</u>	<u>47.9</u>	<u>70.6</u>
21. Unit Avail Factor	<u>93.2</u>	<u>47.9</u>	<u>70.6</u>
22. Unit Cap Factor (MDC Net)	<u>91.6</u>	<u>46.5</u>	<u>67.4</u>
23. Unit Cap Factor (DER Net)	<u>88.3</u>	<u>44.8</u>	<u>66.1</u>
24. Unit Forced Outage Rate	<u>6.8</u>	<u>2.9</u>	<u>13.2</u>
25. Forced Outage Hours	<u>50.8</u>	<u>82.9</u>	<u>5,933.8</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
SURVEILLANCE & MAINTENANCE: 12/22/84 - 2 WEEKS

27. If Currently Shutdown Estimated Startup Date: N/A

* COOK 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

COOK 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * CODK 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
148	08/05/84	F	50.8	A	3	84-020-00	EF	INSTRU	A REACTOR TRIP OCCURRED FROM 100% POWER DUE TO A FAILURE OF VITAL INSTRUMENT, CRID II, INVERTER. THE INVERTER FAILURE WAS DUE TO A BLOWN FUSE. THE BLOWN FUSE, THE SILICON CONTROLLED RECTIFIERS AND DIODES WERE REPLACED.

 * SUMMARY *

 COGK 2 OPERATED WITH 1 OUTAGE AND NO REDUCTIONS DURING AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MICHIGAN
COUNTY.....BERRIEN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR... 11 MI S OF
BENTON HARBOR, MI
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MARCH 10, 1978
DATE ELEC ENER 1ST GENER...MARCH 22, 1978
DATE COMMERCIAL OPERATE...JULY 1, 1978
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....INDIANA & MICHIGAN ELECTRIC
CORPORATE ADDRESS.....1 RIVERSIDE PLAZA
COLUMBUS, OHIO 43216
CONTRACTOR
ARCHITECT/ENGINEER.....AMERICAN ELEC. POWER SERVICE CORP.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....J. A. JONES CONSTRUCTION
TURBINE SUPPLIER.....BROWN BOVERI

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....E. SWANSON
LICENSING PROJ MANAGER.....D. WIGGINTON
DOCKET NUMBER.....50-316
LICENSE & DATE ISSUANCE...DPR-74, DECEMBER 23, 1977
PUBLIC DOCUMENT ROOM.....MAUDE PRESTON PALENSKE MEMORIAL LIBRARY
500 MARKET STREET
ST. JOSEPH, MICHIGAN 49085

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 4, THROUGH JUNE 8, (84-12): SPECIAL UNANNOUNCED INSPECTION BY A TEAM OF SENIOR RESIDENT INSPECTORS OF PROBLEM ALARMS; SYSTEM WALKDOWN AND PRINT VERIFICATION; SURVEILLANCE; MAINTENANCE; INSERVICE TESTING; WORK CONTROLS, INDEPENDENT VERIFICATION; OPERATIONS REVIEW; CALIBRATION; AND MISCELLANEOUS ISSUES. THE INSPECTION INVOLVED A TOTAL OF 142 INSPECTOR-HOURS BY FOUR NRC INSPECTORS INCLUDING 13 HOURS DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JULY 23-27, (84-16): ROUTINE ANNOUNCED INSPECTION OF LICENSEE EVENT REPORTS; STARTUP TEST RESULTS PACKAGES; UNIT 2 CYCLE 4 CORE POWER DISTRIBUTION LIMITS; AND THE PLANT NUCLEAR SAFETY REVIEW COMMITTEE'S REVIEW OF THE UNIT 2, CYCLE 5 CORE RELOAD ANALYSIS. THE INSPECTION INVOLVED A TOTAL OF 49 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS, INCLUDING 11 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

```
*****  
*                                   COOK 2                                   *  
*****
```

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING ROUTINELY.

LAST IE SITE INSPECTION DATE: SEPTEMBER 1-30, 1984

INSPECTION REPORT NO: 84-21

 R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-18	07/09/84	08/09/84	CONTROL ROD MISALIGNMENT.
84-19	07/10/84	08/09/84	PROTECTIVE FUNCTION CHANNEL NOT TRIPPED.

1. Docket: 50-298 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: M. F. NOLET (402) 825-3811

4. Licensed Thermal Power (MWt): 2381

5. Nameplate Rating (Gross MWe): 983 X 0.85 = 836

6. Design Electrical Rating (Net MWe): 778

7. Maximum Dependable Capacity (Gross MWe): 787

8. Maximum Dependable Capacity (Net MWe): 764

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>89,160.0</u>
13. Hours Reactor Critical	<u>707.5</u>	<u>5,595.5</u>	<u>72,598.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>698.4</u>	<u>5,545.2</u>	<u>71,463.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,306,584</u>	<u>10,419,087</u>	<u>140,932,245</u>
18. Gross Elec Ener (MWH)	<u>426,418</u>	<u>3,454,086</u>	<u>44,860,441</u>
19. Net Elec Ener (MWH)	<u>409,237</u>	<u>3,312,235</u>	<u>43,228,894</u>
20. Unit Service Factor	<u>93.9</u>	<u>94.7</u>	<u>80.2</u>
21. Unit Avail Factor	<u>93.9</u>	<u>94.7</u>	<u>80.2</u>
22. Unit Cap Factor (MDC Net)	<u>72.0</u>	<u>74.0</u>	<u>63.5</u>
23. Unit Cap Factor (DER Net)	<u>70.7</u>	<u>72.7</u>	<u>62.3</u>
24. Unit Forced Outage Rate	<u>6.1</u>	<u>2.3</u>	<u>3.7</u>
25. Forced Outage Hours	<u>45.6</u>	<u>130.5</u>	<u>2,087.8</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


REFUELING & MAINTENANCE: 09/24/84 - 7 MOS.

27. If Currently Shutdown Estimated Startup Date: N/A

* COOPER STATION *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

COOPER STATION



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* COOPER STATION *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-5	08/08/84	F	45.6	H	3	84-010			HIGH TEMPERATURE INDICATION IN MAIN STEAM LINE BREAK DETECTION SYSTEM, CAUSING GROUP I ISOLATION AND SCRAM. CAUSE WAS HOT SUMMER DAY TIME TEMPERATURES AND POOR INSULATION AROUND THE MAIN STEAM LINES. ADDED INSULATION WAS PLACED AROUND MAIN STEAM LINES TO PREVENT RECURRENCE.

***** COOPER STATION OPERATED WITH 1 OUTAGE AND NO REDUCTIONS DURING AUGUST.
* SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* COOPER STATION *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEBRASKA

COUNTY.....NEMAHA

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...23 MI S OF
NEBRASKA CITY, NEB

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...FEBRUARY 21, 1974
DATE ELEC ENER 1ST GENER...MAY 10, 1974
DATE COMMERCIAL OPERATE...JULY 1, 1974

CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MISSOURI RIVER

ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NEBRASKA PUBLIC POWER DISTRICT

CORPORATE ADDRESS.....P.O. BOX 499
COLUMBUS, NEBRASKA 68601

CONTRACTOR
ARCHITECT/ENGINEER.....BURNS & ROE

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....BURNS & ROE

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....D. DUBOIS

LICENSING PROJ MANAGER.....E. SYLVESTER
DOCKET NUMBER.....50-298

LICENSE & DATE ISSUANCE...DPR-46, JANUARY 18, 1974

PUBLIC DOCUMENT ROOM.....AUBURN PUBLIC LIBRARY
1118 15TH STREET
AUBURN, NEBRASKA 68305

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED MAY 1-JUNE 30, (84-11): ROUTINE, ANNOUNCED INSPECTION INCLUDING OPERATIONAL SAFETY VERIFICATIONS, MONTHLY SURVEILLANCE AND MAINTENANCE OBSERVATION, LICENSEE EVENT FOLLOWUP, DECLARATION OF UNUSUAL EVENT, PREPARATION FOR REFUELING, OBSERVATION OF ANNUAL EMERGENCY PREPAREDNESS EXERCISE, FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS, AND BWR RECIRCULATION SYSTEM PIPE REPLACEMENT. WITHIN THE NINE AREAS INSPECTED, TWO VIOLATIONS WERE IDENTIFIED (FAILURE TO HAVE PROCEDURES FOR MAINTENANCE; FAILURE TO PERFORM A SAFETY REVIEW OF A CHANGE MADE TO THE FACILITY).

INSPECTION CONDUCTED JUNE 4-8, 1984 (84-12): ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S TRANSPORTATION AND SOLID RADIOACTIVE WASTE ACTIVITIES, OUTSTANDING OPEN ITEMS, AND NONLICENSED TRAINING. WITHIN THE THREE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED (TRANSPORTATION OF LICENSED MATERIAL).

INSPECTION CONDUCTED JUNE 12-15, 1984 (84-): ROUTINE, UNANNOUNCED IN-SPECTION OF THE SECURITY PLAN AND IMPLEMENTING PROCEDURES INCLUDING: SECURITY ORGANIZATION, TESTING AND MAINTENANCE, PHYSICAL BARRIERS-PROTECTED AREA SECURITY SYSTEM POWER SUPPLY, COMPENSATORY MEASURES, ASSESSMENTS AIDS, ACCESS CONTROL PERSONNEL, ACCESS CONTROL-VEHICLES, DETECTION AIDS-PROTECTED AREA, ALARM STATIONS, AND COMMUNICATIONS. WITHIN THE 11 AREAS INSPECTED, ONE VIOLATION AND FOUR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* COOPER STATION *

ENFORCEMENT SUMMARY

10 CFR PART 50, APPENDIX B, CRITERION V, STATES, IN PART, "ACTIVITIES AFFECTING QUALITY SHALL BE PRESCRIBED BY DOCUMENTED INSTRUCTIONS, ...AND SHALL BE ACCOMPLISHED IN ACCORDANCE WITH THESE INSTRUCTIONS, PROCEDURES..." COOPER NUCLEAR STATION ADMINISTRATIVE PROCEDURE 1.14, "MATERIAL TAGGING," REVISION 7, DATED JUNE 19, 1982, STATES IN SECTIONS II. C.1. AND 2., "REJECTED TAGS (ATTACHMENT "D") WILL BE ATTACHED TO MATERIAL IDENTIFIED AS NEEDING TO BE DISPOSED OF BY DESTRUCTION, RETURN TO THE VENDOR, ETC. ...REJECTED TAGS WILL REMAIN ON AN ITEM UNTIL REMOVED FROM SITE, DESTROYED (IN PART OR WHOLE), OR UNTIL AUTHORIZED DISPOSITION ALTERS ITS STATUS." CONTRARY TO THE ABOVE, REJECTED TAGS WERE NOT BEING USED FOR MATERIAL IDENTIFIED AS REJECTED AND AWAITING DISPOSITION.
(8409 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

ROUTINE POWER OPERATION

LAST IE SITE INSPECTION DATE: JUNE 12-15, 1984

INSPECTION REPORT NO: 50-298/8413

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-009/0	7/19/84	8/17/84	TECHNICAL SPECIFICATION/FLOW UNIT OPERATION CONFLICT.

1. Docket: 50-302 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: D. GRAHAM (904) 795-3802

4. Licensed Thermal Power (MWt): 2544

5. Nameplate Rating (Gross MWe): 989 X 0.9 = 890

6. Design Electrical Rating (Net MWe): 825

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 821

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>65,495.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,540.0</u>	<u>43,110.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,275.5</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,498.3</u>	<u>42,117.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,772,846</u>	<u>13,209,697</u>	<u>95,174,032</u>
18. Gross Elec Ener (MWH)	<u>605,154</u>	<u>4,553,684</u>	<u>32,480,420</u>
19. Net Elec Ener (MWH)	<u>576,490</u>	<u>4,341,045</u>	<u>30,858,128</u>
20. Unit Service Factor	<u>100.0</u>	<u>93.9</u>	<u>64.3</u>
21. Unit Avail Factor	<u>100.0</u>	<u>93.9</u>	<u>64.3</u>
22. Unit Cap Factor (MDC Net)	<u>94.4</u>	<u>90.3</u>	<u>57.4</u>
23. Unit Cap Factor (DER Net)	<u>93.9</u>	<u>89.9</u>	<u>57.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.3</u>	<u>21.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>73.9</u>	<u>11,689.2</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
REFUELING OUTAGE MARCH 9, 1985 FOR 20 WEEKS.

27. If Currently Shutdown Estimated Startup Date: N/A

* CRYSTAL RIVER 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
CRYSTAL RIVER 3



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * CRYSTAL RIVER 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-28	08/17/84	S	0.0	B	5		HC	HTEXCH	REDUCED POWER TO CLEAN CONDENSER WATERBOXES AND REPAIR LEAKING CONDENSER TUBE.

 * SUMMARY *

 CRYSTAL RIVER 3 OPERATED ROUTINELY DURING THE REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* CRYSTAL RIVER 3 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....FLORIDA

COUNTY.....CITRUS

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...7 MI NW OF
CRYSTAL RIVER, FLA

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...JANUARY 14, 1977
DATE ELEC ENER 1ST GENER...JANUARY 30, 1977
DATE COMMERCIAL OPERATE...MARCH 13, 1977

CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...GULF OF MEXICO

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER CORPORATION

CORPORATE ADDRESS.....3201 34TH STREET, SOUTH
ST PETERSBURG, FLORIDA 33733

CONTRACTOR
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES

NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX

CONSTRUCTOR.....J. A. JONES CONSTRUCTION

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....T. STETKA
LICENSING PROJ MANAGER.....H. SILVER
DOCKET NUMBER.....50-302

LICENSE & DATE ISSUANCE...DPR-72, JANUARY 28, 1977

PUBLIC DOCUMENT ROOM.....CRYSTAL RIVER PUBLIC LIBRARY
668 N.W. FIRST
CRYSTAL RIVER, FLORIDA 32639

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 30 - AUGUST 3 (84-24): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 32 INSPECTOR-HOURS ON SITE DURING REGULAR HOURS INSPECTING: INTERNAL AND EXTERNAL EXPOSURE CONTROL; RADIATION WORK PERMIT PROGRAM; HEALTH PHYSICS TRAINING AND QUALIFICATIONS; RESPIRATORY PROTECTION PROGRAM; QUALITY ASSURANCE SURVEILLANCE PROGRAM; ALARA PROGRAM; POSTING, LABELING, AND CONTROL OF RADIOLOGICAL AREAS; ROUTINE AND SPECIAL RADIATION SURVEYS; AND INSPECTOR FOLLOWUP ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO TECHNICAL SPECIFICATIONS 6.8.1.A AND 4.3.3.6 NO PROCEDURE WAS WRITTEN AND IMPLEMENTED TO CALIBRATE THE EMERGENCY FEEDWATER ULTRASONIC FLOW INDICATORS NOR WERE THESE INDICATORS CALIBRATED. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION II, THE LICENSEE'S QUALITY PROGRAM, PARAGRAPH 1.7.1.2, AND ANSI STANDARD N18.7-1976, PLANT MAINTENANCE WAS NOT PROPERLY SCHEDULED OR PLANNED IN THAT AN INSTRUMENT WAS REMOVED FROM SERVICE IN A MANNER THAT COMPROMISED PLANT SAFETY.
(8419 4)

10 CFR 20, APPENDIX A, REQUIRES THAT SUPPLIED AIR HOODS USED FOR RESPIRATORY PROTECTION SHALL BE OPERATED IN A MANNER THAT ENSURES THAT PROPER AIR FLOW RATES ARE MAINTAINED, INCLUDING USE OF CALIBRATED AIRLINE PRESSURE GAUGES OR FLOW MEASURING DEVICES. CONTRARY TO THE ABOVE, ON JUNE 20, 1984, LICENSEE PERSONNEL WERE OBSERVED USING SUPPLIED-AIR HOODS FOR RESPIRATORY PROTECTION; THE

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* CRYSTAL RIVER 3 *

ENFORCEMENT SUMMARY

SUPPLIED AIR SYSTEM WAS NOT EQUIPPED WITH AN AIRLINE PRESSURE GAUGE OR A FLOW MEASURING DEVICE.
(8420 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: JULY 30 - AUGUST 3, 1984 +

INSPECTION REPORT NO: 56-302/84-24 +

R E P O R T S F R O M L I C E N S E E

```

=====

```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-012	06/15/84	07/13/84	INSTRUMENT AIR SUPPLY LINE TO DAMPERS FOR AUX BLDG EXHAUST FANS WAS BROKEN, REPAIRED AND RETURNED TO SERVICE.
84-014	06/25/84	07/25/84	THE AUXILIARY BLDG EXHAUST FANS WERE TAKEN OUT OF SERVICE IN ORDER TO PERFORM MODIFICATIONS TO THE VENTILATION SYSTEM DAMPERS.
84-015	07/13/84	08/09/84	AUTO START OF EMERGENCY DIESEL GENERATOR-A DRAIN PETCOCK ON AN AIR FILTER IN THE 'B' EMERGENCY DIESEL GENERATOR AIR START SYSTEM FAILED.
84-016	07/20/84	08/15/84	THE ALARM/TRIP SETPOINT FOR THE FUEL STORAGE POOL AREA GASEOUS MONITOR WAS NOT IN ACCORDANCE WITH TECHNICAL SPECIFICATION, THIS EVENT REQUIRED NO IMMEDIATE CORRECTIVE ACTIONS.

```

=====

```

1. Docket: 50-346 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: BILAL SARSOOR (419) 25 5000 X384

4. Licensed Thermal Power (MWt): 2772

5. Nameplate Rating (Gross MWe): 1069 X 0.9 = 962

6. Design Electrical Rating (Net MWe): 906

7. Maximum Dependable Capacity (Gross MWe): 918

8. Maximum Dependable Capacity (Net MWe): 874

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____


11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>53,376.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,276.4</u>	<u>32,778.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>134.8</u>	<u>4,014.1</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,236.9</u>	<u>31,388.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,732.7</u>
17. Gross Therm Ener (MWH)	<u>1,862,784</u>	<u>13,426,681</u>	<u>74,470,495</u>
18. Gross Elec Ener (MWH)	<u>601,231</u>	<u>4,390,990</u>	<u>24,683,183</u>
19. Net Elec Ener (MWH)	<u>568,838</u>	<u>4,143,374</u>	<u>23,142,073</u>
20. Unit Service Factor	<u>100.0</u>	<u>89.4</u>	<u>58.8</u>
21. Unit Avail Factor	<u>100.0</u>	<u>89.4</u>	<u>62.1</u>
22. Unit Cap Factor (MDC Net)	<u>87.5</u>	<u>81.0</u>	<u>49.6</u>
23. Unit Cap Factor (DER Net)	<u>84.4</u>	<u>78.1</u>	<u>47.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>10.6</u>	<u>17.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>618.1</u>	<u>7,202.1</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):	<u>REFUELING OUTAGE: 9/14/84 THROUGH 12/26/84</u>		

27. If Currently Shutdown Estimated Startup Date: N/A

 * DAVIS-BESSE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 DAVIS-BESSE 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* DAVIS-BESSE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

* SUMMARY *

DAVIS-BESSE 1 OPERATED ROUTINELY DURING THE REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* DAVIS-BESSE 1 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....OHIO

COUNTY.....OTTAWA

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...21 MI E OF
TOLEDO, OH

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...AUGUST 12, 1977
DATE ELEC ENER 1ST GENER...AUGUST 28, 1977
DATE COMMERCIAL OPERATE....JULY 31, 1978
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER....LAKE ERIE

ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY
LICENSEE.....TOLEDO EDISON

CORPORATE ADDRESS.....300 MADISON AVENUE
TOLEDO, OHIO 43652

CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....W. ROGERS

LICENSING PROJ MANAGER.....A. DEGAZIO
DOCKET NUMBER.....50-346

LICENSE & DATE ISSUANCE...NPF-3, APRIL 22, 1977

PUBLIC DOCUMENT ROOM.....UNIVERSITY OF TOLEDO LIBRARY
GOVERNMENT DOCUMENTS COLLECTION
2801 WEST BANCROFT AVENUE
TOLEDO, OHIO 43606

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 11- JULY 23, (84-12): ROUTINE, UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS; OPEATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; LICENSEE EVENT REPORTS; PLANT TRIPS; ACTION ON REGIONAL REQUESTS AND NUREG 737 ITEM II.B.1. THE INSPECTION INVOLVED 236 INSPECTOR HOURS ONSITE BY THREE NRC INSPECTORS INCLUDING 95 INSPECTOR HOURS ONSITE DURING OFF-SHIFTS. OF THE EIGHT AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATION WERE IDENTIFIED IN SIX AREAS; TWO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN TWO AREAS (FAILURE TO ESTABLISH ADEQUATE PROCEDURES FOR DETERMINING 10 CFR 21.21 REPORTING AND FAILURE TO FOLLOW MAINTENANCE PROCEDURES).

INSPECTION ON JUNE 25-29, (84-13): INCLUDED A REVIEW OF SECURITY PLAN AND IMPLEMENTING PROCEDURES; MANAGEMENT EFFECTIVENESS; SECURITY ORGANIZATION; RECORDS AND REPORTS; TESTING AND MAINTENANCE; SECURITY SYSTEM POWER SUPPLY; COMPENSATORY MEASURES; ACCESS CONTROL - PERSONNEL; ACCESS CONTROL - VEHICLES; INDEPENDENT INSPECTION EFFORT; AND LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS. THE INSPECTION INVOLVED 69 HOURS OF DIRECT INSPECTION EFFORT BY TWO NRC INSPECTORS. THE INSPECTION BEGAN DURING THE DAY SHIFT. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED DURING THIS INSPECTION EXCEPT FOR THE FOLLOWING ITEM: ACCESS CONTROL - PERSONNEL: A MEMBER OF THE SECURITY FORCE FAILED TO POSITIVELY IDENTIFY TWO VISITORS REQUESTING ACCESS TO THE PROTECTED AREA. THE INSPECTORS REVIEWED THE CORRECTIVE ACTIONS TAKEN BY THE LICENSEE ON PREVIOUS ITEMS OF NONCOMPLIANCE. ONE ITEM OF NONCOMPLIANCE DEALING WITH 10 CFR 73.71(C) REPORTING REQUIREMENTS WAS CLOSED. INADEQUACIES IN BOTH PROTECTED AND VITAL AREA DETECTION AIDS REMAIN OPEN. IMPROVEMENT TOWARDS CORRECTING THESE ITEMS OF NONCOMPLIANCE WAS NOTED. TWO UNRESOLVED ITEMS WERE NOTED. ONE ITEM PERTAINED TO COMPENSATORY MEASURES. THE OTHER ITEM PERTAINED TO PROTECTION REQUIREMENTS FOR CERTAIN EQUIPMENT. THESE ISSUES WILL BE SENT TO NRC:HQ FOR RESOLUTION.

INSPECTION SUMMARY

INSPECTION ON JULY 24, (84-16): ROUTINE, ANNOUNCED INSPECTION OF FOLLOWUP OF TITEFLEX METALLIC BELLOWS - IMPROPER ATTACHMENT DESIGN, NDE AND QUALIFICATION TESTING. THIS INSPECTION INVOLVED THREE INSPECTOR HOURS ONSITE BY ONE NRC INSPECTOR. NO ITEMS OF NONCOMPLIANCE OR DEVIATION WERE IDENTIFIED.

ENFORCEMENT SUMMARY

TWO NRC INSPECTORS WERE NOT POSITIVELY IDENTIFIED WHILE REQUESTING ACCESS TO THE PROTECTED AREA.
 (8413 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: SEPTEMBER 10-14, 1984

INSPECTION REPORT NO: 84-21

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-18	07/09/84	08/08/84	CONTROL ROD MISALIGNMENT.
84-19	07/10/84	08/09/84	PROTECTIVE FUNCTION CHANNEL NOT TRIPPED.

1. Docket: 50-237 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: D. C. MAXWELL (815) 942-2920

4. Licensed Thermal Power (MWt): 2527

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 794

7. Maximum Dependable Capacity (Gross MWe): 812

8. Maximum Dependable Capacity (Net MWe): 772

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>125,375.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,667.3</u>	<u>97,892.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,565.2</u>	<u>93,466.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,681,976</u>	<u>12,994,536</u>	<u>189,732,132</u>
18. Gross Elec Ener (MWH)	<u>512,582</u>	<u>4,176,556</u>	<u>60,679,723</u>
19. Net Elec Ener (MWH)	<u>502,443</u>	<u>3,978,284</u>	<u>57,375,728</u>
20. Unit Service Factor	<u>100.0</u>	<u>95.1</u>	<u>74.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>95.1</u>	<u>74.5</u>
22. Unit Cap Factor (MDC Net)	<u>87.5</u>	<u>88.0</u>	<u>59.3</u>
23. Unit Cap Factor (DER Net)	<u>85.1</u>	<u>85.6</u>	<u>57.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.9</u>	<u>11.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>289.8</u>	<u>4,710.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING & MAINTENANCE: 10/1/84 - 12 WEEKS

27. If Currently Shutdown Estimated Startup Date: N/A

* D R E S D E N 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
D R E S D E N 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* DRESDEN 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

* SUMMARY *

DRESDEN 2 OPERATED ROUTINELY DURING THE REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* DRESDEN 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....GRUNDY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9 MI E OF
MORRIS, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JANUARY 7, 1970
DATE ELEC ENER 1ST GENER...APRIL 13, 1970
DATE COMMERCIAL OPERATE....JUNE 9, 1970
CONDENSER COOLING METHOD...COOLING LAKE
CONDENSER COOLING WATER....KANKAKEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....T. TONGUE
LICENSING PROJ MANAGER....R. GILBERT
DOCKET NUMBER.....50-237
LICENSE & DATE ISSUANCE...DPR-19, DECEMBER 22, 1969
PUBLIC DOCUMENT ROOM.....MORRIS PUBLIC LIBRARY
604 LIBERTY STREET
MORRIS, ILLINOIS 60450

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 18-JULY 26, (84-12): ROUTINE UNANNOUNCED RESIDENT INSPECTION OF ACTION ON PREVIOUS INSPECTION FINDINGS, PART 21 REPORTS, OPERATIONAL SAFETY, FIRE BRIGADE DRILL, ONSITE EVENTS, SURVEILLANCES, MAINTENANCE, LICENSEE EVENT REPORTS, IE INFORMATION NOTICES, UNIT 1 CHEMICAL CLEANING, SPENT FUEL SHIPMENTS, AND REPORT REVIEW. THE INSPECTION INVOLVED A TOTAL OF 195 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS INCLUDING 29 INSPECTOR-HOURS ONSITE DURING OFF-SHIFT. OF THE TWELVE AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN ELEVEN AREAS; ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN ONE AREA (INADEQUATE CORRECTIVE ACTION).

ENFORCEMENT SUMMARY

10 CFR 50, APPENDIX B, CRITERION XVI, AS IMPLEMENTED BY COMMONWEALTH EDISON COMPANY TOPICAL REPORT CE-1A, "QUALITY ASSURANCE PROGRAM FOR NUCLEAR GENERATING STATIONS," SECTION 16, STATES THAT MEASURES SHALL BE ESTABLISHED TO ASSURE THAT SIGNIFICANT CONDITIONS ADVERSE TO QUALITY ARE IDENTIFIED AND CORRECTED IN SUCH A WAY AS TO PRECLUDE REPETITION. CONTRARY TO THE ABOVE, INADEQUATE CORRECTIVE ACTIONS WERE TAKEN IN RESPONSE TO A LICENSEE IDENTIFIED TECHNICAL SPECIFICATION VIOLATION CONCERNING THE FINDING OF THE UNIT 2 REACTOR BUILDING WEST CORNER ROOM SUBMARINE DOOR OPEN ON DECEMBER 10, 1983. THIS RESULTED IN A SIMILAR INCIDENT OCCURRING ON FEBRUARY 8, 1984 WHERE THE SUBMARINE DOOR FOR THE EAST CORNER ROOM WAS FOUND TO BE OPEN.
(8412 4)

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* D R E S D E N 2 *

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY. PLANNED REFUELING OUTAGE TO BEGIN ON 10/1/84

LAST IE SITE INSPECTION DATE: SEPTEMBER 7, 1984

INSPECTION REPORT NO: 84-17

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-12	07/09/84	07/17/84	REACTOR SCRAM.
84-13	07/22/84	08/15/84	REACTOR SCRAM.
84-14	01/09/84	08/02/84	HPCI TURBINE TRIP LOW REACTOR PRESSURE SURV. PERFORMED LATE.
84-15	06/27/84	08/02/84	SURV. INTERVAL EXCEEDED FOR PUMPING D/W EQUIPMENT DRAIN.

=====

1. Docket: 50-249 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: D. C. MAXWELL (815) 942-2920

4. Licensed Thermal Power (MWt): 2527

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 794

7. Maximum Dependable Capacity (Gross MWe): 812

8. Maximum Dependable Capacity (Net MWe): 773

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>114,960.0</u>
13. Hours Reactor Critical	<u>713.0</u>	<u>1,293.2</u>	<u>84,128.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>687.6</u>	<u>873.8</u>	<u>80,736.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,469,741</u>	<u>1,718,334</u>	<u>161,681,338</u>
18. Gross Elec Ener (MWH)	<u>444,512</u>	<u>519,053</u>	<u>52,471,962</u>
19. Net Elec Ener (MWH)	<u>437,647</u>	<u>472,206</u>	<u>49,702,789</u>
20. Unit Service Factor	<u>92.4</u>	<u>14.9</u>	<u>70.2</u>
21. Unit Avail Factor	<u>92.4</u>	<u>14.9</u>	<u>70.2</u>
22. Unit Cap Factor (MDC Net)	<u>76.1</u>	<u>10.4</u>	<u>55.9</u>
23. Unit Cap Factor (DER Net)	<u>74.1</u>	<u>10.2</u>	<u>54.5</u>
24. Unit Forced Outage Rate	<u>7.5</u>	<u>6.0</u>	<u>12.5</u>
25. Forced Outage Hours	<u>55.8</u>	<u>55.8</u>	<u>6,471.0</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* DRESDEN 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
DRESDEN 3



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* DRESDEN 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
1	08/05/84	S	0.6	B	3			PLANNED TURBINE OVERSPEED TEST.
2	08/21/84	F	55.8	A	3	84-10/036-0		3A FEEDWATER REGULATOR VALVE FAILURE.

* SUMMARY *

DRESDEN 3 OPERATED WITH 2 OUTAGES AND NO REDUCTIONS DURING AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	?-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

* DRESDEN 3 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....GRUNDY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9 MI E OF
MORRIS, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JANUARY 31, 1971
DATE ELEC ENER 1ST GENER...JULY 22, 1971
DATE COMMERCIAL OPERATE...NOVEMBER 16, 1971
CONDENSER COOLING METHOD...COOLING LAKE
CONDENSER COOLING WATER...KANKAKEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....T. TONGUE
LICENSING PROJ MANAGER.....R. GILBERT
DOCKET NUMBER.....50-249
LICENSE & DATE ISSUANCE....DPR-25, MARCH 2, 1971
PUBLIC DOCUMENT ROOM.....MORRIS PUBLIC LIBRARY
604 LIBERTY STREET
MORRIS, ILLINOIS 60450

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 18-JULY 26, (84-11): ROUTINE UNANNOUNCED RESIDENT INSPECTION OF ACTION ON PREVIOUS INSPECTION FINDINGS, PART 21 REPORTS, OPERATIONAL SAFETY, FIRE BRIGADE DRILL, ONSITE EVENTS, SURVEILLANCES, MAINTENANCE, LICENSEE EVENT REPORTS, IE INFORMATION NOTICES, UNIT 1 CHEMICAL CLEANING, SPENT FUEL SHIPMENTS, AND REPORT REVIEW. THE INSPECTION INVOLVED A TOTAL OF 195 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS INCLUDING 29 INSPECTOR-HOURS ONSITE DURING OFF-SHIFT. OF THE TWELVE AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN ELEVEN AREAS; ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN ONE AREA (INADEQUATE CORRECTIVE ACTION).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

OTHER ITEMS

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

PLANT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: SEPTEMBER 7, 1984

INSPECTION REPORT NO: 84-16

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-05	07/16/84	08/13/84	EAST LPCI SUBMARINE DOOR FOUND OPEN.
84-06	07/18/84	08/03/84	REACTOR NOT VENTED WITH VESSE' TEMP LESS THAN PRESS. TEMP.
84-07	07/22/84	08/17/84	REACTOR SCRAM.
84-08	08/04/84	08/26/84	DRYWELL TO TORUS PRESSURE LESS THAN 1 PSID.

=====

1. Docket: 50-331 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: KEN S. PUTNAM (319) 851-7456

4. Licensed Thermal Power (MWt): 1658

5. Nameplate Rating (Gross MWe): 663 X 0.9 = 597

6. Design Electrical Rating (Net MWe): 538

7. Maximum Dependable Capacity (Gross MWe): 545

8. Maximum Dependable Capacity (Net MWe): 515

9. If Changes Occur Above Since Last Report, Give Reason: NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any: NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>83,999.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,467.4</u>	<u>60,402.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>130.3</u>	<u>130.3</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,365.6</u>	<u>58,808.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,161,298</u>	<u>6,461,514</u>	<u>74,210,076</u>
18. Gross Elec Ener (MWH)	<u>384,086</u>	<u>2,169,351</u>	<u>24,863,408</u>
19. Net Elec Ener (MWH)	<u>361,015</u>	<u>2,042,423</u>	<u>23,278,793</u>
20. Unit Service Factor	<u>100.0</u>	<u>74.6</u>	<u>70.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>74.6</u>	<u>70.0</u>
22. Unit Cap Factor (MDC Net)	<u>94.2</u>	<u>67.7</u>	<u>53.8</u>
23. Unit Cap Factor (DER Net)	<u>90.2</u>	<u>64.8</u>	<u>51.5</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>15.3</u>	<u>17.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>789.9</u>	<u>12,124.2</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
MAINTENANCE OUTAGE 09/28 - 10/21/84.

27. If Currently Shutdown Estimated Startup Date: N/A

* DUANE ARNOLD *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
DUANE ARNOLD



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* DUANE ARNOLD *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

DUANE ARNOLD OPERATED AT NEAR FULL POWER DURING AUGUST.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System & Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* DUANE ARNOLD *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....IOWA
COUNTY.....LINN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...8 MI NW OF
CEDAR RAPIDS, IA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MARCH 23, 1974
DATE ELEC ENER 1ST GENER...MAY 19, 1974
DATE COMMERCIAL OPERATE...FEBRUARY 1, 1975
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...CEDAR KAPIDS RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....IOWA ELECTRIC POWER & LIGHT
CORPORATE ADDRESS.....I E TOWERS, P.O. BOX 351
CEDAR RAPIDS, IOWA 52406
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....L. CLARDY
LICENSING PROJ MANAGER.....M. THADANI
DOCKET NUMBER.....50-331
LICENSE & DATE ISSUANCE...DPR-49, FEBRUARY 22, 1974
PUBLIC DOCUMENT ROOM.....REFERENCE SERVICE
CEDAR RAPIDS PUBLIC LIBRARY
428 THIRD AVENUE, S.E.
CEDAR RAPIDS, IOWA 52401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 1 - JULY 25, (84-08): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTOR OF LICENSEE ACTIONS ON OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; LICENSEE EVENT REPORTS; TMI ITEMS; AND INDEPENDENT INSPECTION. THE INSPECTION INVOLVED A TOTAL OF 147 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR INCLUDING 30 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. OF THE AREAS INSPECTED NO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED.

INSPECTION ON JULY 31-AUGUST 2, (84-10): ROUTINE ANNOUNCED INSPECTION OF THE DUANE ARNOLD ENERGY CENTER EMERGENCY PREPAREDNESS EXERCISE INVOLVING OBSERVATIONS BY SEVEN NRC REPRESENTATIVES OF KEY FUNCTIONS AND LOCATIONS DURING THE EXERCISE, AND LICENSEE ACTION ON A PREVIOUSLY IDENTIFIED ITEM RELATED TO EMERGENCY PREPAREDNESS. THE INSPECTION INVOLVED 125 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS AND FOUR CONSULTANTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

```
*****
*                       DUANE ARNOLD                       *
*****
```

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

PLANT IS OPERATING ROUTINELY.

LAST IE SITE INSPECTION DATE: SEPTEMBER 4-6, 1984

INSPECTION REPORT NO: 84-14

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-24	06/30/84	07/30/84	UNPLANNED RWCU ISOLATION.
84-26	07/12/84	08/10/84	BOTH STANDBY FILTER UNITS INOPERABLE.
84-27	07/12/84	08/10/84	REACTOR SCRAM FROM JARRED INSTRUMENT RACK.
84-28	07/14/84	08/13/84	DEGRADED OFFSITE VOLTAGE
84-29	07/18/84	08/17/84	STANDBY LIQUID CONTROL SYSTEM MISALIGNMENT.

1. Docket: 50-348 OPERATING STATUS
 2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0
 3. Utility Contact: J. D. WOODARD (205) 899-5156
 4. Licensed Thermal Power (MWt): 2652
 5. Nameplate Rating (Gross MWe): 1045 X 0.85 = 888
 6. Design Electrical Rating (Net MWe): 829
 7. Maximum Dependable Capacity (Gross MWe): 842
 8. Maximum Dependable Capacity (Net MWe): 797
 9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____
 11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>59,183.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,076.8</u>	<u>39,200.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,650.7</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,992.0</u>	<u>38,095.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,973,088</u>	<u>10,147,468</u>	<u>96,248,992</u>
18. Gross Elec Ener (MWH)	<u>636,288</u>	<u>3,264,504</u>	<u>30,506,368</u>
19. Net Elec Ener (MWH)	<u>602,976</u>	<u>3,069,822</u>	<u>28,770,884</u>
20. Unit Service Factor	<u>100.0</u>	<u>68.2</u>	<u>64.4</u>
21. Unit Avail Factor	<u>100.0</u>	<u>68.2</u>	<u>64.4</u>
22. Unit Cap Factor (MDC Net)	<u>101.7</u>	<u>65.4</u>	<u>61.0*</u>
23. Unit Cap Factor (DER Net)	<u>97.8</u>	<u>63.2</u>	<u>58.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>2.0</u>	<u>14.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>79.5</u>	<u>6,246.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * FARLEY 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 FARLEY 1



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* FARLEY 1 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

FARLEY 1 OPERATED AT FULL POWER DURING THE AUGUST REPORTING PERIOD.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System & Component</u>	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

* FARLEY 1 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ALABAMA
COUNTY.....HOUSTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...28 MI SE OF
DOTHAN, ALA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 9, 1977
DATE ELEC ENER 1ST GENER...AUGUST 18, 1977
DATE COMMERCIAL OPERATE...DECEMBER 1, 1977
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...CHATAHOOCHEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ALABAMA POWER CO.
CORPORATE ADDRESS.....600 NORTH 18TH STREET
BIRMINGHAM, ALABAMA 35203
CONTRACTOR
ARCHITECT/ENGINEER.....SOUTHERN SERVICES INCORPORATED
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....W. BRADFORD
LICENSING PROJ MANAGER.....E. REEVES
DOCKET NUMBER.....50-348
LICENSE & DATE ISSUANCE...NPF-2, JUNE 25, 1977
PUBLIC DOCUMENT ROOM.....G.S. HOUSTON MEMORIAL LIBRARY
212 W. BURDESHAW STREET
DOTHAN, ALABAMA 36301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JUNE 25-29 (84-18): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 37 INSPECTOR-HOURS ON SITE IN THE AREAS OF ORGANIZATION, TRAINING, INTERNAL EXPOSURE, EXTERNAL EXPOSURE, CONTROL OF RADIOACTIVE MATERIAL, ALARA, SOLID WASTES AND THE POST ACCIDENT SAMPLING SYSTEM. ONE VIOLATION WAS IDENTIFIED - THREE EXAMPLES OF FAILURE TO ADHERE TO RADIATION CONTROL PROCEDURES.

INSPECTION AUGUST 7-10 (84-21): THIS ROUTINE UNANNOUNCED INSPECTION ENTAILED 14 INSPECTOR-HOURS ON SITE IN THE AREAS OF INSERVICE TESTING (IST) OF PUMPS AND VALVES; INSERVICE INSPECTION (ISI); IE BULLETINS; AND INSPECTOR FOLLOWUP ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.8.1 REQUIRES THAT WRITTEN PROCEDURES SHALL BE ESTABLISHED AND IMPLEMENTED FOR SURVEILLANCE, ADMINISTRATIVE, AND CALIBRATION PROCEDURES. CONTRARY TO THE ABOVE, THE LICENSEE DID NOT ADEQUATELY ESTABLISHED AND IMPLEMENT SURVEILLANCE, ADMINISTRATIVE AND CALIBRATION PROCEDURES AS FOLLOWS: (A) ALTHOUGH FNP-0-AP-14 REQUIRES THE REMOVAL OF HOLD TAGS AND REPOSITIONING OF CONTROL DEVICES IN A SEQUENCE SPECIFIED BY A TAGGING OPERATIONS ORDER, A SYSTEM OPERATOR POSITIONED A VALVE OUT OF THE SPECIFIED SEQUENCE FOR TAGGING ORDER NUMBER 84-0461-2. (B) FNP-1-SOP-22.0 HAD AN INADEQUATE SYSTEM CHECKLIST IN THAT THE TURBINE DRIVE AUXILIARY FEEDWATER PUMP SPEED CONTROL WAS NOT INCLUDED. (C) INSTRUMENT MAINTENANCE PROCEDURES WERE INADEQUATE IN THAT INDEPENDENT VERIFICATION OF TRANSMITTER VALVE POSITION UPON RETURN TO SERVICE WAS NOT REQUIRED. (D) INSTRUMENT

ENFORCEMENT SUMMARY

MAINTENANCE PROCEDURES WERE INADEQUATE IN THAT VALVES MANIPULATED FOR TRANSMITTER CALIBRATIONS WERE NOT IDENTIFIED IN THE PROCEDURE.
(8417 4)

TECHNICAL SPECIFICATION 6.11 REQUIRES THAT PROCEDURES FOR PERSONNEL RADIATION PROTECTION SHALL BE ADHERED TO FOR ALL OPERATIONS INVOLVING PERSONNEL RADIATION EXPOSURE. CONTRARY TO THE ABOVE, PROCEDURES FOR PERSONNEL RADIATION PROTECTION WERE NOT ADHERED TO AS FOLLOWS: (A) ALTHOUGH LICENSEE PROCEDURE FNP-0-RCP-740, PARAGRAPH 8.8 REQUIRES THAT EVALUATIONS OF TLD AND POCKET ION CHAMBER DOSIMETERS BE PERFORMED FOR DISCREPANCIES GREATER THAN 30% AND 100 MILLIREM, NO SUCH EVALUATIONS HAD BEEN PERFORMED BY THE LICENSEE FOR IDENTIFIED TLD AND DOSIMETER DISCREPANCIES DURING THE PERIOD OCTOBER 1983 TO JUNE 1984; (B) ALTHOUGH LICENSEE PROCEDURE FNP-0-RCP-112, SECTION 9.0 REQUIRES THAT MAINTENANCE FOR THE CONTAINMENT BREATHING AIR SYSTEM BE PERFORMED IN ACCORDANCE WITH THE VENDOR INSTALLATION AND OPERATING INSTRUCTION, THE LICENSEE HAD NOT PERFORMED ANNUAL FILTER REPLACEMENT ON THE CONTAINMENT BREATHING AIR SYSTEMS AS SPECIFIED BY THE VENDOR INSTRUCTION SINCE THE UNITS WERE FIRST OPERATED IN JUNE 1980 FOR UNIT 1 AND OCTOBER 1982 FOR UNIT 2; (C) ALTHOUGH LICENSEE PROCEDURE FNP-0-RCP-28, PARAGRAPH 4.1 REQUIRES THAT ALL PERSONNEL FRISK AFTER EXITING A CONTAMINATION CONTROL ZONE, TWO LICENSEE EMPLOYEES WHO EXITED A CONTAMINATION CONTROL ZONE ON THE 155 FOOT ELEVATION OF THE UNIT 1 AUXILIARY BUILDING DID NOT PERFORM A WHOLE BODY FRISK.
(8418 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

+ R. P. MCDONALD PROMOTED TO SENIOR VICE PRESIDENT, W. G. HAIRSTON PROMOTED TO MANAGER NUCLEAR ENGINEERING AND TECHNICAL SUPPORT, J. D. WOODARD PROMOTED TO PLANT MANAGER.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: AUGUST 7-10, 1984 +

INSPECTION REPORT NO: 50-348/84-21 +

Report Period AUG 1984

R E P O R T S F R O M L I C E N S E E

* FARLEY 1 *

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-013	07/16/84	08/15/84	CONTINUOUS FIRE WATCH NOT POSTED AS REQUIRED, A FIRE WATCH WAS POSTED IMMEDIATELY.

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-364 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. D. WOODARD (205) 899-5156

4. Licensed Thermal Power (MWt): 2652

5. Nameplate Rating (Gross MWe): 860

6. Design Electrical Rating (Net MWe): 829

7. Maximum Dependable Capacity (Gross MWe): 853

8. Maximum Dependable Capacity (Net MWe): 809

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>27,096.0</u>
13. Hours Reactor Critical	<u>739.2</u>	<u>5,803.2</u>	<u>24,340.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>138.4</u>
15. Hrs Generator On-Line	<u>739.0</u>	<u>5,754.7</u>	<u>24,053.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,951,599</u>	<u>15,078,128</u>	<u>61,988,820</u>
18. Gross Elec Ener (MWH)	<u>618,924</u>	<u>4,867,680</u>	<u>19,854,528</u>
19. Net Elec Ener (MWH)	<u>589,240</u>	<u>4,634,062</u>	<u>18,834,088</u>
20. Unit Service Factor	<u>99.3</u>	<u>98.3</u>	<u>88.8</u>
21. Unit Avail Factor	<u>99.3</u>	<u>98.3</u>	<u>88.8</u>
22. Unit Cap Factor (MDC Net)	<u>97.9</u>	<u>97.4</u>	<u>85.9</u>
23. Unit Cap Factor (DER Net)	<u>95.5</u>	<u>95.5</u>	<u>83.8</u>
24. Unit Forced Outage Rate	<u>.7</u>	<u>1.7</u>	<u>4.5</u>
25. Forced Outage Hours	<u>5.0</u>	<u>100.3</u>	<u>1,132.1</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
REFUELING/MAINT. OUTAGE, 1/4/85, APPROX. 6 WKS

27. If Currently Shutdown Estimated Startup Date: 09/14/84

* FARLEY 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FARLEY 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* FARLEY 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
006	08/31/84	F	5.0	H	1	84-008-00	AB	SG	UNIT SHUT DOWN DUE TO RE-ANALYSIS OF CYCLE II-III EDDY CURRENT TEST RESULTS WHICH SHOWED SIGNIFICANT TUBE WALL DEGRADATION IN TWO TUBES EXCEEDING THE TUBE PLUGGING LIMIT OF TECHNICAL SPECIFICATION 3/4.4.6.

***** FARLEY 2 OPERATED WITH 1 OUTAGE AND NO REDUCTIONS, SHUTTING DOWN ON THE 31ST FOR MAINTENANCE.
* SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* FARLEY 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ALABAMA
COUNTY.....HOUSTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...28 MI SE OF
DOTHAN, ALA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 5, 1981
DATE ELEC ENER 1ST GENER...MAY 25, 1981
DATE COMMERCIAL OPERATE...JULY 30, 1981
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...CHATAHOOCHEE RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ALABAMA POWER CO.
CORPORATE ADDRESS.....600 NORTH 18TH STREET
BIRMINGHAM, ALABAMA 35203
CONTRACTOR
ARCHITECT/ENGINEER.....SOUTHERN SERVICES INCORPORATED
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....W. BRADFORD
LICENSING PROJ MANAGER.....E. REEVES
DOCKET NUMBER.....50-364
LICENSE & DATE ISSUANCE...NPF-8, MARCH 31, 1981
PUBLIC DOCUMENT ROOM.....G.S. HOUSTON MEMORIAL LIBRARY
212 W. BURDESHAW STREET
DOTHAN, ALABAMA 36301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JUNE 25-29 (84-18): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 37 INSPECTOR-HOURS ON SITE IN THE AREAS OF ORGANIZATION, TRAINING, INTERNAL EXPOSURE, EXTERNAL EXPOSURE, CONTROL OF RADIOACTIVE MATERIAL, ALARA, SOLID WASTES AND THE POST ACCIDENT SAMPLING SYSTEM. ONE VIOLATION WAS IDENTIFIED - THREE EXAMPLES OF FAILURE TO ADHERE TO RADIATION CONTROL PROCEDURES.

INSPECTION AUGUST 7-10 (84-21): THIS ROUTINE UNANNOUNCED INSPECTION ENTAILED 14 INSPECTOR-HOURS ON SITE IN THE AREAS OF INSERVICE TESTING (IST) OF PUMPS AND VALVES; INSERVICE INSPECTION (ISI); IE BULLETINS; AND INSPECTOR FOLLOWUP ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.8.1 REQUIRES THAT WRITTEN PROCEDURES SHALL BE ESTABLISHED AND IMPLEMENTED FOR SURVEILLANCE, ADMINISTRATIVE, AND CALIBRATION PROCEDURES. CONTRARY TO THE ABOVE, THE LICENSEE DID NOT ADEQUATELY ESTABLISHED AND IMPLEMENT SURVEILLANCE, ADMINISTRATIVE AND CALIBRATION PROCEDURES AS FOLLOWS: (A) ALTHOUGH FNP-0-AP-14 REQUIRES THE REMOVAL OF HOLD TAGS AND REPOSITIONING OF CONTROL DEVICES IN A SEQUENCE SPECIFIED BY A TAGGING OPERATIONS ORDER, A SYSTEM OPERATOR POSITIONED A VALVE OUT OF THE SPECIFIED SEQUENCE FOR TAGGING ORDER NUMBER 84-0461-2. (B) FNP-1-SOP-22.0 HAD AN INADEQUATE SYSTEM CHECKLIST IN THAT THE TURBINE DRIVE AUXILIARY FEEDWATER PUMP SPEED CONTROL WAS NOT INCLUDED. (C) INSTRUMENT MAINTENANCE PROCEDURES WERE INADEQUATE IN THAT INDEPENDENT VERIFICATION OF TRANSMITTER VALVE POSITION UPON RETURN TO SERVICE WAS NOT REQUIRED. (D) INSTRUMENT

ENFORCEMENT SUMMARY

MAINTENANCE PROCEDURES WERE INADEQUATE IN THAT VALVES MANIPULATED FOR TRANSMITTER CALIBRATIONS WERE NOT IDENTIFIED IN THE PROCEDURE.
(8417 4)

TECHNICAL SPECIFICATION 6.11 REQUIRES THAT PROCEDURES FOR PERSONNEL RADIATION PROTECTION SHALL BE ADHERED TO FOR ALL OPERATIONS INVOLVING PERSONNEL RADIATION EXPOSURE. CONTRARY TO THE ABOVE, PROCEDURES FOR PERSONNEL RADIATION PROTECTION WERE NOT ADHERED TO AS FOLLOWS: (A) ALTHOUGH LICENSEE PROCEDURE FNP-0-RCP-740, PARAGRAPH 8.8 REQUIRES THAT EVALUATIONS OF TLD AND POCKET ION CHAMBER DOSIMETERS BE PERFORMED FOR DISCREPANCIES GREATER THAN 30% AND 100 MILLIREM, NO SUCH EVALUATIONS HAD BEEN PERFORMED BY THE LICENSEE FOR IDENTIFIED TLD AND DOSIMETER DISCREPANCIES DURING THE PERIOD OCTOBER 1983 TO JUNE 1984; (B) ALTHOUGH LICENSEE PROCEDURE FNP-0-RCP-112, SECTION 9.0 REQUIRES THAT MAINTENANCE FOR THE CONTAINMENT BREATHING AIR SYSTEM BE PERFORMED IN ACCORDANCE WITH THE VENDOR INSTALLATION AND OPERATING INSTRUCTION, THE LICENSEE HAD NOT PERFORMED ANNUAL FILTER REPLACEMENT ON THE CONTAINMENT BREATHING AIR SYSTEMS AS SPECIFIED BY THE VENDOR INSTRUCTION SINCE THE UNITS WERE FIRST OPERATED IN JUNE 1980 FOR UNIT 1 AND OCTOBER 1982 FOR UNIT 2; (C) ALTHOUGH LICENSEE PROCEDURE FNP-0-RCP-28, PARAGRAPH 4.1 REQUIRES THAT ALL PERSONNEL FRISK AFTER EXITING A CONTAMINATION CONTROL ZONE, TWO LICENSEE EMPLOYEES WHO EXITED A CONTAMINATION CONTROL ZONE ON THE 155 FOOT ELEVATION OF THE UNIT 1 AUXILIARY BUILDING DID NOT PERFORM A WHOLE BODY FRISK.
(8418 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

+ R. P. MCDONALD PROMOTED TO SENIOR VICE PRESIDENT, W. G. HAIRSTON PROMOTED TO MANAGER NUCLEAR ENGINEERING AND TECHNICAL SUPPORT, J. D. WOODARD PROMOTED TO PLANT MANAGER.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: AUGUST 7-10, 1984 +

INSPECTION REPORT NO: 50-364/84-21 +

Report Period AUG 1984

R E P O R T S F R O M L I C E N S E E

* FARLEY 2 *

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NONE.			

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-333 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. COOK (315) 342-3840

4. Licensed Thermal Power (MWt): 2436

5. Nameplate Rating (Gross MWe): 981 X 0.9 = 883

6. Design Electrical Rating (Net MWe): 821

7. Maximum Dependable Capacity (Gross MWe): 830

8. Maximum Dependable Capacity (Net MWe): 810

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>79,752.0</u>
13. Hours Reactor Critical	<u>637.4</u>	<u>5,364.0</u>	<u>57,892.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>615.4</u>	<u>5,234.8</u>	<u>56,434.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,354,488</u>	<u>12,013,608</u>	<u>119,750,194</u>
18. Gross Elec Ener (MWH)	<u>436,680</u>	<u>4,000,960</u>	<u>40,658,280</u>
19. Net Elec Ener (MWH)	<u>422,335</u>	<u>3,873,435</u>	<u>39,372,075</u>
20. Unit Service Factor	<u>82.7</u>	<u>89.4</u>	<u>70.8</u>
21. Unit Avail Factor	<u>82.7</u>	<u>89.4</u>	<u>70.8</u>
22. Unit Cap Factor (MDC Net)	<u>70.1</u>	<u>81.7</u>	<u>64.4*</u>
23. Unit Cap Factor (DER Net)	<u>69.1</u>	<u>80.6</u>	<u>60.1</u>
24. Unit Forced Outage Rate	<u>17.3</u>	<u>5.0</u>	<u>13.8</u>
25. Forced Outage Hours	<u>128.6</u>	<u>274.0</u>	<u>9,157.2</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
MAINTENANCE: 09/14/84 - 30 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

* FITZPATRICK *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
FITZPATRICK



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * FITZPATRICK *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
11	08/05/84	F	128.6	A	2		AD	P	SHUTDOWN TO INVESTIGATE DRYWELL LEAKAGE < 5 GPM WHICH WAS CAUSED BY A RECIRC PUMP SEAL FAILURE. SEAL WAS REPLACED AND UNIT RETURNED TO SERVICE.

 * SUMMARY *

 THE FITZPATRICK PLANT OPERATED AT SLIGHTLY REDUCED POWER DURING THIS REPORTING PERIOD DUE TO HIGH LAKE TEMPERATURES CAUSING A LOW CONDENSER VACUUM. ON 840805 THE PLANT WAS TAKEN OFF LINE TO REPAIR A RECIRC PUMP SEAL AND RETURNED TO SERVICE ON 840811.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* FITZPATRICK *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....NEW YORK
COUNTY.....OSWEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...8 MI NE OF
OSWEGO, NY
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...NOVEMBER 17, 1974
DATE ELEC ENER 1ST GENER...FEBRUARY 1, 1975
DATE COMMERCIAL OPERATE....JULY 28, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER....LAKE ONTARIO
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY
LICENSEE.....POWER AUTHORITY OF STATE OF N.Y.
CORPORATE ADDRESS.....10 COLUMBUS CIRCLE
NEW YORK, NEW YORK 10019
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....GENERAL ELECTRIC
REGULATORY INFORMATION
IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....L. DOERFLEIN
LICENSING PROJ MANAGER.....H. ABELSON
DOCKET NUMBER.....50-333
LICENSE & DATE ISSUANCE....DPR-59, OCTOBER 17, 1974
PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO
PENFIELD LIBRARY - GOVERNMENT DOCUMENTS COL
OSWEGO, NY 13126
(315) 341-2323

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

10 CFR 71.111 STATES, "THE LICENSEE SHALL PRESCRIBE ACTIVITIES AFFECTING QUALITY BY DOCUMENTED INSTRUCTIONS, PROCEDURES, OR DRAWINGS." CONTRARY TO THE ABOVE, THE LICENSEE DID NOT HAVE A PROCEDURE PRESCRIBING THE QUALITY ASSURANCE ACTIVITIES OF WASTE CLASSIFICATION, WASTE CHARACTERIZATION AND LABELING DESCRIBED IN 10 CFR 61 WHICH WAS EFFECTIVE DECEMBER 27, 1983. THIS IS A SEVERITY LEVEL IV VIOLATION (SUPPLEMENT V).
(8409 4)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

OTHER ITEMS

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

```
=====
```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

```
=====
```

1. Docket: 50-285 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: T. P. MATTHEWS (402) 536-4733

4. Licensed Thermal Power (MWt): 1500

5. Nameplate Rating (Gross MWe): 591 X 0.85 = 502

6. Design Electrical Rating (Net MWe): 478

7. Maximum Dependable Capacity (Gross MWe): 501

8. Maximum Dependable Capacity (Net MWe): 478

9. If Changes Occur Above Since Last Report, Give Reasons:
TURBINE BLADING REPAIR

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>95,856.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>2,778.1</u>	<u>73,392.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,309.5</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>2,675.7</u>	<u>72,028.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,103,037</u>	<u>3,713,208</u>	<u>90,472,922</u>
18. Gross Elec Ener (MWH)	<u>365,278</u>	<u>1,196,320</u>	<u>29,825,744</u>
19. Net Elec Ener (MWH)	<u>347,887</u>	<u>1,135,411</u>	<u>28,215,271</u>
20. Unit Service Factor	<u>100.0</u>	<u>45.7</u>	<u>75.1</u>
21. Unit Avail Factor	<u>100.0</u>	<u>45.7</u>	<u>75.1</u>
22. Unit Cap Factor (MDC Net)	<u>97.8</u>	<u>43.3</u>	<u>64.2*</u>
23. Unit Cap Factor (DER Net)	<u>97.8</u>	<u>40.6</u>	<u>61.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.6</u>	<u>3.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>16.3</u>	<u>1,414.7</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* FORT CALHOUN 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
FORT CALHOUN 1



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* FORT CALHOUN 1 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

FORT CALHOUN OPERATED AT OR NEAR FULL POWER DURING THE REPORT PERIOD.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System & Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

* FORT CALHOUN 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEBRASKA

COUNTY.....WASHINGTON

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...19 MI N OF
 OMAHA, NEB

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...AUGUST 6, 1973
DATE ELEC ENER 1ST GENER...AUGUST 25, 1973
DATE COMMERCIAL OPERATE....JUNE 20, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MISSOURI RIVER

ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
 RELIABILITY COORDINATION
 AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....OMAHA PUBLIC POWER DISTRICT

CORPORATE ADDRESS.....1623 HARNEY STREET
 OMAHA,, NEBRASKA 68102

CONTRACTOR
ARCHITECT/ENGINEER.....GIBBS, HILL, DURHAM & RICHARDSON
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....GIBBS, HILL, DURHAM & RICHARDSON
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....L. VANDELL
LICENSING PROJ MANAGER.....E. TOURIGNY
DOCKET NUMBER.....50-285
LICENSE & DATE ISSUANCE....DPR-40, AUGUST 9, 1973
PUBLIC DOCUMENT ROOM.....W. DALE CLARK LIBRARY
 215 S. 15TH STREET
 OMAHA, NEBRASKA 68102

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED JULY 1-31, 1984 (84-16): ROUTINE, ANNOUNCED INSPECTION OF OPERATIONAL SAFETY VERIFICATION, SURVEILLANCE TESTING, MAINTENANCE, PLANT STARTUP ACTIVITIES, AND OPPD REORGANIZATION. WITHIN THE FIVE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* FORT CALHOUN 1 *

OTHER ITEMS

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

ROUTINE POWER OPERATION

LAST IE SITE INSPECTION DATE: JULY 1-31, 1984 BY L. A. YANDELL

INSPECTION REPORT NO: 50-285/84-16

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-09 REV 0	6/22/84	7/23/84	10 CFR 50.49 TESTING OF CONAX ELECTRICAL PENETRATIONS.
84-11 REV 0	7/20/84	8/19/84	RADIATION MONITOR DISCONNECTED.
84-13 REV 0	7/22/84	8/21/84	REACTOR TRIP.
84-15 REV 0	7/2/84	8/1/84	LOAD OVER THE RCS.

=====

1. Docket: 50-267 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: FRANK NOVACHEK (303) 785-2224

4. Licensed Thermal Power (Mwt): 842

5. Nameplate Rating (Gross MWe): 403 X 0.85 = 343

6. Design Electrical Rating (Net MWe): 330

7. Maximum Dependable Capacity (Gross MWe): 342

8. Maximum Dependable Capacity (Net MWe): 330

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): 280

11. Reasons for Restrictions, If Any:
B-0 STARTUP TESTING.

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>45,336.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>1,324.1</u>	<u>27,151.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>660.1</u>	<u>18,463.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>340,047</u>	<u>9,709,799</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>95,438</u>	<u>3,248,888</u>
19. Net Elec Ener (MWH)	<u>-3,571</u>	<u>67,084</u>	<u>2,938,614</u>
20. Unit Service Factor	<u>.0</u>	<u>11.3</u>	<u>40.7</u>
21. Unit Avail Factor	<u>.0</u>	<u>11.3</u>	<u>40.7</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>3.5</u>	<u>19.6</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>3.5</u>	<u>19.6</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>72.3</u>	<u>42.1</u>
25. Forced Outage Hours	<u>744.0</u>	<u>1,723.5</u>	<u>13,400.5</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 11/01/84

* FORT ST VRAIN *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FORT ST VRAIN



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* FORT ST VRAIN *

<u>No.</u>	<u>Date</u>	<u>Type</u>	<u>Hours</u>	<u>Reason</u>	<u>Method</u>	<u>LER Number</u>	<u>System</u>	<u>Component</u>	<u>Cause & Corrective Action to Prevent Recurrence</u>
84-006	07/01/84	F	744.0	A	4	50-267/84008	AA	JC	CONTROL ROD DRIVE INVESTIGATION CONTINUES.

***** FORT ST. VRAIN REMAINS SHUTDOWN IN A CONTINUING REPAIR OUTAGE.
* SUMMARY *

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System & Component</u>	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

* FORT ST VRAIN *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....COLORADO
COUNTY.....WELD
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...35 MI N OF
DENVER, COL
TYPE OF REACTOR.....HTGR
DATE INITIAL CRITICALITY...JANUARY 31, 1974
DATE ELEC ENER 1ST GENER...DECEMBER 11, 1976
DATE COMMERCIAL OPERATE....JULY 1, 1979
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...S. PLATTE RIVER
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY
LICENSEE.....PUBLIC SERVICE OF COLORADO
CORPORATE ADDRESS.....P.O. BOX 840
DENVER, COLORADO 80201
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ATOMIC CORP.
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV
IE RESIDENT INSPECTOR.....G. PLUMLEE
LICENSING PROJ MANAGER.....P. WAGNER
DOCKET NUMBER.....50-267
LICENSE & DATE ISSUANCE....DPR-34, DECEMBER 21, 1973
PUBLIC DOCUMENT ROOM.....GREELEY PUBLIC LIBRARY
CITY COMPLEX BUILDING
GREELEY, COLORADO 80631

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED JUNE 4-8, 1984 (84-17):

ROUTINE, UNANNOUNCED INSPECTION OF THE COLLECTION, STORAGE, AND MAINTENANCE OF QUALITY ASSURANCE (QA) RECORDS FOR NUCLEAR POWER PLANTS.

WITHIN THE ONE AREA INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CABLE PENETRATION THRU FIRE BARRIER FOUND UNSEALED WITHOUT FIRE WATCH POSTED.
(8412 4)

LICENSEE FAILED TO UPDATE COPY OF CONTROL ROOM P&ID AS REQUIRED BY PROCEDURE.
(8412 5)

CONTRARY TO ADMINISTRATIVE PROCEDURE Q-11, SURVEILLANCE SR5.2.16F-RX, AND MAINTENANCE PROCEDURE MP 11-3, THE NRC INSPECTOR DETERMINED THAT THE SR AND MP DID NOT PROVIDE PROOF TEST REQUIREMENTS AND WERE NOT ADEQUATELY FOLLOWED. CONTRARY TO ADMINISTRATION

ENFORCEMENT SUMMARY

TIVE PROCEDURE P-2, THE NRC INSPECTOR DETERMINED THAT THE NITROGEN BLANKETING SUBSYSTEM FOR THE SYSTEM 46 SURGE TANKS HAD BEEN A DEVIATION SITUATION WITHOUT OPERATIONS KNOWLEDGE.

CONTRARY TO ADMINISTRATIVE PROCEDURE P-8 AND MAINTENANCE PROCEDURE MP 11-9, THE NRC INSPECTOR IDENTIFIED AREAS INSIDE THE REACTOR BUILDING WHERE COMBUSTIBLE MATERIAL WAS NOT CONTROLLED AND WORK AREAS WERE NOT CONTROLLED IN ACCORDANCE WITH ANSI HOUSKEEPING REQUIREMENTS.
(8414 4)

CONTRARY TO OVERALL PLANT OPERATING PROCEDURES, THE NRC INSPECTOR DETERMINED THAT REACTOR POWER WAS GREATER THAN 2 PERCENT WITHOUT HAVING OPOP I.C.COMPLETED.

CONTRARY TO ADMINISTRATIVE PROCEDURE Q-5, THE NRC INSPECTOR DETERMINED THE CURRENT PROCESS FOR PERFORMING/CONTROLLING CONTROL WORK PERMITS (CWP), PROCEDURE/INSPECTION/TEST/REPORTS (PITR), AND DEVIATION REPORTS (DR), WHICH ARE ACTIVITIES AFFECTING QUALITY, IS NOT PRESCRIBED BY INSTRUCTIONS/PROCEDURES AND THEREFORE NOT PERFORMED IN ACCORDANCE WITH SUCH DOCUMENTS.
(8414 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

ON JUNE 23, 1984, SIX CONTROL ROD PAIRS FAILED TO DROP INTO THE CORE DURING A REACTOR SCRAM. THE LICENSEE IS CONTINUING WITH THEIR CRDM INSPECTION PROGRAM. FOUR CRDMs HAVE BEEN REFURBISHED TO DATE, WITH FOUR REMAINING TO BE REFURBISHED IN ACCORDANCE WITH THE LICENSEE'S PROPOSED INSPECTION PROGRAM.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE PLANT IS IN A MAINTENANCE SHUTDOWN STATUS. FSV IS CONTINUING WITH THEIR CRDM INSPECTION PROGRAM.

LAST IE SITE INSPECTION DATE: JUNE 4-5, 1984

INSPECTION REPORT NO: 50-267/84-17

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-007	5-29-84	6-28-84	ON MAY 29, 1984, REACTOR AT LESS THAN 2% POWER, LOOP I SHUTDOWN OCCURRED WHEN THE RRR-1 ON THE 4160/480 V TRANSFORMER ACTIVATED.
84-008	6-23-84	7-23-84	ON JUNE 23, 1984, THE PPS INITIATED AN AUTOMATIC HIGH PRESSURE TRIP. 6 OF 37 CONTROL ROD PAIRS FAILED TO AUTOMATICALLY INSERT.

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-244 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: ANDREW MC NAMARA (315) 524-4446

4. Licensed Thermal Power (Mwt): 1520

5. Nameplate Rating (Gross MWe): 608 X 0.85 = 517

6. Design Electrical Rating (Net MWe): 470

7. Maximum Dependable Capacity (Gross MWe): 490

8. Maximum Dependable Capacity (Net MWe): 470

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>129,431.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,919.7</u>	<u>97,519.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>56.2</u>	<u>1,687.7</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,851.3</u>	<u>95,362.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>8.5</u>
17. Gross Therm Ener (MWH)	<u>1,106,304</u>	<u>5,600,136</u>	<u>131,857,505</u>
18. Gross Elec Ener (MWH)	<u>361,908</u>	<u>1,854,810</u>	<u>43,019,181</u>
19. Net Elec Ener (MWH)	<u>343,735</u>	<u>1,761,791</u>	<u>40,788,035</u>
20. Unit Service Factor	<u>100.0</u>	<u>65.8</u>	<u>73.7</u>
21. Unit Avail Factor	<u>100.0</u>	<u>65.8</u>	<u>73.7</u>
22. Unit Cap Factor (MDC Net)	<u>98.3</u>	<u>64.0</u>	<u>68.8*</u>
23. Unit Cap Factor (DER Net)	<u>98.3</u>	<u>64.0</u>	<u>68.8*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>7.2</u>	<u>7.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>296.9</u>	<u>4,099.0</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* GINNA *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
GINNA



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * GINNA *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
5	08/27/84	F	0.0	A	5		CH	PIPEXX	STEAM LEAK ON 1B MAIN F.W. PUMP SUCTION RELIEF VALVE NO. 3972 - PIPING REACTOR POWER LEVEL WAS REDUCED TO APPROXIMATELY 43% TO ACCOMPLISH THIS TASK. A TURBINE RUNBACK OCCURRED DUE TO A DROPPED ROD SIGNAL CAUSED BY A BLOWN CONTROL POWER FUSE - DEFEATED CHANNEL 44 (E-13.1 PROCEDURE). AS A RESULT OF THE TURBINE RUNBACK REACTOR POWER LEVEL WAS FURTHER REDUCED TO APPROXIMATELY 26%.

 * SUMMARY *

 GINNA OPERATED WITH 1 REDUCTION DURING AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

* GINNA *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....WAYNE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...15 MI NE OF
ROCHESTER, NY
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 8, 1969
DATE ELEC ENER 1ST GENER...DECEMBER 2, 1969
DATE COMMERCIAL OPERATE....JULY 1, 1970
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE ONTARIO
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....ROCHESTER GAS & ELECTRIC
CORPORATE ADDRESS.....89 EAST AVENUE
ROCHESTER, NEW YORK 14604
CONTRACTOR
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....W. COOK
LICENSING PROJ MANAGER.....G. DICK
DOCKET NUMBER.....50-244
LICENSE & DATE ISSUANCE...DPR-18, SEPTEMBER 19, 1969
PUBLIC DOCUMENT ROOM.....ROCHESTER PUBLIC LIBRARY
BUSINESS AND SOCIAL SCIENCE DIVISION
115 SOUTH AVENUE
ROCHESTER, NEW YORK 14604

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

SECTION 7.1 OF THE EMERGENCY PLAN STATES IN PART "TRAINING CLASSES ON THE RADIATION EMERGENCY PLAN SHALL BE CONDUCTED ANNUALLY FOR ALL STATION PERSONNEL WHO MAY ACTIVELY PARTICIPATE IN THE RADIATION EMERGENCY PLAN." PROCEDURE NO. SC-600, EMERGENCY PLAN QUALIFICATION AND NOTIFICATION PROVIDES A LIST OF MEMBERS OF THE EMERGENCY RESPONSE ORGANIZATION. CONTRARY TO THE ABOVE, THREE MEMBERS OF THE EMERGENCY RESPONSE ORGANIZATION HAD NOT ATTENDED CLASSES ON THE RADIATION EMERGENCY PLAN SINCE DECEMBER 1982. (8408 4)

AS A RESULT OF THE INSPECTION CONDUCTED ON MAY 7 -11, 1984 AND IN ACCORDANCE WITH THE REVISED NRC ENFORCEMENT POLICY (10 CFR 2, APPENDIX C), PUBLISHED IN THE FEDERAL REGISTER NOTICE (49 FR 8583) DATED MARCH 8, 1984 THE FOLLOWING VIOLATION WAS IDENTIFIED: TECHNICAL SPECIFICATION 6.11 AND 6.8.1, REQUIRES, IN PART, THE LICENSEE TO DEVELOP WRITTEN RADIATION MONITORING PROCEDURES CONSISTENT WITH 10 CFR 20. 10 CFR 20.103(A)3 REQUIRES SUITABLE MEASUREMENTS OF CONCENTRATIONS OF RADIOACTIVE MATERIALS IN AIR. CONTRARY TO THE ABOVE, THE LICENSEES PROCEDURES WERE INADEQUATE IN THAT PROCEDURES HP 4.3, HP 6.1 AND HP 6.2 WHICH REQUIRE AIRBORNE MONITORING DID NOT SPECIFY THE TECHNIQUE TO BE USED TO MONITOR AREA AND BREATHING ZONE CONCENTRATIONS AND TO PROVIDE

Report Period AUG 1984

R E P O R T S F R O M L I C E N S E E

XX
M GINNA
XX

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-213 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. P. DRAGO (203) 267-2556-X452

4. Licensed Thermal Power (MWt): 1825

5. Nameplate Rating (Gross MWe): 667 X 0.9 = 600

6. Design Electrical Rating (Net MWe): 582

7. Maximum Dependable Capacity (Gross MWe): 596

8. Maximum Dependable Capacity (Net MWe): 569

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>146,111.0</u>
13. Hours Reactor Critical	<u>10.8</u>	<u>5,121.8</u>	<u>126,323.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,200.5</u>
15. Hrs Generator On-Line	<u>3.3</u>	<u>5,114.3</u>	<u>121,021.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>373.7</u>
17. Gross Therm Ener (MWH)	<u>2,590</u>	<u>8,858,743</u>	<u>210,231,303</u>
18. Gross Elec Ener (MWH)	<u>770</u>	<u>2,896,058</u>	<u>69,009,301</u>
19. Net Elec Ener (MWH)	<u>-2,806</u>	<u>2,754,031</u>	<u>65,654,732</u>
20. Unit Service Factor	<u>.4</u>	<u>87.3</u>	<u>82.8</u>
21. Unit Avail Factor	<u>.4</u>	<u>87.3</u>	<u>83.1</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>82.7</u>	<u>62.8*</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>80.8</u>	<u>77.0*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>5.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>1,158.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 10/09/84

* HADDAM NECK *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

HADDAM NECK



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* HADDAM NECK *

<u>No.</u>	<u>Date</u>	<u>Type</u>	<u>Hours</u>	<u>Reason</u>	<u>Method</u>	<u>LER Number</u>	<u>System</u>	<u>Component</u>	<u>Cause & Corrective Action to Prevent Recurrence</u>
84-01	08/01/84	S	740.7	C	1		RC	FUELXX	CORE XII - XIII REFUELING BEGINS.

* SUMMARY *

HADDAM NECK (CONNECTICUT YANKEE) SHUTDOWN ON AUGUST 1ST FOR REFUELING.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System & Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* HADDAM NECK *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....CONNECTICUT
COUNTY.....MIDDLESEX
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...13 MI E OF
MERIDEN, CONN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JULY 24, 1967
DATE ELEC ENER 1ST GENER...AUGUST 7, 1967
DATE COMMERCIAL OPERATE....JANUARY 1, 1968
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER....CONNECTICUT RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CONNECTICUT YANKEE ATOMIC POWER
CORPORATE ADDRESS.....P.O. BOX 270
HARTFORD, CONNECTICUT 06101
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....P. SWETLAND
LICENSING PROJ MANAGER.....J. LYONS
DOCKET NUMBER.....50-213
LICENSE & DATE ISSUANCE....DPR-61, DECEMBER 27, 1974
PUBLIC DOCUMENT ROOM.....RUSSELL LIBRARY
123 BROAD STREET
MIDDLETOWN, CONNECTICUT 06457

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.8 STATES, "WRITTEN PROCEDURES AND ADMINISTRATIVE POLICIES SHALL BE ESTABLISHED, IMPLEMENTED AND MAINTAINED THAT MEET OR EXCEED THE REQUIREMENTS AND RECOMMENDATIONS OF SECTION 5.1 AND 5.3 OF ANSI N18.7-1976 AND APPENDIX "A" OF USAEC REGULATORY GUIDE 1.33..." SECTION 2.0, "APPLICABILITY", OF CONNECTICUT YANKEE QUALITY ASSURANCE PROCEDURE NO. QA1.2-7, "RECEIPT, INSPECTION AND IDENTIFICATION OF MATERIALS, PARTS AND COMPONENTS," DEVELOPED PURSUANT TO THE ABOVE, STATES THAT THE "PROCEDURE APPLIES TO PURCHASED CATEGORY I, RADWASTE QA, FIRE PROTECTION QA AND CATEGORY II MATERIAL, PARTS AND COMPONENTS". SECTION 4.2 OF PROCEDURE NO. QA 1.2-7 STATES THAT THE QA/QC DEPARTMENT IS RESPONSIBLE FOR PERFORMING RECEIPT INSPECTIONS IN ACCORDANCE WITH THE PROCEDURE. CONTRARY TO THE ABOVE, DURING 1984 THE LICENSEE HAS RECEIVED 3 HIGH INTEGRITY CONTAINERS (HIC) RADWASTE QA COMPONENT AND THE QA/QC DEPARTMENT HAS NOT PERFORMED RECEIPT INSPECTIONS ON ANY OF THE HIGH INTEGRITY CONTAINERS. THIS IS A SEVERITY LEVEL IV VIOLATION (SUPPLEMENT V). 10 CFR 20.311 (D) (3) REQUIRES ANY GENERATING LICENSEE WHO TRANSFERS RADIOACTIVE WASTE TO A LAND DISPOSAL FACILITY TO CONDUCT A QUALITY CONTROL PROGRAM TO ASSURE COMPLIANCE WITH 10 CFR 61.55 AND 10 CFR 61.56. CONTRARY TO THE ABOVE, THE LICENSEE HAS TRANSFERRED RADIOACTIVE WASTE TO A LAND DISPOSAL FACILITY AT LEAST FIVE TIMES DURING 1984 AND THE LICENSEE HAS NOT CONDUCTED A QUALITY CONTROL PROGRAM TO ASSURE COMPLIANCE WITH 10 CFR 61.55 AND 10 CFR 61.56. THIS IS A SEVERITY LEVEL IV VIOLATION (SUPPLEMENT V).

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* HADDAM NECK *

ENFORCEMENT SUMMARY

(8411 4)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-321 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: P. J. NORTH (912) 367-7851

4. Licensed Thermal Power (MWt): 2436

5. Nameplate Rating (Gross MWe): 1000 X 0.85 = 850

6. Design Electrical Rating (Net MWe): 777

7. Maximum Dependable Capacity (Gross MWe): 801

8. Maximum Dependable Capacity (Net MWe): 752

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>75,983.0</u>
13. Hours Reactor Critical	<u>704.9</u>	<u>4,966.6</u>	<u>54,472.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>675.2</u>	<u>4,806.5</u>	<u>51,199.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,434,030</u>	<u>10,750,439</u>	<u>107,885,554</u>
18. Gross Elec Ener (MWH)	<u>435,960</u>	<u>3,399,500</u>	<u>34,848,480</u>
19. Net Elec Ener (MWH)	<u>412,468</u>	<u>3,233,436</u>	<u>33,083,927</u>
20. Unit Service Factor	<u>90.8</u>	<u>82.1</u>	<u>67.4</u>
21. Unit Avail Factor	<u>90.8</u>	<u>82.1</u>	<u>67.4</u>
22. Unit Cap Factor (MDC Net)	<u>73.7</u>	<u>73.4</u>	<u>57.9</u>
23. Unit Cap Factor (DER Net)	<u>71.4</u>	<u>71.1</u>	<u>56.0</u>
24. Unit Forced Outage Rate	<u>9.2</u>	<u>16.7</u>	<u>16.0</u>
25. Forced Outage Hours	<u>68.8</u>	<u>963.9</u>	<u>9,573.8</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
REFUELING: 10-1-84; 10 WEEK DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

* HATCH 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
HATCH 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * HATCH 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-59	08/01/84	F	0.0	A	5		HA	TURBIN	13TH STAGE BUCKETS WERE DAMAGED & OUT FOR THE DURATION OF AUGUST.
84-60	08/03/84	F	26.1	A	3	1-84-15	EG	TRANSF	SHORT IN 1B AUX. TRANSFORMER. SCRAM ON TCV FAST CLOSURE.
84-61	08/04/84	F	0.0	B	5		EG	TRANSF	LOAD REDUCTION FOR TRANSFORMER WORK.
84-62	08/18/84	S	0.0	B	5		HA	TURBIN	LOAD REDUCTION FOR WEEKLY TURBINE TESTING.
84-63	08/18/84	F	0.0	A	5		CB	PUMPXX	RECIRC PUMP TRIPS.
84-64	08/28/84	F	0.0	A	5		HF	FILTER	LOSS OF CONDENSER VACUUM. CIRC. WATER SCREENS CLOGGED.
84-65	08/28/84	F	21.8	A	2		HF	FILTER	LOSS OF CONDENSER VACUUM. CIRC. WATER SCREENS CLOGGED. OUTAGE.
84-66	08/29/84	S	0.0	H	5		IF	INSTRU	POWER INCREASE DISCONTINUED FOR P-1 RUN.
84-67	08/31/84	F	0.0	A	5		HC	XXXXXX	LOSS OF CONDENSER VACUUM FROM IN LEAKAGE THROUGH CRACK BETWEEN CONDENSER & LP TURBINE.
84-68	08/31/84	F	20.9	A	2		HC	XXXXXX	LOSS OF CONDENSER VACUUM FROM IN LEAKAGE THROUGH CRACK BETWEEN CONDENSER & LP TURBINE. OUTAGE.

 * HATCH 1 OPERATED ROUTINELY DURING THE REPORT PERIOD.
 * SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* HATCH 1 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....GEORGIA
COUNTY.....APPLING
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI N OF
BAXLEY, GA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...SEPTEMBER 12, 1974
DATE ELEC ENER 1ST GENER...NOVEMBER 11, 1974
DATE COMMERCIAL OPERATE...DECEMBER 31, 1975
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...ALTAMAHA RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....GEORGIA POWER
CORPORATE ADDRESS.....333 PIEDMONT AVENUE
ATLANTA, GEORGIA 30308
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....GEORGIA POWER CO.
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....R. CRLENJAK
LICENSING PROJ MANAGER.....G. RIVENBARK
DUCKET NUMBER.....50-321
LICENSE & DATE ISSUANCE...DPR-57, OCTOBER 13, 1974
PUBLIC DOCUMENT ROOM.....APPLING COUNTY PUBLIC LIBRARY
301 CITY HALL DRIVE
BAXLEY, GEORGIA 31563

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JUNE 21 - JULY 20 (84-24): THIS INSPECTION INVOLVED 84 INSPECTOR-HOURS ON SITE IN THE AREAS OF TECHNICAL SPECIFICATION COMPLIANCE, OPERATOR PERFORMANCE, OVERALL PLANT OPERATIONS, QUALITY ASSURANCE PRACTICES, STATION AND CORPORATE MANAGEMENT PRACTICES, CORRECTIVE AND PREVENTIVE MAINTENANCE ACTIVITIES, SITE SECURITY PROCEDURES, RADIATION CONTROL ACTIVITIES, AND SURVEILLANCE ACTIVITIES. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 16-20 (84-26): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 34 INSPECTOR-HOURS ON SITE IN THE AREAS OF REVIEW OF TEST PROCEDURE NO. HNP-2-10183, INTEGRATED ECCS TEST II, REVIEW OF TEST PROCEDURE FOR THE ROD BLOCK MONITORING SYSTEM ARTS MODIFICATION FOR DCR 84-105, VERIFICATION OF AS-BUILTS, INDEPENDENT INSPECTION, REVIEW OF THE SNUBBER SURVEILLANCE PROGRAM, AND PLANT TOUR. OF THE FIVE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 16-20 (84-28): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 16 INSPECTOR-HOURS ON SITE IN THE AREAS OF RADIATION PROTECTION TRAINING, INTERNAL EXPOSURE, EXTERNAL EXPOSURE FOR RECIRCULATION PIPING REPLACEMENT, SOLID WASTE, TRANSPORTATION, LIQUID AND GASEOUS WASTES. ONE VIOLATION WAS IDENTIFIED - FAILURE TO POST A RADIATION AREA.

INSPECTION JULY 30 - AUGUST 3 (84-29): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 87 (20 INSPECTOR HOURS NONROUTINE) INSPECTOR-HOURS ON SITE IN THE AREA OF A LIMITED SCALE EMERGENCY PREPAREDNESS EXERCISE. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 21 - AUGUST 20 (84-30): THIS INSPECTION INVOLVED 85 INSPECTOR-HOURS ON SITE IN THE AREAS OF TECHNICAL

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* HATCH 1 *

INSPECTION SUMMARY

SPECIFICATION COMPLIANCE, OPERATOR PERFORMANCE, OVERALL PLANT OPERATIONS, QUALITY ASSURANCE PRACTICES, STATION AND CORPORATE MANAGEMENT PRACTICES, CORRECTIVE AND PREVENTIVE MAINTENANCE ACTIVITIES, SITE SECURITY PROCEDURES, RADIATION CONTROL ACTIVITIES, REFUELING, AND SURVEILLANCE ACTIVITIES. OF THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED (FAILURE TO FOLLOW PROCEDURES/INSTRUCTIONS).

ENFORCEMENT SUMMARY

10 CFR 20.203(B) REQUIRES A LICENSEE TO POST EACH RADIATION AREA WITH A CONSPICUOUS SIGN OR SIGNS BEARING THE RADIATION CAUTION SYMBOL AND THE WORDS: "CAUTION RADIATION AREA". CONTRARY TO THE ABOVE, THE LICENSEE DID NOT POST A RADIATION SIGN IN THE RADIOACTIVE WASTE HANDLING BUILDING.
(8428 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

+ REFUELING SCHEDULED OCTOBER 1, 1984, 5 WEEKS.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: JULY 21 - AUGUST 20, 1984 +

INSPECTION REPORT NO: 50-321/84-30 +

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-005	07/20/84	08/14/84	CABLE SEPARATION, UNLANDED CABLES, AND OPEN LINKS, CAUSE DUE TO PERSONNEL ERROR AND INADEQUATE ADMINISTRATIVE CONTROLS.

1. Docket: 50-366 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: P. J. NORTH (912) 367-7851

4. Licensed Thermal Power (MWt): 2436

5. Nameplate Rating (Gross MWe): 1000 X 0.85 = 850

6. Design Electrical Rating (Net MWe): 784

7. Maximum Dependable Capacity (Gross MWe): 804

8. Maximum Dependable Capacity (Net MWe): 748

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>43,752.0</u>
13. Hours Reactor Critical	<u>66.2</u>	<u>374.4</u>	<u>27,613.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>308.2</u>	<u>26,241.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,638</u>	<u>728,550</u>	<u>56,294,846</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>242,640</u>	<u>18,547,990</u>
19. Net Elec Ener (MWH)	<u>-5,475</u>	<u>212,868</u>	<u>17,631,110</u>
20. Unit Service Factor	<u>.0</u>	<u>5.3</u>	<u>60.0</u>
21. Unit Avail Factor	<u>.0</u>	<u>5.3</u>	<u>60.0</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>4.9</u>	<u>53.9</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>4.6</u>	<u>51.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>11.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>3,425.8</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 09/03/84

* HATCH 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

HATCH 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* HATCH 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-5	01/13/84	S	744.0	H	4		CB	PIPEXX	RECIRC PIPE REPLACEMENT OUTAGE CONTINUES.

* SUMMARY *

HATCH 2 REMAINS SHUTDOWN IN A CONTINUING MAINTENANCE OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* HATCH 2 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....GEORGIA

COUNTY.....APPLING

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI N OF
BAXLEY, GA

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...JULY 4, 1978

DATE ELEC ENER 1ST GENER...SEPTEMBER 22, 1978

DATE COMMERCIAL OPERATE...SEPTEMBER 5, 1979

CONDENSER COOLING METHOD...COOLING TOWER

CONDENSER COOLING WATER...ALTAMAHA RIVER

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....GEORGIA POWER

CORPORATE ADDRESS.....333 PIEDMONT AVENUE
ATLANTA, GEORGIA 30308

CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....GEORGIA POWER CO.

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....R. CRLENJAK

LICENSING PROJ MANAGER.....G. RIVENBARK
DOCKET NUMBER.....50-366

LICENSE & DATE ISSUANCE...NPF-5, JUNE 13, 1978

PUBLIC DOCUMENT ROOM.....APPLING COUNTY PUBLIC LIBRARY
301 CITY HALL DRIVE
BAXLEY, GEORGIA 31563

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JUNE 21 - JULY 20 (84-24): THIS INSPECTION INVOLVED 83 INSPECTOR-HOURS ON SITE IN THE AREAS OF TECHNICAL SPECIFICATION COMPLIANCE, OPERATOR PERFORMANCE, OVERALL PLANT OPERATIONS, QUALITY ASSURANCE PRACTICES, STATION AND CORPORATE MANAGEMENT PRACTICES, CORRECTIVE AND PREVENTIVE MAINTENANCE ACTIVITIES, SITE SECURITY PROCEDURES, RADIATION CONTROL ACTIVITIES, AND SURVEILLANCE ACTIVITIES. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 16-20 (84-26): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 33 INSPECTOR-HOURS ON SITE IN THE AREAS OF REVIEW OF TEST PROCEDURE NO. HNP-2-10183, INTEGRATED ECCS TEST II, REVIEW OF TEST PROCEDURE FOR THE ROD BLOCK MONITORING SYSTEM ARTS MODIFICATION FOR DCR 84-105, VERIFICATION OF AS-BUILTS, INDEPENDENT INSPECTION, REVIEW OF THE SNUBBER SURVEILLANCE PROGRAM, AND PLANT TOUR. OF THE FIVE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 16-20 (84-28): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 16 INSPECTOR-HOURS ON SITE IN THE AREAS OF RADIATION PROTECTION TRAINING, INTERNAL EXPOSURE, EXTERNAL EXPOSURE FOR RECIRCULATION PIPING REPLACEMENT, SOLID WASTE, TRANSPORTATION, LIQUID AND GASEOUS WASTES. ONE VIOLATION WAS IDENTIFIED - FAILURE TO POST A RADIATION AREA.

INSPECTION JULY 30 - AUGUST 3 (84-29): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 87 (20 INSPECTOR HOURS NONROUTINE) INSPECTOR-HOURS ON SITE IN THE AREA OF A LIMITED SCALE EMERGENCY PREPAREDNESS EXERCISE. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 21 - AUGUST 20 (84-30): THIS INSPECTION INVOLVED 84 INSPECTOR-HOURS ON SITE IN THE AREAS OF TECHNICAL

Report Period AUG 1984

R E P O R T S F R O M L I C E N S E E

* HATCH 2 *

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-006	07/16/84	08/14/84	A CONTROL ROD HAD BEEN MOVED PRIOR TO DEMONSTRATING OPERATION OF THE HOIST'S LOADED INTERLOCK, A PROCEDURE REVISION WILL BE MADE.
84-009	07/11/84	08/10/84	THE PLANT HAD AN UNPLANNED LOGIC ACTUATION FOR MORE THAN ONE ENGINEERED SAFETY FEATURE, CAUSE WAS DUE TO A DEFECTIVE REVISION TO HNP-2-3191.

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-247 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: MIKE BLATT (914) 526-5127

4. Licensed Thermal Power (MWt): 2758

5. Nameplate Rating (Gross MWe): 1126 X 0.9 = 1013

6. Design Electrical Rating (Net MWe): 873

7. Maximum Dependable Capacity (Gross MWe): 885

8. Maximum Dependable Capacity (Net MWe): 849

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____


11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>89,160.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>3,228.6</u>	<u>59,176.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,119.1</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>3,204.7</u>	<u>57,400.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>8,228,228</u>	<u>149,268,727</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>2,579,530</u>	<u>46,237,106</u>
19. Net Elec Ener (MWH)	<u>-1,618</u>	<u>1,865,952</u>	<u>43,493,044</u>
20. Unit Service Factor	<u>.0</u>	<u>54.7</u>	<u>64.4</u>
21. Unit Avail Factor	<u>.0</u>	<u>54.7</u>	<u>64.4</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>37.3</u>	<u>57.6*</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>36.5</u>	<u>55.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>12.7</u>	<u>9.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>466.5</u>	<u>5,842.7</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>NONE</u>			

27. If Currently Shutdown Estimated Startup Date: 10/16/84

* INDIAN POINT 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
INDIAN POINT 2



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* INDIAN POINT 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
4	06/02/84	S	744.0	C	4		RC	FUELXX	CYCLE 6/7 REFUELING OUTAGE CONTINUED FROM JUNE.

* SUMMARY *

INDIAN POINT 2 REMAINS SHUTDOWN IN A CONTINUING REFUELING OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* INDIAN POINT 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....WESTCHESTER
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI N OF
NEW YORK CITY, NY
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 22, 1973
DATE ELEC ENER 1ST GENER...JUNE 26, 1973
DATE COMMERCIAL OPERATE...AUGUST 1, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...HUDSON RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CONSOLIDATED EDISON
CORPORATE ADDRESS.....4 IRVING PLACE
NEW YORK, NEW YORK 10003
CONTRACTOR
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....WESTINGHOUSE DEVELOPMENT CORP
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....P. KOLTAY
LICENSING PROJ MANAGER.....P. POLK
DOCKET NUMBER.....50-247
LICENSE & DATE ISSUANCE...DPR-26, SEPTEMBER 28, 1973
PUBLIC DOCUMENT ROOM.....WHITE PLAINS PUBLIC LIBRARY
100 MARTINE AVENUE
WHITE PLAINS, NEW YORK 10601

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INP'T PROVIDED.

ENFORCEMENT SUMMARY

10 CFR 71.12 (C) REQUIRES THAT A PERSON USING A PACKAGE TO TRANSPORT LICENSED MATERIAL MUST HAVE A COPY OF THE CERTIFICATE OF COMPLIANCE, AND THE PERSON MUST ALSO COMPLY WITH THE CONDITIONS OF THE CERTIFICATE. CERTIFICATE OF COMPLIANCE NO. 6601, REVISION NO. 15, REQUIRES THAT PRIOR TO EACH SHIPMENT, THE PACKAGING MUST BE LEAK TESTED IN ACCORDANCE WITH SECTION 8.2.2 OF THE APPLICATION. CONTRARY TO THE ABOVE, THE LICENSEE DID NOT PERFORM A LEAK TEST PRIOR TO THE TYPE B QUANTITY SHIPMENT OF RESIN MADE ON MAY 1, 1984 IN A CASK HAVING THE CERTIFICATE OF COMPLIANCE NO. 6601. CERTIFICATE OF COMPLIANCE NO. 6601, REVISION NO. 15, REQUIRES THAT THE EXTERNAL DOSE RATE AT 3 FEET FROM THE SURFACE OF THE PACKAGE NOT EXCEED 125 MREM/HR. CONTRARY TO THE ABOVE, THE LICENSEE DID NOT DETERMINE IF A PACKAGE SHIPPED ON MAY 1, 1984, HAVING THE CERTIFICATE OF COMPLIANCE NO. 6601, HAD AN EXTERNAL DOSE RATE AT 3 FEET NOT EXCEEDING 125 MREM/HR. THIS IS A SEVERITY LEVEL IV VIOLATION (SUPPLEMENT V).
(8414 4)

TECHNICAL SPECIFICATION 6.8.2 REQUIRES EACH PROCEDURE THAT MEETS OR EXCEEDS THE REQUIREMENTS AND RECOMMENDATION OF SECTIONS 5.1 AND 5.3 OF ANSI 18.7-1972, AND APPENDIX "A" OF USAEC REGULATORY GUIDE 1.33 BE REVIEWED AND APPROVED FOR IMPLEMENTATION IN ACCORDANCE WITH A WRITTEN ADMINISTRATIVE CONTROL PROCEDURE APPROVED BY THE APPROPRIATE GENERAL MANAGER, AND WITH THE CONCURRENCE

ENFORCEMENT SUMMARY

OF THE STATION NUCLEAR SAFETY COMMITTEE AND THE NUCLEAR FACILITIES SAFETY COMMITTEE. CONTRARY TO THE ABOVE, THE LICENSEE HAS IMPLEMENTED A TRANSPORT PACKAGE LOADING PROCEDURE AND THE PROCEDURE WAS NOT REVIEWED AND APPROVED FOR IMPLEMENTATION IN ACCORDANCE WITH A WRITTEN ADMINISTRATIVE CONTROL PROCEDURE APROVED BY THE APPROPRIATE GENERAL MANAGER, AND WITH THE CONCURRENCE OF THE STATION NUCLEAR SAFETY COMMITTEE AND THE NUCLEAR FACILITIES SAFETY COMMITTEE. THIS IS A SEVERITY LEVEL V VIOLATION (SUPPLEMENT V).
(8414 5)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

1. Docket: 50-286 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: L. KELLY (914) 739-8200

4. Licensed Thermal Power (MWt): 3025

5. Nameplate Rating (Gross MWe): 1126 X 0.9 = 1013

6. Design Electrical Rating (Net MWe): 965

7. Maximum Dependable Capacity (Gross MWe): 1000

8. Maximum Dependable Capacity (Net MWe): 965

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>70,176.0</u>
13. Hours Reactor Critical	<u>740.7</u>	<u>5,101.5</u>	<u>39,526.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>653.2</u>	<u>4,875.6</u>	<u>38,017.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,886,630</u>	<u>13,936,563</u>	<u>98,306,399</u>
18. Gross Elec Ener (MWH)	<u>598,390</u>	<u>4,540,915</u>	<u>30,907,526</u>
19. Net Elec Ener (MWH)	<u>575,245</u>	<u>4,370,133</u>	<u>29,614,311</u>
20. Unit Service Factor	<u>87.8</u>	<u>83.3</u>	<u>54.2</u>
21. Unit Avail Factor	<u>87.8</u>	<u>83.3</u>	<u>54.2</u>
22. Unit Cap Factor (MDC Net)	<u>80.1</u>	<u>77.3</u>	<u>43.7</u>
23. Unit Cap Factor (DER Net)	<u>80.1</u>	<u>77.3</u>	<u>43.7</u>
24. Unit Forced Outage Rate	<u>3.3</u>	<u>15.1</u>	<u>22.6</u>
25. Forced Outage Hours	<u>22.2</u>	<u>870.3</u>	<u>11,067.1</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
S/G INSPECTION: 10/13/84 - 4 WEEKS.

27. If Currently Shutdown Estimated Startup Date: N/A

* INDIAN POINT 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

INDIAN POINT 3



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * INDIAN POINT 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
10	08/28/84	F	22.2	A	3	84-013-00	CH	PUMPXX	MBFP CONTROL OIL SYSTEM CAUSED FEED FLOW PERTURBATIONS WHICH ULTIMATELY LED TO A HI-HI LEVEL STEAM GENERATOR UNIT TRIP.
11	08/28/84	S	68.6	A	1		HF	HTEXCH	REPAIR OF CONDENSER CIRCULATING WATER CONDENSER SEAMS AND ELECTRICAL GENERATOR HYDROGEN COOLERS.

 * SUMMARY *

 INDIAN POINT 3 OPERATED WITH 2 OUTAGES FOR EQUIPMENT FAILURE DURING AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* INDIAN POINT 3 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....WESTCHESTER
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI N OF
NEW YORK CITY, NY
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 6, 1976
DATE ELEC ENER 1ST GENER...APRIL 27, 1976
DATE COMMERCIAL OPERATE...AUGUST 30, 1976
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...HUDSON RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....POWER AUTHORITY OF STATE OF N.Y.
CORPORATE ADDRESS.....10 COLUMBUS CIRCLE
NEW YORK, NEW YORK 10019
CONTRACTOR
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....WESTINGHOUSE DEVELOPMENT CORP
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. KENNY
LICENSING PROJ MANAGER.....P. POLK
DOCKET NUMBER.....50-286
LICENSE & DATE ISSUANCE...DPR-64, APRIL 5, 1976
PUBLIC DOCUMENT ROOM.....WHITE PLAINS PUBLIC LIBRARY
100 MARTINE AVENUE
WHITE PLAINS, NEW YORK 10601

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* INDIAN POINT 3 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-305 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: G.RUITER (414) 388-2560 X207

4. Licensed Thermal Power (MWt): 1650

5. Nameplate Rating (Gross MWe): 622 X 0.9 = 560

6. Design Electrical Rating (Net MWe): 535

7. Maximum Dependable Capacity (Gross MWe): 529

8. Maximum Dependable Capacity (Net MWe): 503

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>89,520.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,641.5</u>	<u>75,821.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,330.5</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,599.4</u>	<u>74,411.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>10.0</u>
17. Gross Therm Ener (MWH)	<u>1,222,297</u>	<u>7,301,828</u>	<u>116,272,914</u>
18. Gross Elec Ener (MWH)	<u>401,200</u>	<u>2,408,600</u>	<u>38,266,700</u>
19. Net Elec Ener (MWH)	<u>381,602</u>	<u>2,293,515</u>	<u>36,425,551</u>
20. Unit Service Factor	<u>100.0</u>	<u>78.6</u>	<u>83.1</u>
21. Unit Avail Factor	<u>100.0</u>	<u>78.6</u>	<u>83.1</u>
22. Unit Cap Factor (MDC Net)	<u>102.0</u>	<u>77.9</u>	<u>78.3*</u>
23. Unit Cap Factor (DER Net)	<u>95.9</u>	<u>73.2</u>	<u>76.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.3</u>	<u>3.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>15.7</u>	<u>2,745.4</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING & MAINTENANCE: 02/15/85 - 2 MONTHS

27. If Currently Shutdown Estimated Startup Date: N/A

* KEWAUNEE *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

KEWAUNEE



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* KEWAUNEE *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

KEWAUNEE OPERATED AT FULL POWER DURING THE AUGUST REPORT PERIOD.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System & Component</u>	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

* KEWAUNEE *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....WISCONSIN
COUNTY.....KEWAUNEE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...27 MI E OF
GREEN BAY, WI.
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MARCH 7, 1974
DATE ELEC ENER 1ST GENER...APRIL 8, 1974
DATE COMMERCIAL OPERATE...JUNE 16, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY
LICENSEE.....WISCONSIN PUBLIC SERVICE
CORPORATE ADDRESS.....P.O. BOX 19002
GREEN BAY, WISCONSIN 54307
CONTRACTOR
ARCHITECT/ENGINEER.....PIONEER SERVICES & ENGINEERING
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....PIONEER SERVICES & ENGINEERING
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....R. NELSON
LICENSING PROJ MANAGER.....M. FAIRTILE
DOCKET NUMBER.....50-305
LICENSE & DATE ISSUANCE...DPR-43, DECEMBER 21, 1973
PUBLIC DOCUMENT ROOM.....UNIVERSITY OF WISCONSIN
LIBRARY LEARNING CENTER
2420 NICOLET DRIVE
GREEN BAY, WISCONSIN 54301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JULY 9-13, (84-07): ROUTINE, ANNOUNCED INSPECTION OF THE FOLLOWING AREAS OF THE EMERGENCY PREPAREDNESS PROGRAM: EMERGENCY DETECTION AND CLASSIFICATION; PROTECTIVE ACTION DECISIONMAKING; NOTIFICATIONS AND COMMUNICATIONS; CHANGES TO THE EMERGENCY PREPAREDNESS PROGRAM; SHIFT STAFFING AND AUGMENTATION; KNOWLEDGE AND PERFORMANCE OF DUTIES (TRAINING); DOSE CALCULATION AND ASSESSMENT; LICENSEE AUDITS; AND LICENSEE ACTIONS ON PREVIOUSLY-IDENTIFIED ACTIONS. THE INSPECTION INVOLVED 144 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS AND TWO CONSULTANTS. ONE APPARENT ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN ONE AREA FOR FAILURE TO CARRY OUT REQUIRED MONTHLY COMMUNICATIONS TESTS (NOTIFICATIONS AND COMMUNICATIONS). NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN THE REMAINING SEVEN AREAS INSPECTED.

INSPECTION ON AUGUST 2-3, (84-10): SPECIAL ANNOUNCED INSPECTION OF IMPLEMENTATION OF 10 CFR PART 20 AND 10 CFR PART 61 REQUIREMENTS FOR DISPOSAL OF LOW-LEVEL RADIOACTIVE WASTES INCLUDING MANAGEMENT CONTROLS, QUALITY CONTROL, TOUR OF THE FACILITY, AND IMPLEMENTATION OF WASTE FORM AND WASTE CLASSIFICATION REQUIREMENTS. THE INSPECTION INVOLVED 10 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON AUGUST 1-3, (84-11): ROUTINE, UNANNOUNCED INSPECTION BY ONE REGIONAL INSPECTOR OF PREVIOUS INSPECTION FINDINGS. THE INSPECTION INVOLVED 19 INSPECTOR-HOURS ONSITE. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

1. Docket: 50-409 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: G. R. GADOW (608) 689-2331

4. Licensed Thermal Power (MWt): 165

5. Nameplate Rating (Gross MWe): 76.8 X 0.85 = 65

6. Design Electrical Rating (Net MWe): 50

7. Maximum Dependable Capacity (Gross MWe): 50

8. Maximum Dependable Capacity (Net MWe): 48

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>130,034.0</u>
13. Hours Reactor Critical	<u>510.2</u>	<u>4,725.0</u>	<u>85,469.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>478.0</u>
15. Hrs Generator On-Line	<u>469.0</u>	<u>4,431.2</u>	<u>79,267.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>70.0</u>
17. Gross Therm Ener (MWH)	<u>62,988</u>	<u>661,197</u>	<u>10,943,501</u>
18. Gross Elec Ener (MWH)	<u>19,246</u>	<u>209,450</u>	<u>3,266,678</u>
19. Net Elec Ener (MWH)	<u>17,745</u>	<u>196,817</u>	<u>3,024,052</u>
20. Unit Service Factor	<u>63.0</u>	<u>75.7</u>	<u>61.0</u>
21. Unit Avail Factor	<u>63.0</u>	<u>75.7</u>	<u>61.0</u>
22. Unit Cap Factor (MDC Net)	<u>49.7</u>	<u>70.0</u>	<u>48.4</u>
23. Unit Cap Factor (DER Net)	<u>47.7</u>	<u>67.2</u>	<u>46.5</u>
24. Unit Forced Outage Rate	<u>37.0</u>	<u>21.6</u>	<u>10.3</u>
25. Forced Outage Hours	<u>275.0</u>	<u>1,217.6</u>	<u>8,060.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING, MARCH 1, 1985, 6 WEEKS

27. If Currently Shutdown Estimated Startup Date: 09/08/84

* LA CROSSE *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

LA CROSSE



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * LA CROSSE *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-07	08/17/84	F	138.9	A	1		RB	CRDRVE	THE REACTOR WAS MANUALLY SHUTDOWN DUE TO WATER LEAKAGE FROM THE MECHANICAL SEAL OF UPPER CONTROL ROD DRIVE MECHANISM (UCRDM) NO. 19. THE MECHANICAL SEAL WAS REPLACED AND THE MECHANISM WAS PMED.
84-08	08/23/84	F	73.5	A	1		RB	CRDRVE	THE REACTOR WAS MANUALLY SHUTDOWN AFTER UCRDM NO. 19 STARTED LEAKING WATER AT THE FLANGE WHERE IT BOLTS TO THE VESSEL NOZZLE. THE O-RING WAS REPLACED.
84-09	08/29/84	F	62.6	A	1		RB	CRDRVE	THE REACTOR WAS MANUALLY SHUTDOWN AFTER UCRDM NO. 19 STARTED LEAKING WATER AT THE FLANGE.

 * SUMMARY *

 LACROSSE SHUTDOWN ON AUGUST 29TH FOR MAINTENANCE AND REPAIRS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-016f)

* LA CROSSE *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....WISCONSIN
COUNTY.....VERNON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...19 MI S OF
LACROSSE, WISC
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JULY 11, 1967
DATE ELEC ENER 1ST GENER...APRIL 26, 1968
DATE COMMERCIAL OPERATE...NOVEMBER 1, 1969
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DAIRYLAND POWER
CORPORATE ADDRESS.....2615 EAST AVENUE SOUTH
LACROSSE, WISCONSIN 54601
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...ALLIS-CHALMERS
CONSTRUCTOR.....MAXON CONSTRUCTION COMPANY
TURBINE SUPPLIER.....ALLIS-CHALMERS

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. WIEBE
LICENSING PROJ MANAGER.....R. DUDLEY
DOCKET NUMBER.....50-409
LICENSE & DATE ISSUANCE...DPR-45, AUGUST 28, 1973
PUBLIC DOCUMENT ROOM.....LA CROSSE PUBLIC LIBRARY
800 MAIN STREET
LA CROSSE, WISCONSIN 54601

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MAY 16 THROUGH JULY 15, (84-07): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTOR OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, OPERATIONAL SAFETY, MAINTENANCE SURVEILLANCE, LICENSEE EVENT REPORTS, SPECIAL REPORTS, PLANT TRIPS, HIGH RADIATION AREAS, REGULATORY IMPROVEMENT PROGRAM AND DESIGN CHANGES AND MODIFICATIONS. THE INSPECTION INVOLVED A TOTAL OF 155 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR INCLUDING A TOTAL OF 26 INSPECTOR-HOURS ONSITE DURING BACKSHIFTS. OF THE NINE AREAS INSPECTED, ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN ONE AREA (FAILURE TO PROVIDE POSITIVE CONTROL OVER AN AREA WHICH HAD RADIATION LEVELS GREATER THAN 1000 MR/HR).

INSPECTION ON JULY 17-25, (84-10): REACTIVE, ANNOUNCED INSPECTION TO OBSERVE THE LICENSEE'S ACTIONS TO AN UNUSUAL EV NT. THE INSPECTION INVOLVED A TOTAL OF 61 INSPECTOR-HOURS ONSITE BY TWO INSPECTORS AND INCLUDES 22 INSPECTOR-HOURS DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

THE LA CROSSE BOILING WATER REACTOR (LACBWR) TECHNICAL SPECIFICATIONS, PARAGRAPH 6.12.2 REQUIRES IN PART, THAT FOR EACH AREA WITH RADIATION LEVELS GREATER THAN 1000 MREMS/HR THE ENTRANCE OR ACCESS POINT TO THE AREA SHALL BE EQUIPPED WITH A CONTROL DEVICE WHICH SHALL ENERGIZE A CONSPICUOUS VISIBLE OR AUDIBLE ALARM SIGNAL OR THE ENTRANCE OR ACCESS POINT TO THE AREA MAINTAINED LOCKED EXCEPT WHEN ACCESS TO THE AREA IS REQUIRED AND THERE IS POSITIVE CONTROL OVER EACH INDIVIDUAL ENTRY. CONTRARY TO THE ABOVE, FROM 1800 ON

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* LA CROSSE *

ENFORCEMENT SUMMARY

JULY 3 TO 1103 ON JULY 5, 1984. THE STOP VALVE AREA (AN AREA WITH RADIATION LEVELS GREATER THAN 1000 MREMS/HR) ACCESS ALARM WAS OUT OF SERVICE AND THE ENTRANCE WAS NOT LOCKED NOR WAS POSITIVE CONTROL ESTABLISHED OVER EACH INDIVIDUAL ENTRY.
(8407 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IN COLD SHUTDOWN TO REPAIR UPPER FLANGE LEAK ON CROM NO. 19.

LAST IE SITE INSPECTION DATE: JULY 17-25, 1984

INSPECTION REPORT NO: 84-10

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	DESCRIPTION
84-10	07/16/84	08/08/84	FAILURE OF CONTROL ROD 29 TO INSERT.
84-11	07/16/84	08/08/84	LOSS OF OFFSITE POWER.

1. Docket: 50-373 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: RANDY S. DUS (815) 357-6761 X324

4. Licensed Thermal Power (MWt): 3323

5. Nameplate Rating (Gross MWe): 1078

6. Design Electrical Rating (Net MWe): 1078

7. Maximum Dependable Capacity (Gross MWe): 1078

8. Maximum Dependable Capacity (Net MWe): 1078

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):


11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>5,855.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,745.8</u>	<u>4,745.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>1,076.3</u>	<u>1,076.3</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,585.7</u>	<u>4,585.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>1.0</u>	<u>1.0</u>
17. Gross Therm Ener (MWH)	<u>2,223,602</u>	<u>19,262,542</u>	<u>19,262,542</u>
18. Gross Elec Ener (MWH)	<u>713,445</u>	<u>4,283,229</u>	<u>4,283,229</u>
19. Net Elec Ener (MWH)	<u>677,248</u>	<u>4,080,111</u>	<u>4,080,111</u>
20. Unit Service Factor	<u>100.0</u>	<u>78.3</u>	<u>78.3</u>
21. Unit Avail Factor	<u>100.0</u>	<u>78.3</u>	<u>78.3</u>
22. Unit Cap Factor (MDC Net)	<u>84.4</u>	<u>64.6</u>	<u>64.6</u>
23. Unit Cap Factor (DER Net)	<u>84.4</u>	<u>64.6</u>	<u>64.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>18.0</u>	<u>18.0</u>
25. Forced Outage Hours	<u>.0</u>	<u>1,005.4</u>	<u>1,005.4</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>INSPECTION & SURVEILLANCE: 10/01/84 - 1 MONTH</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

* LASALLE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

LASALLE 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* LASALLE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
15	08/04/84	S	0.0	H	5				REDUCED POWER TO REPAIR STEAM LEAKS ON HIGH PRESSURE HEATER.

* SUMMARY *

LASALLE 1 OPERATED WITH 1 REDUCTION DURING AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* LASALLE 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....LA SALLE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI SE OF
OTTAWA, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JUNE 21, 1982
DATE ELEC ENER 1ST GENER...SEPTEMBER 4, 1982
DATE COMMERCIAL OPERATE...JANUARY 1, 1984
CONDENSER COOLING METHOD...POND
CONDENSER COOLING WATER...RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....M. JORDAN
LICENSING PROJ MANAGER....A. BOURNIA
DOCKET NUMBER.....50-373
LICENSE & DATE ISSUANCE...NPF-11, AUGUST 13, 1982
PUBLIC DOCUMENT ROOM.....ILLINOIS VALLEY COMMUNITY COLLEGE
RURAL ROUTE NO. 1
OGLESBY, ILLINOIS 16348

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 19 THROUGH JULY 30, (84-17): ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY RESIDENT INSPECTORS OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MONTHLY SURVEILLANCE; STARTUP TESTING WITNESSING; PLANT TRIPS; POTENTIAL GUARD STRIKE; FOLLOWUP ON REGIONAL REQUESTS; IE BULLETINS; REVIEW OF PERIODIC AND SPECIAL REPORTS, AND LICENSEE EVENT REPORTS. THE INSPECTION INVOLVED A TOTAL OF 279 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS INCLUDING 56 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. IN THE TEN AREAS INSPECTED, ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED (FAILURE TO CONTROL ACCESS TO A HIGH RADIATION AREA).

INSPECTION ON JULY 24-26, (84-19): ROUTINE UNANNOUNCED INSPECTION BY ONE REGIONAL INSPECTOR OF PREVIOUS INSPECTION FINDINGS AND THE STARTUP TESTING AUDIT PROGRAM. THE INSPECTION INVOLVED 23 INSPECTOR-HOURS ONSITE. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

1. Docket: 50-374 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: RANDY S. DUS (815) 357-6761 X324

4. Licensed Thermal Power (MWt): 3323

5. Nameplate Rating (Gross MWe): 1078

6. Design Electrical Rating (Net MWe): 1078

7. Maximum Dependable Capacity (Gross MWe): 1078

8. Maximum Dependable Capacity (Net MWe): 1036

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>3,197.9</u>	<u>3,197.9</u>
13. Hours Reactor Critical	<u>292.6</u>	<u>2,238.4</u>	<u>2,238.4</u>
14. Rx Reserve Shtdwn Hrs	<u>451.4</u>	<u>959.5</u>	<u>959.5</u>
15. Hrs Generator On-Line	<u>237.0</u>	<u>1,941.9</u>	<u>1,941.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>475,310</u>	<u>3,280,800</u>	<u>3,280,800</u>
18. Gross Elec Ener (MWH)	<u>137,874</u>	<u>915,324</u>	<u>915,324</u>
19. Net Elec Ener (MWH)	<u>130,211</u>	<u>860,720</u>	<u>860,720</u>
20. Unit Service Factor			
21. Unit Avail Factor		NOT IN	
22. Unit Cap Factor (MDC Net)		COMMERCIAL	
23. Unit Cap Factor (DER Net)		OPERATION	
24. Unit Forced Outage Rate			
25. Forced Outage Hours	<u>477.2</u>	<u>732.7</u>	<u>732.7</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* LASALLE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

LASALLE 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * LASALLE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
24	07/28/84	S	29.8	B	4				REPAIR STEAM LEAKS ON MOISTURE SEPARATOR REHEATER.
25	08/05/84	F	21.1	G	3				UNAUTHORIZED PERSON INCORRECTLY CONNECTED DVM RESULTING IN A TURBINE TRIP.
26	08/10/84	F	135.6	B	3				CLOSURE OF NO. 1 TURBINE CONTROL VALVE RESULTED IN HIGH REACTOR PRESSURE.
27	08/17/84	F	320.5	A	3				LOSS OF EXCITATION TO U-2 GENERATOR CAUSED A TURBINE TRIP.

 * SUMMARY *

 LASALLE 2 OPERATED WITH 4 OUTAGES AND NO REDUCTIONS DURING THE REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* LASALLE 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....LA SALLE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...11 MI SE OF
OTTAWA, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MARCH 10, 1984
DATE ELEC ENER 1ST GENER...APRIL 20, 1984
DATE COMMERCIAL OPERATE....*****
CONDENSER COOLING METHOD...POND
CONDENSER COOLING WATER...RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....M. JORDAN
LICENSING PROJ MANAGER....A. BOURNIA
DOCKET NUMBER.....50-374
LICENSE & DATE ISSUANCE...NPF-18, MARCH 23, 1984
PUBLIC DOCUMENT ROOM.....ILLINOIS VALLEY COMMUNITY COLLEGE
RURAL ROUTE NO. 1
OGLESBY, ILLINOIS 16348

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 19 THROUGH JULY 30, (84-22): ROUTINE, UNANNOUNCED INSPECTION CONDUCTED BY RESIDENT INSPECTORS OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MONTHLY SURVEILLANCE; STARTUP TESTING WITNESSING; PLANT TRIPS; POTENTIAL GUARD STRIKE; FOLLOWUP ON REGIONAL REQUESTS; IE BULLETINS; REVIEW OF PERIODIC AND SPECIAL REPORTS, AND LICENSEE EVENT REPORTS. THE INSPECTION INVOLVED A TOTAL OF 279 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS INCLUDING 56 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. IN THE TEN AREAS INSPECTED, ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED (FAILURE TO CONTROL ACCESS TO A HIGH RADIATION AREA).

INSPECTION ON JULY 24-26, (84-25): ROUTINE UNANNOUNCED INSPECTION BY ONE REGIONAL INSPECTOR OF PREVIOUS INSPECTION FINDINGS AND THE STARTUP TESTING AUDIT PROGRAM. THE INSPECTION INVOLVED 23 INSPECTOR-HOURS ONSITE. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITF'S

84-46 08/05/84 08/21/84 RWCU ISOLATION-LEAK DETECTION HI AMBIENT TEMP.

84-47 08/05/84 08/21/84 REACTOR SCRAM CAUSED BY VENDOR ERROR.

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-309 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: S. BIEMILLER (617) 827-8100

4. Licensed Thermal Power (MWt): 2630

5. Nameplate Rating (Gross MWe): 864

6. Design Electrical Rating (Net MWe): 825

7. Maximum Dependable Capacity (Gross MWe): 850

8. Maximum Dependable Capacity (Net MWe): 810

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>103,547.6</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,850.4</u>	<u>82,461.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,732.0</u>	<u>79,811.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,936,832</u>	<u>9,095,819</u>	<u>178,207,607</u>
18. Gross Elec Ener (MWH)	<u>635,070</u>	<u>2,972,490</u>	<u>58,325,640</u>
19. Net Elec Ener (MWH)	<u>615,006</u>	<u>2,869,881</u>	<u>55,571,583</u>
20. Unit Service Factor	<u>100.0</u>	<u>63.7</u>	<u>77.1</u>
21. Unit Avail Factor	<u>100.0</u>	<u>63.7</u>	<u>77.1</u>
22. Unit Cap Factor (MDC Net)	<u>102.1</u>	<u>60.5</u>	<u>68.3*</u>
23. Unit Cap Factor (DER Net)	<u>100.2</u>	<u>59.4</u>	<u>66.4*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>2.2</u>	<u>7.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>83.8</u>	<u>5,497.2</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* MAINE YANKEE *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MAINE YANKEE



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * MAINE YANKEE *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
	08/16/84	F	0.0	A	5		RB	INSTRU	REDUCED POWER DURING RECOVERY OF DROPPED CEA.
	08/25/84	S	0.0	B	5		HA	VALVEX	REDUCED POWER FOR ROUTINE TURBINE VALVE TESTING AND MUSSEL CONTROL.

 * SUMMARY *

 MAINE YANKEE OPERATED WITH 2 REDUCTIONS AND NO OUTAGES IN AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* MAINE YANKEE *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MAINE
COUNTY.....LINCOLN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...10 MI N OF
BATH, ME
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 23, 1972
DATE ELEC ENER 1ST GENER...NOVEMBER 8, 1972
DATE COMMERCIAL OPERATE...DECEMBER 28, 1972
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...BACK RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....MAINE YANKEE ATOMIC POWER
CORPORATE ADDRESS.....83 EDISON DRIVE
AUGUSTA, MAINE 04366
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....C. HOLDEN
LICENSING PROJ MANAGER....K. HEITNER
DOCKET NUMBER.....50-309
LICENSE & DATE ISSUANCE...DPR-36, JUNE 29, 1973
PUBLIC DOCUMENT ROOM.....WISCASSET PUBLIC LIBRARY
HIGH STREET
WISCASSET, MAINE 04578

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 3.0.C STATES THAT DURING CONDITION 4 OR HIGHER OPERATING CONDITIONS, TWO POWER SOURCES, NORMAL AND EMERGENCY, ARE REQUIRED TO DETERMINE OPERABILITY. THIS TECHNICAL SPECIFICATIONS PROVIDES THE EXCEPTION THAT IF A SYSTEM, SUBSYSTEM, TRAIN, COMPONENT OR DEVICE IS DETERMINED TO BE INOPERABLE SOLELY BECAUSE ITS NORMAL OR EMERGENCY POWER SOURCE IS OPERABLE, IT MAY BE CONSIDERED OPERABLE FOR THE PURPOSE OF SATISFYING THE REQUIREMENTS OF ITS APPLICABLE LIMITING CONDITION FOR OPERATION, PROVIDED: A) ITS CORRESPONDING NORMAL OR EMERGENCY POWER SOURCE IS OPERABLE AND; B) ALL OF ITS REDUNDANT SYSTEM(S), TRAIN(S), COMPONENT(S) AND DEVICE(S) ARE OPERABLE, OR LIKEWISE SATISFY THE REQUIREMENTS OF THIS SPECIFICATION. CONTRARY TO THIS REQUIREMENT, DIESEL DG1A WAS REMOVED FROM SERVICE ON MARCH 7, 1984, DURING POWER OPERATION WITHOUT VERIFICATION OF THE OPERABILITY OF REDUNDANT EQUIPMENT AND THE REQUIRED REMEDIAL ACTION WAS NOT TAKEN. THIS IS A SEVERITY LEVEL IV VIOLATION (SUPPLEMENT I). DRAFT 6 OF ANS 3.2, OCTOBER 1980 REQUIRES THAT TEMPORARY MODIFICATIONS, SUCH AS ELECTRICAL JUMPERS, LIFTED ELECTRICAL LEADS, AND TEMPORARY TRIP POINT SETTINGS, SHALL BE CONTROLLED BY PROCEDURES WHICH REQUIRE INDEPENDENT VERIFICATION BY EITHER A SECOND PERSON OR A FUNCTIONAL TEST WHICH CONCLUSIVELY PROVES THE PROPER INSTALLATION OR REMOVAL OF THE TEMPORARY MODIFICATION. DRAFT 6 OF ANS 3.2, OCTOBER 1980, FURTHER REQUIRES THAT AFTER PERMISSION HAS BEEN GRANTED TO REMOVE A SYSTEM FROM SERVICE, IT SHALL BE MADE SAFE TO WORK ON. EQUIPMENT AND SYSTEMS IN A CONTROLLED STATUS SHALL BE CLEARLY IDENTIFIED, AT A MINIMUM, AT ANY LOCATION WHERE THE

ENFORCEMENT SUMMARY

EQUIPMENT CAN BE OPERATED. SUPPLEMENTAL PROVISIONS REQUIRE A SECOND QUALIFIED OPERATOR TO VERIFY CORRECT IMPLEMENTATION OF EQUIPMENT CONTROL PROVISIONS SUCH AS TAGGING AND RETURN TO SERVICE. CONTRARY TO THE ABOVE, THE LICENSEE HAS NOT IMPLEMENTED AN ADEQUATE PROGRAM TO VERIFY THE CORRECT PERFORMANCE OF OPERATING ACTIVITIES. SPECIFIC EXAMPLES OF INEFFECTIVE IMPLEMENTATION INCLUDE: - MAINE YANKEE OPERATIONAL SAFEGUARD YELLOW TAG CONTROL LOG, REVISION 5 DATED OCTOBER 27, 1982 DOES NOT REQUIRE INDEPENDENT VERIFICATION OF THE PROPER INSTALLATION OR REMOVAL OF TEMPORARY MODIFICATIONS. - INDEPENDENT VERIFICATION FOR THE RETURN TO SERVICE OF EQUIPMENT IMPORTANT TO SAFETY IS NOT PERFORMED. ONLY "SAFEGUARD" EQUIPMENT AS CONTRASTED WITH SAFETY RELATED IS INCLUDED WITHIN THE SCOPE OF THE LICENSEE'S PROGRAM. SAFEGUARD VALVES ARE ONLY RECHECKED WITHIN ONE WEEK OF CHANGING THEIR POSITION FOLLOWING MONTHLY SURVEILLANCE TEST PROCEDURE 3.1.2. ADDITIONAL EXAMPLES INCLUDE, PROCEDURE STP 3.15, AUXILIARY FEED PUMP TESTING DOES NOT REQUIRE INDEPENDENT VERIFICATION WHEN THE PUMP DISCHARGE VALVE IS CYCLED CLOSED/OPEN. PROCEDURE 1-11-6 FOR THE CHEMICAL AND VOLUME CONTROL SYSTEM DOES NOT REQUIRE INDEPENDENT VERIFICATION OF LOCKED VALVE ARRANGEMENT WHEN REALIGNING A HIGH PRESSURE SAFETY INJECTION PUMP. INSTRUMENTATION PROCEDURES DO NOT REQUIRE INDEPENDENT VERIFICATION WHEN INSTRUMENT AND ROOT-STOP VALVES ARE RETURNED TO SERVICE. - MAINE YANKEE TAGGING RULES, REVISED JANUARY 12, 1984 DO NOT REQUIRE IDENTIFYING EQUIPMENT AND SYSTEMS IN A CONTROLLED STATUS AT ANY LOCATION (E.G., CONTROL ROOM) WHERE THE EQUIPMENT CAN BE OPERATED. THIS IS A SEVERITY LEVEL IV VIOLATION (SUPPLEMENT I).
(8402 4)

TECHNICAL SPECIFICATION 5.8 REQUIRES THAT WRITTEN PROCEDURES FOR MAINE YANKEE SHALL BE ESTABLISHED, IMPLEMENTED AND MAINTAINED COVERING THE APPLICABLE PROCEDURES RECOMMENDED IN APPENDIX "A" OF REGULATORY GUIDE 1.33, NOVEMBER 1972. IN ADDITION TECHNICAL SPECIFICATION 5.8 FURTHER REQUIRES EACH OF THESE PROCEDURES AND CHANGES THERETO, SHALL BE REVIEWED BY THE PORC AND APPROVED BY THE PLANT MANAGER PRIOR TO IMPLEMENTATION. CONTRARY TO THE ABOVE, OPERATIONAL MEMOS PROVIDING OPERATION PROCEDURES AND ANNUNCIATOR PROCEDURES HAVE BEEN ISSUED AND IMPLEMENTED WITHOUT PORC APPROVAL, AND THE "IN-HOUSE ELECTRICAL DISTRIBUTION BOOK" USED FOR TAGGING ELECTRICAL EQUIPMENT IS NOT CONTROLLED NOR IS IT APPROVED BY THE PORC. THIS IS A SEVERITY LEVEL V VIOLATION (SUPPLEMENT I). THE LICENSEE'S QUALITY ASSURANCE PROG. ALSO COMMITS TO ANSI N45.2, 1977 WHICH STATES: "MEASURES SHALL BE ESTABLISHED AND DOCUMENTED TO CONTROL THE ISSUANCE OF DOCU., SUCH AS INSTRUCTIONS, PROCEDURES & DRWNGS, INCL CHANGES THERETO.." IT ALSO STATES IN PART THAT DOCU. CONTROL MEASURES SHALL PROVIDE FOR IDENTIF. OF INDIVIDUALS OR ORGAN. RESPONSIBLE FOR PREPARING, RECVG, APPROVING, & ISSUING DOCUMENTS AND REVISIONS THERETO. LICENSEE PROC. NO. 0-06-2, "PROCEDURE REVIEW, APPROVAL, DISTRIB., & ADHERENCE" STATES IN PART THAT CLASS A PROCEDURES SHALL BE REVIEWED EVERY TWO YEARS. CONTRARY TO ABOVE, ON 3/8/84, THE FOLLOWING DOCUMENTS WERE IDENTIFIED THAT DO NOT COMPLY WITH THE LICENSEE'S COMMITMENTS FOR CONTROLLING CLASS "A" DOCUMENTS. -THE DISTRIBUTION OF A CLASS "A" DOCU. WAS NOT ACCOMPLISHED IN THAT FE'S (CONTROLLED PRINTS FOR IDENTIFYING ELEC LOADS) WERE NOT PROVIDED IN THE CONTROL RM FOR USE IN TAGGING ELEC EQUIP. - A DOCU. USED FOR TAGGING ELEC EQUIP, "IN-HOUSE ELECL. DISTRIB. BOOK" IS NOT CONTROLLED OR APPROVED BY THE PORC OR ANY OTHER ORGANIZ. - THERE IS NO WRITTEN DOCUMENTATION DELINEATING AN INDIV. OR ORGANIZ. RESPONSIBLE FOR REVISING OR REVIEWING "THE TECH. DATA BOOK" WHICH IS USED IN CONJUNCTION WITH THE REACTOR START-UP PROCEDURES, PARTICULARLY, SHEET RE-RS-1.2 WHICH IS THE ESTIMATED CRITICAL POSITION CALCULATION. LACK OF PROCEDURE CONTROL WAS EVIDENCED BY THE INSPECTOR'S IDENTIFICATION OF SEVERAL POCEDURES FOUND IN VARIOUS LOCATIONS WHICH WERE NOT IN USE. THIS IS A SEVERITY LEVEL V VIOLATION (SUPPLEMENT I).
(8402 5)

CONTAINS SAFEGUARDS INFORMATION - NOT FOR PUBLICDISCLOSURE.

(8412 4)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* MAINE YANKEE *

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-369 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-8552

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1305

6. Design Electrical Rating (Net MWe): 1180

7. Maximum Dependable Capacity (Gross MWe): 1225

8. Maximum Dependable Capacity (Net MWe): 1180

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>24,119.0</u>
13. Hours Reactor Critical	<u>708.6</u>	<u>4,083.3</u>	<u>16,611.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>704.5</u>	<u>4,019.9</u>	<u>15,969.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,370,549</u>	<u>13,063,817</u>	<u>40,500,886</u>
18. Gross Elec Ener (MWH)	<u>813,620</u>	<u>4,558,996</u>	<u>14,076,120</u>
19. Net Elec Ener (MWH)	<u>782,638</u>	<u>4,365,134</u>	<u>13,321,389</u>
20. Unit Service Factor	<u>94.7</u>	<u>68.7</u>	<u>66.2</u>
21. Unit Avail Factor	<u>94.7</u>	<u>68.7</u>	<u>66.2</u>
22. Unit Cap Factor (MDC Net)	<u>89.1</u>	<u>63.2</u>	<u>46.8</u>
23. Unit Cap Factor (DER Net)	<u>89.1</u>	<u>63.2</u>	<u>46.8</u>
24. Unit Forced Outage Rate	<u>5.3</u>	<u>5.1</u>	<u>17.1</u>
25. Forced Outage Hours	<u>39.5</u>	<u>214.4</u>	<u>3,299.9</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
REFUELING - FEBRUARY 7, 1985 - 8 WEEKS

27. If Currently Shutdown Estimated Startup Date: N/A

* MCGUIRE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MCGUIRE 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * MCGUIRE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
8	08/21/84	F	39.5	A	3		EA	INSTRU	BREAKERS OF 230KV SWITCHYARD WERE OPENED DURING COMPUTER WORK.
32-P	08/23/84	F	0.0	A	5		HI	HTEXCH	SECONDARY CHEMISTRY REQUIREMENTS.

***** MCGUIRE 1 OPERATED WITH 1 REDUCTION AND 1 OUTAGE DURING AUGUST.
 * SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

* MCGUIRE 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NORTH CAROLINA

COUNTY.....MECKLENBURG

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI N OF
 CHARLOTTE, NC

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...AUGUST 8, 1981

DATE ELEC EMER 1ST GENER...SEPTEMBER 12, 1981

DATE COMMERCIAL OPERATE...DECEMBER 1, 1981

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER...LAKE NORMAN

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
 RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER

CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
 CHARLOTTE, NORTH CAROLINA 28242

CONTRACTOR
ARCHITECT/ENGINEER.....DUKE POWER

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....DUKE POWER

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....W. ORDERS

LICENSING PROJ MANAGER.....R. BIRKEL
DOCKET NUMBER.....50-369

LICENSE & DATE ISSUANCE...NPF-9, JULY 8, 1981

PUBLIC DOCUMENT ROOM.....MS. DAWN HUBBS
 ATKINS LIBRARY
 UNIVERSITY OF NORTH CAROLINA - CHARLOTTE
 UNCC STATION,
 CHARLOTTE, NC 28223

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION MAY 20 - JUNE 20 (84-17): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 122 INSPECTOR-HOURS ON SITE IN THE AREAS OF OPERATIONS SAFETY VERIFICATION, SURVEILLANCE TESTING, MAINTENANCE ACTIVITIES AND OPEN ITEMS REVIEW. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 30 - AUGUST 8 (84-22): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 22.5 INSPECTOR-HOURS ONSITE IN THE AREAS OF INSERVICE INSPECTION-REVIEW AND EVALUATION OF RECORDS; OBSERVATION OF UNIT 2 COOLANT PUMP "2A" NUMBER 1 SEAL REPLACEMENT; AND TWO-INCH DECAY HEAT (ND) PIPE BREAK AND PIPE SUPPORT FAILURES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* MCGUIRE 1 *

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

POWER OPERATIONS.

LAST IE SITE INSPECTION DATE: JULY 30 - AUGUST 8, 1984 +

INSPECTION REPORT NO: 50-369/84-22 +

 R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-018	06/04/84	07/05/84	TRAIN B CHILLER OF CNTL AREA VENTILATION SYS TRIPPED, DUE TO LOW OIL LEVEL
84-020	06/06/84	07/06/84	REACTOR TRIPPED WHEN A SPURIOUS UNDERVOLTAGE RELAY ACTUATION DEENERGIZED 1 OF REACTOR COOLANT PUMPS, COMPONENT MALFUNCTIONED.

=====

1. Docket: 50-370 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS EXT (704) 373-7567

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1450 X .9 = 1305

6. Design Electrical Rating (Net MWe): 1180

7. Maximum Dependable Capacity (Gross MWe): 1225

8. Maximum Dependable Capacity (Net MWe): 1180

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

 NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>4,415.0</u>	<u>4,415.0</u>
13. Hours Reactor Critical	<u>199.0</u>	<u>3,455.3</u>	<u>3,455.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>196.8</u>	<u>3,431.1</u>	<u>3,431.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>614,384</u>	<u>11,296,013</u>	<u>11,296,013</u>
18. Gross Elec Ener (MWH)	<u>217,617</u>	<u>4,017,748</u>	<u>4,017,748</u>
19. Net Elec Ener (MWH)	<u>201,614</u>	<u>3,856,769</u>	<u>3,856,769</u>
20. Unit Service Factor	<u>26.5</u>	<u>77.7</u>	<u>77.7</u>
21. Unit Avail Factor	<u>26.5</u>	<u>77.7</u>	<u>77.7</u>
22. Unit Cap Factor (MDC Net)	<u>23.0</u>	<u>74.0</u>	<u>74.0</u>
23. Unit Cap Factor (DER Net)	<u>23.0</u>	<u>74.0</u>	<u>74.0</u>
24. Unit Forced Outage Rate	<u>73.5</u>	<u>20.7</u>	<u>20.7</u>
25. Forced Outage Hours	<u>547.2</u>	<u>897.3</u>	<u>897.3</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


MAINTENANCE OUTAGE - 12/01/84 - 4 WEEKS

27. If Currently Shutdown Estimated Startup Date: N/A

 * MCGUIRE 2 *

 AVERAGE DAILY POWER LEVEL (MWe) PLOT

MCGUIRE 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * MCGUIRE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
11A	07/29/84	F	181.0	A	4		CB	PUMPXX	REPLACE LEAKING REACTOR COOLANT PUMP SEAL.
11B	08/08/84	F	282.3	A	9		CF	HTEXCH	RESIDUAL HEAT REMOVAL LETDOWN HEAT EXCHANGER PIPE REPAIRS.
11C	08/20/84	F	38.6	A	9		SF	ACCUMU	REACTOR COOLANT SYSTEM LEAK THRU UPPER HEAD INJECTION VENT LINE.
11D	08/21/84	F	30.6	A	3		IA	HTEXCH	REACTOR TRIP FROM MODE 3 ON STEAM GENERATOR LO LO LEVEL (REACTOR NOT CRITICAL).
41-P	08/24/84	F	0.0	A	5		HI	HTEXCH	STEAM GENERATOR CHEMISTRY PROBLEMS.
42-P	08/24/84	F	0.0	A	5		HI	HTEXCH	STEAM GENERATOR CHEMISTRY PROBLEMS.
43-P	08/29/84	F	0.0	A	5		HA	TURBIN	HIGH TURBINE BEARING VIBRATION.
12	08/31/84	F	14.7	G	3		ZZ	ZZZZZZ	TECHNICIAN WORKED ON WRONG CONNECTION DURING PROTECTION CABINET TESTING.

 * SUMMARY *

 MCGUIRE 2 OPERATED WITH 5 OUTAGES AND 3 REDUCTIONS IN AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* MCGUIRE 2 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NORTH CAROLINA
COUNTY.....MECKLENBURG
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI N OF
CHARLOTTE, NC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 8, 1983
DATE ELEC ENER 1ST GENER...MAY 23, 1983
DATE COMMERCIAL OPERATE...MARCH 1, 1984
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE NORMAN
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....POWER BLDG., BOX 2178
CHARLOTTE, NORTH CAROLINA 28201
CONTRACTOR
ARCHITECT/ENGINEER.....DUKE POWER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....W. ORDERS
LICENSING PROJ MANAGER.....R. BIRKEL
DOCKET NUMBER.....50-370
LICENSE & DATE ISSUANCE....NPF-17, MAY 27, 1983
PUBLIC DOCUMENT ROOM.....MS. DAWN HUBBS
ATKINS LIBRARY
UNIVERSITY OF NORTH CAROLINA - CHARLOTTE
UNCC STATION,
CHARLOTTE, NC 28223

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION MAY 20 - JUNE 20 (84-14): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 122 INSPECTOR-HOURS ON SITE IN THE AREAS OF OPERATIONS SAFETY VERIFICATION, SURVEILLANCE TESTING, MAINTENANCE ACTIVITIES AND OPEN ITEMS REVIEW. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 30 - AUGUST 8 (84-19): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 22.5 INSPECTOR-HOURS ONSITE IN THE AREAS OF INSERVICE INSPECTION-REVIEW AND EVALUATION OF RECORDS; OBSERVATION OF UNIT 2 COOLANT PUMP "2A" NUMBER 1 SEAL REPLACEMENT; AND TWO-INCH DECAY HEAT (ND) PIPE BREAK AND PIPE SUPPORT FAILURES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

1. Docket: 50-245 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: GEORGE HARRAN (203) 447-1791 X4194

4. Licensed Thermal Power (Mwt): 2011

5. Nameplate Rating (Gross MWe): 735 X 0.9 = 662

6. Design Electrical Rating (Net MWe): 660

7. Maximum Dependable Capacity (Gross MWe): 684

8. Maximum Dependable Capacity (Net MWe): 654

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>120,599.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,061.2</u>	<u>90,825.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,775.8</u>
15. Hrs Generator On-Line	<u>702.5</u>	<u>3,990.3</u>	<u>88,007.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>26.5</u>
17. Gross Therm Ener (MWH)	<u>1,203,671</u>	<u>7,581,367</u>	<u>160,630,235</u>
18. Gross Elec Ener (MWH)	<u>404,800</u>	<u>2,579,300</u>	<u>53,942,496</u>
19. Net Elec Ener (MWH)	<u>385,280</u>	<u>2,454,541</u>	<u>51,435,798</u>
20. Unit Service Factor	<u>94.4</u>	<u>68.2</u>	<u>73.0</u>
21. Unit Avail Factor	<u>94.4</u>	<u>68.2</u>	<u>73.0</u>
22. Unit Cap Factor (MDC Net)	<u>79.2</u>	<u>64.1</u>	<u>65.2</u>
23. Unit Cap Factor (DER Net)	<u>78.5</u>	<u>63.5</u>	<u>64.6</u>
24. Unit Forced Outage Rate	<u>5.6</u>	<u>1.0</u>	<u>13.5</u>
25. Forced Outage Hours	<u>41.5</u>	<u>41.5</u>	<u>5,715.2</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* MILLSTONE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MILLSTONE 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * MILLSTONE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
4	08/02/84	F	41.5	B	1				REDUCED POWER TO < 1% REACTOR POWER TO ENTER THE DRYWELL TO FIND THE CAUSE OF AN INCREASING DRYWELL LEAK RATE. THE LEAK WAS FOUND TO BE A PACKING LEAK ON THE RECIRCULATION SYSTEM RISER INSTRUMENT VALVE.

 * SUMMARY *

 MILLSTONE 1 OPERATED WITH 1 OUTAGE FOR MAINTENANCE IN AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* MILLSTONE 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....CONNECTICUT
COUNTY.....NEW LONDON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI SW OF
NEW LONDON, CONN
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...OCTOBER 26, 1970
DATE ELEC ENER 1ST GENER...NOVEMBER 29, 1970
DATE COMMERCIAL OPERATE....MARCH 1, 1971
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LONG ISLAND SOUND
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHEAST NUCLEAR ENERGY
CORPORATE ADDRESS.....P.O. BOX 270
HARTFORD, CONNECTICUT 06101

CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....J. SHEDLOSKY
LICENSING PROJ MANAGER.....J. SHEA
DOCKET NUMBER.....50-245
LICENSE & DATE ISSUANCE....DPR-21, OCTOBER 26, 1970
PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LIBRARY
45 ROPE FERRY ROAD
ROUTE 156
WATERFORD, CONNECTICUT 06385

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.11 REQUIRES THAT PROCEDURES SHALL BE ADHERED TO FOR ALL OPERATIONS INVOLVING PERSONNEL RADIATION EXPOSURE. STATION PROCEDURE SHP 4912, RADIATION WORK PERMIT (RWP) COMPLETION AND FLOW CONTROL, REVISION 4, REQUIRES THAT WORKERS ARE RESPONSIBLE FOR UNDERSTANDING AND FOLLOWING RWP INSTRUCTION; THAT A DIFFERENT RWP BE WRITTEN FOR EACH EVOLUTION, EVEN THOUGH THEY OCCUR IN THE SAME AREA; AND THAT HEALTH PHYSICS SIGNIFY THAT ADEQUATE RADIATION CONTROLS HAVE BEEN ESTABLISHED AND ARE (OR WILL BE) IN EFFECT FOR THE RWP. CONTRARY TO THE ABOVE: ON MAY 11, 1984, PERSONNEL PERFORMING CARPENTRY WORK ON SCAFFOLDING IN THE REACTOR BUILDING SOUTHWEST ECCS CORNER ROOM PERFORMED THE WORK UNDER RWP 402788 WHICH HAD BEEN DEVELOPED TO COVER REPLACEMENT OF PIPING SPRING CAN HANGERS BY GRINDING AND WELDING. FURTHER, THE WORKERS DID NOT COMPLY WITH THE PROTECTIVE CLOTHING REQUIREMENTS OF RWP 402788. EIGHT DIFFERENT JOBS INVOLVING RADIOLOGICAL OPERATIONS WERE CONDUCTED UNDER RWP 2103584 FROM MAY 27 THROUGH JUNE 1984. A SEPARATE RWP WAS NOT WRITTEN FOR EACH JOB. THE EIGHT JOBS WERE SUFFICIENTLY UNIQUE TO BE DEEMED AS DIFFERENT "EVOLUTIONS." UNAUTHORIZED ACCESS BY LICENSEE INTO THE PROTECTED AREA.
(8411 4)

1. Docket: 50-336 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: R. BORCHERT (203) 447-1791 X4418

4. Licensed Thermal Power (MWt): 2700

5. Nameplate Rating (Gross MWe): 1011 X 0.9 = 910

6. Design Electrical Rating (Net MWe): 870

7. Maximum Dependable Capacity (Gross MWe): 895

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>76,127.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,731.9</u>	<u>54,096.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,166.9</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,429.1</u>	<u>51,611.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>468.2</u>
17. Gross Therm Ener (MWH)	<u>1,995,846</u>	<u>14,000,111</u>	<u>130,316,487</u>
18. Gross Elec Ener (MWH)	<u>630,800</u>	<u>4,505,001</u>	<u>42,302,373</u>
19. Net Elec Ener (MWH)	<u>607,738</u>	<u>4,327,526</u>	<u>40,544,274</u>
20. Unit Service Factor	<u>100.0</u>	<u>92.7</u>	<u>67.8</u>
21. Unit Avail Factor	<u>100.0</u>	<u>92.7</u>	<u>68.4</u>
22. Unit Cap Factor (MDC Net)	<u>95.0</u>	<u>85.9</u>	<u>63.3*</u>
23. Unit Cap Factor (DER Net)	<u>93.9</u>	<u>85.0</u>	<u>62.5*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>3.1</u>	<u>17.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>173.4</u>	<u>9,796.2</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING & MAINTENANCE OUTAGE: 02/85 - 4 MONTHS

27. If Currently Shutdown Estimated Startup Date: N/A

* M I L L S T O N E 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MILLSTONE 2



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * MILLSTONE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
8	08/02/84	F	0.0	A	5		AA	ROD	WHILE AT 100% POWER AND DURING CEA POWER SUPPLY MEASUREMENT, CEA DROPPED INTO CORE. POWER WAS REDUCED TO < 70% POWER AND CEA WAS RECOVERED.

 * SUMMARY *

 MILLSTONE 2 OPERATED WITH 1 REDUCTION FOR EQUIPMENT FAILURE DURING AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	D-Regulatory Restriction	9-Other	(LER) File (NUREG-0161)
	H-Other		
	E-Operator Training		
	& License Examination		

* MILLSTONE 2 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....CONNECTICUT
COUNTY.....NEW LONDON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI SW OF
NEW LONDON, CONN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 17, 1975
DATE ELEC ENER 1ST GENER...NOVEMBER 9, 1975
DATE COMMERCIAL OPERATE...DECEMBER 26, 1975
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LONG ISLAND SOUND
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHEAST NUCLEAR ENERGY
CORPORATE ADDRESS.....P.O. BOX 270
HARTFORD, CONNECTICUT 06101
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....J. SHEDLOSKY
LICENSING PROJ MANAGER.....D. OSBORNE
DOCKET NUMBER.....50-336
LICENSE & DATE ISSUANCE...DPR-65, SEPTEMBER 30, 1975
PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LIBRARY
45 ROPE FERRY ROAD
ROUTE 156
WATERFORD, CONNECTICUT 06385

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

FAILURE TO PERFORM SEMIANNUAL SURVEILLANCE TESTING ON SMOKE DETECTORS (UNIT 2) TECHNICAL SPECIFICATION (TS) 4.3.3.7.1 REQUIRES THAT FIRE DETECTION INSTRUMENTS SHALL BE DEMONSTRATED OPERABLE ONCE PER 6 MONTHS BY PERFORMANCE OF A CHANNEL FUNCTIONAL TEST. THE LICENSEE COULD NOT PROVIDE THE INSPECTOR WITH DOCUMENTARY EVIDENCE THAT THIS 6 MONTH TESTING FREQUENCY OF THE FIRE DETECTION INSTRUMENTS WAS MAINTAINED DURING THE PERIOD BETWEEN MARCH 83 AND MAY 84. THE INSPECTOR DETERMINED THAT THE 6 MONTH SURVEILLANCE TESTING REQUIRED WAS NOT PERFORMED. THIS IS A VIOLATION OF T.S. 4.3.3.7.1.

SWITCH GEAR BATTERY ROOM A AND B FIRE BARRIER WALLS HAVE UNSEALED PENETRATIONS. 10 CFR 50 APPENDIX R REQUIRES THAT 3 HOUR FIRE BARRIERS SYSTEMS BE INSTALLED AS NECESSARY TO PROTECT REDUNDANT SYSTEMS AND COMPONENTS NECESSARY FOR SAFE SHUT DOWN. CONTRARY TO THE ABOVE, THE 3 HOUR FIRE BARRIER WALLS INSTALLED TO PROTECT THE REDUNDANT SWITCH GEAR BATTERY ROOMS A AND B NECESSARY FOR SAFE SHUT DOWN, CONTAIN UNSEALED PENETRATIONS, THAT DO NOT MEET THE 3 HOUR FIRE RATING. THIS IS A VIOLATION OF APPENDIX R REQUIREMENTS.
(8415 4)

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* MILLSTONE 2 *

ENFORCEMENT SUMMARY

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

1. Docket: 50-263 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: A. L. Myrabo (612) 295-5151

4. Licensed Thermal Power (MWt): 1670

5. Nameplate Rating (Gross MWe): 632 X 0.9 = 569

6. Design Electrical Rating (Net MWe): 545

7. Maximum Dependable Capacity (Gross MWe): 553

8. Maximum Dependable Capacity (Net MWe): 525

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>115,464.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>810.5</u>	<u>89,915.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>940.7</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>808.8</u>	<u>88,003.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>897,898</u>	<u>141,233,814</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>296,117</u>	<u>45,185,053</u>
19. Net Elec Ener (MWH)	<u>-1,274</u>	<u>271,865</u>	<u>43,184,171</u>
20. Unit Service Factor	<u>.0</u>	<u>13.8</u>	<u>76.2</u>
21. Unit Avail Factor	<u>.0</u>	<u>13.8</u>	<u>76.2</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>8.8</u>	<u>71.2</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>8.5</u>	<u>68.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>5.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>1,288.8</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 11/15/84

* MONTICELLO *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MONTICELLO



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* MONTICELLO *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
2	02/03/84	S	744.0	C	4		ZZ	ZZZZZZ	CONTINUATION OF 1984 REFUELING OUTAGE.

* SUMMARY *

MONTICELLO REMAINS SHUTDOWN IN A CONTINUING REFUELING OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* MONTICELLO *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MINNESOTA
COUNTY.....WRIGHT
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI NW OF
MINNEAPOLIS, MINN
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...DECEMBER 10, 1970
DATE ELEC ENER 1ST GENER...MARCH 5, 1971
DATE COMMERCIAL OPERATE...JUNE 30, 1971
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHERN STATES POWER
CORPORATE ADDRESS.....414 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....C. BROWN
LICENSING PROJ MANAGER.....V. ROONEY
DOCKET NUMBER.....50-263
LICENSE & DATE ISSUANCE...DPR-22, JANUARY 9, 1981
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY
MINNEAPOLIS PUBLIC LIBRARY
300 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 17 - JULY 7, (84-12): A ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTOR OF ONSITE REVIEW COMMITTEE; PROCEDURES; RECIRCULATION VESSEL RISER; AND LONG TERM SHUTDOWN. THE INSPECTION INVOLVED A TOTAL OF 60 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR INCLUDING 12 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JUNE 25-29, (84-14): ROUTINE, UNANNOUNCED INSPECTION OF RADIATION PROTECTION ACTIVITIES DURING A MAJOR OUTAGE. ACTIVITIES REVIEWED INCLUDED AUDITS AND APPRAISALS, CHANGES, PLANNING AND PREPARATION, TRAINING AND QUALIFICATION OF NEW PERSONNEL, EXTERNAL EXPOSURE CONTROL, INTERNAL EXPOSURE CONTROL, CONTROL OF RADIOACTIVE MATERIALS AND CONTAMINATION, AND ALARA. ALSO REVIEWED WERE THE STATUS OF CERTAIN NUREG-0737 TASK ITEMS, IE INFORMATION NOTICES, AND LICENSEE ACTION INVOLVING A RADIOACTIVE WASTE SHIPMENT WHICH CONTAINED LIQUID. THE INSPECTION INVOLVED 70 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. OF THE 11 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN TEN AREAS; ONE VIOLATION WAS IDENTIFIED IN THE REMAINING AREA (SOLID RADWASTE CONTAINING FREE STANDING LIQUID).

ENFORCEMENT SUMMARY

10 CFR 30.41 PROHIBITS THE TRANSFER OF BYPRODUCT MATERIAL EXCEPT AS AUTHORIZED THEREIN. TRANSFERS TO NONGOVERNMENTAL TRANSFERORS MUST BE TO PERSONS EITHER EXEMPTED FROM LICENSING REQUIREMENTS OR AUTHORIZED TO RECEIVE SUCH BYPRODUCT MATERIAL UNDER TERMS OF A

1. Docket: 50-220 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: THOMAS W. ROMAN (315) 349-2422

4. Licensed Thermal Power (MWt): 1850

5. Nameplate Rating (Gross MWe): 755 X 0.85 = 642

6. Design Electrical Rating (Net MWe): 620

7. Maximum Dependable Capacity (Gross MWe): 630

8. Maximum Dependable Capacity (Net MWe): 610

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>130,031.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,569.0</u>	<u>89,871.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,204.2</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,506.5</u>	<u>86,994.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>20.2</u>
17. Gross Therm Ener (MWH)	<u>1,353,699</u>	<u>6,064,082</u>	<u>144,158,439</u>
18. Gross Elec Ener (MWH)	<u>442,840</u>	<u>2,021,484</u>	<u>47,653,266</u>
19. Net Elec Ener (MWH)	<u>428,905</u>	<u>1,959,003</u>	<u>46,153,762</u>
20. Unit Service Factor	<u>100.0</u>	<u>59.9</u>	<u>66.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>59.9</u>	<u>66.9</u>
22. Unit Cap Factor (MDC Net)	<u>94.5</u>	<u>54.9</u>	<u>58.2</u>
23. Unit Cap Factor (DER Net)	<u>93.0</u>	<u>54.0</u>	<u>57.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>16.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>12,940.9</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* NINE MILE POINT 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

NINE MILE POINT 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* NINE MILE POINT 1 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

NINE MILE POINT 1 OPERATED ROUTINELY DURING AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* NINE MILE POINT 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEW YORK
COUNTY.....OSWEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...8 MI NE OF
OSWEGO, NY
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...SEPTEMBER 5, 1969
DATE ELEC ENER 1ST GENER...NOVEMBER 9, 1969
DATE COMMERCIAL OPERATE...DECEMBER 1, 1969
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE ONTARIO
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NIAGARA MOHAWK POWER CORP.
CORPORATE ADDRESS.....300 ERIE BOULEVARD WEST
SYRACUSE, NEW YORK 13202
CONTRACTOR
ARCHITECT/ENGINEER.....NIAGARA MOHAWK POWER CORP.
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....S. HUDSON
LICENSING PROJ MANAGER.....R. HERMANN
DOCKET NUMBER.....50-220
LICENSE & DATE ISSUANCE...DPR-63, DECEMBER 26, 1974
PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO
PENFIELD LIBRARY - DOCUMENTS
OSWEGO, NY 13126
(315) 341-2323

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.5.2.8.C REQUIRES THAT ONCE PER SIX MONTHS AUDITS BE PERFORMED UNDER THE COGNIZANCE OF THE SRAB, ENCOMPASSING THE RESULTS OF ALL ACTIONS TAKEN TO CORRECT DEFICIENCIES OCCURING IN FACILITY EQUIPMENT, STRUCTURES, SYSTEMS, OR METHODS OF OPERATIONS THAT EFFECT NUCLEAR SAFETY. CONTRARY TO THE ABOVE, THE SRAB DEFICIENCY AUDIT DATED FEB 13, 1984 PERFORMED TO SATISFY THIS TECHNICAL SPECIFICATION, ONLY ADDRESSED DEFICIENCIES IDENTIFIED IN OTHER SRAB AUDITS. THE AUDIT DID NOT ADDRESS NONCONFORMANCES, AUDIT AND SURVEILLANCE FINDINGS, OCCURENCE REPORTS AND LER'S AND THE CORRECTIVE MAINTENANCE SYSTEM. THIS IS A SEVERITY LEVEL IV VIOLATION (SUPPLEMENT I).
(3409 4)

OTHER ITEMS

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* NINE MILE POINT 1 *

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

1. Docket: 50-338 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: JOAN N. LEE (703) 894-5151 X2527

4. Licensed Thermal Power (MWt): 2775

5. Nameplate Rating (Gross MWe): 947

6. Design Electrical Rating (Net MWe): 907

7. Maximum Dependable Capacity (Gross MWe): 937

8. Maximum Dependable Capacity (Net MWe): 890

9. If Changes Occur Above Since Last Report, Give Reasons:

CHANGES IN GROSS AND NET

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>54,696.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>2,442.3</u>	<u>36,029.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>7.1</u>	<u>2,182.8</u>
15. Hrs Generator Jn-Line	<u>.0</u>	<u>2,420.0</u>	<u>35,081.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>6,596,736</u>	<u>91,652,513</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>2,238,267</u>	<u>29,622,453</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>2,126,605</u>	<u>27,957,819</u>
20. Unit Service Factor	<u>.0</u>	<u>41.3</u>	<u>64.1</u>
21. Unit Avail Factor	<u>.0</u>	<u>41.3</u>	<u>64.1</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>41.0</u>	<u>57.4</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>40.0</u>	<u>56.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>23.7</u>	<u>13.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>752.2</u>	<u>5,320.4</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


FALL MAINTENANCE, 11-23-84 - SCHEDULED 10 DAYS

27. If Currently Shutdown Estimated Startup Date: 09/19/84

* NORTH ANNA 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

NORTH ANNA 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* NORTH ANNA 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-14	05/11/84	S	744.0	C	4				REFUELING OUTAGE CONTINUED THROUGH THE MONTH.

***** NORTH ANNA 1 REMAINS SHUT DOWN FOR REFUELING.
* SUMMARY *

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	L-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

* NORTH ANNA 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....VIRGINIA
COUNTY.....LOUISA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR... 40 MI NW OF
RICHMOND, VA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 5, 1978
DATE ELEC ENER 1ST GENER...APRIL 17, 1978
DATE COMMERCIAL OPERATE...JUNE 6, 1978
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE ANNA
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VIRGINIA ELECTRIC & POWER
CORPORATE ADDRESS.....P.O. BOX 26666
RICHMOND, VIRGINIA 23261

CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....D. JOHNSON
LICENSING PROJ MANAGER.....L. ENGLE
DOCKET NUMBER.....50-338
LICENSE & DATE ISSUANCE...NPF-4, APRIL 1, 1978
PUBLIC DOCUMENT ROOM.....ALDERMAN LIBRARY/MANUSCRIPTS DEPT.
UNIV. OF VIRGINIA/CHARLOTTESVILLE VA 22901
& LOUISA COUNTY COURTHOUSE,
LOUISA, VA 23093

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 19 (84-26): THIS REACTIVE, ANNOUNCED INSPECTION INVOLVED 7.5 INSPECTOR-HOURS ON SITE IN THE AREAS OF FUEL PERFORMANCE, AND FOLLOWUP OF OUTSTANDING ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 6 - AUGUST 5 (84-27): THIS ROUTINE INSPECTION BY THE RESIDENT INSPECTORS INVOLVED 105.5 INSPECTOR-HOURS ONSITE IN THE AREAS OF MAINTENANCE, SURVEILLANCE, REFUELING ACTIVITIES, LICENSEE EVENT REPORTS, ESF WALKDOWNS, OFF-SITE REVIEW ORGANIZATION, FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS AND LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS. OF THE EIGHT AREAS INSPECTED, ONE VIOLATION AND ONE DEVIATION WERE IDENTIFIED IN THE ESF WALKDOWN AREA DISCUSSED IN PARAGRAPH 8.

INSPECTION JULY 12-13 (84-28): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 7 INSPECTOR-HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION AUGUST 6-10 (84-31): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 18 INSPECTOR-HOURS ON SITE (FOUR HOURS ON BACK SHIFT) INSPECTING: SECURITY ORGANIZATION-RESPONSE; PHYSICAL BARRIERS - PROTECTED AREA (PA) AND VITAL AREA (VA); SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; ACCESS CONTROL-PERSONNEL, PACKAGES, AND VEHICLES; DETECTION AIDS - PA AND VA; ALARM STATIONS AND COMMUNICATIONS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.8.1.C REQUIRES THAT WRITTEN PROCEDURES BE ESTABLISHED, IMPLEMENTED, AND MAINTAINED COVERING SURVEILLANCE AND TEST ACTIVITIES OF SAFETY-RELATED EQUIPMENT. CONTRARY TO THE ABOVE, ON JUNE 12, 1984, EMP-P-RT-30 "PROTECTIVE RELAY MAINTENANCE FOR BREAKER 15H2 EMERGENCY SUPPLY TO BUS '1H' AND EMP-P-RT-38" PROTECTIVE RELAY MAINTENANCE FOR BUS '1H' WERE NOT FOLLOWED IN THAT, NUMEROUS STEPS IN THESE PROCEDURES WERE NOT SIGNED AS VERIFIED OR COMPLETED. THE FAILURE OF THE LICENSEE'S AUTHORIZATION AND CONTROL PERSONNEL TO FOLLOW PROCEDURES IS A REPEAT VIOLATION.
(8419 4)

TECHNICAL SPECIFICATION 3.3.3.10(3.3.3.9 - UNIT 2) REQUIRES THAT WITH LESS THAN THE MINIMUM NUMBER OF RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION CHANNELS OPERABLE, FOR REASONS OTHER THAN AN ALARM/TRIP SETPOINT LESS CONSERVATIVE THAN REQUIRED, ACTION 26 OF TABLE 3.3-13 MUST BE TAKEN. THIS REQUIRES 12 HOUR GRAB SAMPLES DURING DISCHARGE. CONTRARY TO THE ABOVE, WITH RM SW 108 INOPERABLE DURING THE PERIOD JULY 2-9, 1984, AND SERVICE WATER BEING DISCHARGED TO LAKE ANNA, THE 12 HOUR GRAB SAMPLES REQUIRED BY ACTION 26 OF TABLE 3.3-13 WERE NOT OBTAINED.
(8427 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

REFUELING.

LAST IE SITE INSPECTION DATE: AUGUST 6-10, 1984 +

INSPECTION REPORT NO: 50-338/84-31 +

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE.			

1. Docket: 52-339 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: JOAN N. LEE (703) 894-5151 X2527

4. Licensed Thermal Power (MWt): 2775

5. Nameplate Rating (Gross MWe): 947

6. Design Electrical Rating (Net MWe): 907

7. Maximum Dependable Capacity (Gross MWe): 939

8. Maximum Dependable Capacity (Net MWe): 890

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>32,567.0</u>
13. Hours Reactor Critical	<u>47.8</u>	<u>4,814.3</u>	<u>24,461.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>14.6</u>	<u>2,254.6</u>
15. Hrs Generator On-Line	<u>47.8</u>	<u>4,714.5</u>	<u>23,992.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>122,483</u>	<u>12,215,461</u>	<u>62,636,491</u>
18. Gross Elec Ener (MWH)	<u>40,335</u>	<u>4,026,505</u>	<u>20,762,872</u>
19. Net Elec Ener (MWH)	<u>38,076</u>	<u>3,812,318</u>	<u>19,664,400</u>
20. Unit Service Factor	<u>6.4</u>	<u>80.5</u>	<u>73.7</u>
21. Unit Avail Factor	<u>6.4</u>	<u>80.5</u>	<u>73.7</u>
22. Unit Cap Factor (MDC Net)	<u>5.8</u>	<u>73.2</u>	<u>67.8</u>
23. Unit Cap Factor (DER Net)	<u>5.6</u>	<u>71.8</u>	<u>66.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>3.1</u>	<u>13.0</u>
25. Forced Outage Hours	<u>.0</u>	<u>148.6</u>	<u>3,596.1</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
SPRING MAINTENANCE: MAY 24, 1985 - 10 DAYS

27. If Currently Shutdown Estimated Startup Date: 10/23/84

* NORTH ANNA 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
NORTH ANNA 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * NORTH ANNA 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
84-34	08/02/84	S	696.2	C	1	006		UNIT 2 RAMPED DOWN DUE TO APPLICATION OF UNQUALIFIED PROTECTIVE COATING ON CONTAINMENT VENTILATION DUCTWORK. UNIT 2 REMAINED OFF LINE FOR SCHEDULED REFUELING OUTAGE. ENDED THIS MONTH WITH UNIT 2 IN MODE 6.

 * SUMMARY *

 NORTH ANNA 2 EXPERIENCED 1 SHUTDOWN IN AUGUST AND REMAINS SHUT DOWN FOR REFUELING.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	H-Other	4-Continued	Data Entry Sheet
	D-Regulatory Restriction	5-Reduced Load	Licensee Event Report
	E-Operator Training & License Examination	9-Other	(LER) File (NUREG-0161)

* NORTH ANNA 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....VIRGINIA

COUNTY.....LOUISA

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI NW OF
RICHMOND, VA

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...JUNE 12, 1980

DATE ELEC ENER 1ST GENER...AUGUST 25, 1980

DATE COMMERCIAL OPERATE...DECEMBER 14, 1980

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER...LAKE ANNA

ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VIRGINIA ELECTRIC & POWER

CORPORATE ADDRESS.....P.O. BOX 26666
RICHMOND, VIRGINIA 23261

CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER

NUC STEAM SYS SUPPLIER...WESTINGHOUSE

CONSTRUCTOR.....STONE & WEBSTER

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II

IE RESIDENT INSPECTOR.....D. JOHNSON

LICENSING PROJ MANAGER.....L. ENGLE
DOCKET NUMBER.....50-339

LICENSE & DATE ISSUANCE...NPF-7, AUGUST 21, 1980

PUBLIC DOCUMENT ROOM.....ALDERMAN LIBRARY/MANUSCRIPTS DEPT.
UNIV. OF VIRGINIA/CHARLOTTESVILLE VA 22901
& LOUISA COUNTY COURTHOUSE,
LOUISA, VA 23093

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 19 (84-26): THIS REACTIVE, ANNOUNCED INSPECTION INVOLVED 7.5 INSPECTOR-HOURS ON SITE IN THE AREAS OF FUEL PERFORMANCE, AND FOLLOWUP OF OUTSTANDING ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 6 - AUGUST 5 (84-27): THIS ROUTINE INSPECTION BY THE RESIDENT INSPECTORS INVOLVED 105.5 INSPECTOR-HOURS ONSITE IN THE AREAS OF MAINTENANCE, SURVEILLANCE, REFUELING ACTIVITIES, LICENSEE EVENT REPORTS, ESF WALKDOWNS, OFF-SITE REVIEW ORGANIZATION, FOLLOWUP OF PREVIOUSLY IDENTIFIED ITEMS AND LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS. OF THE EIGHT AREAS INSPECTED, ONE VIOLATION AND ONE DEVIATION WERE IDENTIFIED IN THE ESF WALKDOWN AREA DISCUSSED IN PARAGRAPH 8.

INSPECTION JULY 12-13 (84-28): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 7 INSPECTOR-HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION AUGUST 6-10 (84-31): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 18 INSPECTOR-HOURS ON SITE (FOUR HOURS ON BACK SHIFT) INSPECTING: SECURITY ORGANIZATION-RESPONSE; PHYSICAL BARRIERS - PROTECTED AREA (PA) AND VITAL AREA (VA); SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; ACCESS CONTROL-PERSONNEL, PACKAGES, AND VEHICLES; DETECTION AIDS - PA AND VA; ALARM STATIONS AND COMMUNICATIONS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

1. Docket: 50-269 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (MWt): 2568

5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934

6. Design Electrical Rating (Net MWe): 887

7. Maximum Dependable Capacity (Gross MWe): 899

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>97,560.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,839.1</u>	<u>70,371.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,822.0</u>	<u>67,211.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,919,527</u>	<u>14,920,393</u>	<u>161,218,425</u>
18. Gross Elec Ener (MWH)	<u>660,700</u>	<u>5,218,490</u>	<u>56,086,720</u>
19. Net Elec Ener (MWH)	<u>629,976</u>	<u>4,990,648</u>	<u>53,156,199</u>
20. Unit Service Factor	<u>100.0</u>	<u>99.4</u>	<u>68.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>99.4</u>	<u>68.9</u>
22. Unit Cap ractor (MDC Net)	<u>98.5</u>	<u>99.1</u>	<u>63.2*</u>
23. Unit Cap Factor (DER Net)	<u>95.5</u>	<u>96.1</u>	<u>61.5*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.6</u>	<u>16.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>35.0</u>	<u>12,080.6</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
REFUELING - OCTOBER 5, 1984 - 7 WEEKS

27. If Currently Shutdown Estimated Startup Date: N/A

* OCONEE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

OCONEE 1



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * OCONEE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
13-P	08/10/84	S	0.0	B	5		CC	VALVEX	CONTROL AND STOP VALVE PT'S.
14-P	08/11/84	S	0.0	F	5		ZZ	ZZZZZ	ECONOMIC DISPATCH REDUCTION.

 * SUMMARY *

 OCONEE 1 OPERATED ROUTINELY IN AUGUST WITH NO SHUTDOWNS REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* OCONEE 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....OCONEE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI W OF
GREENVILLE, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 19, 1973
DATE ELEC ENER 1ST GENER...MAY 6, 1973
DATE COMMERCIAL OPERATE...JULY 15, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE KEOWEE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
CHARLOTTE, NORTH CAROLINA 28242
CONTRACTOR
ARCHITECT/ENGINEER.....DUKE & BECHTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. BRYANT
LICENSING PROJ MANAGER.....H. NICOLARAS
DOCKET NUMBER.....50-269
LICENSE & DATE ISSUANCE...DPR-38, FEBRUARY 6, 1973
PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY
501 W. SOUTH BROAD ST.
WALHALLA, SOUTH CAROLINA 29691

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 16-20 (84-17): THIS ROUTINE UNANNOUNCED INSPECTION ENTAILED 12 INSPECTOR-HOURS ON SITE (SIX HOURS ON BACKSHIFT) INSPECTING: SECURITY ORGANIZATION - PERSONNEL/RESPONSE; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL/ PACKAGES/VEHICLES; DETECTION AIDS - PROTECTED AND VITAL AREAS; ALARM STATION; AND COMMUNICATIONS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 30-AUGUST 3 (84-18): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 11 INSPECTOR-HOURS ON SITE IN THE AREAS OF GASEOUS AND LIQUID WASTE SYSTEMS; RADIOLOGICAL EFFLUENT ACCOUNTABILITY; AND REACTOR COOLANT, SECONDARY WATER, AND RADIOLOGICAL ENVIRONMENTAL TECHNICAL SPECIFICATION REQUIREMENTS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

1. Docket: 50-270 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (MWt): 2568

5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934

6. Design Electrical Rating (Net MWe): 887

7. Maximum Dependable Capacity (Gross MWe): 899

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>87,480.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,855.0</u>	<u>63,168.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,855.0</u>	<u>62,015.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>905,476</u>	<u>14,983,497</u>	<u>147,474,163</u>
18. Gross Elec Ener (MWH)	<u>644,650</u>	<u>5,157,330</u>	<u>50,262,186</u>
19. Net Elec Ener (MWH)	<u>616,022</u>	<u>4,944,195</u>	<u>47,755,764</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>70.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>70.9</u>
22. Unit Cap Factor (MDC Net)	<u>96.3</u>	<u>98.2</u>	<u>63.3*</u>
23. Unit Cap Factor (DER Net)	<u>93.3</u>	<u>95.2</u>	<u>61.6*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>15.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>10,256.1</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
REFUELING - FEBRUARY 28, 1985 - 9 WEEKS

27. If Currently Shutdown Estimated Startup Date: N/A

* OCONEE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
OCONEE 2



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * OCONEE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
10-P	08/03/84	S	0.0	B	5		RB	CONROD	CONTROL ROD DRIVE MOVEMENT PT'S.
11-P	08/10/84	S	0.0	B	5		CC	VALVEX	STOP AND CONTROL VALVE MOVEMENT PT'S.
12-P	08/10/84	S	0.0	F	5		ZZ	ZZZZZZ	ECONOMIC DISPATCH REDUCTION.

 * SUMMARY *

 OCONEE 2 OPERATED ROUTINELY IN AUGUST WITH NO SHUTDOWNS REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	H-Other	4-Continued	Data Entry Sheet
	D-Regulatory Restriction	5-Reduced Load	Licensee Event Report
	E-Operator Training	9-Other	(LER) File (NUREG-0161)
	& License Examination		

* OCONEE 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....OCONEE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI W OF
GREENVILLE, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 11, 1973
DATE ELEC ENER 1ST GENER...DECEMBER 5, 1973
DATE COMMERCIAL OPERATE...SEPTEMBER 9, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE KEOWEE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
CHARLOTTE, NORTH CAROLINA 28242
CONTRACTOR
ARCHITECT/ENGINEER.....DUKE & BECHTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. BRYANT
LICENSING PROJ MANAGER.....H. NICOLARAS
DOCKET NUMBER.....50-270
LICENSE & DATE ISSUANCE...DPR-47, OCTOBER 6, 1973
PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY
501 W. SOUTH BROAD ST.
WALHALLA, SOUTH CAROLINA 29691

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 16-20 (84-16): THIS ROUTINE UNANNOUNCED INSPECTION ENTAILED 11 INSPECTOR-HOURS ON SITE (SIX HOURS ON BACKSHIFT) INSPECTING: SECURITY ORGANIZATION - PERSONNEL/RESPONSE; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL/ PACKAGES/VEHICLES; DETECTION AIDS - PROTECTED AND VITAL AREAS; ALARM STATION; AND COMMUNICATIONS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 30-AUGUST 3 (84-17): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 11 INSPECTOR-HOURS ON SITE IN THE AREAS OF GASEOUS AND LIQUID WASTE SYSTEMS; RADIOLOGICAL EFFLUENT ACCOUNTABILITY; AND REACTOR COOLANT, SECONDARY WATER, AND RADIOLOGICAL ENVIRONMENTAL TECHNICAL SPECIFICATION REQUIREMENTS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* DCONEE 2 *

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

POWER OPERATIONS.

LAST IE SITE INSPECTION DATE: JULY 30 - AUGUST 3, 1984 +

INSPECTION REPORT NO: 50-270/84-17 +

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NONE.			
=====			

1. Docket: 50-287 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (MWt): 2568

5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934

6. Design Electrical Rating (Net MWe): 887

7. Maximum Dependable Capacity (Gross MWe): 899

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>85,127.0</u>
13. Hours Reactor Critical	<u>698.8</u>	<u>3,906.6</u>	<u>60,616.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>695.5</u>	<u>3,867.4</u>	<u>59,450.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,776,953</u>	<u>9,636,403</u>	<u>145,128,966</u>
18. Gross Elec Ener (MWH)	<u>610,600</u>	<u>3,324,570</u>	<u>50,139,164</u>
19. Net Elec Ener (MWH)	<u>582,363</u>	<u>3,171,331</u>	<u>47,738,449</u>
20. Unit Service Factor	<u>93.5</u>	<u>66.1</u>	<u>69.8</u>
21. Unit Avail Factor	<u>93.5</u>	<u>66.1</u>	<u>69.8</u>
22. Unit Cap Factor (MDC Net)	<u>91.0</u>	<u>63.0</u>	<u>65.0*</u>
23. Unit Cap Factor (DER Net)	<u>88.2</u>	<u>61.1</u>	<u>63.3*</u>
24. Unit Forced Outage Rate	<u>6.5</u>	<u>2.1</u>	<u>14.5</u>
25. Forced Outage Hours	<u>48.5</u>	<u>84.3</u>	<u>10,226.3</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* OCONEE 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

OCONEE 3



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * OCONEE 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
12-P	08/11/84	S	0.0	B	5		CC	VALVEX	TURBINE VALVE MOVEMENT PT'S.
5	08/14/84	F	48.5	A	3		PA	VALVEX	FAILED AIR SUPPLY RESULTED INLOW SUCTION PRESSURE ON MAIN FEEDWATER PUMP.

***** OCONEE 3 INCURRED 1 SHUTDOWN IN AUGUST FOR LOW SUCTION ON MAIN FEEDWATER PUMP.
 * SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training & License Examination		

* OCONEE 3 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....OCONEE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI W OF
GREENVILLE, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...SEPTEMBER 5, 1974
DATE ELEC ENER 1ST GENER...SEPTEMBER 18, 1974
DATE COMMERCIAL OPERATE...DECEMBER 16, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE KEOWEE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY
LICENSEE.....DUKE POWER
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET
CHARLOTTE, NORTH CAROLINA 28242

CONTRACTOR
ARCHITECT/ENGINEER.....DUKE & BECHTEL
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX
CONSTRUCTOR.....DUKE POWER
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....J. BRYANT
LICENSING PROJ MANAGER....H. NICOLARAS
DOCKET NUMBER.....50-287
LICENSE & DATE ISSUANCE...DPR-55, JULY 19, 1974
PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY
501 W. SOUTH BROAD ST.
WALHALLA, SOUTH CAROLINA 29691

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 30-AUGUST 3 (84-15): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 10 INSPECTOR-HOURS ON SITE IN THE AREAS OF GASEOUS AND LIQUID WASTE SYSTEMS; RADIOLOGICAL EFFLUENT ACCOUNTABILITY; AND REACTOR COOLANT, SECONDARY WATER, AND RADIOLOGICAL ENVIRONMENTAL TECHNICAL SPECIFICATION REQUIREMENTS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 16-20 (84-19): THIS ROUTINE UNANNOUNCED INSPECTION ENTAILED 11 INSPECTOR-HOURS ON SITE (SIX HOURS ON BACKSHIFT) INSPECTING: SECURITY ORGANIZATION - PERSONNEL/RESPONSE; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL/ PACKAGES/VEHICLES; DETECTION AIDS - PROTECTED AND VITAL AREAS; ALARM STATION; AND COMMUNICATIONS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

1. Docket: 50-219 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: JOSEPH R. MOLNAR (609) 971-4699

4. Licensed Thermal Power (MWt): 1930

5. Nameplate Rating (Gross MWe): 722 X .9 = 650

6. Design Electrical Rating (Net MWe): 650

7. Maximum Dependable Capacity (Gross MWe): 650

8. Maximum Dependable Capacity (Net MWe): 620

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>128,783.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>696.0</u>	<u>85,319.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>468.2</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>82,693.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>136,301,260</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>46,056,905</u>
19. Net Elec Ener (MWH)	<u>-3,127</u>	<u>-15,877</u>	<u>44,269,806</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>64.2</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>64.2</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>55.8*</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>52.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>11.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>8,916.8</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 09/30/84

* OYSTER CREEK 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

OYSTER CREEK 1



AUGUST 1984

* Item calculated with a Weighted Average

PAGE 2-210

Report period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* OYSTER CREEK 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
31	02/11/83	S	744.0	C	4		ZZ	ZZZZZZ	REFUELING AND MAINTENANCE DUTAGE CONTINUES.

* SUMMARY *

OYSTER CREEK WAS SHUT DOWN FOR REFUELING THROUGHOUT ALL OF AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	G-Oper Error	3-Auto Scram	Preparation of
	C-Refueling	4-Continued	Data Entry Sheet
	H-Other	5-Reduced Load	Licensee Event Report
	D-Regulatory Restriction	9-Other	(LER) File (NUREG-0161)
	E-Operator Training		
	& License Examination		

* OYSTER CREEK 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEW JERSEY
COUNTY.....OCEAN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9 MI S OF
TOMS RIVER, NJ
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MAY 3, 1969
DATE ELEC ENER 1ST GENER...SEPTEMBER 23, 1969
DATE COMMERCIAL OPERATE...DECEMBER 1, 1969
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER....BARNEGAT BAY
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....GPU NUCLEAR CORPORATION
CORPORATE ADDRESS.....100 INTERPACE PARKWAY
PARSIPPANY, NEW JERSEY 07054
CONTRACTOR
ARCHITECT/ENGINEER.....BURNS & ROE
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BURNS & ROE
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....C. COWGILL
LICENSING PROJ MANAGER.....J. LOMBARDO
DUCKET NUMBER.....50-219
LICENSE & DATE ISSUANCE....DPR-16, AUGUST 1, 1969
PUBLIC DOCUMENT ROOM.....OCEAN COUNTY LIBRARY
101 WASHINGTON STREET
TOMS RIVER, NEW JERSEY 08753

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

I N S P E C T I O N S T A T U S

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* O Y S T E R C R E E K 1 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NO INPUT PROVIDED.			

=====

1. Docket: 50-255 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: A. F. DIENES (616) 764-8913

4. Licensed Thermal Power (MWt): 2530

5. Nameplate Rating (Gross MWe): 955 X 0.85 = 812

6. Design Electrical Rating (Net MWe): 805

7. Maximum Dependable Capacity (Gross MWe): 675

8. Maximum Dependable Capacity (Net MWe): 635

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>111,350.0</u>
13. Hours Reactor Critical	<u>216.8</u>	<u>363.5</u>	<u>59,623.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>207.3</u>	<u>226.0</u>	<u>56,504.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>166,704</u>	<u>176,520</u>	<u>115,536,744</u>
18. Gross Elec Ener (MWH)	<u>46,320</u>	<u>48,780</u>	<u>35,799,220</u>
19. Net Elec Ener (MWH)	<u>37,928</u>	<u>39,370</u>	<u>33,667,384</u>
20. Unit Service Factor	<u>27.9</u>	<u>3.9</u>	<u>50.7</u>
21. Unit Avail Factor	<u>27.9</u>	<u>3.9</u>	<u>50.7</u>
22. Unit Cap Factor (MDC Net)	<u>8.0</u>	<u>1.1</u>	<u>47.6</u>
23. Unit Cap Factor (DER Net)	<u>6.3</u>	<u>.8</u>	<u>37.6</u>
24. Unit Forced Outage Rate	<u>72.1</u>	<u>71.1</u>	<u>32.5</u>
25. Forced Outage Hours	<u>536.7</u>	<u>554.7</u>	<u>13,080.3</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>NONE</u>			

27. If Currently Shutdown Estimated Startup Date: 09/02/84

* PALISADES *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PALISADES



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* PALISADES *

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
3	08/04/84	F	23.3	A	3			LOSS OF TURBINE EHC DUE TO A FAILED FITTING.
4	08/10/84	F	513.4	A	1	84-16		FAILED WELD ON PCS INSTRUMENT LINE.

* SUMMARY *

THERE WERE 2 SHUTDOWNS AT PALISADES IN AUGUST AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

* PALISADES *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MICHIGAN
COUNTY.....VANBUREN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S OF
SOUTH HAVEN, MI
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 24, 1971
DATE ELEC ENER 1ST GENER...DECEMBER 31, 1971
DATE COMMERCIAL OPERATE....DECEMBER 31, 1971
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER....LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....EAST CENTRAL AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CONSUMERS POWER
CORPORATE ADDRESS.....212 WEST MICHIGAN AVENUE
JACKSON, MICHIGAN 49201
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....B. JORGENSEN
LICENSING PROJ MANAGER.....W. PAULSON
DOCKET NUMBER.....50-255
LICENSE & DATE ISSUANCE....DPR-20, OCTOBER 16, 1972
PUBLIC DOCUMENT ROOM.....KALAMAZOO PUBLIC LIBRARY
315 SOUTH ROSE STREET
REFERENCE DEPARTMENT
KALAMAZOO, MICHIGAN 49007

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MAY 29 THROUGH JULY 13, (84-10): ROUTINE, UNANNOUNCED INSPECTION BY RESIDENT AND REGION III INSPECTORS OF LICENSEE ACTIONS ON PREVIOUSLY IDENTIFIED ITEMS; PLANT SAFETY; WORK ACTIVITIES, TESTING ACTIVITIES; AND INDEPENDENT INSPECTION AREAS. THE INSPECTION INVOLVED A TOTAL OF 240 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS INCLUDING 44 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. OF THE FIVE AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN FOUR AREAS; ONE ITEM OF NONCOMPLIANCE (FAILURE TO FOLLOW PROCEDURES) WAS IDENTIFIED IN THE REMAINING AREA.

INSPECTION ON JULY 11 AND 12, (84-13): CORRECTIVE ACTION TAKEN ON LICENSEE EVENT REPORT RELATIVE TO THE CABLES DAMAGED DUE TO EXCESSIVELY HIGH TEMPERATURE. THE INSPECTION INVOLVED A TOTAL OF 24 INSPECTION HOURS BY TWO NRC INSPECTORS. NO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.8.1.A, BY REFERENCE TO APPENDIX "A" OF REGULATORY GUIDE 1.33, REQUIRES IMPLEMENTATION OF WRITTEN ADMINISTRATIVE PROCEDURES COVERING EQUIPMENT CONTROL. PLANT ADMINISTRATIVE PROCEDURE 4.02 "CONTROL OF EQUIPMENT STATUS" STIPULATES OPERATORS PERFORMING CHECKLISTS SHALL DOCUMENT DISCOVERY OF SPECIFIED ABNORMAL CONDITIONS INCLUDING MISSING TAGS. CONTRARY TO THE ABOVE, THE INSPECTORS IDENTIFIED FIVE INSTANCES EACH ON CHECKLISTS 3.7 "ENGINEERED SAFEGUARDS SYSTEM CHECKLIST -

1. Docket: 50-277 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: W. M. Alden (215) 841-5022

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1051

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>89,063.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>2,583.9</u>	<u>62,283.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>2,544.8</u>	<u>60,556.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>7,865,391</u>	<u>178,420,001</u>
18. Gross Elec Ensr (MWH)	<u>0</u>	<u>2,547,570</u>	<u>58,718,660</u>
19. Net Elec Ener (MWH)	<u>-5,923</u>	<u>2,442,181</u>	<u>56,278,611</u>
20. Unit Service Factor	<u>.0</u>	<u>43.5</u>	<u>68.0</u>
21. Unit Avail Factor	<u>.0</u>	<u>43.5</u>	<u>68.0</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>39.7</u>	<u>60.1</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>39.2</u>	<u>59.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.4</u>	<u>12.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>116.4</u>	<u>8,628.6</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): NONE

27. If Currently Shutdown Estimated Startup Date: 12/31/84

 * PEACH BOTTOM 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PERCH BOTTOM 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* PEACH BOTTOM 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
5	04/27/84	S	744.0	C	4		RC - FUELXX		SHUTDOWN FOR ITS SIXTH REFUELING OUTAGE.

* SUMMARY *

PEACH BOTTOM 2 REMAINS SHUTDOWN FOR REFUELING

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	G-Oper Error	3-Auto Scram	Preparation of
	C-Refueling	4-Continued	Data Entry Sheet
	H-Other	5-Reduced Load	Licensee Event Report
	D-Regulatory Restriction	9-Other	(LER) File (NUREG-0161)
	E-Operator Training & License Examination		

* PEACH BOTTOM 2 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....YORK
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...19 MI S OF
LANCASTER, PA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...SEPTEMBER 16, 1973
DATE ELCC ENER 1ST GENER...FEBRUARY 18, 1974
DATE COMMERCIAL OPERATE....JULY 5, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER....SUSQUEHANNA RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PHILADELPHIA ELECTRIC
CORPORATE ADDRESS.....2301 MARKET STREET
PHILADELPHIA, PENNSYLVANIA 19105
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....A. BLOUGH
LICENSING PROJ MANAGER....G. GEARS
DOCKET NUMBER.....50-277
LICENSE & DATE ISSUANCE...DPR-44, DECEMBER 14, 1973
PUBLIC DOCUMENT ROOM.....GOVERNMENT PUBLICATIONS SECTION
STATE LIBRARY OF PENNSYLVANIA
FORUM BUILDING
COMMONWEALTH AND WALNUT STREET
HARRISBURG, PENNSYLVANIA 17105

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

INADEQUATE CORRECTIVE ACTIONS FOR NONCONFORMANCES IN MECHANICAL OUTDOOR STORAGE AND ENGINEERING REVIEW REQUEST PROGRAMS.
(8414 4)

CONTRARY TO T.S.6.8, REG GUIDE 1.33, AND PROCEDURE HPO/CO-100, ON MAY 16, 1984, THREE FIRE BARRIER SEALS IN THE REACTOR BUILDING
165-FOOT ELEVATION HAD REMOVABLE SURFACE CONTAMINATION OF 1700 TO 23,000 DPM/100 CM2 AND WERE NOT POSTED WITH "CONTAMINATED AREA"
SIGNS OR A RADIATION TAPE BARRIER LINE.

(8415 4)

APPENDIX A TO LICENSE NOS. OPR-44 AND DPR-56, TECHNICAL SPECIFICATION SECTION 6.11, REQUIRES THAT PROCEDURES FOR PERSONNEL
RADIATION PROTECTION SHALL BE APPROVED, MAINTAINED AND ADHERED TO FOR ALL OPERATORS. CONTRARY TO THE ABOVE REQUIREMENTS, WRITTEN

OTHER ITEMS

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-278 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: W. M. Alden (215) 841-5022

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1035

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):


11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>84,959.0</u>
13. Hours Reactor Critical	<u>696.8</u>	<u>4,964.8</u>	<u>61,764.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>684.3</u>	<u>4,894.4</u>	<u>60,210.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,176,104</u>	<u>15,542,487</u>	<u>176,580,792</u>
18. Gross Elec Ener (MWH)	<u>721,700</u>	<u>5,174,020</u>	<u>57,989,140</u>
19. Net Elec Ener (MWH)	<u>696,707</u>	<u>5,008,311</u>	<u>55,672,096</u>
20. Unit Service Factor	<u>92.0</u>	<u>83.6</u>	<u>70.9</u>
21. Unit Avail Factor	<u>92.0</u>	<u>83.6</u>	<u>70.9</u>
22. Unit Cap Factor (MDC Net)	<u>90.5</u>	<u>82.6</u>	<u>63.3</u>
23. Unit Cap Factor (DER Net)	<u>87.9</u>	<u>80.3</u>	<u>61.5</u>
24. Unit Forced Outage Rate	<u>8.0</u>	<u>13.2</u>	<u>7.8</u>
25. Forced Outage Hours	<u>59.7</u>	<u>747.1</u>	<u>5,078.0</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>NONE</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

* PEACH BOTTOM 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PERCH BOTTOM 3



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* PEACH BOTTOM 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
7	08/21/84	F	59.7	A	3		CH	INSTRU	LOW REACTOR WATER LEVEL CAUSED BY MALFUNCTION IN FEEDWATER CONTROL CIRCUIT.

* SUMMARY *

PEACH BOTTOM 2 EXPERIENCED 1 SHUTDOWN I-4 AUGUST FOR LOW REACTOR WATER LEVEL.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* PEACH BOTTOM 3 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....YORK
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...19 MI S OF
LANCASTER, PA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...AUGUST 7, 1974
DATE ELEC ENER 1ST GENER...SEPTEMBER 1, 1974
DATE COMMERCIAL OPERATE...DECEMBER 23, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...SUSQUEHANNA RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PHILADELPHIA ELECTRIC
CORPORATE ADDRESS.....2301 MARKET STREET
PHILADELPHIA, PENNSYLVANIA 19105
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

E REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....A. BLOUGH
LICENSING PROJ MANAGER.....G. GEARS
DOCKET NUMBER.....50-278
LICENSE & DATE ISSUANCE...DPR-56, JULY 2, 1974
PUBLIC DOCUMENT ROOM.....GOVERNMENT PUBLICATIONS SECTION
STATE LIBRARY OF PENNSYLVANIA
FORUM BUILDING
COMMONWEALTH AND WALNUT STREET
HARRISBURG, PENNSYLVANIA 17105

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

INADEQUATE CORRECTIVE ACTIONS FOR NONCONFORMANCES IN MECHANICAL OUTDOOR STORAGE AND ENGINEERING REVIEW REQUEST PROGRAMS.
(8412 4)

APPENDIX A TO LICENSE NOS. DPR-44 AND DPR-56, TECHNICAL SPECIFICATION SECTION 6.11, REQUIRES THAT PROCEDURES FOR PERSONNEL RADIATION PROTECTION SHALL BE APPROVED, MAINTAINED AND ADHERED TO FOR ALL OPERATORS. CONTRARY TO THE ABOVE REQUIREMENTS, WRITTEN PROCEDURES WERE NOT APPROVED AND MAINTAINED FOR OPERATION OF WHOLE BODY COUNTING SYSTEMS. THE MOVING FED SYSTEM AND ASSOCIATED SOFTWARE WAS PLACED IN SERVICE ON 2-10-84 AND THE STAND UP SYSTEM AND ASSOCIATED SOFTWARE WAS PLACED IN SERVICE ON 5-7-84.
(8414 5)

10 CFR 50, APPENDIX B, CRITERION XVI, "CORRECTIVE ACTION" REQUIRES THAT MEASURES BE ESTABLISHED TO ASSURE THAT CONDITIONS ADVERSE TO QUALITY ARE PROMPTLY IDENTIFIED AND CORRECTED AND IN THE CASE OF SIGNIFICANT CONDITIONS ADVERSE TO QUALITY, THE MEASURES ARE

ENFORCEMENT SUMMARY

REQUIRED TO ASSURE THAT THE CORRECTIVE ACTION PRECLUDES REPETITION. PEACH BOTTOM QUALITY ASSURANCE PLAN, VOLUME III, PROGRAM SECTION, PARAGRAPH 16.1, "CORRECTIVE ACTION" STATES, IN PART, THAT "MEASURES BE ESTABLISHED TO ASSURE THAT CONDITIONS ADVERSE TO QUALITY ARE PROMPTLY IDENTIFIED AND CORRECTED." PECO DEFINES CONDITIONS ADVERSE TO QUALITY AS "...NONCONFORMANCES TO SPECIFIED REQUIREMENTS." CONTRARY TO THE ABOVE, AS OF MAY 18, 1984, NONCONFORMANCES HAD NOT BEEN CORRECTED THAT HAD BEEN IDENTIFIED IN QUALITY ASSURANCE AUDIT REPORT AP83-40PR DATED JANUARY 26, 1984, AND PREVIOUSLY IN NONCONFORMANCE REPORT NCR A82-37-01 DATED DECEMBER 15, 1982, REGRADING FAILURE TO REVIEW MAINTENANCE ADMINISTRATIVE PROCEDURES AT THE PRECIBED PERIODICITY. 10 CFR 50, APPENDIX B, CRITERION XI, "TEST CONTROL" REQUIRES THAT MEASURES BE ESTABLISHED TO ASSURE THAT TESTING REQUIRED TO DEMONSTRATE THAT STRUCTURES, SYSTEMS, AND COMPONENTS WILL PERFORM SATISFACTORILY IN SERVICE IS PERFORMED IN ACCORDANCE WITH WRITTEN TEST PROCEDURES WHICH INCORPORATE THE REQUIREMENTS AND ACCEPTANCE LIMITS. PEACH BOTTOM QUALITY ASSURANCE PLAN, VOLUME III, PROGRAM SECTION, PARAGRAPH 11.1 STATES, IN PART, THAT TESTING SHALL BE PERFORMED IN ACCORDANCE WITH WRITTEN TEST PROCEDURES WHICH INCORPORATE OR REFERENCE ACCEPTANCE LIMITS CONTAINED IN DESIGN DOCUMENTS. THE ACTIVITIES SECTION OF THAT PLAN, PARAGRAPH 11.4 STATES THAT PROCEDURES SHALL BE DESIGNED TO PERMIT EVALUATION OF THE SYSTEM'S OR COMPONENT'S PERFORMANCE. CONTRARY TO THE ABOVE, SURVEILLANCE TEST PROCEDURES ST 12.15.1-3, ST 12.15.3-3 AND ST 12.15.-3 WHICH PARTIALLY IMPLEMENT TECHNICAL SPECIFICATION 6.14 WHICH REQUIRES A PROGRAM TO REDUCE LEAKAGE OF POTENTIALLY HIGHLY RADIOACTIVE FLUIDS FROM SYSTEMS OUTSIDE CONTAINMENT CONTAIN NEITHER ACCEPTANCE CRITERIA NOR THE DATA ON WHICH THE EVALUATION OF THE SYSTEM'S OR COMPONENT'S PERFORMANCE CAN BE EVALUATED.
(8415 5)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

1. Docket: 50-293 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: P. HAMILTON (617) 746-7905

4. Licensed Thermal Power (MWt): 1998

5. Nameplate Rating (Gross MWe): 780 X 0.87 = 678

6. Design Electrical Rating (Net MWe): 655

7. Maximum Dependable Capacity (Gross MWe): 690

8. Maximum Dependable Capacity (Net MWe): 670

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>102,815.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>69,733.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>67,521.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>.0</u>	<u>.0</u>	<u>116,932,632</u>
18. Gross Elec Ener (MWH)	<u>.0</u>	<u>.0</u>	<u>39,228,314</u>
19. Net Elec Ener (MWH)	<u>.0</u>	<u>.0</u>	<u>37,693,409</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>65.7</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>65.7</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>54.7</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>56.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>9.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>6,842.5</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 10/16/84

* PILGRIM 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PILGRIM 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* PILGRIM 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
16	12/10/83	S	744.0	C	4				SHUTDOWN FOR REFUELING AND RECIRCULATION PIPE REPLACEMENT.

* SUMMARY *

PILGRIM 1 REMAINS SHUT DOWN FOR REFUELING AND RECIRCULATION PIPING REPLACEMENT.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* PILGRIM 1 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MASSACHUSETTS
COUNTY.....PLYMOUTH
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...4 MI SE OF
PLYMOUTH, MASS
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JUNE 16, 1972
DATE ELEC ENER 1ST GENER...JULY 19, 1972
DATE COMMERCIAL OPERATE....DECEMBER 1, 1972
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER....CAPE COD BAY
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....BOSTON EDISON
CORPORATE ADDRESS.....800 BOYLSTON STREET
BOSTON, MASSACHUSETTS 02199
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....J. JOHNSON
LICENSING PROJ MANAGER.....P. LEECH
DOCKET NUMBER.....50-293
LICENSE & DATE ISSUANCE....DPR-35, SEPTEMBER 15, 1972
PUBLIC DOCUMENT ROOM.....PLYMOUTH PUBLIC LIBRARY
11 NORTH STREET
PLYMOUTH, MASSACHUSETTS 02360

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

FAILURE TO CONTAIN FALLING SLAG IN ACCORDANCE WITH LICENSEE'S PROCEDURE 1.5.5
(8411 4)

TECHNICAL SPECIFICATION 6.8 STATES "WRITTEN PROCEDURES AND ADMINISTRATIVE POLICIES SHALL BE ESTABLISHED, IMPLEMENTED AND MAINTAINED THAT MEET OR EXCEED THE REQUIREMENTS AND RECOMMENDATIONS OF SECTION 5.1 AND 5.3 OF ANSI N18.7 - 1972 AND APPENDIX "A" OF UNSRC REGULATORY GUIDE 1.33" TECHNICAL SPECIFICATION 6.8.B STATES "EACH PROCEDURE...AND CHANGES THERETO, SHALL BE REVIEWED BY THE ORC AND APPROVED BY THE ORC CHAIRMAN PRIOR TO IMPLEMENTATION". CONTRARY TO THE ABOVE, THE LICENSEE HAS USED THREE CONTRACTOR PROCEDURES DURING 1984, AND THE PROCEDURES HAVE NOT BEEN REVIEWED BY THE ORC (OPERATING REVIEW COMMITTEE) AND NEITHER HAVE THEY BEEN APPROVED BY THE ORC CHAIRMAN. THIS IS A SEVERITY LEVEL IV VIOLATION (SUPPLEMENT V). 10 CFR 71.12 (C) REQUIRES THAT A PERSON USING A PACKAGE TO TRANSPORT LICENSED MATERIAL MUST HAVE A COY OF THE CERTIFICATE OF COMPLIANCE, AND THE PERSON MUST ALSO COMPLY WITH THE CONDITIONS OF THE CERTIFICATE. CERTIFICATE OF COMPLIANCE NO. 6601, REVISION NO. 13, CONDITION 5(B)(2), REQUIRES THAT THE DECAY HEAT LOAD NOT EXCEED 40. CONTRARY TO THE ABOVE, THE LICENSEE DID NOT DETERMINE THE DECAY HEAT LOAD OF A PACKAGE OF 118 CURIES OF LICENSED MATERIAL SHIPPED ON FEBRUARY 10, 1984, HAVING THE CERTIFICATE OF COMPLIANCE NO. 6601. CONDITION 10 OF

ENFORCEMENT SUMMARY

CERTIFICATE OF COMPLIANCE 6601, REVISION 26.13 STATES, "FOR ALL PACKAGES CONTAINING RESIDUAL WATER OR OTHER SUBSTANCES WHICH COULD RADIOLYTICALLY GENERATE COMBUSTIBLE GASES, A DETERMINATION MUST BE MADE BY TEST AND MEASUREMENTS OF A REPRESENTATIVE PACKAGE SUCH THAT THE FOLLOWING CRITERIA ARE MET OVER A PERIOD OF TIME THAT IS TWICE THE EXPECTED SHIPMENT TIME: (I) THE HYDROGEN GENERATED MUST BE LIMITED TO A MOLAR QUANTITY THAT WOULD BE NO MORE THAN 5% BY VOLUME (OR EQUIVALENT LIMITS FOR OTHER IMFLAMMABLE GASES) OF THE SECONDARY CONTAINER GAS VOID IF PRESENT AT STP (I.E., NO MORE THAN 0.063G-MOLAS/3 FT AT 14.7 PSIA AND 70 F); OR (II) THE SECONDARY CONTAINER AND CAST CAVITY MUST BE INERTED WITH A DILUENT TO ASSURE THAT OXYGEN SHALL BE LIMITED TO 5% BY VOLUME IN THOSE PORTIONS OF THE PACKAGE WHICH COULD HAVE HYDROGEN GREATER THAN 5%. FOR PACKAGES TO BE DELIVERED TO A CARRIER FOR TRANSPORT, THE SECONDARY CONTAINER MUST BE PREPARED FOR SHIPMENT IN SAME WAY IN WHICH DETERMINATION FOR GAS GENERATION IS MADE.... CONTRARY TO THE ABOVE, ON FEBRUARY 10, 1984, THE LICENSEE USED PACKAGE MODEL NO. CNSI 8-120, CERTIFICATE OF COMPLIANCE 6601, TO TRANSPORT 118 CURIES OF LICENSED MATERIAL TO BARNWELL, SOUTH CAROLINA, AND THE LICENSEE DID NOT DETERMINE BY TESTS OR MEASUREMENTS THAT THE CRITERIA DESCRIBED ABOVE WERE MET. THIS IS A SEVERITY LEVEL IV VIOLATION (SUPPLEMENT V). (8413 4)

10 CFR 71.101(B) REQUIRES EACH LICENSEE TO ESTABLISHED A QUALITY ASSURANCE PROGRAM FOR PACKAGES... 10 CFR 71.101 (F) STATES THAT A COMMISSION APPROVED QUALITY ASSURANCE PROGRAM THAT SATISFIED THE APPLICABLE CRITERIA OF APPENDIX B OF PART 50 OF THIS CHAPTER, AND WHICH IS ESTABLISHED, MAINTAINED, AND EXECUTED WITH REGARD TO TRANSPORT PACKAGES WILL BE ACCEPTED AS SATISFYING THE REQUIREMENTS OF PARAGRAPH (B) OF THIS SECTION. CRITERIA II, APPENDIX B OF PART 50 OF THE LICENSEE'S PREVIOUSLY APPROVED PROGRAM REQUIRES THAT THE LICENSEE IDENTIFY THE STRUCTURES, SYSTEMS, AND COMPONENTS TO BE COVERED BY THE QUALITY ASSURANCE PROGRAM. CONTRARY TO THE ABOVE, AS OF APRIL 27, 1984, THE LICENSEE HAS NOT IDENTIFIED TRANSPORT PACKAGES AS A STRUCTURE, SYSTEM, OR COMPONENT TO BE COVERED BY THE QUALITY ASSURANCE PROGRAM. THIS IS A SEVERITY LEVEL V VIOLATION (SUPPLEMENT V). (8415 5)

10 CFR 19.12, "INSTRUCTIONS TO WORKERS", REQUIRES THAT "ALL INDIVIDUALS WORKING IN OR FREQUENTING ANY PORTION OF A RESTRICTED AREA SHALL BE KEPT INFORMED OF THE STORAGE, TRANSFER, OR USE OF RADIOACTIVE MATERIALS OR OF RADIATION IN SUCH PORTIONS OF THE RESTRICTED AREA; SHALL BE INSTRUCTED IN THE HEALTH PROTECTION PROBLEMS ASSOCIATED WITH EXPOSURE TO SUCH RADIOACTIVE MATERIALS OR RADIATION, IN PRECAUTIONS OR PROCEDURES TO MINIMIZE EXPOSURE, AND IN THE PURPOSES AND FUNCTIONS OF PROTECTIVE DEVICES EMPLOYED". CONTRARY TO THE ABOVE: ON MAY 7, 1984, THE LICENSEE FAILED TO ADEQUATELY INFORM A WORKER OF THE PRESENCE AND EXTENT OF RADIOACTIVE CONTAMINATION AND RADIATION IN THE "A" RESIDUAL HEAT REMOVAL (RHR) QUADRANT. THE WORKER WAS NOT ADVISED TO USE RESPIRATORY PROTECTIVE EQUIPMENT AND PLASTIC PROTECTIVE CLOTHING; CONSEQUENTLY, THE WORKER WAS SUBJECTED TO INTERNAL AND EXTERNAL PERSONAL CONTAMINATION. 10 CFR 20.201, "SURVEYS", REQUIRES THAT "EACH LICENSEE SHALL MAKE OR CAUSE TO BE MADE SUCH SURVEYS (EVALUATIONS OF THE RADIATION HAZARDS INCIDENT TO THE PRODUCTION, USE, RELEASE, DISPOSAL OR PRESENCE OF RADIOACTIVE MATERIALS) AS (1) MAY BE NECESSARY FOR THE LICENSEE TO COMPLY WITH THE REGULATIONS IN THIS PART, AND (2) ARE REASONABLE UNDER THE CIRCUMSTANCES TO EVALUATE THE EXTENT OF RADIATION HAZARDS THAT MAY BE PRESENT". CONTRARY TO THE ABOVE: ON MAY 7, 1984, THE LICENSEE FAILED TO MAKE AN EVALUATION OF THE "A" RHR QUADRANT TO SUPPORT THE ENTRY OF A WORKER PERFORMING OPERATIONS IN THE AREA. THE RADIOLOGICAL CONDITIONS OF THE AREA WERE NOT EVALUATED SUFFICIENTLY TO IDENTIFY THE NEED FOR RESPIRATORY PROTECTIVE MEASURES IN ACCORDANCE WITH 10 CFR 20.103 AND PROVISIONS FOR CONTROLLING PERSONNEL OCCUPATIONAL EXPOSURE IN ACCORDANCE WITH 10 CFR 20.101. ON APRIL 19, 1984, PERSONNEL REMOVED THE SPOOL PIECE FROM THE "B" RECIRCULATION LOOP IN THE DRYWELL, WITHOUT A RADIOLOGICAL EVALUATION BEING PERFORMED IN SUPPORT OF THE ACTIVITY. SUCH RADIOLOGICAL SURVEILLANCE WAS REQUIRED IN ORDER TO ASSURE THAT ADEQUATE RADIOLOGICAL CONTROLS WERE ESTABLISHED CONSISTENT WITH THE REQUIREMENTS OF 10 CFR 20.101 AND 10 CFR 20.103.

TECHNICAL SPECIFICATION 6.11, "RADIATION PROTECTION PROGRAM", REQUIRES THAT "PROCEDURES FOR PERSONNEL RADIATION PROTECTION SHALL BE PREPARED CONSISTENT WITH THE REQUIREMENTS OF 10 CFR PART 20 AND SHALL BE...ADHERED TO FOR ALL OPERATIONS INVOLVING PERSONNEL RADIATION EXPOSURE". CONTRARY TO THE ABOVE, ON MAY 7, 1984, HEALTH PHYSICS PROCEDURE NO. 6.4-067, "OPERATION OF THE EBERLINE RM-14 RADIATION MONITOR", WHICH PROVIDES INSTRUCTIONS FOR USE OF THE INSTRUMENT AS A MONITORING DEVICE TO DETERMINE PERSONEL CONTAMINATION WAS NOT FOLLOWED. AN INDIVIDUAL WHO WAS SIGNIFICANTLY CONTAMINATED FROM WORK PERFORMED IN THE "A" RHR QUADRANT, FAILED TO FRISK IN ACCORDANCE WITH THE DIRECTIONS STATED IN THE PROCEDURE SUFFICIENT TO DETECT AND PROPERLY RESPOND TO THE PRESENCE OF SIGNIFICANT LEVELS (IN EXCESS OF 200,000 DPM/100 CM2) OF RADIOACTIVE CONTAMINATION ON SKIN AND CLOTHING. (8414 4)

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-266 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: C. W. KRAUSE (414) 277-2001

4. Licensed Thermal Power (MWt): 1518

5. Nameplate Rating (Gross MWe): 582 X 0.9 = 524

6. Design Electrical Rating (Net MWe): 497

7. Maximum Dependable Capacity (Gross MWe): 519

8. Maximum Dependable Capacity (Net MWe): 485

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>121,151.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,491.1</u>	<u>97,569.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>4.3</u>	<u>629.7</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,451.0</u>	<u>95,058.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>9.0</u>	<u>802.5</u>
17. Gross Therm Ener (MWH)	<u>1,121,693</u>	<u>5,045,733</u>	<u>128,581,045</u>
18. Gross Elec Ener (MWH)	<u>384,970</u>	<u>1,739,920</u>	<u>43,135,900</u>
19. Net Elec Ener (MWH)	<u>368,646</u>	<u>1,662,817</u>	<u>41,030,699</u>
20. Unit Service Factor	<u>100.0</u>	<u>58.9</u>	<u>78.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>59.1</u>	<u>79.1</u>
22. Unit Cap Factor (MDC Net)	<u>102.2</u>	<u>58.6</u>	<u>69.3*</u>
23. Unit Cap Factor (DER Net)	<u>99.7</u>	<u>57.1</u>	<u>68.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>2.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>2,406.3</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* POINT BEACH 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
POINT BEACH 1



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* POINT BEACH 1 *

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

* SUMMARY *

POINT BEACH 1 OPERATED ROUTINELY IN AUGUST WITH NO SHUTDOWNS OR POWER REDUCTIONS REPORTED.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System & Component</u>	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

* POINT BEACH 1 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....WISCONSIN
COUNTY.....MANITOWOC
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...15 MI N OF
MANITOWOC, WISC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 2, 1970
DATE ELEC ENER 1ST GENER...NOVEMBER 6, 1970
DATE COMMERCIAL OPERATE...DECEMBER 21, 1970
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....WISCONSIN ELECTRIC POWER COMPANY
CORPORATE ADDRESS.....231 WEST MICHIGAN STREET
MILWAUKEE, WISCONSIN 53201
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....R. HAGUE
LICENSING PROJ MANAGER.....T. COLBURN
DOCKET NUMBER.....50-266
LICENSE & DATE ISSUANCE...DPR-24, OCTOBER 5, 1970
PUBLIC DOCUMENT ROOM.....JOSEPH MANN PUBLIC LIBRARY
1516 16TH ST.
TWO RIVERS, WISCONSIN 54241

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 1 THROUGH JULY 31, (84-07): ROUTINE, UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; INDEPENDENT INSPECTION AND PLANT TRIPS. THE INSPECTION INVOLVED A TOTAL OF 231 INSPECTOR-HOURS ONSITE BY TWO INSPECTORS INCLUDING 31 INSPECTOR-HOURS ON OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JUNE 25-29, (84-10): ROUTINE, UNANNOUNCED INSPECTION OF OPERATIONAL RADIATION PROTECTION PROGRAM INCLUDING: MANAGEMENT, STAFFING, EXPOSURE CONTROL, ALARA, SURVEYS, POSTING AND CONTROLS, LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, REFUELING CASK SURVEYS, AND STATUS OF CERTAIN TMI ACTION ITEMS. THE INSPECTION INVOLVED 32 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JULY 2-3, (84-11): ROUTINE, ANNOUNCED INSPECTION OF LICENSEE'S FOLLOW-UP ACTION OF PREVIOUSLY IDENTIFIED INSPECTION FINDINGS. THE INSPECTION INVOLVED 22 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS INCLUDING 0 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JULY 23-27, (84-13): ROUTINE, UNANNOUNCED INSPECTION OF THE FOLLOWING AREAS OF THE EMERGENCY PREPAREDNESS PROGRAM: EMERGENCY DETECTION AND CLASSIFICATION; PROTECTIVE ACTION DECISIONMAKING; NOTIFICATIONS AND COMMUNICATIONS; CHANGES TO THE EMERGENCY PREPAREDNESS PROGRAM; SHIFT STAFFING AND AUGMENTATION; KNOWLEDGE AND PERFORMANCE OF DUTIES (TRAINING); LICENSEE AUDITS; AND LICENSEE ACTIONS ON PREVIOUSLY IDENTIFIED EMERGENCY PREPAREDNESS ITEMS. THE INSPECTION INVOLVED 157 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS AND TWO CONSULTANTS. THREE APPARENT ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN THREE AREAS: FAILURE TO REVIEW EMERGENCY ACTION LEVELS WITH THE STATE OF WISCONSIN (EMERGENCY DETECTION AND CLASSIFICATION); FAILURE OF SHIFT SUPERINTENDENTS TO

1. Docket: 50-301 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: C. W. KRAUSE (414) 277-2001

4. Licensed Thermal Power (MWt): 1518

5. Nameplate Rating (Gross MWe): 582 X 0.9 = 524

6. Design Electrical Rating (Net MWe): 497

7. Maximum Dependable Capacity (Gross MWe): 519

8. Maximum Dependable Capacity (Net MWe): 485

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>105,936.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,829.6</u>	<u>94,257.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>8.8</u>	<u>207.1</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,765.9</u>	<u>92,668.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>15.4</u>	<u>198.1</u>
17. Gross Therm Ener (MWH)	<u>1,126,993</u>	<u>8,621,411</u>	<u>129,516,188</u>
18. Gross Elec Ener (MWH)	<u>379,450</u>	<u>2,913,830</u>	<u>43,873,660</u>
19. Net Elec Ener (MWH)	<u>362,470</u>	<u>2,784,411</u>	<u>41,789,676</u>
20. Unit Service Factor	<u>100.0</u>	<u>98.5</u>	<u>87.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>98.7</u>	<u>87.7</u>
22. Unit Cap Factor (MDC Net)	<u>100.5</u>	<u>96.6</u>	<u>80.3*</u>
23. Unit Cap Factor (DER Net)	<u>98.0</u>	<u>95.7</u>	<u>79.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>1.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>692.2</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
REFUELING OUTAGE: SEPTEMBER 28, 1984, 7 WEEKS

27. If Currently Shutdown Estimated Startup Date: N/A

* P O I N T B E A C H 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
POINT BEACH 2



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* POINT BEACH 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

* SUMMARY *

POINT BEACH 2 OPERATED ROUTINELY IN AUGUST WITH NO SHUTDOWNS OR POWER REDUCTIONS REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* POINT BEACH 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....WISCONSIN
COUNTY.....MANITOWOC
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...15 MI N OF
MANITOWOC, WISC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MAY 30, 1972
DATE ELEC ENER 1ST GENER...AUGUST 2, 1972
DATE COMMERCIAL OPERATE...OCTOBER 1, 1972
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....WISCONSIN ELECTRIC POWER COMPANY
CORPORATE ADDRESS.....231 WEST MICHIGAN STREET
MILWAUKEE, WISCONSIN 53201
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....R. HAGUE
LICENSING PROJ MANAGER.....T. COLBURN
DOCKET NUMBER.....50-301
LICENSE & DATE ISSUANCE...DPR-27, MARCH 8, 1973
PUBLIC DOCUMENT ROOM.....JOSEPH MANN PUBLIC LIBRARY
1516 16TH ST.
TWO RIVERS, WISCONSIN 54241

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JUNE 1 THROUGH JULY 31, (84-05): ROUTINE, UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; INDEPENDENT INSPECTION AND PLANT TRIPS. THE INSPECTION INVOLVED A TOTAL OF 231 INSPECTOR-HOURS ONSITE BY TWO INSPECTORS INCLUDING 31 INSPECTOR-HOURS ON OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JUNE 25-29, (84-08): ROUTINE, UNANNOUNCED INSPECTION OF OPERATIONAL RADIATION PROTECTION PROGRAM INCLUDING: MANAGEMENT, STAFFING, EXPOSURE CONTROL, ALARA, SURVEYS, POSTING AND CONTROLS, LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, REFUELING CASK SURVEYS, AND STATUS OF CERTAIN TMI ACTION ITEMS. THE INSPECTION INVOLVED 32 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JULY 2-3, (84-09): ROUTINE, ANNOUNCED INSPECTION OF LICENSEE'S FOLLOW-UP ACTION OF PREVIOUSLY IDENTIFIED INSPECTION FINDINGS. THE INSPECTION INVOLVED 22 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS INCLUDING 0 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JULY 23-27, (84-11): ROUTINE, UNANNOUNCED INSPECTION OF THE FOLLOWING AREAS OF THE EMERGENCY PREPAREDNESS PROGRAM: EMERGENCY DETECTION AND CLASSIFICATION; PROTECTIVE ACTION DECISIONMAKING; NOTIFICATIONS AND COMMUNICATIONS; CHANGES TO THE EMERGENCY PREPAREDNESS PROGRAM; SHIFT STAFFING AND AUGMENTATION; KNOWLEDGE AND PERFORMANCE OF DUTIES (TRAINING); LICENSEE AUDITS; AND LICENSEE ACTIONS ON PREVIOUSLY IDENTIFIED EMERGENCY PREPAREDNESS ITEMS. THE INSPECTION INVOLVED 157 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS AND TWO CONSULTANTS. THREE APPARENT ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN THREE AREAS: FAILURE TO REVIEW EMERGENCY ACTION LEVELS WITH THE STATE OF WISCONSIN (EMERGENCY DETECTION AND CLASSIFICATION); FAILURE OF SHIFT SUPERINTENDENTS TO

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* POINT BEACH 2 *

INSPECTION SUMMARY

MAKE AN ADEQUATE OFFSITE PROTECTIVE ACTION RECOMMENDATION (PROTECTIVE ACTION DECISIONMAKING); AND FAILURE TO REVIEW ANNUALLY THE ADEQUACY OF INTERFACES WITH STATE AND LOCAL GOVERNMENTS (LICENSEE AUDITS). NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN THE REMAINING FIVE AREAS INSPECTED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT OPERATING NORMALLY. REFUELING OUTAGE PLANNED FOR 10/84.

LAST IE SITE INSPECTION DATE: SEPTEMBER 10-13, 1984

INSPECTION REPORT NO: 84-14

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE			

1. Docket: 50-282 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: DALE DUGSTAD (612) 388-1121

4. Licensed Thermal Power (MWt): 1650

5. Nameplate Rating (Gross MWe): 659 X 0.9 = 593

6. Design Electrical Rating (Net MWe): 530

7. Maximum Dependable Capacity (Gross MWe): 534

8. Maximum Dependable Capacity (Net MWe): 503

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>93,887.0</u>
13. Hours Reactor Critical	<u>734.2</u>	<u>5,795.6</u>	<u>77,468.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>5,571.1</u>
15. Hrs Generator On-Line	<u>729.5</u>	<u>5,769.5</u>	<u>76,150.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,148,066</u>	<u>9,309,618</u>	<u>119,620,780</u>
18. Gross Elec Ener (MWH)	<u>372,180</u>	<u>3,074,640</u>	<u>38,954,440</u>
19. Net Elec Ener (MWH)	<u>348,166</u>	<u>2,899,615</u>	<u>36,491,044</u>
20. Unit Service Factor	<u>98.1</u>	<u>98.5</u>	<u>81.1</u>
21. Unit Avail Factor	<u>98.1</u>	<u>98.5</u>	<u>81.1</u>
22. Unit Cap Factor (MDC Net)	<u>93.0</u>	<u>98.5</u>	<u>77.3</u>
23. Unit Cap Factor (DER Net)	<u>88.3</u>	<u>93.4</u>	<u>73.3</u>
24. Unit Forced Outage Rate	<u>1.9</u>	<u>.3</u>	<u>8.0</u>
25. Forced Outage Hours	<u>14.5</u>	<u>14.5</u>	<u>2,935.4</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
TEN YEAR OVERHAUL IN JANUARY 1985.

27. If Currently Shutdown Estimated Startup Date: N/A

* PRAIRIE ISLAND 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PRAIRIE ISLAND 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * PRAIRIE ISLAND 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
	08/18/84	S	0.0	B	5				CONDENSER TUBE CLEANING AND REPAIR, TURBINE VALVES TEST.
	08/19/84	S	0.0	B	5				CONDENSER TUBE CLEANING AND REPAIR.
	08/25/84	S	0.0	H	5				CHLORINATION OF CIRCULATING WATER SYSTEM.
	08/30/84	F	8.6	G	3	84-005			TRIPPED DURING THE PROCESS OF A FLUX MAP TEST.
	08/31/84	F	5.9	A	3	84-006	SJ	FI	TRIPPED DURING POWER ESCALATION DUE TO STEAM FLOW FEED FOW MISMATCH.

 * SUMMARY *

 PRAIRIE ISLAND 1 OPERATED ROUTINELY IN AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	H-Other	4-Continued	Data Entry Sheet
	D-Regulatory Restriction	5-Reduced Load	Licensee Event Report
	E-Operator Training	9-Other	(LER) File (NUREG-0161)
	& License Examination		

FACILITY DESCRIPTION

LOCATION
STATE.....MINNESOTA

COUNTY.....GOODHUE

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...28 MI SE OF
MINNEAPOLIS, MINN

TYPE OF REACTOR.....PWR

DATE INITIAL CRITICALITY...DECEMBER 1, 1973
DATE ELEC ENER 1ST GENER...DECEMBER 4, 1973
DATE COMMERCIAL OPERATE...DECEMBER 16, 1973
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHERN STATES POWER

CORPORATE ADDRESS.....414 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401

CONTRACTOR
ARCHITECT/ENGINEER.....FLUOR PIONEER, INC.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....NORTHERN STATES POWER COMPANY
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. HARD
LICENSING PROJ MANAGER.....D. DIANNI
DOCKET NUMBER.....50-282
LICENSE & DATE ISSUANCE...DPR-42, APRIL 5, 1974
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY
MINNEAPOLIS PUBLIC LIBRARY
300 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JULY 9-13, (84-10): INCLUDED A REVIEW OF SECURITY PLAN AND IMPLEMENTING PROCEDURES; MANAGEMENT EFFECTIVENESS; SECURITY ORGANIZATION; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS: PROTECTED AREA; PHYSICAL BARRIERS: VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL; ACCESS CONTROL - PACKAGES; ACCESS CONTROL - VEHICLES; DETECTION AIDS - PROTECTED AREA; DETECTION AIDS - VITAL AREAS; ALARM STATIONS; COMMUNICATIONS; AND LICENSEE CORRECTIVE ACTIONS ON PREVIOUSLY IDENTIFIED ITEMS OF NONCOMPLIANCE. THE INSPECTION INVOLVED 70 TOTAL INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. THE INSPECTION BEGAN DURING THE DAYSHIFT PERIOD; SIX HOURS WERE ACCOMPLISHED DURING OFF-SHIFT PERIODS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED DURING THIS INSPECTION EXCEPT FOR THE FOLLOWING ITEMS: PHYSICAL BARRIERS - PROTECTED AREA: THE LICENSEE FAILED TO PROVIDE AN EFFECTIVE BARRIER IN A PORTION OF THE PROTECTED AREA PERIMETER. DETECTION AIDS - PROTECTED AREAS: THE PROTECTED AREA INTRUSION DETECTION SYSTEM FAILED TO DETECT ATTEMPTED PENETRATIONS IN SEVERAL ZONES.

ENFORCEMENT SUMMARY

THE LICENSEE FAILED TO PROVIDE AN EFFECTIVE BARRIER IN A PORTION OF THE PROTECTED AREA PERIMETER. THE PROTECTED AREA INTRUSION DETECTION SYSTEM FAILED TO DETECT ATTEMPTED PENETRATIONS IN SEVERAL ZONES.

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* PRAIRIE ISLAND 1 *

ENFORCEMENT SUMMARY

(8410 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT IS RETURNING TO NORMAL OPERATION FOLLOWING UNIT TRIP DURING SURVEILLANCE TESTING.

LAST IE SITE INSPECTION DATE: AUGUST 11 - OCTOBER 12, 1984

INSPECTION REPORT NO: 84-11

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-04	07/18/84	08/17/84	BOTH DIESEL GENERATORS STARTED ON LOSS OF 2RY TRANSFORMER.

=====

1. Docket: 50-306 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: DALE DUGSTAD (612) 388-1121

4. Licensed Thermal Power (MWt): 1650

5. Nameplate Rating (Gross MWe): 659 X 0.9 = 593

6. Design Electrical Rating (Net MWe): 530

7. Maximum Dependable Capacity (Gross MWe): 531

8. Maximum Dependable Capacity (Net MWe): 500

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>85,005.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>5,855.0</u>	<u>74,105.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,516.1</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>5,855.0</u>	<u>73,146.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,028,044</u>	<u>9,274,888</u>	<u>115,006,746</u>
18. Gross Elec Ener (MWH)	<u>334,160</u>	<u>3,072,320</u>	<u>37,179,720</u>
19. Net Elec Ener (MWH)	<u>311,829</u>	<u>2,906,631</u>	<u>34,881,514</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>86.1</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>86.1</u>
22. Unit Cap Factor (MDC Net)	<u>83.8</u>	<u>99.3</u>	<u>82.1</u>
23. Unit Cap Factor (DER Net)	<u>79.1</u>	<u>93.7</u>	<u>77.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>4.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>3,315.5</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
REFUELING OUTAGE ON SEPTEMBER 4, 1984.

27. If Currently Shutdown Estimated Startup Date: N/A

* PRAIRIE ISLAND 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
PRAIRIE ISLAND 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* PRAIRIE ISLAND 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
	08/11/84	S	0.0	B	5				CONDENSER TUBE REPAIR AND TURBINE VALVES TEST.

* SUMMARY *

PRAIRIE ISLAND 2 OPERATED ROUTINELY IN AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructic , for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* PRAIRIE ISLAND 2 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MINNESOTA
COUNTY.....GOODHUE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...28 MI SE OF
MINNEAPOLIS, MINN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 17, 1974
DATE ELEC ENER 1ST GENER...DECEMBER 21, 1974
DATE COMMERCIAL OPERATE...DECEMBER 21, 1974
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-CONTINENT AREA
RELIABILITY COORDINATION
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....NORTHERN STATES POWER
CORPORATE ADDRESS.....414 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401

CONTRACTOR
ARCHITECT/ENGINEER.....FLUOR PIONEER, INC.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....NORTHERN STATES POWER COMPANY
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. HARD
LICENSING PROJ MANAGER.....D. DIANNI
DOCKET NUMBER.....50-306
LICENSE & DATE ISSUANCE...DPR-60, OCTOBER 29, 1974
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY
MINNEAPOLIS PUBLIC LIBRARY
300 NICOLLET MALL
MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JULY 9-13, (84-09): INCLUDED A REVIEW OF SECURITY PLAN AND IMPLEMENTING PROCEDURES; MANAGEMENT EFFECTIVENESS; SECURITY ORGANIZATION; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AREA; PHYSICAL BARRIERS - VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; COMPENSATORY MEASURES; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL; ACCESS CONTROL - PACKAGES; ACCESS CONTROL - VEHICLES; DETECTION AIDS - PROTECTED AREA; DETECTION AIDS - VITAL AREAS; ALARM STATIONS; COMMUNICATIONS; AND LICENSEE CORRECTIVE ACTIONS ON PREVIOUSLY IDENTIFIED ITEMS OF NONCOMPLIANCE. THE INSPECTION INVOLVED 70 TOTAL INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. THE INSPECTION BEGAN DURING THE DAYSHIFT PERIOD; SIX HOURS WERE ACCOMPLISHED DURING OFF-SHIFT PERIODS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED DURING THIS INSPECTION EXCEPT FOR THE FOLLOWING ITEMS: PHYSICAL BARRIERS - PROTECTED AREA: THE LICENSEE FAILED TO PROVIDE AN EFFECTIVE BARRIER IN A PORTION OF THE PROTECTED AREA PERIMETER. DETECTION AIDS - PROTECTED AREAS: THE PROTECTED AREA INTRUSION DETECTION SYSTEM FAILED TO DETECT ATTEMPTED PENETRATIONS IN SEVERAL ZONES.

INSPECTION ON JUNE 14 - JULY 18, (84-20): SPECIAL INSPECTION BY RESIDENT INSPECTORS OF CONDITIONS RELATED TO THE QUESTION OF OPERABILITY OF 22 AFWP AND OF THE UNPLANNED OPENING OF UNIT 2 RWST VALVES 32182 AND 32183. THE INSPECTION INCLUDED AN ENFORCEMENT CONFERENCE WITH THE LICENSEE. THE INSPECTION INVOLVED A TOTAL OF 55 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS INCLUDING 6 INSPECTOR-HOURS OFFSITE BY THE SAME INSPECTORS. ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED (UNPLANNED OPENING OF TWO RWST VALVES).

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* PRAIRIE ISLAND 2 *

ENFORCEMENT SUMMARY

THE LICENSEE FAILED TO PROVIDE AN EFFECTIVE BARRIER IN A PORTION OF THE PROTECTED AREA PERIMETER. THE PROTECTED AREA INTRUSION DETECTION SYSTEM FAILED TO DETECT ATTEMPTED PENETRATIONS IN SEVERAL ZONES.

(8409 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS IN COASTDOWN FOR SCHEDULED REFUELING OUTAGE.

LAST IE SITE INSPECTION DATE: SEPTEMBER 6-7, 1984

INSPECTION REPORT NO: 84-13

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE			

1. Docket: 50-254 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: DAVE KIMLER (309) 654-2241 X192

4. Licensed Thermal Power (MWt): 2511

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 789

7. Maximum Dependable Capacity (Gross MWe): 813

8. Maximum Dependable Capacity (Net MWe): 769

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>107,879.0</u>
13. Hours Reactor Critical	<u>330.8</u>	<u>1,892.9</u>	<u>85,448.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,421.9</u>
15. Hrs Generator On-Line	<u>282.0</u>	<u>1,843.2</u>	<u>82,190.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>909.2</u>
17. Gross Therm Ener (MWH)	<u>436,851</u>	<u>4,096,583</u>	<u>169,203,289</u>
18. Gross Elec Ener (MWH)	<u>147,522</u>	<u>1,360,670</u>	<u>54,619,398</u>
19. Net Elec Ener (MWH)	<u>136,965</u>	<u>1,281,172</u>	<u>50,886,432</u>
20. Unit Service Factor	<u>37.9</u>	<u>31.5</u>	<u>76.2</u>
21. Unit Avail Factor	<u>37.9</u>	<u>31.5</u>	<u>77.0</u>
22. Unit Cap Factor (MDC Net)	<u>23.9</u>	<u>28.5</u>	<u>61.3</u>
23. Unit Cap Factor (DER Net)	<u>23.3</u>	<u>27.7</u>	<u>59.8</u>
24. Unit Forced Outage Rate	<u>13.2</u>	<u>2.3</u>	<u>5.9</u>
25. Forced Outage Hours	<u>43.0</u>	<u>63.0</u>	<u>2,771.0</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* Q U A D C I T I E S 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
QUAD CITIES 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * QUAD CITIES 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-14	03/06/84	S	419.0	C	4		RC	FUELXX	REFUELING & MAINTENANCE OUTAGE CONCLUDES.
84-15	08/24/84	S	0.0	B	5		CH	VALVEX	REDUCED LOAD TO 600 MWE FOR HEATER CONTROL VALVE ADJUSTMENT.
84-16	08/25/84	F	35.2	A	3	84-15	HE	VALVEX	REACTOR SCRAM - TURBINE BYPASS VALVE OPENED AND SHUT RAPIDLY CAUSING PRESSURE SPIKE AND HI APRM FLUX.
84-17	08/28/84	F	7.8	H	3	84-16	CC	INSTRU	REACTOR SCRAM - INSTRUMENT MECHANIC FAILED TO FILL REFERENCE LEG OF FLOW TRANSMITTER ON MAIN STEAM LINE.

 * SUMMARY *

 QUAD CITIES 1 INCURRED 3 SHUTDOWNS IN AUGUST AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

* QUAD CITIES 1 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS

COUNTY.....ROCK ISLAND

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI NE OF
MOLINE, ILL

TYPE OF REACTOR.....BWR

DATE INITIAL CRITICALITY...OCTOBER 18, 1971

DATE ELEC ENER 1ST GENER...APRIL 12, 1972

DATE COMMERCIAL OPERATE...FEBRUARY 18, 1973

CONDENSER COOLING METHOD...ONCE THRU

CONDENSER COOLING WATER...MISSISSIPPI RIVER

ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON

CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690

CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY

NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC

CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS

TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III

IE RESIDENT INSPECTOR.....A. MADISON

LICENSING PROJ MANAGER.....R. BEVAN
DOCKET NUMBER.....50-254

LICENSE & DATE ISSUANCE...DPR-29, DECEMBER 14, 1972

PUBLIC DOCUMENT ROOM.....MOLINE PUBLIC LIBRARY
504 17TH STREET
MOLINE, ILLINOIS 61265

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MAY 20 - JUNE 23, (84-08): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; LICENSEE EVENT REPORTS; PROCEDURES; REGIONAL REQUESTS; REFUEL; SCRAMS; SPECIAL OBSERVATIONS; REVIEW OF LICENSEE'S MONTHLY PERFORMANCE REPORT; IE INFORMATION NOTICE FOLLOWUP; RADIATION PROTECTION; REVIEW OF CILRT AND INDEPENDENT INSPECTION. THE INSPECTION INVOLVED 187 INSPECTOR HOURS ONSITE BY THREE NRC INSPECTORS INCLUDING 35 INSPECTOR HRS ONSITE DURING OFF-SHIFTS, AND 19 BY REGION-BASED INSPECTORS. OF THE 14 AREAS INSPECTED, TWO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED (FAILURE TO LOCAL LEAK RATE TEST A GASKETED PENETRATION; FAILURE TO QUANTIFY LEAKAGE DURING ILRT).

INSPECTION ON JUNE 25-28 AND JULY 6, (84-10): ROUTINE, UNANNOUNCED INSPECTION OF: (1) CONFIRMATORY MEASUREMENTS, INCLUDING SAMPLING, LABORATORY QUALITY CONTROL, AND COMPARISON OF LICENSEE ANALYSIS RESULTS WITH THOSE OF THE REGION III MOBILE LABORATORY AND THE NRC REFERENCE LABORATORY; (2) RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM (REMP) INCLUDING PROGRAM MANAGEMENT, QUALITY CONTROL, AND IMPLEMENTATION; AND (3) LICENSEE ACTIONS TAKEN ON OPEN ITEMS IDENTIFIED IN PREVIOUS INSPECTIONS. THE INSPECTION INVOLVED 49 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED DURING THIS INSPECTION.

INSPECTION ON JUNE 24 THROUGH AUGUST 5, (84-11): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; LICENSEE EVENT REPORTS; IE BULLETIN FOLLOWUP; IE INFORMATION NOTICE FOLLOWUP; TMI ACTION PLAN FOLLOWUP; REVIEW OF LICENSEE'S MONTHLY PERFORMANCE REPORT; FOLLOWUP ON REGIONAL REQUESTS, FOLLOWUP ON 10 CFR PART 21 REPORTS; AND INDEPENDENT INSPECTION. THE INSPECTION INVOLVED A TOTAL OF 242 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS INCLUDING 49 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. OF THE 15 AREAS INSPECTED, TWO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED (FAILURE TO PERFORM CALIBRATION OF SAFETY RELATED INSTRUMENTS; INADEQUATE FIRE BARRIER).

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

Q U A D C I T I E S 1 #

INSPECTION SUMMARY

INSPECTION ON JULY 20-26, (84-12); ROUTINE, ANNOUNCED INSPECTION OF THE CONTAINMENT INTEGRATED LEAK RATE TEST. THE INSPECTION INVOLVED 69 INSPECTOR HOURS BY ONE NRC INSPECTOR, INCLUDING 28 INSPECTOR HOURS ONSITE DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: SEPTEMBER 24-28, 1984

INSPECTION REPORT NO: 84-18

R E P O R T S F R O M L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-14	08/08/84	08/14/84	MO 1-1001-29A AND -29B FAILURE.

1. Docket: 50-265 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: DAVE KIMLER (309) 654-2241 X192

4. Licensed Thermal Power (MWt): 2511

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 789

7. Maximum Dependable Capacity (Gross MWe): 813

8. Maximum Dependable Capacity (Net MWe): 769

9. If Changes Occur Above Since Last Report. Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>106,989.0</u>
13. Hours Reactor Critical	<u>728.7</u>	<u>4,293.8</u>	<u>82,211.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,985.8</u>
15. Hrs Generator On-Line	<u>721.9</u>	<u>4,176.9</u>	<u>79,386.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>702.9</u>
17. Gross Therm Ener (MWH)	<u>1,749,867</u>	<u>9,849,890</u>	<u>165,231,978</u>
18. Gross Elec Ener (MWH)	<u>554,982</u>	<u>3,174,072</u>	<u>52,609,830</u>
19. Net Elec Ener (MWH)	<u>528,825</u>	<u>3,023,454</u>	<u>49,358,328</u>
20. Unit Service Factor	<u>97.0</u>	<u>71.3</u>	<u>74.2</u>
21. Unit Avail Factor	<u>97.0</u>	<u>71.3</u>	<u>74.9</u>
22. Unit Cap Factor (MDC Net)	<u>92.4</u>	<u>67.2</u>	<u>60.0</u>
23. Unit Cap Factor (DER Net)	<u>90.1</u>	<u>65.4</u>	<u>58.5</u>
24. Unit Forced Outage Rate	<u>3.0</u>	<u>3.9</u>	<u>8.4</u>
25. Forced Outage Hours	<u>22.1</u>	<u>170.2</u>	<u>3,360.3</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* QUAD CITIES 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

QUAD CITIES 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * QUAD CITIES 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-29	08/04/84	S	0.0	B	5		CD	VALVEX	REDUCED LOAD TO 400 MWE TO PERFORM MAIN STEAM ISOLATION VALVE QUARTERLY TESTS.
84-30	08/05/84	F	22.1	A	3	84-9	CD	VALVEX	REACTOR SCRAM DUE TO 2B REACTOR PROTECTION SYSTEM MG SET TRIP AND MSIV CLOSURE.
84-31	08/12/84	S	0.0	B	5		HA	TURBIN	REDUCED LOAD TO PERFORM WEEKLY TURBINE TESTS.
84-32	08/19/84	S	0.0	B	5		HA	TURBIN	REDUCED LOAD TO PERFORM WEEKLY TURBINE TESTS.
84-33	08/24/84	S	0.0	H	5		CH	PUMPXX	REDUCED LOAD TO CHANGEOVER REACTOR FEED PUMP.
84-34	08/26/84	S	0.0	B	5		HA	TURBIN	REDUCED LOAD TO PERFORM WEEKLY TURBINE TESTS.

 * QUAD CITIES 2 EXPERIENCED A REACTOR SCRAM IN AUGUST AS DISCUSSED ABOVE.
 * SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* QUAD CITIES 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....ROCK ISLAND
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI NE OF
MOLINE, ILL
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...APRIL 26, 1972
DATE ELEC ENER 1ST GENER...MAY 23, 1972
DATE COMMERCIAL OPERATE...MARCH 10, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MISSISSIPPI RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....A. MADISON
LICENSING PROJ MANAGER....R. BEVAN
DOCKET NUMBER.....50-265
LICENSE & DATE ISSUANCE...DPR-30, DECEMBER 14, 1972
PUBLIC DOCUMENT ROOM.....MOLINE PUBLIC LIBRARY
504 17TH STREET
MOLINE, ILLINOIS 61265

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON MAY 20 - JUNE 23, (84-07): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; LICENSEE EVENT REPORTS; PROCEDURES; REGIONAL REQUESTS; REFUEL; SCRAMS; SPECIAL OBSERVATIONS; REVIEW OF LICENSEE'S MONTHLY PERFORMANCE REPORT; IE INFORMATION NOTICE FOLLOWUP; RADIATION PROTECTION; REVIEW OF CILRT AND INDEPENDENT INSPECTION. THE INSPECTION INVOLVED 187 INSECTOR HOURS ONSITE BY THREE NRC INSPECTORS INCLUDING 35 INSPECTOR HRS ONSITE DURING OFF-SHIFTS, AND 19 BY REGION-BASED INSPECTORS. OF THE 14 AREAS INSPECTED, TWO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED (FAILURE TO LOCAL LEAK RATE TEST A GASKETED PENETRATION; FAILURE TO QUANTIFY LEAKAGE DURING ILRT).

INSPECTION ON JUNE 25-28 AND JULY 6, (84-09): ROUTINE, UNANNOUNCED INSPECTION OF: (1) CONFIRMATORY MEASUREMENTS, INCLUDING SAMPLING, LABORATORY QUALITY CONTROL, AND COMPARISON OF LICENSEE ANALYSIS RESULTS WITH THOSE OF THE REGION III MOBILE LABORATORY AND THE NRC REFERENCE LABORATORY; (2) RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM (REMP) INCLUDING PROGRAM MANAGEMENT, QUALITY CONTROL, AND IMPLEMENTATION; AND (3) LICENSEE ACTIONS TAKEN ON OPEN ITEMS IDENTIFIED IN PREVIOUS INSPECTIONS. THE INSPECTION INVOLVED 49 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED DURING THIS INSPECTION.

INSPECTION ON JUNE 24 THROUGH AUGUST 5, (84-10): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; LICENSEE EVENT REPORTS; IE BULLETIN FOLLOWUP; IE INFORMATION NOTICE FOLLOWUP; TMI ACTION PLAN FOLLOWUP; REVIEW OF LICENSEE'S MONTHLY PERFORMANCE REPORT; FOLLOWUP ON REGIONAL REQUESTS, FOLLOWUP ON 10 CFR PART 21 REPORTS; AND INDEPENDENT INSPECTION. THE INSPECTION INVOLVED A TOTAL OF 242 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS INCLUDING 49 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. OF THE 15 AREAS INSPECTED, TWO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED (FAILURE TO PERFORM CALIBRATION OF SAFETY RELATED INSTRUMENTS; INADEQUATE FIRE BARRIER).

INSPECTION SUMMARYENFORCEMENT SUMMARY

10 CFR 50, APPENDIX J, SECTION III.A.1(A) REQUIRES THAT IF DURING A TYPE A TEST POTENTIALLY EXCESSIVE LEAKAGE PATHS ARE IDENTIFIED WHICH WILL INTERFERE WITH SATISFACTORY COMPLETION OF THE TEST OR WHICH WILL RESULT IN A TYPE A TEST NOT MEETING THE ACCEPTANCE CRITERIA, THE TYPE A TEST SHALL BE TERMINATED AND THE LEAKAGE THROUGH SUCH PATHS SHALL BE MEASURED USING LOCAL LEAKAGE TESTING METHODS. REPAIRS AND/OR ADJUSTMENTS TO EQUIPMENT SHALL BE MADE AND A TYPE A TEST SHALL BE PERFORMED. CONTRARY TO THE ABOVE, DURING THE PERFORMANCE OF A TYPE A TEST IN FEBRUARY 1984 A LEAKING FLANGE ON A HALF INCH TORUS LEVEL INSTRUMENT LINE WAS REPAIRED WITHOUT FIRST MEASURING ITS LEAKAGE RATE.
(8407 4)

10 CFR 50, APPENDIX J, SECTION II.G DEFINES TYPE B TESTS AS THOSE TESTS INTENDED TO DETECT LOCAL LEAKS AND MEASURE LEAKAGES ACROSS EACH PRESSURE-CONTAINING OR LEAKAGE-LIMITING BOUNDARY FOR CONTAINMENT PENETRATIONS WHOSE DESIGN INCORPORATES GASKETS AMONG OTHERS. SECTION III.B DESCRIBES THE TYPE B TEST ACCEPTABLE METHODS, TEST PRESSURE, AND ACCEPTANCE CRITERIA. SECTION III.D.2. PRESCRIBES THE SCHEDULE AND FREQUENCY OF TYPE B TEST TO BE AT EVERY REFUELING OUTAGE BUT IN NO CASE AT INTERVALS EXCEEDING 2 YEARS. CONTRARY TO THE ABOVE A TYPE B LOCAL LEAK RATE TEST HAS NOT BEEN PERFORMED ON A HALF INCH TORUS LEVEL INSTRUMENT LINE FLANGE SINCE IT WAS ORIGINALLY DECLARED OPERABLE ON FEBRUARY 1981. AS A RESULT OF THE INSPECTION CONDUCTED BETWEEN FEBRUARY 24, 1984 AND APRIL 26, 1984, AND IN ACCORDANCE WITH THE NRC ENFORCEMENT POLICY, 10 CFR PART 2, APPENDIX C, 47 FR9987 (MARCH 9, 1982), THE FOLLOWING VIOLATION WAS IDENTIFIED: A. TECHNICAL SPECIFICATION 6.8.1 STATES IN PART THAT, "WRITTEN PROCEDURES SHALL BE ESTABLISHED, IMPLEMENTED, AND MAINTAINED..." ADMINISTRATIVE PROCEDURE AP.2, "REVIEW, APPROVAL, AND MAINTENANCE OF PROCEDURES," REQUIRES THAT CONTROLLED COPIES OF PROCEDURES BE PROPERLY MAINTAINED. CONTRARY TO THE ABOVE, ON APRIL 18, 1984, THE INSPECTOR OBSERVED THAT THE CONTROL ROOM CONTROLLED COPY OF THE SURVEILLANCE PROCEDURES MANUAL DID NOT CONTAIN THE LATEST REVISED COPIES OF SURVEILLANCE PROCEDURES SP 210.01A AND SP 210.01B. THESE TWO SURVEILLANCE PROCEDURES ARE FOR VERIFYING THE TWO AUXILIARY FEEDWATER PUMPS FLOW CAPACITY. THE MANUAL CONTAINED SP 210.01A, REV. 17, AND SP 210.01B, REV. 18, INSTEAD OF REVISIONS 18 AND 19 WHICH WERE ISSUED ON FEBRUARY 29 AND 19, 1984, RESPECTIVELY.
(8407 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: SEPTEMBER 24-28, 1984

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-312 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: RON COLOMBO (916) 452-3211

4. Licensed Thermal Power (MWt): 2772

5. Nameplate Rating (Gross MWe): 1070 X 0.9 = 963

6. Design Electrical Rating (Net MWe): 918

7. Maximum Dependable Capacity (Gross MWe): 917

8. Maximum Dependable Capacity (Net MWe): 873

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>82,176.0</u>
13. Hours Reactor Critical	<u>360.9</u>	<u>3,992.8</u>	<u>48,344.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>790.9</u>	<u>10,104.7</u>
15. Hrs Generator On-Line	<u>336.8</u>	<u>3,841.4</u>	<u>46,383.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,210.2</u>
17. Gross Therm Ener (MWH)	<u>747,653</u>	<u>9,297,562</u>	<u>115,208,904</u>
18. Gross Elec Ener (MWH)	<u>252,288</u>	<u>3,104,302</u>	<u>38,500,374</u>
19. Net Elec Ener (MWH)	<u>225,122</u>	<u>2,898,041</u>	<u>36,272,365</u>
20. Unit Service Factor	<u>45.3</u>	<u>65.6</u>	<u>56.4</u>
21. Unit Avail Factor	<u>45.3</u>	<u>65.6</u>	<u>57.9</u>
22. Unit Cap Factor (MDC Net)	<u>34.7</u>	<u>56.7</u>	<u>50.6</u>
23. Unit Cap Factor (DER Net)	<u>33.0</u>	<u>53.9</u>	<u>48.1</u>
24. Unit Forced Outage Rate	<u>54.7</u>	<u>34.4</u>	<u>28.5</u>
25. Forced Outage Hours	<u>407.2</u>	<u>2,013.6</u>	<u>18,423.6</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING - 1/11/85, THREE MONTHS

27. If Currently Shutdown Estimated Startup Date: 09/30/84

* RANCHO SECO 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

RANCHO SECO 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* RANCHO SECO 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
8	07/03/84	F	407.1	A	4	84-20	CI	HTEXCH	"B" OTSG TUBE LEAK.
9	08/31/84	F	0.1	A	1		CI	HTEXCH	"B" OTSG TUBE LEAK HIGH IODINE LEVEL.

***** RANCHO SECO 1 REMAINED SHUT DOWN UNTIL AUGUST 17 FOR STEAM GENERATOR TUBE LEAK.
* SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* RANCHO SECD 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....CALIFORNIA

COUNTY.....SACRAMENTO

DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI SE OF
SACRAMENTO, CA

TYPE OF REACTOR.....P..R

DATE INITIAL CRITICALITY...SEPTEMBER 16, 1974

DATE ELEC ENER 1ST GENER...OCTOBER 13, 1974

DATE COMMERCIAL OPERATE...APRIL 17, 1975

CONDENSER COOLING METHOD...COOLING TOWERS

CONDENSER COOLING WATER...FOLSOM CANAL

ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY
LICENSEE.....SACRAMENTO MUN. UTIL. DISTRICT

CORPORATE ADDRESS.....6201 S STREET P.O. BOX 15830
SACRAMENTO, CALIFORNIA 95813

CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL

NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX

CONSTRUCTOR.....BECHTEL

TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V

IE RESIDENT INSPECTOR.....J. ECKHARD

LICENSING PROJ MANAGER.....S. MINER
DOCKET NUMBER.....50-312

LICENSE & DATE ISSUANCE...DPR-54. AUGUST 16, 1974

PUBLIC DOCUMENT ROOM.....BUSINESS AND MUNICIPAL DEPARTMENT
SACRAMENTO CITY - COUNTY LIBRARY
828 I STREET
SACRAMENTO, CALIFORNIA 95814

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON JUNE 25-29, 1984 (REPORT NO. 50-312/84-13) AREAS INSPECTED: UNANNOUNCED INSPECTION BY A REGIONAL-BASED INSPECTOR OF CONSTRUCTION ACTIVITIES OF THE ELECTRICAL PORTION OF THE NEW DIESEL GENERATOR BUILDING. THE INSPECTION INVOLVED 43 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

RESULTS: OF THE AREAS EXAMINED, TWO VIOLATIONS WERE IDENTIFIED IN THE AREA OF STORAGE OF SAFETY-RELATED MOTOR CONTROL CENTERS AND CERTIFICATION OF QC INSPECTORS (FAILURE TO FOLLOW APPROVED QUALITY CONTROL PROCEDURES).

+ INSPECTION ON JUNE 26 - JULY 6, 1984 (REPORT NO. 50-312/84-14) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JUNE 18 - JULY 20, 1984 (REPORT NO. 50-312/84-15) AREAS INSPECTED: THIS ROUTINE INSPECTION WAS IN THE AREAS OF PLANT REVIEW COMMITTEE EVALUATION; ENGINEERING DESIGN REVIEW; PREVENTIVE MAINTENANCE; SURVEILLANCE; CONSTRUCTION ACTIVITY; AND OPERATIONAL SAFETY VERIFICATION. THE INSPECTION INVOLVED 189 INSPECTOR-HOURS ONSITE BY THE RESIDENT INSPECTORS AND ONE SENIOR REACTOR ENGINEER.

RESULTS: OF THE AREAS INSPECTED, ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN THE AREA OF ENGINEERING DESIGN REVIEW.

+ INSPECTION ON JULY 23-27, 1984 (REPORT NO. 50-312/84-17) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

Report Period AUG 1984

R E P O R T S F R O M L I C E N S E E

* RANCHO SECO 1 *

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE			

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-261 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: A. E. SCOTT (803) 383-4524

4. Licensed Thermal Power (MWt): 2300

5. Nameplate Rating (Gross MWe): 854 X 0.9 = 769

6. Design Electrical Rating (Net MWe): 700

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 665

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>118,301.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>616.1</u>	<u>84,196.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>38.9</u>	<u>1,675.5</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>615.8</u>	<u>82,665.9</u>
16. Unit Reserve Shtown Hrs	<u>.0</u>	<u>.0</u>	<u>23.2</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>783,895</u>	<u>162,875,180</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>246,010</u>	<u>52,344,876</u>
19. Net Elec Ener (MWH)	<u>-1,648</u>	<u>210,313</u>	<u>49,429,937</u>
20. Unit Service Factor	<u>.0</u>	<u>10.5</u>	<u>69.4</u>
21. Unit Avail Factor	<u>.0</u>	<u>10.5</u>	<u>69.4</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>5.4</u>	<u>62.8</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>5.1</u>	<u>59.7</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>17.2</u>	<u>14.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>128.2</u>	<u>8,233.5</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 10/5/84

* ROBINSON 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ROBINSON 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* ROBINSON 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
0801	01/26/84	S	744.0	C	4		CJ	HTEXCH	CONTINUATION OF REFUELING AND STEAM GENERATOR REPLACEMENT OUTAGE.

***** ROBINSON 2 REMAINED SHUT DOWN IN AUGUST FOR REFUELING AND STEAM GENERATOR REPLACEMENT.
* SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Tes	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* ROBINSON 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....DARLINGTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI NW OF
HARTSVILLE, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...SEPTEMBER 20, 1970
DATE ELEC ENER 1ST GENER...SEPTEMBER 26, 1970
DATE COMMERCIAL OPERATE...MARCH 7, 1971
CONDENSER COOLING METHOD...RECIRCULATION
CONDENSER COOLING WATER...ROBINSON IMPOUNDMENT
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....CAROLINA POWER & LIGHT
CORPORATE ADDRESS.....411 FAYETTEVILLE STREET
RALEIGH, NORTH CAROLINA 27601
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....S. WEISE
LICENSING PROJ MANAGER.....G. REQUA
DOCKET NUMBER.....50-261
LICENSE & DATE ISSUANCE...DPR-23, SEPTEMBER 23, 1970
PUBLIC DOCUMENT ROOM.....HARTSVILLE MEMORIAL LIBRARY
220 N. FIFTH ST.
HARTSVILLE, SOUTH CAROLINA 29550

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 11 - AUGUST 10 (84-26): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 48 RESIDENT INSPECTOR-HOURS ON SITE IN THE AREAS OF TECHNICAL SPECIFICATION COMPLIANCE, PLANT TOUR, OPERATIONS PERFORMANCE, REPORTABLE OCCURRENCES, HOUSEKEEPING, SITE SECURITY, SURVEILLANCE ACTIVITIES, MAINTENANCE ACTIVITIES, QUALITY ASSURANCE PRACTICES, RADIATION CONTROL ACTIVITIES, OUTSTANDING ITEMS REVIEW, IE BULLETIN, AND NOTICE FOLLOWUP, ORGANIZATION AND ADMINISTRATION, AND ENFORCEMENT ACTION FOLLOWUP. OF THE 15 AREAS INSPECTED, NO VIOLATION OR DEVIATIONS WERE IDENTIFIED IN 14 AREAS; ONE VIOLATION WAS FOUND IN ONE AREA (FAILURE TO ESTABLISH SUITABLE CONTROLS). NO APPARENT DEVIATIONS WAS FOUND IN ANY AREA.

INSPECTION JULY 25-27 (84-27): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 23 INSPECTOR-HOURS ON SITE IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFOCEMENT MATTERS, STEAM GENERATOR REPLACEMENT PROJECT, PRESERVICE INSPECTION/INSERVICE INSPECTION AND INSPECTOR FOLLOWUP ITEMS. TWO VIOLATIONS: FAILURE TO IDENTIFY VALVE STATUS, AND FAILURE TO FOLLOW RT CODE. NO DEVIATIONS WERE IDENTIFIED.

INSPECTION AUGUST 9-10 (84-31): THIS SPECIAL UNANNOUNCED INSPECTION INVOLVED 8 INSPECTOR-HOURS ON SITE DURING REGULAR HOURS INSPECTING CORRECTIVE ACTIONS TAKEN BY THE LICENSEE TO CONTROL ACCESS TO LOCKED HIGH RADIATION AREAS. A SECOND EXAMPLE OF A PREVIOUSLY CITED VIOLATION WAS IDENTIFIED RELATED TO IMPROPER CONTROLS OVER ENTRY INTO A LOCKED HIGH RADIATION AREA.

OTHER ITEMS

SHUTDOWN FOR STEAM GENERATORS TUBE BUNDLE REPLACEMENT.

LAST IE SITE INSPECTION DATE: AUGUST 9-10, 1984 +

INSPECTION REPORT NO: 50-261/84-31 +

R E P O R T S F R O M L I C E N S E E

```

=====

```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-006	06/21/84	07/20/84	UNIT SHUTDOWN IN S/G REPLACEMENT OUTAGE AND FUEL IN SPENT FUEL PIT, A SAFETY INJECTION SIGNAL RECEIVED AT 1024 HRS.
84-008	06/26/84	07/26/84	CONDENSATE STORAGE TANK LEVEL TRANSMITTERS WERE IDENTIFIED AS OUT OF CALIBRATION, BOTH TRANSMITTERS WERE RECALIBRATED.
84-009	07/09/84	08/09/84	DATA REVEALED A NON-LINER ERROR OVER THE RANGE OF THE INSTRUMENTS, THE MOST LIKELY CAUSE WAS PERSONNEL ERROR.

```

=====

```

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-272 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: L. K. MILLER (609) 935-6000 X4455

4. Licensed Thermal Power (Mwt): 3338

5. Nameplate Rating (Gross MWe): 1300 X 0.9 = 1170

6. Design Electrical Rating (Net MWe): 1090

7. Maximum Dependable Capacity (Gross MWe): 1124

8. Maximum Dependable Capacity (Net MWe): 1079

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>62,880.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>1,237.6</u>	<u>34,388.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>54.5</u>	<u>3,088.4</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>1,197.8</u>	<u>32,975.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>3,800,023</u>	<u>99,621,600</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>1,281,380</u>	<u>32,894,278</u>
19. Net Elec Ener (MWH)	<u>-5,029</u>	<u>1,201,536</u>	<u>31,172,848</u>
20. Unit Service Factor	<u>.0</u>	<u>20.5</u>	<u>52.4</u>
21. Unit Avail Factor	<u>.0</u>	<u>20.5</u>	<u>52.4</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>19.0</u>	<u>45.9</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>18.8</u>	<u>45.5</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>65.8</u>	<u>33.0</u>
25. Forced Outage Hours	<u>744.0</u>	<u>2,306.2</u>	<u>16,529.5</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: 09/15/84

* SALEM 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SALEM 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* SALEM 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-176	07/09/84	F	744.0	A	4		HA	GENERA	GENERATOR LIQUID COOLING SYSTEM.

* SUMMARY *

SALEM 1 REMAINS SHUT DOWN FOR A GENERATOR LIQUID COOLING SYSTEM PROBLEM.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-311 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: L. K. MILLER (609) 935-6000 X4455

4. Licensed Thermal Power (Mwt): 3411

5. Nameplate Rating (Gross MWe): 1162

6. Design Electrical Rating (Net MWe): 1115

7. Maximum Dependable Capacity (Gross MWe): 1149

8. Maximum Dependable Capacity (Net MWe): 1106

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>25,296.0</u>
13. Hours Reactor Critical	<u>575.8</u>	<u>2,630.9</u>	<u>14,339.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>1,443.0</u>	<u>3,533.6</u>
15. Hrs Generator On-Line	<u>555.8</u>	<u>2,455.2</u>	<u>13,872.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,823,350</u>	<u>7,966,695</u>	<u>41,437,767</u>
18. Gross Elec Ener (MWH)	<u>605,460</u>	<u>2,643,560</u>	<u>13,511,850</u>
19. Net Elec Ener (MWH)	<u>577,255</u>	<u>2,481,323</u>	<u>12,798,574</u>
20. Unit Service Factor	<u>74.7</u>	<u>41.9</u>	<u>54.8</u>
21. Unit Avail Factor	<u>74.7</u>	<u>41.9</u>	<u>54.8</u>
22. Unit Cap Factor (MDC Net)	<u>70.2</u>	<u>38.3</u>	<u>45.7</u>
23. Unit Cap Factor (DER Net)	<u>69.6</u>	<u>38.0</u>	<u>45.4</u>
24. Unit Forced Outage Rate	<u>25.3</u>	<u>58.1</u>	<u>35.3</u>
25. Forced Outage Hours	<u>188.2</u>	<u>3,399.8</u>	<u>7,582.9</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* SALEM 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SALEM 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * SALEM 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-218	07/25/84	F	173.2	A	3		CJ	VALVEX	POWER OPERATED RELIEF AND SAFETY/RELIEF VALVES REACTOR.
84-232	08/26/84	F	15.0	A	3		CH	PUMPXX	FEEDWATER PUMP REPAIRS.
84-234	08/27/84	F	0.0	A	5		CH	PUMPXX	FEEDWATER PUMP REPAIRS.

 * SUMMARY *

 SALEM 2 INCURRED 2 SHUTDOWNS IN AUGUST AS DETAILED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SALEM 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....NEW JERSEY
COUNTY.....SALEM
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...20 MI S OF
WILMINGTON, DEL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 8, 1980
DATE ELEC ENER 1ST GENER...JUNE 3, 1981
DATE COMMERCIAL OPERATE...OCTOBER 13, 1981
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...DELAWARE RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PUBLIC SERVICE ELECTRIC & GAS
CORPORATE ADDRESS.....80 PARK PLACE
NEWARK, NEW JERSEY 07101
CONTRACTOR
ARCHITECT/ENGINEER.....PUBLIC SERVICES & GAS CO.
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....T. LINVILLE
LICENSING PROJ MANAGER.....D. FISCHER
DOCKET NUMBER.....50-311
LICENSE & DATE ISSUANCE...DPR-75, MAY 20, 1981
PUBLIC DOCUMENT ROOM.....SALEM FREE PUBLIC LIBRARY
112 WEST BROADWAY
SALEM, NEW JERSEY 08079

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

CONTRARY TO THE ORDER MODIFYING THE LICENSE DATED MAY 6, 1983, THE LICENSEE FAILED TO PERFORM A REVIEW OF VENDOR MANUALS FOR POST MAINTENANCE TESTING RECOMMENDATIONS. THE REVIEW AND ANY NECESSARY CHANGES TO DEPARTMENTAL PROCEDURES WERE TO BE COMPLETED BY JANUARY 1984.
(8403 4)

CONTRARY TO THE MAY 6, 1983 ORDER MODIFYING THE LICENSE IMMEDIATELY, ON MAY 1, 1984, THE MEL WAS NOT COMPLETE AND ACCURATE AS INDICATED IN THE EXAMPLES BELOW. EVEN THOUGH THE MEL IDENTIFIED THE COMPONENTS INVOLVED AS SAFETY RELATED AND FUNCTIONALLY SAFETY RELATED COMPONENTS RESPECTIVELY IN THE NONSAFETY RELATED PORTION OF THE FEEDWATER SYSTEM, MISCLASSIFICATIONS OCCURRED AS RESULT OF FAILURES OF THE MEL TO ALSO CLASSIFY THEM AS COMPONENTS IN THE SAFETY RELATED REACTOR PROTECTION AND ENGINEERED SAFETY FEATURES ACTUATION SYSTEMS, RESPECTIVELY. A) WORK ORDER MD 946229 WAS NOT CLASSIFIED AS SAFETY RELATED FOR REPLACEMENT OF THE NO. 23 FEEDWATER FLOW NOZZLE F-659-2; AND, B) WORK ORDER MD 946237 WAS NOT CLASSIFIED AS SAFETY RELATED FOR WORK ON THE NO. 23 FEEDWATER MAIN REGULATING BYPASS VALVE (23BF40). CONTRARY TO 10 CFR 50 APPENDIX B, CRITERION XVI AND SECTION 12.2.16 OF THE SALEM GENERATING STATION UFSAR THE LICENSEE QUALITY ASSURANCE PROGRAM, THE LICENSEE DID NOT TAKE ADEQUATE CORRECTIVE ACTION FOR THE

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-206 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: L. I. MAYWEATHER (714) 492-7700 X56223

4. Licensed Thermal Power (MWt): 1347

5. Nameplate Rating (Gross MWe): 500 X 0.9 = 450

6. Design Electrical Rating (Net MWe): 436

7. Maximum Dependable Capacity (Gross MWe): 456

8. Maximum Dependable Capacity (Net MWe): 436

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>150,895.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>88,440.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>84,821.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>108,263,946</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>36,906,434</u>
19. Net Elec Ener (MWH)	<u>-1,085</u>	<u>-13,302</u>	<u>34,928,457</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>56.2</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>56.2</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>53.1</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>53.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>21.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>11,178.3</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 10/16/84

* SAN ONOFRE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SAN ONOFRE 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* SAN ONOFRE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
78	02/27/82	S	744.0	B	4		ZZ		EXTENDED OUTAGE TO ACCOMPLISH SEISMIC BACKFIT AND MISCELLANEOUS MAINTENANCE ITEMS.

* SUMMARY *

SAN ONOFRE 1 REMAINS SHUT DOWN FOR SEISMIC BACKFIT AND MISCELLANEOUS MAINTENANCE

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

INSPECTION SUMMARY

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JUNE 26-29, 1984 & JULY 16-20, 1984 (REPORT NO. 50-206/84-17) AREAS INSPECTED: ROUTINE, UNANNOUNCED REGIONAL-BASED INSPECTION OF OPERATIONS INCLUDING THE FOLLOWING AREAS: LICENSEE EVENT REPORTING SYSTEM AND LICENSEE ACTION ON INDIVIDUAL LICENSEE EVENT REPORTS; LICENSEE EVENT REVIEW GROUP PERFORMANCE INCLUDING THE POST TRIP/TRANSIENT REVIEW PROCESS; LICENSEE ACTION ON IE BULLETINS; AND OFFSITE REVIEW GROUP RESPONSIBILITIES. THE INSPECTION INVOLVED THREE INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS. THE INSPECTION ALSO INVOLVED TWO INSPECTOR-HOURS INOFFICE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JULY 23-27, 1984 (REPORT NO. 50-206/84-18) AREAS INSPECTED: FOLLOWUP ON INFORMATION NOTICE 84-07; SECURITY EVENTS FOLLOWUP; SAFETY/SECURITY ASSESSMENT REPORT FOLLOWUP; SECURITY ORGANIZATION-PERSONNEL; SECURITY ORGANIZATION-RESPONSE; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS-PA; PHYSICAL BARRIERS-VA; SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; ACCESS CONTROL-PERSONNEL; ACCESS CONTROL-PACKAGES; ACCESS CONTROL-VEHICLES; DETECTION AIDS-PA; DETECTION AIDS-VA; ALARM STATIONS; COMMUNICATIONS; PHYSICAL PROTECTION SAFEGUARDS INFORMATION; INDEPENDENT INSPECTION EFFORT AND FOLLOWUP ITEMS FROM PREVIOUS SECURITY INSPECTIONS. THE INSPECTION INVOLVED 37 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JULY 27 - SEPTEMBER 7, 1984 (REPORT NO. 50-206/84-19) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON AUGUST 6-10, 1984 (REPORT NO. 50-206/84-20) AREAS INSPECTED: ROUTINE, UNANNOUNCED REGIONAL-BASED INSPECTION OF OPERATIONS INCLUDING THE FOLLOWING AREAS: INDEPENDENT OFFSITE REVIEW GROUP ACTIVITIES; LICENSEE EVENT REVIEW GROUP PERFORMANCE; REVIEW OF QUALITY ASSURANCE PROGRAM CHANGES; LICENSEE ACTION ON TMI ACTION PLAN REQUIREMENTS; LICENSEE EVENT REPORTS; AND LICENSEE ACTION ON A 10 CFR 21 REPORT. THE INSPECTION INVOLVED 30 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. THE INSPECTION ALSO INVOLVED 10 INSPECTOR-HOURS INOFFICE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON AUGUST 6-17, 1984 (REPORT NO. 50-206/84-21) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON AUGUST 13-17, 1984 (REPORT NO. 50-206/84-22) REPORT CANCELLED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

THE PLANT HAS REMAINED SHUTDOWN SINCE LATE FEBRUARY 1982, FOR SEISMIC UP-GRADING, TMI MODIFICATIONS, STEAM GENERATOR TUBE RE-EVALUATION, EMERGENCY CORE COOLING SYSTEM TESTS, AND ROUTINE MAINTENANCE. THESE PROJECTS ARE NEARING COMPLETION AND RESTART IS

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-361 O P E R A T I N G S T A T U S
 2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0
 3. Utility Contact: L. I. MAYWEATHER (714) 492-7700 X56223
 4. Licensed Thermal Power (MWt): 3410
 5. Nameplate Rating (Gross MWe): 1127
 6. Design Electrical Rating (Net MWe): 1070
 7. Maximum Dependable Capacity (Gross MWe): 1127
 8. Maximum Dependable Capacity (Net MWe): 1070
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____
 11. Reasons for Restrictions, If Any: _____
 NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>9,360.0</u>
13. Hours Reactor Critical	<u>700.0</u>	<u>4,079.5</u>	<u>6,692.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>692.1</u>	<u>3,977.9</u>	<u>6,539.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,234,711</u>	<u>12,926,028</u>	<u>21,419,563</u>
18. Gross Elec Ener (MWH)	<u>733,464</u>	<u>4,338,716</u>	<u>7,250,680</u>
19. Net Elec Ener (MWH)	<u>695,670</u>	<u>4,097,488</u>	<u>6,873,132</u>
20. Unit Service Factor	<u>93.0</u>	<u>67.9</u>	<u>69.9</u>
21. Unit Avail Factor	<u>93.0</u>	<u>67.9</u>	<u>69.9</u>
22. Unit Cap Factor (MDC Net)	<u>87.4</u>	<u>65.3</u>	<u>68.6</u>
23. Unit Cap Factor (DER Net)	<u>87.4</u>	<u>65.3</u>	<u>68.6</u>
24. Unit Forced Outage Rate	<u>7.0</u>	<u>5.0</u>	<u>4.5</u>
25. Forced Outage Hours	<u>51.9</u>	<u>208.7</u>	<u>309.6</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
REFUELING, 10/16/84, 3 1/2 MONTH DURATION

27. If Currently Shutdown Estimated Startup Date: N/A

 * SAN ONOFRE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 SAN ONOFRE 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * SAN ONOFRE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
6	08/08/84	F	24.3	A	3	84-043	JC	JX	REACTOR AND TURBINE TRIP DUE TO SPURIOUS LOW DNBR SIGNALS DUE TO POWER SUPPLY FAILURE. FAULTY POWER SUPPLY REPLACED.
7	08/15/84	S	0.0	H	5				REACTOR POWER REDUCED TO 46% FOR CLEANING OF INTAKE STRUCTURE.
8	08/26/84	F	27.6	A	3	84-050	ED	EKR	TURBINE TRIP AND SUBSEQUENT REACTOR TRIP DUE TO LOW DNBR/HIGH LPD CAUSED BY FAULTY FEEDER BREAKER. THE FEEDER BREAKER WAS REPLACED.

***** SAN ONOFRE 2 EXPERIENCED 2 SHUTDOWNS IN AUGUST AS DISCUSSED ABOVE.
 * SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	G-Oper Error	3-Auto Scram	Preparation of
	C-Refueling	4-Continued	Data Entry Sheet
	H-Other	5-Reduced Load	Licensee Event Report
	D-Regulatory Restriction	9-Other	(LER) File (NUREG-0161)
	E-Operator Training & License Examination		

* SAN ONDFRE 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....CALIFORNIA
COUNTY.....SAN DIEGO
DIST AND DIRECTION FROM
NE REST POPULATION CTR...5 MI S OF
SAN CLEMENTE, CA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JULY 26, 1982
DATE ELEC ENER 1ST GENER...SEPTEMBER 20, 1982
DATE COMMERCIAL OPERATE...AUGUST 8, 1983
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...PACIFIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....SOUTHERN CALIFORNIA EDISON
CORPORATE ADDRESS.....P.O. BOX 800
ROSEMEAD, CALIFORNIA 91770
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC COM (ENG VERSION)

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....A. CHAFFEE
LICENSING PROJ MANAGER.....H. ROOD
DOCKET NUMBER.....50-361
LICENSE & DATE ISSUANCE...., SEPTEMBER 7, 1982
PUBLIC DOCUMENT ROOM.....SAN CLEMENTE LIBRARY
242 AVENIDA DEL MAR
SAN CLEMENTE, CALIFORNIA

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON APRIL 30 - JUNE 11, 1984 (REPORT NO. 50-361/84-16) AREAS INSPECTED: ROUTINE, UNANNOUNCED RESIDENT INSPECTION OF THE OPERATIONS PROGRAM INCLUDING THE FOLLOWING AREAS: OPERATIONAL SAFETY VERIFICATION, EVALUATION OF PLANT TRIPS, LICENSEE EVENT REPORT REVIEW, MONTHLY SURVEILLANCE ACTIVITIES, MONTHLY MAINTENANCE ACTIVITIES, IE BULLETIN FOLLOWUP, AND INDEPENDENT INSPECTION EFFORT. THE INSPECTION INVOLVED 70 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON MAY 14, 1984 (REPORT NO. 50-361/84-17) REPORT CANCELLED.

+ INSPECTION ON JUNE 12 - JULY 24, 1984 (REPORT NO. 50-361/84-18) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JUNE 26-29 AND JULY 16-20, 1984 (REPORT NO. 50-361/84-21) AREAS INSPECTED: ROUTINE, UNANNOUNCED REGIONAL-BASED INSPECTION OF OPERATIONS INCLUDING THE FOLLOWING AREAS: LICENSEE EVENT REPORTING SYSTEM AND LICENSEE ACTION ON INDIVIDUAL LICENSEE EVENT REPORTS; LICENSEE EVENT REVIEW GROUP PERFORMANCE INCLUDING THE POST TRIP/TRANSIENT REVIEW PROCESS; LICENSEE ACTION ON IE BULLETINS; AND OFFSITE REVIEW GROUP RESPONSIBILITIES. THE INSPECTION INVOLVED 49 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS. THE INSPECTION ALSO INVOLVED 13 INSPECTOR-HOURS INOFFICE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-362 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: L. I. MAYWEATHER (714) 492-7700 X56223

4. Licensed Thermal Power (MWt): 3390

5. Nameplate Rating (Gross MWe): 1127

6. Design Electrical Rating (Net MWe): 1080

7. Maximum Dependable Capacity (Gross MWe): 1127

8. Maximum Dependable Capacity (Net MWe): 1080

9. If Changes Occur Above Since Last Report, Give Reasons:
MDC NET & DER REFLECT AUXILIARY STATION LOADS.

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>3,671.0</u>	<u>3,671.0</u>
13. Hours Reactor Critical	<u>546.2</u>	<u>2,345.9</u>	<u>2,345.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>520.5</u>	<u>2,113.0</u>	<u>2,113.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,643,144</u>	<u>6,378,903</u>	<u>6,378,903</u>
18. Gross Elec Ener (MWH)	<u>547,825</u>	<u>2,183,137</u>	<u>2,183,137</u>
19. Net Elec Ener (MWH)	<u>515,656</u>	<u>2,039,455</u>	<u>2,038,455</u>
20. Unit Service Factor	<u>70.0</u>	<u>57.6</u>	<u>57.6</u>
21. Unit Avail Factor	<u>70.0</u>	<u>57.6</u>	<u>57.6</u>
22. Unit Cap Factor (MDC Net)	<u>64.2</u>	<u>51.4</u>	<u>51.4</u>
23. Unit Cap Factor (DER Net)	<u>64.2</u>	<u>51.4</u>	<u>51.4</u>
24. Unit Forced Outage Rate	<u>5.5</u>	<u>2.2</u>	<u>2.2</u>
25. Forced Outage Hours	<u>30.1</u>	<u>46.8</u>	<u>46.8</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):

NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * SAN ONOFRE 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 SAN ONOFRE 3



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * SAN ONDFRE 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
6	07/19/84	S	193.4	D	4		AB	SG	CONTINUATION OF SCHEDULED OUTAGE FOR REPAIR OF PRIMARY TO SECONDARY LEAK IN STEAM GENERATOR E-089.
7	08/23/84	F	30.1	H	2		WI	V	MANUALLY TRIPPED TURBINE AND REACTOR DUE TO HIGH CONDUCTIVITY IN THE CONDENSATE AND FEEDWATER SYSTEMS.

 * SUMMARY *

 SAN ONDFRE 3 RETURNED ONLINE ON AUGUST 9TH FROM MAINTENANCE AND OPERATED WITH ONE ADDITIONAL OUTAGE DURING AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SAN ONOFRE 3 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....CALIFORNIA
COUNTY.....SAN DIEGO
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S OF
SAN CLEMENTE, CA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 29, 1983
DATE ELEC ENER 1ST GENER...SEPTEMBER 25, 1983
DATE COMMERCIAL OPERATE...APRIL 1, 1984
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...PACIFIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY
LICENSEE.....SOUTHERN CALIFORNIA EDISON
CORPORATE ADDRESS.....P.O. BOX 800
ROSEMEAD, CALIFORNIA 91770
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC COM (ENG VERSION)

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....A. CHAFFEE
LICENSING PROJ MANAGER....H. ROOD
DOCKET NUMBER.....50-362
LICENSE & DATE ISSUANCE...NPF-15, NOVEMBER 15, 1982
PUBLIC DOCUMENT ROOM.....SAN CLEMENTE LIBRARY
242 AVENIDA DEL MAR
SAN CLEMENTE, CALIFORNIA

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON APRIL 30 - JUNE 11, 1984 (REPORT NO. 50-362/84-17) AREAS INSPECTED: ROUTINE, UNANNOUNCED RESIDENT INSPECTION OF OPERATIONS PROGRAM INCLUDING THE FOLLOWING AREAS: OPERATIONAL SAFETY VERIFICATION, EVALUATION OF PLANT TRIPS, LICENSEE EVENT REPORT REVIEW, MONTHLY SURVEILLANCE ACTIVITIES, MONTHLY MAINTENANCE ACTIVITIES, IE BULLETIN FOLLOWUP, AND INDEPENDENT INSPECTION. THE INSPECTION INVOLVED 98 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JUNE 12 - JULY 24, 1984 (REPORT NO. 50-362/84-18) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON JUNE 26-29 AND JULY 16-20, 1984 (REPORT NO. 50-362/84-21) AREAS INSPECTED: ROUTINE, UNANNOUNCED REGIONAL-BASED INSPECTION OF OPERATIONS INCLUDING THE FOLLOWING AREAS: LICENSEE EVENT REPORTING SYSTEM AND LICENSEE ACTION ON INDIVIDUAL LICENSEE EVENT REPORTS; LICENSEE EVENT REVIEW GROUP PERFORMANCE INCLUDING THE POST TRIP/TRANSIENT REVIEW PROCESS; LICENSEE ACTION ON IE BULLETINS; AND OFFSITE REVIEW GROUP RESPONSIBILITIES. THE INSPECTION INVOLVED 49 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS. THE INSPECTION ALSO INVOLVED 15 INSPECTOR-HOURS INOFFICE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JULY 16-27, 1984 (REPORT NO. 50-362/84-22) AREAS INSPECTED: A SPECIAL, UNANNOUNCED TEAM INSPECTION OF MECHANICAL, ELECTRICAL, DESIGN, AND OPERATIONS ACTIVITIES ASSOCIATED WITH HARDWARE MODIFICATIONS, PLANT MAINTENANCE AND

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-327 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: MIKE EDDINUS (615) 870-6248

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1220

6. Design Electrical Rating (Net MWe): 1148

7. Maximum Dependable Capacity (Gross MWe): 1183

8. Maximum Dependable Capacity (Net MWe): 1148

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>27,792.0</u>
13. Hours Reactor Critical	<u>718.5</u>	<u>3,394.6</u>	<u>17,836.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>701.2</u>	<u>3,223.0</u>	<u>17,336.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,301,819</u>	<u>9,936,808</u>	<u>55,428,608</u>
18. Gross Elec Ener (MWH)	<u>746,040</u>	<u>3,245,990</u>	<u>18,627,126</u>
19. Net Elec Ener (MWH)	<u>716,572</u>	<u>3,108,379</u>	<u>17,885,307</u>
20. Unit Service Factor	<u>94.2</u>	<u>55.0</u>	<u>62.4</u>
21. Unit Avail Factor	<u>94.2</u>	<u>55.0</u>	<u>62.4</u>
22. Unit Cap Factor (MDC Net)	<u>83.9</u>	<u>46.2</u>	<u>56.1</u>
23. Unit Cap Factor (DER Net)	<u>83.9</u>	<u>46.2</u>	<u>56.1</u>
24. Unit Forced Outage Rate	<u>5.8</u>	<u>28.3</u>	<u>21.2</u>
25. Forced Outage Hours	<u>42.8</u>	<u>1,270.5</u>	<u>4,651.2</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* SEQUOYAH 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SEQUOYAH 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* SEQUOYAH 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
13	08/27/84	F	42.8	A	3				REACTOR TRIP-STEAM FLOW/FEEDWATER FLOW MISMATCH LOOP NO. 1 FEEDWATER REGULATOR VALVE FAILED CLOSE.

* SUMMARY *

SEQUOYAH 1 INCURRED 1 REACTOR TRIP IN AUGUST AS DESCRIBED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

* SEQUOYAH 1 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....TENNESSEE
COUNTY.....HAMILTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9.5 MI NE OF
CHATTANOOGA, TN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JULY 5, 1980
DATE ELEC ENER 1ST GENER...JULY 22, 1980
DATE COMMERCIAL OPERATE...JULY 1, 1981
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CHICKAMAUGA LAKE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY
LICENSEE.....TENNESSEE VALLEY AUTHORITY
CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II
CHATTANOOGA, TENNESSEE 37401
CONTRACTOR
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....E. FORD
LICENSING PROJ MANAGER.....C. STAHL
DOCKET NUMBER.....50-327
LICENSE & DATE ISSUANCE...DPR-77, SEPTEMBER 17, 1980
PUBLIC DOCUMENT ROOM.....CHATTANOOGA - HAMILTON BICENTENNIAL LIBRARY
1001 BROAD STREET
CHATTANOOGA, TENNESSEE 37402

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 18-20 (84-15): THIS ROUTINE ANNOUNCED INSPECTION INVOLVED 62 INSPECTOR-HOURS ON SITE IN THE AREAS OF AN EMERGENCY EXERCISE. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 9-13 (84-16): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 21 INSPECTOR-HOURS ON SIT IN THE AREAS OF PLANT CHEMISTRY AND INSERVICE INSPECTION OF PUMPS AND VALVES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JUNE 6 - JULY 5 (84-17): THIS ROUTINE INSPECTION INVOLVED 69 INSPECTOR-HOURS ON SITE IN THE AREAS OF OPERATIONAL SAFETY VERIFICATION, ESF SYSTEM OPERABILITY VERIFICATION, INDEPENDENT INSPECTION EFFORT, SURVEILLANCE AND MAINTENANCE, AND LER REVIEW. OF THE SIX AREAS INSPECTED NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN FIVE AREAS; TWO WERE FOUND IN ONE AREA (FAILURE TO LOCK CONTAINMENT ISOLATION VALVE 1-33-704, AND FAILURE TO MAINTAIN CONTAINMENT CLEAR OF DEBRIS).

INSPECTION JULY 22-26 (84-19): THIS ROUTINE UNANNOUNCED INSPECTION ENTAILED 18 INSPECTOR-HOURS ON SITE (SIX HOURS ON BACK SHIFT) INSPECTING: SECURITY ORGANIZATION - PERSONNEL AND RESPONSE; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; ACCESS CONTROL - PERSONNEL AND VEHICLES; DETECTION AIDS - PROTECTED AND VITAL AREAS AND COMMUNICATIONS. THREE VIOLATIONS WERE IDENTIFIED - FAILURE TO ESCORT VISITORS WHILE IN THE PROTECTED AREA, FAILURE TO PROPERLY SEARCH VEHICLES PRIOR TO ENTERING THE PROTECTED AREA AND FAILURE TO SECURE A DESIGNATED VEHICLE IN THE PROTECTED AREA.

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-042	06/27/84	07/26/84	DUE TO AN INCOMPLETE MODIFICATION, RADIATION MONITOR 0-RE-90-225 WOULD NOT PROVIDE AUTOMATIC ISOLATION OF DIRECT RELEASES FROM THE NEUTRALIZATION TANK.
84-043	06/27/84	07/19/84	A THERMAL FIRE DETECTOR DISCOVERED INOPERABLE, REPLACED AND RETURNED TO SERVICE BEFORE ERROR WAS DISCOVERED.
84-044	07/05/84	08/03/84	SWITCH WAS RETURNED TO THE NORMAL FROM TEST PRIOR TO RESETTING OF THE SAFETY INJECTION SIGNAL, AUTOMATIC START OF THE REMAINING THREE DIESEL GENERATORS.
84-046	07/27/84	08/10/84	FAILURE TO COMPLY WITH APPENDIX R, FIRE WATCHES HAVE BEEN ESTABLISHED AS REQUIRED.
84-047	07/17/84	08/15/84	AN AUXILIARY BLDG VENTILATION ISOLATION (ABI) AND A CONTAINMENT BUILDING VENTILATION ISOLATION (CVI), A WIRE SLIPPED LOOSE ONTO THE INPUT OF A PCWER SUPPLY.

=====

THIS PAGE INTENTIONALLY LEFT BLANK

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * SEQUOYAH 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
6	08/20/84	F	234.8	A	1				RUPTURED THE DIAPHRAM IN THE PRESSURIZER RELIEF TANK. PRZ RELIEF VALVE LEAKING.
7	08/30/84	F	12./	G	3				UNIT OPERATORS OVER FED THE STEAM GENERATORS CAUSING THE TURBINE AND REACTOR TO TRIP.

 * SUMMARY *

 SEQUOYAH 2 EXPERIENCED 2 SHUTDOWNS IN AUGUST AS DISCUSSED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

* SEQUOYAH 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....TENNESSEE
COUNTY.....HAMILTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...9.5 MI NE OF
CHATTANOOGA, TN
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...NOVEMBER 5, 1981
DATE ELEC ENER 1ST GENER...DECEMBER 23, 1981
DATE COMMERCIAL OPERATE...JUNE 1, 1982
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...CHICKAMAUGA LAKE
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....TENNESSEE VALLEY AUTHORITY
CORPORATE ADDRESS.....831 POWER BUILDING
CHATTANOOGA, TENNESSEE 37401
CONTRACTOR
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....E. FORD
LICENSING PROJ MANAGER.....C. STAHL
DOCKET NUMBER.....50-328
LICENSE & DATE ISSUANCE...DPR-79, SEPTEMBER 15, 1981
PUBLIC DOCUMENT ROOM.....CHATTANOOGA - HAMILTON BICENTENNIAL LIBRARY
1001 BROAD STREET
CHATTANOOGA, TENNESSEE 37402

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 18-20 (84-15): THIS ROUTINE ANNOUNCED INSPECTION INVOLVED 62 INSPECTOR-HOURS ON SITE IN THE AREAS OF AN EMERGENCY EXERCISE. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.
INSPECTION JULY 9-13 (84-16): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 21 INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT CHEMISTRY AND INSERVICE INSPECTION OF PUMPS AND VALVES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.
INSPECTION JUNE 6 - JULY 5 (84-17): THIS ROUTINE INSPECTION INVOLVED 69 INSPECTOR-HOURS ON SITE IN THE AREAS OF OPERATIONAL SAFETY VERIFICATION, ESP SYSTEM OPERABILITY VERIFICATION, INDEPENDENT INSPECTION EFFORT, SURVEILLANCE AND MAINTENANCE, AND LER REVIEW. OF THE SIX AREAS INSPECTED NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN FIVE AREAS; TWO WERE FOUND IN ONE AREA (FAILURE TO LOCK CONTAINMENT ISOLATION VALVE 1-33-704, AND FAILURE TO MAINTAIN CONTAINMENT CLEAR OF DEBRIS).
INSPECTION JULY 22-26 (84-20): THIS ROUTINE UNANNOUNCED INSPECTION ENTAILED 18 INSPECTOR-HOURS ON SITE (SIX HOURS ON BACK SHIFT) INSPECTING: SECURITY ORGANIZATION - PERSONNEL AND RESPONSE; SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS - PROTECTED AND VITAL AREAS; SECURITY SYSTEM POWER SUPPLY; ACCESS CONTROL - PERSONNEL AND VEHICLES; DETECTION AIDS - PROTECTED AND VITAL AREAS AND COMMUNICATIONS. THREE VIOLATIONS WERE IDENTIFIED - FAILURE TO ESCORT VISITORS WHILE IN THE PROTECTED AREA, FAILURE TO PROPERLY SEARCH VEHICLES PRIOR TO ENTERING THE PROTECTED AREA AND FAILURE TO SECURE A DESIGNATED VEHICLE IN THE PROTECTED AREA.

1. Docket: 50-335 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: N. W. GRANT (305) 552-3675

4. Licensed Thermal Power (MWt): 2700

5. Nameplate Rating (Gross MWe): 1000 X 0.89 = 890

6. Design Electrical Rating (Net MWe): 830

7. Maximum Dependable Capacity (Gross MWe): 867

8. Maximum Dependable Capacity (Net MWe): 822

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):


11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>67,463.0</u>
13. Hours Reactor Critical	<u>732.0</u>	<u>2,665.8</u>	<u>47,132.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>205.3</u>
15. Hrs Generator On-Line	<u>708.6</u>	<u>2,446.4</u>	<u>46,023.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>39.3</u>
17. Gross Therm Ener (MWH)	<u>1,882,130</u>	<u>6,297,241</u>	<u>114,965,179</u>
18. Gross Elec Ener (MWH)	<u>628,390</u>	<u>2,097,870</u>	<u>37,471,745</u>
19. Net Elec Ener (MWH)	<u>595,864</u>	<u>1,966,726</u>	<u>35,296,426</u>
20. Unit Service Factor	<u>95.2</u>	<u>41.8</u>	<u>68.2</u>
21. Unit Avail Factor	<u>95.2</u>	<u>41.8</u>	<u>68.3</u>
22. Unit Cap Factor (MDC Net)	<u>97.4</u>	<u>40.9</u>	<u>63.6</u>
23. Unit Cap Factor (DER Net)	<u>96.5</u>	<u>40.5</u>	<u>63.0</u>
24. Unit Forced Outage Rate	<u>4.8</u>	<u>5.0</u>	<u>4.6</u>
25. Forced Outage Hours	<u>35.4</u>	<u>130.1</u>	<u>2,234.8</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>NONE</u>			

27. If Currently Shutdown Estimated Startup Date: N/A

* ST LUCIE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
ST LUCIE 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * ST LUCIE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
08	08/23/84	F	15.0	A	1	84-007	IA	RELAYX	REACTOR TRIPPED DURING LOGIC MATRIX SURVEILLANCE DUE TO LOGIC MATRIX CABINET DC FAILURE. THE UNIT RETURNED TO POWER OPERATION.
09	08/23/84	F	0.8	A	9		HA	INSTRU	THE TURBINE TRIPPED (WITHOUT REACTOR TRIP DUE TO LOW POWER LEVEL) DUE TO ANTI-MOTRING DIFFERENTIAL SWITCH MALFUNCTION. THE UNIT WAS RETURNED TO OPERATION.
10	08/31/84	F	19.6	H	1		HF	ZZZZZ	EXCESSIVE NUMBER OF JELLYFISH IN INTAKE CANAL PREVENTED PLANT OPERATION AT POWER.

 * SUMMARY *

 ST. LUCIE 1 INCURRED 2 SHUTDOWNS IN AUGUST AS DESCRIBED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

* ST LUCIE 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....FLORIDA
COUNTY.....ST LUCIE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...12 MI SE OF
FT. PIERCE, FLA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...APRIL 22, 1976
DATE ELEC ENER 1ST GENER...MAY 7, 1976
DATE COMMERCIAL OPERATE...DECEMBER 21, 1976
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...ATLANTIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER & LIGHT
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 529100
MIAMI, FLORIDA 33152
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....C. FEIERABEND
LICENSING PROJ MANAGER.....D. SELLS
DOCKET NUMBER.....50-335
LICENSE & DATE ISSUANCE...DPR-67, MARCH 1, 1976
PUBLIC DOCUMENT ROOM.....INDIAN RIVER COMMUNITY COLLEGE LIBRARY
3209 VIRGINIA AVENUE
FT. PIERCE, FLORIDA 33450

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 15 - AUGUST 11 (84-23): THIS ROUTINE RESIDENT INSPECTION INVOLVED 74 RESIDENT INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT OPERATION, SURVEILLANCE OBSERVATION, MAINTENANCE OBSERVATION, I.E. BULLETINS, UNIT 1 REACTOR TRIP, AND PREVIOUSLY IDENTIFIED ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

DURING REFUELING OUTAGE, THE THERMAL SHIELD WITHIN THE REACTOR VESSEL WAS FOUND TO BE BROKEN. THE SHIELD HAS BEEN REMOVED.

FACILITY ITEMS (PLANS AND PROCEDURES):

1. Docket: 50-389 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: N. W. GRANT (305) 552-3675

4. Licensed Thermal Power (MWt): 2560

5. Nameplate Rating (Gross MWe): 0850

6. Design Electrical Rating (Net MWe): 804

7. Maximum Dependable Capacity (Gross MWe): 832

8. Maximum Dependable Capacity (Net MWe): 786

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>9,360.0</u>
13. Hours Reactor Critical	<u>710.6</u>	<u>5,803.0</u>	<u>9,030.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>709.9</u>	<u>5,666.5</u>	<u>8,796.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,817,081</u>	<u>14,381,775</u>	<u>22,039,719</u>
18. Gross Elec Ener (MWH)	<u>606,190</u>	<u>4,813,700</u>	<u>7,356,920</u>
19. Net Elec Ener (MWH)	<u>573,260</u>	<u>4,554,289</u>	<u>6,951,875</u>
20. Unit Service Factor	<u>95.4</u>	<u>96.8</u>	<u>94.0</u>
21. Unit Avail Factor	<u>95.4</u>	<u>96.8</u>	<u>94.0</u>
22. Unit Cap Factor (MDC Net)	<u>98.0</u>	<u>99.0</u>	<u>94.5</u>
23. Unit Cap Factor (DER Net)	<u>95.8</u>	<u>96.7</u>	<u>92.4</u>
24. Unit Forced Outage Rate	<u>3.6</u>	<u>2.6</u>	<u>5.6</u>
25. Forced Outage Hours	<u>26.3</u>	<u>150.6</u>	<u>525.2</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING, OCTOBER 1984, 5 WEEKS.

27. If Currently Shutdown Estimated Startup Date: 09/08/84

 * ST LUCIE 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ST LUCIE 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * ST LUCIE 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
06	08/30/84	F	8.9	A	3	389-84-05	IB	RELAYX	A FAILED RELAY IN THE AUXILIARY FEEDWATER ACTUATION SYSTEM RESULTED IN A REACTOR TIRP. RETURN TO POWER OPERATION WAS DELAYED DUE TO FOLLOWING EVENTS.
07	08/30/84	S	7.8	B	9		HF	FILTER	IT WAS DECIDED TO EXTEND THE ABOVE OUTAGE TO REPAIR TRAVELLING SCREENS WHICH WERE DAMAGED BY EXCESSIVE JELLYFISH. RETURN TO POWER OPERATION WAS DELAYED DUE TO FOLLOWING EVENT.
08	08/31/84	F	17.4	H	9		HF	ZZZZZ	EXCESSIVE JELLYFISH IN INTAKE CANAL PREVENTED PLANT OPERATION.

 * SUMMARY *

 ST. LUCIE 2 EXPERIENCED 3 SHORT SHUTDOWNS IN AUGUST AS DESCRIBED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* ST LUCIE 2 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....FLORIDA
COUNTY.....ST LUCIE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...12 MI SE OF
FT. PIERCE, FLA
TYPE OF REACTOR... PWR
DATE INITIAL CRITICALITY...JUNE 2, 1983
DATE ELEC ENER 1ST GENER...JUNE 13, 1983
DATE COMMERCIAL OPERATE...AUGUST 8, 1983
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...ATLANTIC OCEAN
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER & LIGHT
CORPORATE ADDRESS.....9250 WEST FLAGLER ST., P.O. BOX 529100
MIAMI, FLORIDA 33152
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....C. FEYERABEND
LICENSING PROJ MANAGER.....D. SELLS
DOCKET NUMBER.....50-389
LICENSE & DATE ISSUANCE...NPF-16, JUNE 10, 1983
PUBLIC DOCUMENT ROOM.....INDIAN RIVER COMMUNITY COLLEGE LIBRARY
3209 VIRGINIA AVENUE
FT. PIERCE, FLORIDA 33450

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 15 - AUGUST 11 (84-25): THIS ROUTINE RESIDENT INSPECTION INVOLVED 73 RESIDENT INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT OPERATION, SURVEILLANCE OBSERVATION, MAINTENANCE OBSERVATION, I.E. BULLETINS, UNIT 1 REACTOR TRIP, AND PREVIOUSLY IDENTIFIED ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

PERFORMING STARTUP TESTING.
SYSTEMS AND COMPONENT PROBLEMS:
NONE.

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* ST LUCIE 2 *

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JULY 15 - AUGUST 11, 1984 +

INSPECTION REPORT NO: 50-389/84-25 +

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE.			

=====

1. Docket: 50-395 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: G. A. LOIGNON (803) 345-5209

4. Licensed Thermal Power (MWt): 2775

5. Nameplate Rating (Gross MWe): 0900

6. Design Electrical Rating (Net MWe): 900

7. Maximum Dependable Capacity (Gross MWe): 900

8. Maximum Dependable Capacity (Net MWe): 885

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____


 NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>5,855.0</u>
13. Hours Reactor Critical	<u>726.4</u>	<u>4,583.6</u>	<u>4,583.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>718.4</u>	<u>4,425.8</u>	<u>4,425.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,844,750</u>	<u>11,471,650</u>	<u>11,471,650</u>
18. Gross Elec Ener (MWH)	<u>614,320</u>	<u>3,816,853</u>	<u>3,816,853</u>
19. Net Elec Ener (MWH)	<u>587,932</u>	<u>3,638,961</u>	<u>3,638,961</u>
20. Unit Service Factor	<u>96.6</u>	<u>75.6</u>	<u>75.6</u>
21. Unit Avail Factor	<u>96.6</u>	<u>75.6</u>	<u>75.6</u>
22. Unit Cap Factor (MDC Net)	<u>89.3</u>	<u>69.9</u>	<u>70.2</u>
23. Unit Cap Factor (DER Net)	<u>87.8</u>	<u>69.1</u>	<u>69.1</u>
24. Unit Forced Outage Rate	<u>3.4</u>	<u>12.7</u>	<u>12.7</u>
25. Forced Outage Hours	<u>25.6</u>	<u>644.4</u>	<u>644.4</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):	<u>REFUELING, SEPTEMBER 28, 1984, 60 DAYS</u>		
27. If Currently Shutdown Estimated Startup Date:	<u>N/A</u>		

 * S U M M E R 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SUMMER 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * SUMMER 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
9	08/16/84	F	25.6	A	1				REPLACE INSULATOR IN ISOPHASE BUS DUCT.
10	08/19/84	F	0.0	A	5				ISOPHASE BUS DUCT HEATING, REDUCED POWER, DETERMINED CONDITION ACCEPTABLE, INCREASED POWER.

 * SUMMARY *

 SUMMER 1 EXPERIENCED 1 SHUTDOWN IN AUGUST TO REPLACE AN ISOLATOR BUS DUCT INSULATOR.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SUMMER 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION
STATE.....SOUTH CAROLINA
COUNTY.....FAIRFIELD
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...26 MI NW OF
COLUMBIA, SC
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 22, 1982
DATE ELEC ENER 1ST GENER...NOVEMBER 16, 1982
DATE COMMERCIAL OPERATE....JANUARY 1, 1984
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...MONTICELLO RESERVOIR
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY
LICENSEE.....SOUTH CAROLINA ELECTRIC & GAS CO.
CORPORATE ADDRESS.....P.O. BOX 764
COLUMBIA, SOUTH CAROLINA 29202
CONTRACTOR
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....DANIEL INTERNATIONAL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....C. HEHL
LICENSING PROJ MANAGER.....J. HOPKINS
DOCKET NUMBER.....50-395
LICENSE & DATE ISSUANCE...NPF-12, NOVEMBER 12, 1982
PUBLIC DOCUMENT ROOM.....FAIRFIELD COUNTY LIBRARY
GARDEN & WASHINGTON STREETS
WINNSBORO, SOUTH CAROLINA 29180

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 9-13 (84-17): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 82 INSPECTOR-HOURS ON SITE IN THE AREA OF EMERGENCY PREPAREDNESS. OF THE AREA INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 9-13 (84-18): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 98 INSPECTOR-HOURS ON SITE IN THE AREAS OF LICENSEE ACTION ON PREVIOUS ENFORCEMENT MATTERS; QA PROGRAM REVIEW; QA/QC ADMINISTRATION; AUDITS; PROCUREMENT CONTROL; RECEIPT, STORAGE, AND HANDLING OF EQUIPMENT AND MATERIALS; INDEPENDENT INSPECTION; AND LICENSEE ACTION ON PREVIOUSLY IDENTIFIED INSPECTION FINDINGS. OF THE EIGHT AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 23-27 (84-19): THIS ROUTINE, UNANNOUNCED INSPECTION ENTAILED 26 INSPECTOR-HOURS ON SITE (TWO HOURS ON BACK-SHIFT) AND SIX INSPECTOR-HOURS AT THE CORPORATE OFFICE INSPECTING: SECURITY ORGANIZATION-PERSONNEL/RESPONSE, SECURITY PROGRAM AUDIT, TESTING AND MAINTENANCE, PHYSICAL BARRIERS-PROTECTED AREA/VITAL AREAS, SECURITY SYSTEM POWER SUPPLY, ASSESSMENT AIDS, ACCESS CONTROL-PERSONNEL/PACKAGES/ VEHICLES, AND ALARM STATIONS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 23-27 (84-21): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 32 INSPECTOR-HOURS ON SITE IN THE AREAS OF STEAM GENERATOR TUBE LEAKAGE, INSERVICE INSPECTION, INSERVICE TESTING OF PIPES AND VALVES, AND INSPECTOR FOLLOWUP ITEMS - RELATED TO AIR HANDLING UNITS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JULY 1-31 (84-23): THIS ROUTINE, RESIDENT INSPECTION ENTAILED 114 INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT TOURS; OPERATIONAL SAFETY VERIFICATION; MONTHLY SURVEILLANCE OBSERVATIONS; MONTHLY MAINTENANCE OBSERVATION; REVIEW OF INSPECTOR FOLLOWUP


```

=====

```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-028	06/29/84	07/19/84	STEAM INLET FLOW CONTROL VALVE TO TURBINE DRIVEN EMERGENCY FEEDWATER PUMP FAILED OPEN RESULTING IN INADVERTENT START.
84-029	07/13/83	08/10/84	DEFECTIVE BROWN BOVERI SPEED AND TRANSFER SWITCHES EQUIPMENT OPERABILITY CAN BE MAINTAINED TORQUED TO 60 FT./LBS.
84-030	04/12/84	08/10/84	COOLING UNIT, WAS FOUND TO HAVE BEEN SUPPLIED WITHOUT A COIL V-BRACE STRUCTURAL MEMBER. SCE&G RESTORED THE UNIT TO ITS ORIGINAL DESIGN CONDITION.
84-031	07/17/84	08/16/84	SEVEN ELECTRICAL CIRCUITS WERE NOT INCLUDED IN TABLE 3.8-1 OF TECHNICAL SPECIFICATION (TS), THE LICENSEE WILL SUBMIT A TS CHANGE.

```

=====

```


THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-280 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: VIVIAN H. JONES (804) 357-3184

4. Licensed Thermal Power (MWt): 2441

5. Nameplate Rating (Gross MWe): 942 X 0.9 = 848

6. Design Electrical Rating (Net MWe): 788

7. Maximum Dependable Capacity (Gross MWe): 811

8. Maximum Dependable Capacity (Net MWe): 775

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>102,503.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>4,550.8</u>	<u>63,649.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>9.3</u>	<u>3,774.5</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>4,477.8</u>	<u>62,344.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,736.2</u>
17. Gross Therm Ener (MWH)	<u>1,421,403</u>	<u>9,837,649</u>	<u>144,238,262</u>
18. Gross Elec Ener (MWH)	<u>437,625</u>	<u>3,143,785</u>	<u>46,463,628</u>
19. Net Elec Ener (MWH)	<u>408,868</u>	<u>2,971,195</u>	<u>44,048,931</u>
20. Unit Service Factor	<u>100.0</u>	<u>76.5</u>	<u>60.8</u>
21. Unit Avail Factor	<u>100.0</u>	<u>76.5</u>	<u>64.5</u>
22. Unit Cap Factor (MDC Net)	<u>70.9</u>	<u>65.5</u>	<u>55.4</u>
23. Unit Cap Factor (DER Net)	<u>69.7</u>	<u>64.4</u>	<u>54.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.5</u>	<u>20.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>212.3</u>	<u>12,424.1</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
REFUELING 9-28-84 - 75 DAYS

27. If Currently Shutdown Estimated Startup Date: N/A

* SURRY 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SURRY 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* SURRY 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

* SUMMARY *

SURRY 1 OPERATED ROUTINELY IN AUGUST WITH NO SHUTDOWNS OR POWER REDUCTIONS REPORTED.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

* SURRY 1 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....VIRGINIA
COUNTY.....SURRY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI NW OF
NEWPORT NEWS, VA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JULY 1, 1972
DATE ELEC ENER 1ST GENER...JULY 4, 1972
DATE COMMERCIAL OPERATE...DECEMBER 22, 1972
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...JAMES RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VIRGINIA ELECTRIC & POWER
CORPORATE ADDRESS.....P.O. BOX 26666
RICHMOND, VIRGINIA 23261
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....D. BURKE
LICENSING PROJ MANAGER.....D. NEIGHBORS
DOCKET NUMBER.....50-280
LICENSE & DATE ISSUANCE...DPR-32, MAY 25, 1972
PUBLIC DOCUMENT ROOM.....SWEM LIBRARY
COLLEGE OF WILLIAM AND MARY
WILLIAMSBURG, VIRGINIA 23185

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 16-18 (84-21): THIS REACTIVE UNANNOUNCED INSPECTION INVOLVED 19 INSPECTOR-HOURS ON SITE IN THE FOLLOWUP OF LICENSEE EVENTS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.
INSPECTION JULY 1-31 (84-22): THIS INSPECTION INVOLVED 110 INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT OPERATIONS AND OPERATING RECORDS, PLANT MAINTENANCE AND SURVEILLANCE, PLANT SECURITY, FOLLOWUP OF EVENTS, AND LICENSEE EVENT REPORTS. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.
INSPECTION JULY 9-11 (84-23): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 10 INSPECTOR-HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO THE REQUIREMENTS OF TECHNICAL SPECIFICATION 4.17.F, THE PROGRAM IMPLEMENTED TO MONITOR THE SERVICE LIFE OF HYDRAULIC SNUBBERS WAS INADEQUATE.

(8411 3)

1. Docket: 70-281 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: VIVIAN H. JONES (804) 357-3184

4. Licensed Thermal Power (MWt): 2441

5. Nameplate Rating (Gross MWe): 942 X 0.9 = 848

6. Design Electrical Rating (Net MWe): 788

7. Maximum Dependable Capacity (Gross MWe): 811

8. Maximum Dependable Capacity (Net MWe): 775

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level T, Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>99,383.0</u>
13. Hours Reactor Critical	<u>729.3</u>	<u>5,087.6</u>	<u>63,658.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>23.8</u>	<u>23.8</u>
15. Hrs Generator On-Line	<u>727.0</u>	<u>5,031.6</u>	<u>62,607.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,746,844</u>	<u>11,896,464</u>	<u>146,612,336</u>
18. Gross Elec Ener (MWH)	<u>546,780</u>	<u>3,785,785</u>	<u>47,575,644</u>
19. Net Elec Ener (MWH)	<u>517,818</u>	<u>3,586,561</u>	<u>45,093,621</u>
20. Unit Service Factor	<u>97.7</u>	<u>85.9</u>	<u>63.0</u>
21. Unit Avail Factor	<u>97.7</u>	<u>85.9</u>	<u>63.0</u>
22. Unit Cap Factor (MDC Net)	<u>89.8</u>	<u>79.0</u>	<u>58.5</u>
23. Unit Cap Factor (DER Net)	<u>88.3</u>	<u>77.7</u>	<u>57.6</u>
24. Unit Forced Outage Rate	<u>2.3</u>	<u>8.5</u>	<u>13.7</u>
25. Forced Outage Hours	<u>17.0</u>	<u>466.9</u>	<u>7,293.5</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


MAINTENANCE: 11-9-84 TO 11-19-84, 10 DAYS

27. If Currently Shutdown Estimated Startup Date: N/A

 * SURRY 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SURRY 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * SURRY 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-20	08/07/84	F	17.0	A	3	84-013			THE UNIT RECEIVED A TURBINE RUNBACK TO 300 MW'S, THEN TWO MINUTES LATER, RECEIVED A REACTOR TRIP. THE CAUSE OF THE RUNBACK WAS A NIS RUNBACK FROM N-43 WHEN THE CONTROL POWER FUSE BLEW WHILE INST. TECHS. WERE TROUBLE SHOOTING A FAILURE OF THE FLUX METER. THE BLOWN FUSE WAS CAUSED BY USING AN UNGROUNDED CORD ON TEST METER.
84-21	08/15/84	S	0.0	H	5				THE UNIT WAS REDUCED TO 78% POWER (570 MW'S) TO ALLOW REMOVAL AND CLEANING OF "A" WATERBOX.
84-22	08/18/84	F	0.0	A	5				THE UNIT WAS REDUCED TO 67% POWER (485 MW'S) DUE TO THE LOSS OF FOUR CIRCULATORS AT THE LOW LEVEL INTAKE. THE CIRCULATORS TRIPPED OFF ON HIGH WATER LEVEL IN PIT CAUSED BY GROSS LEAKAGE FROM 1-CW-P-1D. THE PUMP WAS REMOVED FROM SERVICE AND IS BEING REPAIRED.
84-23	08/21/84	S	0.0	H	5				THE UNIT WAS REDUCED TO 76% POWER (580 MW'S) TO ALLOW REMOVAL AND CLEANING OF "A" WATERBOX.

 * SUMMARY *

 SURRY 2 OPERATED ROUTINELY IN AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sciad	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

* SURRY 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....VIRGINIA
COUNTY.....SURRY
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...17 MI NW OF
NEWPORT NEWS, VA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...MARCH 7, 1973
DATE ELEC ENER 1ST GENER...MARCH 10, 1973
DATE COMMERCIAL OPERATE...MAY 1, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...JAMES RIVER
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VIRGINIA ELECTRIC & POWER
CORPORATE ADDRESS.....P.O. BOX 26666
RICHMOND, VIRGINIA 23261
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....D. BURKE
LICENSING PROJ MANAGER.....D. NEIGHBORS
DOCKET NUMBER.....50-281
LICENSE & DATE ISSUANCE...DPR-37, JANUARY 29, 1973
PUBLIC DOCUMENT ROOM.....SWEM LIBRARY
COLLEGE OF WILLIAM AND MARY
WILLIAMSBURG, VIRGINIA 23185

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 16-18 (84-21): THIS REACTIVE UNANNOUNCED INSPECTION INVOLVED 19 INSPECTOR-HOURS ON SITE IN THE FOLLOWUP OF LICENSEE EVENTS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.
INSPECTION JULY 1-31 (84-22): THIS INSPECTION INVOLVED 110 INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT OPERATIONS AND OPERATING RECORDS, PLANT MAINTENANCE AND SURVEILLANCE, PLANT SECURITY, FOLLOWUP OF EVENTS, AND LICENSEE EVENT REPORTS. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.
INSPECTION JULY 9-11 (84-23): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 10 INSPECTOR-HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO THE REQUIREMENTS OF TECHNICAL SPECIFICATION 4.17.F, THE PROGRAM IMPLEMENTED TO MONITOR THE SERVICE LIFE OF HYDRAULIC SNUBBERS WAS INADEQUATE.

(8411 3)

Report Period AUG 1984

INSPECTION STATUS - (CONTINUED)

* SURRY 2 *

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.4.A.7 REQUIRES THAT DETAILED WRITTEN PROCEDURES WITH APPROPRIATE CHECK-OFF LISTS AND INSTRUCTIONS SHALL BE PROVIDED FOR PREVENTATIVE OR CORRECTIVE MAINTENANCE OPERATIONS ON SAFETY RELATED EQUIPMENT. CONTRARY TO THE ABOVE REQUIREMENT, THE CORRECTIVE MAINTENANCE PROCEDURE (ELECTRICAL) FOR SAFETY RELATED MOTOR OPERATED VALVES, EMP-C-MOV-50, "TORQUE SWITCH ADJUSTMENTS", DID NOT CONTAIN APPROPRIATE INSTRUCTIONS FOR SETTING OR ADJUSTING THE LIMITORQUE (SMB-000) DOUBLE TORQUE SWITCH ON THE UNIT 1 AND 2 SEA WICE WATER (SW) MOTOR OPERATED VALVES SW-MOV-103A THROUGH D AND SW-MOV-203A THROUGH D, WHICH SUPPLY WATER TO THE RECIRCULATION SPRAY HEAT EXCHANGERS DURING ACCIDENT CONDITIONS. EMP-C-MOV-50 DID NOT PROVIDE INSTRUCTIONS FOR MID-POSITIONING OR MANUALLY DECLUTCHING THE MOV BEFORE SETTING OR ADJUSTING THE TORQUE SWITCHES, WHICH APPARENTLY RESULTED IN THE INCORRECT TORQUE SWITCH SETTINGS ON SW-MOV-203D OBSERVED BY THE INSPECTOR ON JUNE 5, 1984.
(8420 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL AT POWER OPERATIONS.

LAST IE SITE INSPECTION DATE: JULY 9-11, 1984 +

INSPECTION REPORT NO: 50-281/84-23 +

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE.			

1. Docket: 50-387 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: L. A. KUCZYNSKI (717) 542-2181

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1068

8. Maximum Dependable Capacity (Net MWe): 1032

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____

11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>10,824.0</u>
13. Hours Reactor Critical	<u>744.0</u>	<u>3,895.4</u>	<u>7,740.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>209.6</u>	<u>366.3</u>
15. Hrs Generator On-Line	<u>744.0</u>	<u>3,770.7</u>	<u>7,539.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,392,310</u>	<u>11,471,966</u>	<u>22,721,737</u>
18. Gross Elec Ener (MWH)	<u>772,140</u>	<u>3,737,610</u>	<u>7,404,160</u>
19. Net Elec Ener (MWH)	<u>745,057</u>	<u>3,598,837</u>	<u>7,135,210</u>
20. Unit Service Factor	<u>.00.0</u>	<u>64.4</u>	<u>69.7</u>
21. Unit Avail Factor	<u>100.0</u>	<u>64.4</u>	<u>69.7</u>
22. Unit Cap Factor (MDC Net)	<u>97.0</u>	<u>59.6</u>	<u>63.9</u>
23. Unit Cap Factor (DER Net)	<u>94.0</u>	<u>57.7</u>	<u>61.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>18.0</u>	<u>15.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>828.8</u>	<u>1,337.3</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


REFUELING OUTAGE: FEBRUARY 9, 1985; 13 WEEKS

27. If Currently Shutdown Estimated Startup Date: N/A

 * SUSQUEHANNA 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SUSQUEHANNA 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* SUSQUEHANNA 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
10	08/18/84	S	0.0	H	5		RB	CONROD	SCHEDULED CONTROL ROD SEQUENCE EXCHANGE TO MINIMIZE THE CONTROL BLADE HISTORY EFFECT ON THE FUEL.

* SUMMARY *

SUSQUEHANNA 1 OPERATED ROUTINELY IN AUGUST WITH NO SHUTDOWNS REPORTED.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

* SUSQUEHANNA 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....LUZERNE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...7 MI NE OF
BERWICK, PA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...SEPTEMBER 10, 1982
DATE ELEC ENER 1ST GENER...NOVEMBER 16, 1982
DATE COMMERCIAL OPERATE....JUNE 8, 1983
CONDENSER COOLING METHOD...CC,HNDCT
CONDENSER COOLING WATER....SUSQUEHANNA RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PENNSYLVANIA POWER & LIGHT
CORPORATE ADDRESS.....2 NORTH NINTH STREET
ALLENTOWN, PENNSYLVANIA 18101
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....R. JACOBS
LICENSING PROJ MANAGER.....R. PERCH
DOCKET NUMBER.....50-387
LICENSE & DATE ISSUANCE....NPF-14, NOVEMBER 12, 1982
PUBLIC DOCUMENT ROOM.....OSTERHOUT FREE LIBRARY
71 SOUTH FRANKLIN STREET
WILKES-BARRE, PENNSYLVANIA 18701

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

1. Docket: 50-388 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: L. A. KUCZYNSKI (717) 542-3759

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1065

8. Maximum Dependable Capacity (Net MWe): 1065

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____


11. Reasons for Restrictions, If Any: _____

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>1,427.0</u>	<u>1,427.0</u>
13. Hours Reactor Critical	<u>581.9</u>	<u>1,040.6</u>	<u>1,040.6</u>
14. Rx Reserve Shtdwn Hrs	<u>162.1</u>	<u>342.4</u>	<u>342.4</u>
15. Hrs Generator On-Line	<u>373.4</u>	<u>766.3</u>	<u>766.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>142.4</u>	<u>142.4</u>
17. Gross Therm Ener (MWH)	<u>470,952</u>	<u>944,986</u>	<u>944,986</u>
18. Gross Elec Ener (MWH)	<u>132,920</u>	<u>254,250</u>	<u>254,250</u>
19. Net Elec Ener (MWH)	<u>121,170</u>	<u>231,451</u>	<u>231,451</u>
20. Unit Service Factor			
21. Unit Avail Factor		NOT IN	
22. Unit Cap Factor (MDC Net)		COMMERCIAL	
23. Unit Cap Factor (DER Net)		OPERATION	
24. Unit Forced Outage Rate			
25. Forced Outage Hours	<u>260.3</u>	<u>320.5</u>	<u>320.5</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):	<u>MAINTENANCE OUTAGE; OCTOBER 20, 1984; 8 WEEKS</u>		
27. If Currently Shutdown Estimated Startup Date:	<u>09/04/84</u>		

 * SUSQUEHANNA 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
 SUSQUEHANNA 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * SUSQUEHANNA 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
3	07/26/84	S	57.2	B	3	84-013	ZZ	ZZZZZZ	REACTOR SCRAM FOR SCHEDULED STARTUP TEST.
4	08/07/84	S	53.1	B	3		ZZ	ZZZZZZ	REACTOR SCRAM AS PART OF SCHEDULED STARTUP TEST.
5	08/10/84	F	53.9	H	3		HA	XXXXXX	GENERATOR REMOVED FROM GRID TO INSTALL MISSING GASKET IN MAIN STEAM LINE.
6	08/13/84	F	95.7	H	3		HA	XXXXXX	GENERATOR REMOVED FROM GRID TO INSTALL GASKET IN MAIN STEAM LINE.
7	08/26/84	F	28.6	A	3	84-017	HA	VALVEX	REACTOR SCRAM FOLLOWING TURBINE TRIP ON MOISTURE SEPARATOR DRAIN TANK HIGH LEVEL.
8	08/28/84	F	82.1	A	3	84-017	HA	VALVEX	REACTOR SCRAM FOLLOWING TURBINE TRIP ON MOISTURE SEPARATOR DRAIN TANK HIGH LEVEL.

 * SUMMARY *

 SUSQUEHANNA CONTINUES IN TESTING AND APPROACH TO FULL POWER.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* SUSQUEHANNA 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....PENNSYLVANIA
COUNTY.....LUZERNE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...7 MI NE OF
BERWICK, PA
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MAY 8, 1984
DATE ELEC ENER 1ST GENER...JULY 3, 1984
DATE COMMERCIAL OPERATE....*****
CONDENSER COOLING METHOD...CC,HNDCT
CONDENSER COOLING WATER...SUSQUEHANNA RIVER
ELECTRIC RELIABILITY
COUNCIL.....MID-ATLANTIC
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PENNSYLVANIA POWER & LIGHT
CORPORATE ADDRESS.....2 NORTH NINTH STREET
ALLENTOWN, PENNSYLVANIA 18101
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....L. PLISCO
LICENSING PROJ MANAGER....R. PERCH
DOCKET NUMBER.....50-388
LICENSE & DATE ISSUANCE...NPF-22, JUNE 27, 1984
PUBLIC DOCUMENT ROOM.....

WILKES-BARRE, PENNSYLVANIA 18701

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

* SUSQUEHANNA 2 *

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

1. Docket: 50-289 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: C. W. SMYTH (717) 948-8551

4. Licensed Thermal Power (MWt): 2535

5. Nameplate Rating (Gross MWe): 968 X 0.9 = 871

6. Design Electrical Rating (Net MWe): 819

7. Maximum Dependable Capacity (Gross MWe): 840

8. Maximum Dependable Capacity (Net MWe): 776

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):


11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>87,648.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>31,731.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>839.5</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>31,180.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>76,531,071</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>25,484,330</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>23,840,053</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>35.6</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>35.6</u>
22. Unit Cap Factor (Net)	<u>.0</u>	<u>.0</u>	<u>34.8*</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>33.2</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>61.1</u>
25. Forced Outage Hours	<u>744.0</u>	<u>5,855.0</u>	<u>48,980.5</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>NONE</u>			

27. If Currently Shutdown Estimated Startup Date: N/A

* THREE MILE ISLAND 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT
THREE MILE ISLAND 1



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* THREE MILE ISLAND 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/17/79	F	744.0	D	4		ZZ	ZZZZZ	REGULATORY RESTRAINT ORDER CONTINUES.

* SUMMARY *

THREE MILE ISLAND 1 REMAINS SHUT DOWN FOLLOWING THE ACCIDENT AT UNIT 2.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.8.1 REQUIRES, IN PART, THAT WRITTEN PROCEDURES IMPORTANT TO SAFETY SHALL BE IMPLEMENTED. ADMINISTRATIVE PROCEDURE 1043, REVISION 6, JANUARY 10, 1984, CONTROL OF PLANT MODIFICATIONS, PARAGRAPHS 3.8.5 AND 3.8.11 REQUIRE, IN PART, THAT THE GROUP INSTALLING A MODIFICATION OBSERVE THE REQUIREMENTS OF THE INSTALLATION PROCEDURES APPLICABLE TO A JOB ORDER(S) AND THAT, UPON COMPLETION OF THE WORK, THE GROUP SHALL SIGN THE COMPLETION SECTION OF THE JOB ORDER LISTING ANY DEFICIENCIES OR INCOMPLETE WORK LIST ITEMS. THE JOB ORDER A25A-30377, MODIFICATION OF THE UNIT 2 CONDENSATE STORAGE TANK (CST) FOR USE BY UNIT 1, REQUIRES, IN PART, THE INSTALLATION OF A WELDED VENT CAP OVER A STORM DRAIN PIPE TO PREVENT CST WATER OVERFLOW (POTENTIALLY CONTAMINATED) DIRECTLY INTO THE NEARBY STORM DRAIN SYSTEM. CONTRARY TO THE ABOVE, AS OF APRIL 18, 1984, THE VENT CAP FOR THE STORM DRAIN PIPE NEAR THE UNIT 2 CST (DESIGNATED FOR USE BY UNIT 1) WAS NOT INSTALLED AND WELDED. IN ADDITION, THE ASSOCIATED JOB ORDER WAS SIGNED OFF AS BEING COMPLETE WITH NO DEFICIENCIES OR INCOMPLETE WORK ITEMS LISTED REGARDING THE VENT CAP INSTALLATION. THIS IS A SEVERITY LEVEL IV VIOLATION (SUPPLEMENT I).
(8411 4)

TECHNICAL SPECIFICATION 6.8.1 SPECIFIES THAT WRITTEN PROCEDURES RECOMMENDED IN APPENDIX A OF REGULATORY GUIDE 1.33, REVISION 2, FEBRUARY 1978 SHALL BE ESTABLISHED, IMPLEMENTED AND MAINTAINED. RWP PROCEDURE 1613, REVISION 25, SECTION 5.2 STATES, "A DOSE RATE INSTRUMENT OR AN ALARMING DOSIMETER IS REQUIRED FOR ENTRY INTO AN AREA THAT IS ENTERED UNDER A STANDING RWP." RADIATION WORK PERMIT NO. 25908, A STANDING RWP FOR THE NUCLEAR SAMPLING ROOM REQUIRES A DOSE RATE INSTRUMENT OR XETEX FOR ENTRY INTO THE AREA COVERED BY THIS PERMIT. CONTRARY TO THE ABOVE, THE PROVISIONS OF THE RADIATION WORK PERMIT WERE NOT FOLLOWED. ON JUNE 7, 1984, AT APPROXIMATELY 9:00 A.M. AND AGAIN AT APPROXIMATELY 9:30 A.M., A CHEMISTRY TECHNICIAN WAS OBSERVED BY THE INSPECTOR ENTERING THE AREA COVERED BY RADIATION WORK PERMIT NO. 25908 WITHOUT A DOSE RATE INSTRUMENT OR XETEX WITH HIM. POSTED DOSE RATE READINGS WERE LOCALIZED ON AREAS OF THE FLOOR AT 100 MILLIREMS (GAMMA) AND 120 MILLIREMS (GAMMA).
(8416 5)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

Report Period AUG 1984

R E P O R T S F R O M L I C E N S E E

* THREE MILE ISLAND 1 *****

=====
NUMBER DATE OF DATE OF SUBJECT
EVENT REPORT

NO INPUT PROVIDED.

=====
=====
=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-344 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: G. G. BAIR (503) 556-3713 X234

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1280 X 0.95 = 1216

6. Design Electrical Rating (Net MWe): 1130

7. Maximum Dependable Capacity (Gross MWe): 1122

8. Maximum Dependable Capacity (Net MWe): 1080

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>70,127.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>2,793.6</u>	<u>41,643.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,875.4</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>2,776.2</u>	<u>40,330.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,237.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>9,111,746</u>	<u>127,675,599</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>2,940,315</u>	<u>41,515,806</u>
19. Net Elec Ener (MWH)	<u>-4,468</u>	<u>2,808,125</u>	<u>39,222,151</u>
20. Unit Service Factor	<u>.0</u>	<u>47.4</u>	<u>57.5</u>
21. Unit Avail Factor	<u>.0</u>	<u>47.4</u>	<u>62.1</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>44.4</u>	<u>51.8</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>42.4</u>	<u>49.5</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.8</u>	<u>17.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>50.3</u>	<u>8,352.1</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 09/12/84

 * TROJAN *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

TROJAN



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* TROJAN *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-07	04/27/84	S	744.0	C	3	84-06	TA	ZZZZZ	CONTINUED ANNUAL REFUELING/MAINTENANCE OUTAGE WHICH BEGAN AT 1827 ON APRIL 27, 1984.

***** TROJAN REMAINED SHUT DOWN FOR REFUELING AND MAINTENANCE DURING ALL OF AUGUST. * SUMMARY * *****

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

* TROJAN *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....OREGON
COUNTY.....COLUMBIA
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...42 MI N OF
PORTLAND, ORE
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 15, 1975
DATE ELEC ENER 1ST GENER...DECEMBER 23, 1975
DATE COMMERCIAL OPERATE...MAY 20, 1976
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...COLUMBIA RIVER
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....PORTLAND GENERAL ELECTRIC
CORPORATE ADDRESS.....121 S.W. SALMON STREET
PORTLAND, OREGON 97204
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....G. JOHNSTON
LICENSING PROJ MANAGER.....C. TRAMMELL
DOCKET NUMBER.....50-344
LICENSE & DATE ISSUANCE...NPF-1, NOVEMBER 21, 1975
PUBLIC DOCUMENT ROOM.....MULTNOMAH COUNTY LIBRARY
SOCIAL SCIENCES & SCIENCE DEPARTMENT
801 SW 10TH AVENUE
PORTLAND, OREGON 97205

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON JULY 12 - AUGUST 6, 1984 (REPORT 50-344/84-18) AREAS INSPECTED: ROUTINE INSPECTION OF OPERATIONAL SAFETY VERIFICATION, CORRECTIVE ACTION, MAINTENANCE, SURVEILLANCE, FOLLOWUP ON PREVIOUS INSPECTION ITEMS, REFUELING ACTIVITIES, SHIFT TURNOVER PRACTICES, AND SPLIT PIN REPLACEMENT WORK. THE INSPECTION INVOLVED 251 INSPECTOR-HOURS ONSITE BY THE NRC RESIDENT INSPECTORS.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JULY 30 - AUGUST 3, 1984 (REPORT NO. 50-344/84-19) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF THE NONCONFORMANCE PROGRAM, ROUTINE (NONAUDIT) QUALITY FINDINGS, QUALIFICATION OF VENDOR SUPPORT PERSONNEL, MAINTENANCE AND TRAINING PROGRAMS. THE INSPECTION INVOLVED 79 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON AUGUST 13 - 17, 1984 (REPORT NO. 50-344/84-20) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON AUGUST 7 - SEPTEMBER 30, 1984 (REPORT NO. 50-344/84-21) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON AUGUST 20-24, 1984 (REPORT NO. 50-344/84-22) REPORT CANCELLED.

1. Docket: 50-250 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: N. W. GRANT (305) 552-3675

4. Licensed Thermal Power (MWt): 2200

5. Nameplate Rating (Gross MWe): 894 X 0.85 = 760

6. Design Electrical Rating (Net MWe): 693

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 666

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>102,920.6</u>
13. Hours Reactor Critical	<u>729.6</u>	<u>4,893.3</u>	<u>72,918.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>844.3</u>
15. Hrs Generator On-Line	<u>725.5</u>	<u>4,783.8</u>	<u>70,706.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>121.8</u>
17. Gross Therm Ener (MWH)	<u>1,535,986</u>	<u>10,249,479</u>	<u>145,738,071</u>
18. Gross Elec Ener (MWH)	<u>487,535</u>	<u>3,294,300</u>	<u>46,504,865</u>
19. Net Elec Ener (MWH)	<u>462,803</u>	<u>3,120,424</u>	<u>44,033,441</u>
20. Unit Service Factor	<u>97.5</u>	<u>81.7</u>	<u>68.7</u>
21. Unit Avail Factor	<u>97.5</u>	<u>81.7</u>	<u>68.8</u>
22. Unit Cap Factor (MDC Net)	<u>93.4</u>	<u>80.0</u>	<u>66.0*</u>
23. Unit Cap Factor (DER Net)	<u>89.8</u>	<u>76.9</u>	<u>61.7</u>
24. Unit Forced Outage Rate	<u>2.5</u>	<u>9.5</u>	<u>5.6</u>
25. Forced Outage Hours	<u>18.5</u>	<u>502.8</u>	<u>3,682.9</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* TURKEY POINT 3 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

TURKEY POINT 3



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * TURKEY POINT 3 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
15	08/22/84	F	0.0	A	5		RB	CONROD	A SHUTDOWN BANK CONTROL ROD DROPPED DUE TO A BLOWN FUSE WHICH CAUSED A TURBINE RUNBACK.
16	08/22/84	F	18.5	A	1	250-84-23	RB	CONROD	THE UNIT WAS SHUTDOWN TO REPAIR A LOOSE CABLE WHICH CAUSED CONTROL ROD FUSE TO BLOW. THE UNIT WAS RETURNED TO POWER OPERATION.
17	08/27/84	F	0.0	A	5		HB	PIPEXX	A CRACKED WELD ON A STEAM GENERATOR FEED PUMP DRAIN LINE REQUIRED A POWER REDUCTION TO REPAIR.
18	08/29/84	F	0.0	A	5		HB	PIPEXX	A FURTHER POWER REDUCTION WAS REQUIRED TO REPAIR ABOVE DRAIN LINE.

 * SUMMARY *

 TURKEY POINT 3 OPERATED ROUTINELY IN AUGUST.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

* TURKEY POINT 3 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....FLORIDA
COUNTY.....DADE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI S OF
MIAMI, FLA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...OCTOBER 20, 1972
DATE ELEC ENER 1ST GENER...NOVEMBER 2, 1972
DATE COMMERCIAL OPERATE....DECEMBER 14, 1972
CONDENSER COOLING METHOD...CLOSED CANAL
CONDENSER COOLING WATER...CLOSED CYCLE CANAL
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER & LIGHT
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 013100
MIAMI, FLORIDA 33174
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....T. PEEBLES
LICENSING PROJ MANAGER.....D. MCDONALD
DOCKET NUMBER.....50-250
LICENSE & DATE ISSUANCE....DPR-31, JULY 19, 1972
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL AND URBAN AFFAIRS LIBRARY
FLORIDA INTERNATIONAL UNIVERSITY
MIAMI, FLORIDA 33199

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JUNE 10 - JULY 14 (84-22): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 190 INSPECTION HOURS ON SITE, INCLUDING 98 HOURS OF BACKSHIFT, IN THE AREAS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, LER FOLLOWUP, ANNUAL AND MONTHLY SURVEILLANCE, ANNUAL AND MONTHLY MAINTENANCE, OPERATIONAL SAFETY VERIFICATION, EMERGENCY SAFETY FEATURES (ESF) WALKDOWN, PLANT EVENTS, AND INDEPENDENT INSPECTION. OF THE EIGHT AREAS INSPECTED NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN FOUR AREAS: FOUR VIOLATIONS WERE FOUND IN FOUR AREAS; LACK OF OPERABILITY CRITERIA FOR TECHNICAL SPECIFICATION (TS) REQUIRED CHARGING PUMPS AND BORIC ACID TRANSFER PUMPS; FAILURE OF SUPERVISORY PERSONNEL TO IMPLEMENT CORRECTIVE ACTIONS PER REQUIREMENTS AND FAILURE TO ESTABLISH AN ADEQUATE PROCEDURE TO PERFORM MAINTENANCE; FAILURE TO ESTABLISH QC HOLDPOINTS; AND FAILURE TO PERFORM A TS SURVEILLANCE FOR THE SECOND TIME.

INSPECTION AUGUST 7-10 (84-24): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 18 INSPECTOR-HOURS ON SITE IN THE AREA OF INSERVICE TESTING (IST) OF PUMPS AND VALVES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

TS 6.8.1 REQUIRES WRITTEN PROCEDURES AND ADMINISTRATIVE POLICIES BE ESTABLISHED, IMPLEMENTED AND MAINTAINED THAT MEET OR EXCEED REQUIREMENTS AND RECOMMENDATIONS OF SECTION 5.1 AND 5.3 OF ANSI N18.7-1972 AND APP. "A" OF USNRC REG. GUIDE 1.33. SECTION 5.3.5(2) OF ANSI N18.7-1972, "PERFORMANCE OF MAINTENANCE", STATES PROCEDURES SHOULD CONTAIN DETAIL TO PERMIT THE MAINTENANCE WORK

ENFORCEMENT SUMMARY

TO BE PERFORMED SAFELY AND EXPEDITIOUSLY. CONTRARY TO THE ABOVE: (A) ON 6/19/84, MP 4107.7 "HIGH HEAD SIS PUMP DISASSEMBLY, REPLACEMENT OF ROTATING ELEMENT AND REASSEMBLY", FAILED TO MEET THE REQUIREMENTS OF TS 6.8.1 IN THAT: (1) MP-4107.7 DID NOT CONTAIN SUFFICIENT DETAIL TO PREVENT THE THRUST BEARINGS FROM BEING INSTALLED IMPROPERLY. (2) MP-4107.7 CONTAINED TWO SUPERSEDED PAGES ITEMIZING TOLERANCE DATA WHICH WAS NOT ACCURATE AND CONSEQUENTLY USE OF THE PROCEDURE COULD HAVE PREVENTED THE SAFE AND EXPEDITIOUS REPAIR OF THE PUMP. (3) MP-4107.7 DID NOT REQUIRE THE PUMP BE REFILLED WITH OIL. (4) MP-4107.7 DID NOT CONTAIN SUFFICIENT DETAIL TO REQUIRE VENTING OF THE PUMP PRIOR TO OPERATION. (B) AP 0190.10, "CLEANING OF NUCLEAR SAFETY RELATED SYSTEMS AND COMPONENTS" WAS NOT PROPERLY IMPLEMENTED ON 6/19/84. THE PROCEDURE STATES THAT ALL OPENINGS IN NUC. SAFETY RELATED SYSTEMS OR COMPONENTS SHALL BE PROTECTED FROM OUTSIDE CONTAMINANTS EXCEPT WHEN NECESSARY TO CARRY OUT REQUIRED OPERATIONS. DURING THE PERFORMANCE OF MP 4107.7 "HIGH HEAD SIS PUMP DISASSEMBLY, REPLACEMENT OF ROTATING ELEMENT AND REASSEMBLY", NUMEROUS PIECES OF COMPONENT COOLING WATER PIPE WERE DISASSEMBLED AND LEFT WITH PIPE ENDS OPEN TO THE ENVIRONMENT AND NOT PROTECTED AGAINST FOREIGN MATERIAL INTRUSION. (C) AP 0103.11, "HOUSEKEEPING" WAS NOT PROPERLY IMPLEMENTED ON 6/19/84. THE PROCEDURE ESTABLISHES GUIDELINES FOR THE CONTROL OF WORK ACTIVITIES, EQUIPMENT, MATERIAL AND ENVIRONMENTS WHICH AFFECT THE CLEANLINESS OF THE PLANT SITE. IT PROVIDES PROCEDURES FOR INSPECTION AND SUBSEQUENT CORRECTION OF UNSATISFACTORY CLEANLINESS CONDITIONS. SECTION 5.2. OF AP 0103.11 REQUIRES THAT SUPERVISORS ENSURE AND VERIFY THAT AREAS UNDER THEIR COGNIZANCE ARE MAINTAINED IN A CLEAN CONDITION AND DIRECTS SUPERVISORS TO ENSURE CORRECTIVE ACTIONS ARE INITIATED TO RESOLVE UNSATISFACTORY CONDITIONS. 10 CFR 50, APPENDIX B, CRITERION X AS IMPLEMENTED BY FP&L TOPICAL QUALITY ASSURANCE REPORT REV. 6; TQR 10.0 "INSPECTION"; QUALITY PROCEDURE 10.3 REV. 5 "INSPECTION AND SURVEILLANCE OF MAINTENANCE ACTIVITIES OPERATIONS AND FUEL HANDLING" AND ADMINISTRATIVE PROCEDURE (AP) 0190.19, "CONTROL OF MAINTENANCE ON NUCLEAR SAFETY RELATED AND FIRE PROTECTION SYSTEMS", REQUIRES IN AP-0190.19 APPENDIX "A" THAT QUALITY CONTROL (QC) HOLD POINTS SHALL BE INCLUDED IN MAINTENANCE PROCEDURES SO THAT QC INSPECTORS CAN WITNESS AND VERIFY CRITICAL MEASUREMENTS AND ADJUSTMENTS ON NUCLEAR SAFETY RELATED SYSTEMS AND COMPONENTS IN CIRCUMSTANCES WHERE SUCH ADJUSTMENTS OR MEASUREMENTS CANNOT BE VERIFIED TO COMPLETION OF THE REPAIR. CONTRARY TO THE ABOVE, QC HOLDPOINTS FOR SEVERAL PROCEDURAL STEPS WHICH DEAL WITH CRITICAL MEASUREMENTS AND ADJUSTMENTS WERE NOT ESTABLISHED IN MAINTENANCE PROCEDURE (MP) 4107.7, "HIGH HEAD SIS PUMP DISASSEMBLY, REPLACEMENT OF ROTATING ELEMENT AND REASSEMBLY. TECHNICAL SPECIFICATION 1.4 STATES THAT A COMPONENT IS OPERABLE WHEN IT IS CAPABLE OF PERFORMING ITS INTENDED FUNCTION. T.S. 3.6 REQUIRES THAT CHARGING PUMPS BE OPERABLE DURING CERTAIN REACTOR CONDITIONS. CONTRARY TO THE ABOVE, ON JULY 3, 1984, DURING UNIT 3 POWER OPERATION, THE "3A" CHARGING PUMP WAS NOT CAPABLE OF PERFORMING ITS INTENDED FUNCTION AND THE PUMP WAS NOT DECLARED INOPERABLE BECAUSE THE LICENSEE HAD NO OPERABILITY CRITERIA FOR THE PUMPS.

(8422 4)

TECHNICAL SPECIFICATION 4.1 SPECIFIES EQUIPMENT AND SAMPLING THAT SHALL BE CONDUCTED AS SPECIFIED IN TABLE 4.1-2. ITEM 1(H)(2) OF TABLE 4.1-2 SPECIFIES THAT AN ISOTOPIC ANALYSIS FOR IODINE SAMPLE SHALL BE OBTAINED BETWEEN 2 AND 6 HOURS FOLLOWING A THERMAL POWER CHANGE EXCEEDING 15 PERCENT OF THE RATED POWER WITHIN A ONE HOUR PERIOD. CONTRARY TO THE ABOVE, ON MAY 13, 1984, AN ISOTOPIC ANALYSIS FOR IODINE SAMPLE WAS NOT OBTAINED BETWEEN 2 AND 6 HOURS FOLLOWING A THERMAL POWER CHANGE EXCEEDING 15 PERCENT OF THE RATED POWER WITHIN A ONE HOUR PERIOD.

(8422 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

OTHER ITEMS

PEP IN PROGRESS.

PLANT STATUS:

OPERATING.

LAST IE SITE INSPECTION DATE: AUGUST 7-10, 1984 +

INSPECTION REPORT NO: 50-250/84-24 +

R E P O R T S F R O M L I C E N S E E

```

=====
NUMBER   DATE OF   DATE OF   SUBJECT
EVENT    REPORT
-----
84-018   07/17/84   07/24/84   TURKEY POINT PLANT WAS NOTIFIED BY BECHTEL POWER CORPORATION AND POWER PLANT ENGINEERING OF A 10
CFR PART 21 DEFICIENCY CONCERNING THE CONTROL CIRCUITRY FOR PRESSURE CONTROLLERS.
84-020   07/12/84   08/10/84   REACTOR COOLANT SYSTEM LEAK OF APPROXIMATELY 13.5 GPM, THE CAUSE WAS LEAKAGE DUE TO A BROKEN
GLAND FLANGE.
=====

```


THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-251 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: N. W. GRANT (305) 552-3675

4. Licensed Thermal Power (MWt): 2200

5. Nameplate Rating (Gross MWe): 894 X 0.85 = 760

6. Design Electrical Rating (Net MWe): 693

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 666

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>96,648.0</u>
13. Hours Reactor Critical	<u>630.0</u>	<u>3,148.2</u>	<u>67,787.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>166.6</u>
15. Hrs Generator On-Line	<u>625.5</u>	<u>2,984.6</u>	<u>65,453.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>31.2</u>
17. Gross Therm Ener (MWH)	<u>1,357,861</u>	<u>6,544,891</u>	<u>138,300,632</u>
18. Gross Elec Ener (MWH)	<u>429,075</u>	<u>2,021,830</u>	<u>43,943,192</u>
19. Net Elec Ener (MWH)	<u>405,672</u>	<u>1,902,597</u>	<u>41,609,705</u>
20. Unit Service Factor	<u>84.1</u>	<u>51.0</u>	<u>67.7</u>
21. Unit Avail Factor	<u>84.1</u>	<u>51.0</u>	<u>67.8</u>
22. Unit Cap Factor (MDC Net)	<u>81.9</u>	<u>48.8</u>	<u>66.4*</u>
23. Unit Cap Factor (DER Net)	<u>78.7</u>	<u>46.9</u>	<u>62.1</u>
24. Unit Forced Outage Rate	<u>15.9</u>	<u>21.6</u>	<u>5.4</u>
25. Forced Outage Hours	<u>118.5</u>	<u>824.3</u>	<u>3,366.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* TURKEY POINT 4 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

TURKEY POINT 4



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* TURKEY POINT 4 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
19	08/07/84	F	118.5	G	3	84-017	EB	RELAYX	REACTOR TRIP CAUSED BY THE LOSS OF POWER TO A FEED PUMP AND CONDENSATE PUMP DUE TO AN INCORRECT SWITCHING ORDER WHICH CAUSED LOSS OF A TRANSFORMER. POWER WAS RESTORED AND THE UNIT RETURNED TO FULL POWER OPERATION FOLLOWING VERIFICATION OF THE MODERATOR TEMPERATURE COEFFICIENT.

* SUMMARY *

TURKEY POINT 4 INCURRED 1 SHUTDOWN IN AUGUST AS DETAILED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* TURKEY POINT 4 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....FLORIDA
COUNTY.....DADE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI S OF
MIAMI, FLA
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JUNE 11, 1973
DATE ELEC ENER 1ST GENER...JUNE 21, 1973
DATE COMMERCIAL OPERATE....SEPTEMBER 7, 1973
CONDENSER COOLING METHOD...CLOSED CANAL
CONDENSER COOLING WATER....CLOSED CYCLE CANAL
ELECTRIC RELIABILITY
COUNCIL.....SOUTHEASTERN ELECTRIC
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....FLORIDA POWER & LIGHT
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 013100
MIAMI, FLORIDA 33174
CONTRACTOR
ARCHITECT/ENGINEER.....BECHTEL
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II
IE RESIDENT INSPECTOR.....T. PEEBLES
LICENSING PROJ MANAGER.....D. MCDONALD
DOCKET NUMBER.....50-251
LICENSE & DATE ISSUANCE....DPR-41, APRIL 10, 1973
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL AND URBAN AFFAIRS LIBRARY
FLORIDA INTERNATIONAL UNIVERSITY
MIAMI, FLORIDA 33199

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JUNE 10 - JULY 14 (84-23): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 190 INSPECTION HOURS ON SITE, INCLUDING 98 HOURS OF BACKSHIFT, IN THE AREAS OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, LER FOLLOWUP, ANNUAL AND MONTHLY SURVEILLANCE, ANNUAL AND MONTHLY MAINTENANCE, OPERATIONAL SAFETY VERIFICATION, EMERGENCY SAFETY FEATURES (ESF) WALKDOWN, PLANT EVENTS, AND INDEPENDENT INSPECTION. OF THE EIGHT AREAS INSPECTED NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN FOUR AREAS: FOUR VIOLATIONS WERE FOUND IN FOUR AREAS; LACK OF OPERABILITY CRITERIA FOR TECHNICAL SPECIFICATION (TS) REQUIRED CHARGING PUMPS AND BORIC ACID TRANSFER PUMPS; FAILURE OF SUPERVISORY PERSONNEL TO IMPLEMENT CORRECTIVE ACTIONS PER REQUIREMENTS AND FAILURE TO ESTABLISH AN ADEQUATE PROCEDURE TO PERFORM MAINTENANCE; FAILURE TO ESTABLISH QC HOLDPOINTS; AND FAILURE TO PERFORM A TS SURVEILLANCE FOR THE SECOND TIME.

INSPECTION AUGUST 7-10 (84-25): THIS ROUTINE UNANNOUNCED INSPECTION INVOLVED 17 INSPECTOR-HOURS ON SITE IN THE AREA OF INSERVICE TESTING (IST) OF PUMPS AND VALVES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

TS 6.8.1 REQUIRES WRITTEN PROCEDURES AND ADMINISTRATIVE POLICIES BE ESTABLISHED, IMPLEMENTED AND MAINTAINED THAT MEET OR EXCEED REQUIREMENTS AND RECOMMENDATIONS OF SECTION 5.1 AND 5.3 OF ANSI N18.7-1972 AND APP. "A" OF USNRC REG. GUIDE 1.33. SECTION 5.3.5(2) OF ANSI N18.7-1972, "PERFORMANCE OF MAINTENANCE", STATES PROCEDURES SHOULD CONTAIN DETAIL TO PERMIT THE MAINTENANCE WORK

ENFORCEMENT SUMMARY

TO BE PERFORMED SAFELY AND EXPEDITIOUSLY. CONTRARY TO THE ABOVE: (A) ON 6/19/84, MP 4107.7 "HIGH HEAD SIS PUMP DISASSEMBLY, REPLACEMENT OF ROTATING ELEMENT AND REASSEMBLY", FAILED TO MEET THE REQUIREMENTS OF TS 6.8.1 IN THAT: (1) MP-4107.7 DID NOT CONTAIN SUFFICIENT DETAIL TO PREVENT THE THRUST BEARINGS FROM BEING INSTALLED IMPROPERLY. (2) MP-4107.7 CONTAINED TWO SUPERSEDED PAGES ITEMIZING TOLERANCE DATA WHICH WAS NOT ACCURATE AND CONSEQUENTLY USE OF THE PROCEDURE COULD HAVE PREVENTED THE SAFE AND EXPEDITIOUS REPAIR OF THE PUMP. (3) MP-4107.7 DID NOT REQUIRE THE PUMP BE REFILLED WITH OIL. (4) MP-4107.7 DID NOT CONTAIN SUFFICIENT DETAIL TO REQUIRE VENTING OF THE PUMP PRIOR TO OPERATION. (B) AP 0190.10, "CLEANING OF NUCLEAR SAFETY RELATED SYSTEMS AND COMPONENTS" WAS NOT PROPERLY IMPLEMENTED ON 6/19/84. THE PROCEDURE STATES THAT ALL OPENINGS IN NUC. SAFETY RELATED SYSTEMS OR COMPONENTS SHALL BE PROTECTED FROM OUTSIDE CONTAMINANTS EXCEPT WHEN NECESSARY TO CARRY OUT REQUIRED OPERATIONS. DURING THE PERFORMANCE OF MP 4107.7 "HIGH HEAD SIS PUMP DISASSEMBLY, REPLACEMENT OF ROTATING ELEMENT AND REASSEMBLY", NUMEROUS PIECES OF COMPONENT COOLING WATER PIPE WERE DISASSEMBLED AND LEFT WITH PIPE ENDS OPEN TO THE ENVIRONMENT AND NOT PROTECTED AGAINST FOREIGN MATERIAL INTRUSION. (C) AP 0103.11, "HOUSEKEEPING" WAS NOT PROPERLY IMPLEMENTED ON 6/19/84. THE PROCEDURE ESTABLISHES GUIDELINES FOR THE CONTROL OF WORK ACTIVITIES, EQUIPMENT, MATERIAL AND ENVIRONMENTS WHICH AFFECT THE CLEANLINESS OF THE PLANT SITE. IT PROVIDES PROCEDURES FOR INSPECTION AND SUBSEQUENT CORRECTION OF UNSATISFACTORY CLEANLINESS CONDITIONS. SECTION 5.2. OF AP 0103.11 REQUIRES THAT SUPERVISORS ENSURE AND VERIFY THAT AREAS UNDER THEIR COGNIZANCE ARE MAINTAINED IN A CLEAN CONDITION AND DIRECTS SUPERVISORS TO ENSURE CORRECTIVE ACTIONS ARE INITIATED TO RESOLVE UNSATISFACTORY CONDITIONS. 10 CFR 50, APPENDIX B, CRITERION X AS IMPLEMENTED BY FP&L TOPICAL QUALITY ASSURANCE REPORT REV. 6; TQR 10.0 "INSPECTION"; QUALITY PROCEDURE 10.3 REV. 5 "INSPECTION AND SURVEILLANCE OF MAINTENANCE ACTIVITIES OPERATIONS AND FUEL HANDLING" AND ADMINISTRATIVE PROCEDURE (AP) 0190.19, "CONTROL OF MAINTENANCE ON NUCLEAR SAFETY RELATED AND FIRE PROTECTION SYSTEMS", REQUIRES IN AP-0190.19 APPENDIX "A" THAT QUALITY CONTROL (QC) HOLD POINTS SHALL BE INCLUDED IN MAINTENANCE PROCEDURES SO THAT QC INSPECTORS CAN WITNESS AND VERIFY CRITICAL MEASUREMENTS AND ADJUSTMENTS ON NUCLEAR SAFETY RELATED SYSTEMS AND COMPONENTS IN CIRCUMSTANCES WHERE SUCH ADJUSTMENTS OR MEASUREMENTS CANNOT BE VERIFIED TO COMPLETION OF THE REPAIR. CONTRARY TO THE ABOVE, QC HOLDPOINTS FOR SEVERAL PROCEDURAL STEPS WHICH DEAL WITH CRITICAL MEASUREMENTS AND ADJUSTMENTS WERE NOT ESTABLISHED IN MAINTENANCE PROCEDURE (MP) 4107.7, "HIGH HEAD SIS PUMP DISASSEMBLY, REPLACEMENT OF ROTATING ELEMENT AND REASSEMBLY. TECHNICAL SPECIFICATION 1.4 STATES THAT A COMPONENT IS OPERABLE WHEN IT IS CAPABLE OF PERFORMING ITS INTENDED FUNCTION. T.S. 3.6 REQUIRES THAT CHARGING PUMPS BE OPERABLE DURING CERTAIN REACTOR CONDITIONS. CONTRARY TO THE ABOVE, ON JULY 3, 1984, DURING UNIT 3 POWER OPERATION, THE "3A" CHARGING PUMP WAS NOT CAPABLE OF PERFORMING ITS INTENDED FUNCTION AND THE PUMP WAS NOT DECLARED INOPERABLE BECAUSE THE LICENSEE HAD NO OPERABILITY CRITERIA FOR THE PUMPS.
(8423 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

COMPLETED STEAM GENERATOR REPLACEMENT.

MANAGERIAL ITEMS:

PEP IN PROGRESS.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: AUGUST 7-10, 1984 +

OTHER ITEMS

INSPECTION REPORT NO: 50-251/84-25 +

R E P O R T S F R O M L I C E N S E E

```
=====
```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-013	06/24/84	07/24/84	AUTOMATIC INITIATION OF AUXILIARY FEEDWATER OCCURRED. THE ROOT CAUSE WAS DETERMINED TO STEM FROM THE TRIP OF THE 4B STEAM GENERATOR FEEDWATER PUMP DUE TO INADEQUATE SUCTION PRESSURE.
84-014	06/26/84	07/25/84	REACTOR TRIP WHILE AT HOT SHUTDOWN CONDITIONS, DUE TO SOURCE RANGE DETECTOR FAILED HIGH ABOVE REACTOR TRIP SETPOINT N-32, THAT FAILED HIGH ABOVE THE REACTOR TRIP SETPOINT.
84-015	07/16/84	08/10/84	UNIT 4 EXPERIENCED AN UNEXPECTED START OF THE 4A HIGH HEAD SAFETY INJECTION PUMP. CONSTRUCTION PERSONNEL INADVERTENTLY STRIKING THE LOCAL CONTROL SWITCH.

```
=====
```

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-271 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: F. J. BURGER (802) 257-7711 X136

4. Licensed Thermal Power (MWt): 1593

5. Nameplate Rating (Gross MWe): 626 X 0.9 = 563

6. Design Electrical Rating (Net MWe): 514

7. Maximum Dependable Capacity (Gross MWe): 535

8. Maximum Dependable Capacity (Net MWe): 504

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>104,713.8</u>
13. Hours Reactor Critical	<u>579.7</u>	<u>4,466.1</u>	<u>84,164.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>471.8</u>	<u>4,326.0</u>	<u>81,818.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>533,537</u>	<u>6,466,307</u>	<u>118,626,979</u>
18. Gross Elec Ener (MWH)	<u>165,593</u>	<u>2,177,861</u>	<u>39,470,939</u>
19. Net Elec Ener (MWH)	<u>152,446</u>	<u>2,081,736</u>	<u>37,446,752</u>
20. Unit Service Factor	<u>63.4</u>	<u>73.9</u>	<u>78.1</u>
21. Unit Avail Factor	<u>63.4</u>	<u>73.9</u>	<u>78.1</u>
22. Unit Cap Factor (MDC Net)	<u>40.8</u>	<u>70.5</u>	<u>71.0</u>
23. Unit Cap Factor (DER Net)	<u>40.0</u>	<u>69.2</u>	<u>69.6</u>
24. Unit Forced Outage Rate	<u>15.5</u>	<u>5.2</u>	<u>7.3</u>
25. Forced Outage Hours	<u>86.8</u>	<u>237.4</u>	<u>5,128.6</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

 * VERMONT YANKEE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

VERMONT YANKEE 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * VERMONT YANKEE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-12	06/15/84	S	185.4	C	1				REFUELING OUTAGE CONCLUDES.
84-13	08/09/84	F	55.6	A	1		CD	ELECON	LOSS OF MSIV POSITION INDICATION CAUSED BY FAILURE OF RECENTLY INSTALLED CONNECTORS. CONNECTORS WERE REPLACED.
84-14	08/14/84	F	31.2	A	1		HC	H1EXCH	HIGH REACTOR COOLANT CONDUCTIVITY CAUSED BY MAIN CONDENSER TUBE LEAKAGE. FAILED TUBES WERE PLUGGED.

***** VERMONT YANKEE RETURNED TO OPERATION AFTER REFUELING AND EXPERIENCED 2 ADDITIONAL SHUTDOWNS IN AUGUST. *****

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

* VERMONT YANKEE 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....VERMONT
COUNTY.....WINDHAM
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...5 MI S OF
BRATTLEBORO, VT
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...MARCH 24, 1972
DATE ELEC ENER 1ST GENER...SEPTEMBER 20, 1972
DATE COMMERCIAL OPERATE...NOVEMBER 30, 1972
CONDENSER COOLING METHOD...COOLING TOWER
CONDENSER COOLING WATER...CONNECTICUT RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....VERMONT YANKEE NUCLEAR POWER
CORPORATE ADDRESS.....1671 WORCESTER ROAD
FRAMINGHAM, MASSACHUSETTS 01701
CONTRACTOR
ARCHITECT/ENGINEER.....EBASCO
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....EBASCO
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....W. RAYMOND
LICENSING PROJ MANAGER....V. ROONEY
DOCKET NUMBER.....50-271
LICENSE & DATE ISSUANCE...DPR-28, FEBRUARY 28, 1973
PUBLIC DOCUMENT ROOM.....BROOKS MEMORIAL LIBRARY
224 MAIN STREET
BRATTLEBORO, VERMONT 05301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.5.A REQUIRES THAT DETAILED WRITTEN PROCEDURES, INCLUDING APPLICABLE CHECK-OFF LISTS, BE PREPARED, IMPLEMENTED AND FOLLOWED. PROCEDURE OP 4374 WAS WRITTEN PURSUANT TO THE ABOVE TO PROVIDE FOR THE PERIODIC CALIBRATION AND TESTING OF THE TORUS LEVEL INSTRUMENT CHANNELS. OP 4374 REQUIRES THAT CERTAIN CHECKS BE COMPLETED AND NOTIFICATIONS BE MADE TO SECURE FROM TESTING FOLLOWING THE COMPLETION OF A CHANNEL CALIBRATION. CONTRARY TO THE ABOVE, TESTING ACTIVITIES WERE TERMINATED AT 3:45 P.M. ON MAY 8, 1984, FOLLOWING A CALIBRATION OF THE TORUS LEVEL INSTRUMENTS AND THE FOLLOWING ACTIONS WERE NOT COMPLETED IN ACCORDANCE WITH OP 4374: RECORDING THE FINAL TORUS LEVEL INDICATION TO VERIFY IT WAS PROPER; VERIFYING THE HIGH PRESSURE COOLANT INJECTION PUMP SUCTION VALVES WERE RETURNED TO THE PROPER STANDBY ALIGNMENT; NOTIFYING THE SHIFT SUPERVISOR OF THE TEST RESULTS AND THE STATUS OF TESTING; AND OBTAINING THE SHIFT SUPERVISOR'S REVIEW AND CONCURRENCE THAT THE TEST RESULTS WERE ACCEPTABLE. THIS IS A SEVERITY LEVEL 4 VIOLATION (SUPPLEMENT I).
(8410 5)

OTHER ITEMS

1. Docket: 50-397 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: LEONARD HUTCHISON (509) 377-2501 X2486

4. Licensed Thermal Power (Mwt): 3323

5. Nameplate Rating (Gross MWe): 1100

6. Design Electrical Rating (Net MWe): 1100

7. Maximum Dependable Capacity (Gross MWe): 1155

8. Maximum Dependable Capacity (Net MWe): 1100

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): _____


11. Reasons for Restrictions, If Any: _____
 NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>2,306.2</u>	<u>2,306.2</u>
13. Hours Reactor Critical	<u>465.7</u>	<u>1,117.8</u>	<u>1,117.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>235.8</u>	<u>663.2</u>	<u>663.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>377,947</u>	<u>844,192</u>	<u>844,192</u>
18. Gross Elec Ener (MWH)	<u>96,968</u>	<u>199,448</u>	<u>199,448</u>
19. Net Elec Ener (MWH)	<u>88,842</u>	<u>181,528</u>	<u>181,528</u>
20. Unit Service Factor			
21. Unit Avail Factor		NOT IN	
22. Unit Cap Factor (MDC Net)		COMMERCIAL	
23. Unit Cap Factor (DER Net)		OPERATION	
24. Unit Forced Outage Rate			
25. Forced Outage Hours	<u>427.3</u>	<u>1,545.7</u>	<u>1,545.7</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):	<u>MAINTENANCE M2 OUTAGE, 10/4 THRU 10/10/84</u>		
27. If Currently Shutdown Estimated Startup Date:	<u>N/A</u>		

 * WASHINGTON NUCLEAR 2 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

WASHINGTON NUCLEAR 2



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * WASHINGTON NUCLEAR 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-12	07/10/84	F	44.7	A	4	84-075	EB	GENERA	DIESEL GENERATOR REPAIR AND MODIFICATION OUTAGE CONCLUDED.
84-13	08/03/84	F	15.1	A	1		HJ	HTEXCH	PLANT WAS SHUTDOWN TO REPAIR A SEVERE STEAM LEAK FROM A HANDHOLE ON THE MOISTURE SEPARATOR HEATER DRAIN TANK. THE LEAK WAS REPAIRED BY SEAL WELDING THE HANDHOLE TO PREVENT RECURRENCE.
84-14	08/07/84	S	80.9	B	3		EA	XXXXXX	LOSS OF POWER TEST CONDUCTED AS PART OF THE POWER ASCENSION TEST PROGRAM.
84-15	08/12/84	F	66.3	A	1	84-083	HC	HTEXCH	PLANT WAS SHUTDOWN DUE TO HIGH CONDUCTIVITY CAUSED BY A CONDENSER TUBE LEAK. ONE FAILED CONDENSER TUBE WAS FOUND IN THE CENTER OF A TUBE BUNDLE. THE TUBE WAS PLUGGED AND A CHEMISTRY GUIDANCE LETTER ISSUED TO AID IN EARLY CONDUCTIVITY EXCURSION ASSESSMENT. (SEE LER 84.083)
84-16	08/16/84	F	30.1	B	3	84-089	IA	INSTRU	MSL - HI RAD DIV II SURVEILLANCE CAUSED 1/2 SCRAM AND C.R. BLOCK FLOW COMPARATOR SURVEILLANCE CAUSED SECOND 1/2 SCRAM FOR DIV I RESULTING IN REACTOR TRIP. (SEE LER 84-089)
84-17	08/17/84	F	5.3	A	1		HH	PIPEXX	COULD NOT ATTAIN SUFFICIENT VACUUM AFTER STARTUP DUE TO 6A AND B HIGH PRESSURE FW HEATER RUPTURED DISCS, DOWNSTREAM OF RV'S, BEING RUPTURED FROM PREVIOUS SCRAM. THE CAUSE WAS DETERMINED AND THE RUPTURED DISCS REPLACED.
84-18	08/18/84	F	265.8	A	1		HC	HTEXCH	PLANT WAS SHUTDOWN DUE TO HIGH CONDUCTIVITY CAUSED BY CONDENSER TUBE LEAKS. IT WAS DETERMINED THERE WERE NINE (9) RELATIVELY MINOR TUBE LEAKS AND ONE (1) MAJOR LEAK. THE CAUSE OF LEAKAGE WAS DETERMINED THE LEAKING TUBES WERE PLUGGED AND THE CONDENSER RETURNED TO SERVICE.

 * SUMMARY *

 WNP-2 CONTINUES TESTING AND APPROACH TO FULL POWER OPERATION.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

FACILITY DESCRIPTION

LOCATION
STATE.....WASHINGTON
COUNTY.....BENTON
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...30 MI NW OF
RICHLAND, WASH
TYPE OF REACTOR.....BWR
DATE INITIAL CRITICALITY...JANUARY 16, 1984
DATE ELEC ENER 1ST GENER...MAY 27, 1984
DATE COMMERCIAL OPERATE...*****
CONDENSER COOLING METHOD...COOLING TOWERS
CONDENSER COOLING WATER...MECHANICAL TOWERS
ELECTRIC RELIABILITY
COUNCIL.....WESTERN SYSTEMS
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....WASHINGTON PUBLIC POWER SUPPLY SYSTEM
CORPORATE ADDRESS.....P.O. BOX 968
RICHLAND, WASHINGTON 99352
CONTRACTOR
ARCHITECT/ENGINEER.....BURNS & ROE
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC
CONSTRUCTOR.....BECHTEL
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V
IE RESIDENT INSPECTOR.....R. FEIL
LICENSING PROJ MANAGER.....R. AULUCK
DOCKET NUMBER.....50-397
LICENSE & DATE ISSUANCE...NPF-21, APRIL 13, 1984
PUBLIC DOCUMENT ROOM.....RICHLAND PUBLIC LIBRARY
SWIFT AND NORTHGATE STREETS
RICHLAND, WA 99352

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION ON JUNE 6 - JULY 6, 1984 (REPORT NO. 50-397/84-18) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF CONTROL ROOM OPERATIONS, ENGINEERED SAFETY FEATURE STATUS, SURVEILLANCE PROGRAM, MAINTENANCE PROGRAM, POWER ASCENSION TEST PROGRAM, LICENSEE EVENT REPORTS, SPECIAL INSPECTION TOPICS, AND LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS. THE INSPECTION INVOLVED 128 INSPECTOR-HOURS ONSITE BY TWO RESIDENT INSPECTORS.

RESULTS: TWO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN THE AREAS OF SURVEILLANCE (CONTROL OF ELECTRICAL JUMPERS) AND MAINTENANCE (TIMELINESS OF CORRECTIVE ACTIONS).

+ INSPECTION ON JULY 8 - AUGUST 3, 1984 (REPORT NO. 50-397/84-19) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF CONTROL ROOM OPERATIONS, ENGINEERED SAFETY FEATURE STATUS, SURVEILLANCE PROGRAM, MAINTENANCE PROGRAM, POWER ASCENSION TEST PROGRAM, LICENSEE EVENT REPORTS, SPECIAL INSPECTION TOPICS, AND LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS. THE INSPECTION INVOLVED 122 INSPECTOR-HOURS ONSITE BY TWO RESIDENT INSPECTORS.

RESULTS: NO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED.

+ INSPECTION ON JULY 31 - AUGUST 3, 1984 AND TELEPHONE CONVERSATIONS ON AUGUST 8, 1984 (REPORT NO. 50-397/84-20) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S STARTUP RADIATION PROTECTION PROGRAM, STARTUP RADWASTE PROCESSING AND NUREG-0737 ITEMS II.B.3 AND II.F.1. THE INSPECTION INVOLVED 27 INSPECTOR-HOURS ONSITE BY ONE REGIONAL-BASED INSPECTOR AND 14 HOURS OF INOFFICE EXAMINATION.

* WASHINGTON NUCLEAR 2 *

R E P O R T S F R O M L I C E N S E E

Report Period AUG 1984

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT

NONE			

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-029 OPERATING STATUS

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: S. WHIPPLE (617) 872-8100

4. Licensed Thermal Power (MWt): 600

5. Nameplate Rating (Gross MWe): 185 X 1.0 = 185

6. Design Electrical Rating (Net MWe): 175

7. Maximum Dependable Capacity (Gross MWe): 180

8. Maximum Dependable Capacity (Net MWe): 167

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>208,556.0</u>
13. Hours Reactor Critical	<u>450.7</u>	<u>3,565.2</u>	<u>165,089.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>436.8</u>	<u>3,461.5</u>	<u>160,373.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>248,273</u>	<u>1,977,435</u>	<u>86,861,029</u>
18. Gross Elec Ener (MWH)	<u>75,322</u>	<u>605,230</u>	<u>26,328,096</u>
19. Net Elec Ener (MWH)	<u>70,407</u>	<u>566,696</u>	<u>24,635,085</u>
20. Unit Service Factor	<u>58.7</u>	<u>59.1</u>	<u>76.9</u>
21. Unit Avail Factor	<u>58.7</u>	<u>59.1</u>	<u>76.9</u>
22. Unit Cap Factor (MDC Net)	<u>56.7</u>	<u>57.9</u>	<u>77.7*</u>
23. Unit Cap Factor (DER Net)	<u>54.1</u>	<u>55.3</u>	<u>69.3*</u>
24. Unit Forced Outage Rate	<u>41.3</u>	<u>17.2</u>	<u>5.5</u>
25. Forced Outage Hours	<u>307.2</u>	<u>721.0</u>	<u>8,207.4</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

* YANKEE-ROWE 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

YANKEE-ROWE 1



AUGUST 1984

* Item calculated with a Weighted Average

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* YANKEE-ROWE 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-6	08/02/84	F	307.2	A	1	84-13	EC	BKR	DUE TO ELECTRICAL FIRE ASSOCIATED WITH BREAKER 448 IN THE BUS ROOM AND THE INOPERABLE 480 VOLT BUS NO. 4-1 THE PLANT WAS REMOVED FROM THE GRID IN ACCORDANCE WITH T. S. 3.8.2.1.

* SUMMARY *

YANKEE ROWE INCURRED 1 SHUTDOWN IN AUGUST AS DESCRIBED ABOVE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

* YANKEE-ROWE 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....MASSACHUSETTS
COUNTY.....FRANKLIN
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...25 MI NE OF
PITTSFIELD, MASS
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...AUGUST 19, 1960
DATE ELEC ENER 1ST GENER...NOVEMBER 10, 1960
DATE COMMERCIAL OPERATE...JULY 1, 1961
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...DEERFIELD RIVER
ELECTRIC RELIABILITY
COUNCIL.....NORTHEAST POWER
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....YANKEE ATOMIC ELECTRIC
CORPORATE ADDRESS.....1671 WORCESTER RD.
FRAMINGHAM, MASSACHUSETTS 01701
CONTRACTOR
ARCHITECT/ENGINEER.....STONE & WEBSTER
*
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....STONE & WEBSTER
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I
IE RESIDENT INSPECTOR.....H. EICHENHOLZ
LICENSING PROJ MANAGER.....P. ERICKSON
DOCKET NUMBER.....50-029
LICENSE & DATE ISSUANCE...DPR-3, DECEMBER 24, 1963
PUBLIC DOCUMENT ROOM.....GREENFIELD COMMUNITY COLLEGE
1 COLLEGE DRIVE
GREENFIELD, MASSACHUSETTS 01301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

CONTRARY TO IMPLEMENTING PROCEDURES FOR THE LICENSEE'S SECURITY PLAN, PROPER COMPENSATORY MEASURES WERE NOT TAKEN WHEN PORTIONS OF THE SECURITY SYSTEM WERE INOPERABLE.
(8406 4)

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period AUG 1984

I N S P E C T I O N S T A T U S - (CONTINUED)

***** 'XXXXXXXXXXXXXXXXXXXXXXXXXXXX'
* YANKEE-ROWE 1 *

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S F R O M L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-295 O P E R A T I N G S T A T U S

2. Reporting Period: 08/01/84 Outage + On-line Hrs: 744.0

3. Utility Contact: GERRI AUSTIN (312) 746-2084

4. Licensed Thermal Power (Mwt): 3250

5. Nameplate Rating (Gross MWe): 1220 X 0.9 = 1098

6. Design Electrical Rating (Net MWe): 1040

7. Maximum Dependable Capacity (Gross MWe): 1085

8. Maximum Dependable Capacity (Net MWe): 1040

9. If Changes Occur Above Since Last Report, Give Reasons:
NONE

10. Power Level To Which Restricted, If Any (Net MWe):

11. Reasons for Restrictions, If Any:
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>744.0</u>	<u>5,855.0</u>	<u>93,527.0</u>
13. Hours Reactor Critical	<u>153.9</u>	<u>4,031.7</u>	<u>66,107.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,621.8</u>
15. Hrs Generator On-Line	<u>79.0</u>	<u>3,796.3</u>	<u>64,264.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>125,843</u>	<u>11,689,908</u>	<u>181,611,391</u>
18. Gross Elec Ener (MWH)	<u>35,560</u>	<u>3,828,354</u>	<u>58,548,233</u>
19. Net Elec Ener (MWH)	<u>23,028</u>	<u>3,664,318</u>	<u>55,567,623</u>
20. Unit Service Factor	<u>10.6</u>	<u>64.8</u>	<u>68.7</u>
21. Unit Avail Factor	<u>10.6</u>	<u>64.8</u>	<u>68.7</u>
22. Unit Cap Factor (MDC Net)	<u>3.0</u>	<u>60.2</u>	<u>57.1</u>
23. Unit Cap Factor (DER Net)	<u>3.0</u>	<u>60.2</u>	<u>57.1</u>
24. Unit Forced Outage Rate	<u>89.4</u>	<u>29.5</u>	<u>14.4</u>
25. Forced Outage Hours	<u>665.0</u>	<u>1,586.2</u>	<u>10,198.2</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):
REFUELING - JANUARY 1985

27. If Currently Shutdown Estimated Startup Date: N/A

* Z I O N 1 *

AVERAGE DAILY POWER LEVEL (MWe) PLOT

Z I O N 1



AUGUST 1984

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

* ZION 1 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
9	07/18/84	F	665.0	B	4	84-021			CONTINUED SHUTDOWN FOR THE PERFORMANCE OF THE INTERGRATED LEAK RATE TEST.

***** ZION 1 REMAINED SHUT DOWN UNTIL AUGUST 28 FOR INTEGRATED LEAK TESTING.
* SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-016 f)

* ZION 1 *

F A C I L I T Y D A T A

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....LAKE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI N OF
CHICAGO, ILL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...JUNE 19, 1973
DATE ELEC ENER 1ST GENER...JUNE 28, 1973
DATE COMMERCIAL OPERATE...DECEMBER 31, 1973
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60600
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. WATERS
LICENSING PROJ MANAGER.....J. NORRIS
DOCKET NUMBER.....50-295
LICENSE & DATE ISSUANCE...DPR-39, OCTOBER 19, 1973
PUBLIC DOCUMENT ROOM.....ZION - BENTON PUBLIC LIBRARY
2400 GABRIEL AVENUE
ZION, ILLINOIS 60099

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION SUMMARIES RECEIVED FOR THIS TIME PERIOD.

ENFORCEMENT SUMMARY

10 CFR 30.41 STATES THAT NO LICENSEE SHALL TRANSFER BYPRODUCT MATERIAL EXCEPT AS AUTHORIZED THEREIN. CONTRARY TO THE ABOVE, ON FEBRUARY 9, 1984, THE LICENSEE SHIPPED FOUR AMERICIUM-241 SOURCES TOTALLING ABOUT 0.1 MICROCURIE TO THE BYRON STATION. THE BYRON STATION'S BYPRODUCT MATERIAL LICENSE DOES NOT AUTHORIZE THE POSSESSION OF THESE SOURCES. 10 CFR 30.41 STATES THAT NO LICENSEE SHALL TRANSFER BYPRODUCT MATERIAL EXCEPT AS AUTHORIZED THEREIN. CONTRARY TO THE ABOVE, ON FEBRUARY 9, 1984, THE LICENSEE SHIPPED FOUR AMERICIUM-241 SOURCES TOTALLING ABOUT 0.1 MICROCURIE TO THE BYRON STATION. THE BYRON STATION'S BYPRODUCT MATERIAL LICENSE DOES NOT AUTHORIZE THE POSSESSION OF THESE SOURCES.
(8408 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

Report Period AUG 1984

UNIT SHUTDOWNS / REDUCTIONS

 * ZION 2 *

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
9	08/15/84	F	21.1	H	3	84-020			CONTAINMENT TEMPERATURES EXCEEDED TECH SPEC LIMIT, DUE TO INCREASE INLAKE TEMPERATURES.

***** ZION 2 OPERATED ROUTINELY IN AUGUST WITH 1 SHUTDOWN REPORTED.
 * SUMMARY *

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

* ZION 2 *

FACILITY DATA

Report Period AUG 1984

FACILITY DESCRIPTION

LOCATION
STATE.....ILLINOIS
COUNTY.....LAKE
DIST AND DIRECTION FROM
NEAREST POPULATION CTR...40 MI N OF
CHICAGO, ILL
TYPE OF REACTOR.....PWR
DATE INITIAL CRITICALITY...DECEMBER 24, 1973
DATE ELEC ENER 1ST GENER...DECEMBER 26, 1973
DATE COMMERCIAL OPERATE...SEPTEMBER 17, 1974
CONDENSER COOLING METHOD...ONCE THRU
CONDENSER COOLING WATER...LAKE MICHIGAN
ELECTRIC RELIABILITY
COUNCIL.....MID-AMERICA
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY
LICENSEE.....COMMONWEALTH EDISON
CORPORATE ADDRESS.....P.O. BOX 767
CHICAGO, ILLINOIS 60690
CONTRACTOR
ARCHITECT/ENGINEER.....SARGENT & LUNDY
NUC STEAM SYS SUPPLIER...WESTINGHOUSE
CONSTRUCTOR.....COMMONWEALTH EDISON
TURBINE SUPPLIER.....NONE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III
IE RESIDENT INSPECTOR.....J. WATERS
LICENSING PROJ MANAGER.....J. NORRIS
DOCKET NUMBER.....50-304
LICENSE & DATE ISSUANCE...DPR-48, NOVEMBER 14, 1973
PUBLIC DOCUMENT ROOM.....ZION - BENTON PUBLIC LIBRARY
2400 GABRIEL AVENUE
ZION, ILLINOIS 60099

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION SUMMARIES RECEIVED FOR THIS TIME PERIOD.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

THIS PAGE INTENTIONALLY LEFT BLANK

SECTION 3

APPENDIX

* PRESSURIZED* STATUS OF SPENT FUEL STORAGE CAPABILITY

* WATER *

* REACTORS *

FACILITY *****	(a)				REMAINING CAPACITY		(b)	
	CORE SIZE (NO. OF ASSEMBLIES) *****	PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) *****	NO. OF ASSEMBLIES STORED *****	REMAINING CAPACITY (NO. OF ASSEMBLIES) *****	IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) *****	NEXT REFUEL SCHED. DATE *****	WILL FILL PRESENT AUTH. CAPACITY *****	
ARKANSAS 1	177	988	316	672		10-84	1998	
ARKANSAS 2	177	988	168	820		05-85	2003	
BEAVER VALLEY 1	157	833	52	781		10-84	1995	
CALVERT CLIFFS 1	217	1830(c)	868(c)	961(c)(m)	1098	03-85	1991	
CALVERT CLIFFS 2	217					10-85	1991	
COOK 1	193	2050(c)	553(c)	1497(c)		N/S	1994	
COOK 2	193					N/S		
CRYSTAL RIVER 3	177	1163	171	992		N/S	1997	
DAVIS-BESSE 1	177	735	140	595		09-84	1993	
DIABLO CANYON 1								
FARLEY 1	157	675	114	561	1293	N/S	1991	
FARLEY 2	157	675	62	613	1345	01-85	1994	
FORT CALHOUN 1	133	729	305	424		10-85	1996	
GINNA	121	595	340	255		N/S	1992	
HADDAM NECK	157	1168	493	675		08-84	1994	
INDIAN POINT 1	0	288	160	128		N/S		
INDIAN POINT 2	193	482	332	150	916	N/S	1986	
INDIAN POINT 3	193	837	140	697		N/S	1993	
KEWAUNEE	121	990	268	722(m)		N/S	1991	
MAINE YANKEE	217	953	577	376	1678	N/S	1987	
MCGUIRE 1	193	500	91	409(n)	1781	N/S	1990	
MCGUIRE 2						01-85		
MILLSTONE 2	217	667	376	291		N/S	1987	
NORTH ANNA 1	157	966(c)	168(c)	798		N/S	1991	
NORTH ANNA 2	157					08-84	1990	
OCONEE 1	177	1312(l)	1086	226(l)(n)		10-84	1991	
OCONEE 2	177					03-85		
OCONEE 3	177	825	104	721		09-85		
PALISADES	204	784	480	304		N/S	1988	
POINT BEACH 1	121	1058(c)	484(c)	1078(c)		N/S	1995	
POINT BEACH 2	121					09-84		
PRAIRIE ISLAND 1	121	1017(c)	561(c)	456(c)(m)	720	N/S	1988	
PRAIRIE ISLAND 2	121					08-84		
RANCHO SECO 1	177	579	280	299		01-85	1987	
ROBINSON 2	157	276	152	124(e)	431	N/S	1985(g)	
SALEM 1	193	1170	212	958		N/S	1996	
SALEM 2	193	1170	72	1093		N/S	2000	
SAN ONOFRE 1	157	216	94	122		N/S	1985	
SAN ONOFRE 2	217	800	0	800		11-84		
SAN ONOFRE 3	217	800	0	800		N/S		
SEQUOYAH 1	193	800	65	735		N/S	1993	
SEQUOYAH 2(d)	193	800	65	735		09-84	1994	
ST LUCIE 1	217	728	352	376		N/S	1990	
ST LUCIE 2						10-84		
SUMMER 1	157	682	0	682	1276	09-84		
SURRY 1	157	1044(c)	556(c)	484(c)		N/S	1987	
SURRY 2	157					09-84		

* PRESSURIZED* STATUS OF SPENT FUEL STORAGE CAPABILITY

* WATER *
* REACTORS * (a)

FACILITY *****	(a)		NO. OF ASSEMBLIES STORED *****	REMAINING CAPACITY (NO. OF ASSEMBLIES) *****	REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) *****	(b)	
	CORE SIZE (NO. OF ASSEMBLIES) *****	PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) *****				NEXT REFUEL SCHED. DATE *****	WILL FILL PRESENT AUTH. CAPACITY *****
THREE MILE ISLAND 1	177	752	208	544		N/S	1986
THREE MILE ISLAND 2	177	442	0	442		N/S	1986
TROJAN	193	651	312	339		N/S	1990
TURKEY POINT 3	157	621	445	175(m)		N/S	1987
TURKEY POINT 4	157	621	430	191		N/S	1988
YANKEE-ROWE 1	76	391	250	141	471	N/S	1988
ZION 1	193	2112(c)	863(c)	1249(c)		12-84	1995
ZION 2	193					09-85	1995

INDEPENDENT SPENT FUEL STORAGE INSTALLATIONS(h)

MORRIS OPERATIONS	750 MTU(j)	315	385 M.U(j)	1490 MTU(j)
NFS(i)	250 MTU	170 MTU	80 MTU	

- (a) At each refueling outage approximately 1/3 of a PWR core and 1/4 of a BWR core is off-loaded.
- (b) Some of these dates have been adjusted by staff assumptions.
- (c) This is the total for both units.
- (d) Plant not in commercial operation.
- (e) Some spent fuel stored at Brunswick.
- (f) Authorized a total 2772 BWR and 1232 PWR assemblies for both pools.
- (g) Robinson 2 assemblies being shipped to Brunswick for storage.
- (h) Capacity is in metric tons of uranium; 1 MTU = 2 PWR assemblies or 5 BWR assemblies.
- (i) No longer accepting spent fuel.
- (j) Racked for 700 MTU.
- (k) Reserved.
- (l) This is the station total.
- (m) Installed capacity is less than that authorized.
- (n) McGuire 1 authorized to accept Oconee fuel assemblies.

N/S = Not Scheduled

* BOILING * STATUS OF SPENT FUEL STORAGE CAPABILITY

* WATER *

* REACTORS *

FACILITY *****	(a)		NO. OF ASSEMBLIES STORED *****	REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) *****	REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) *****	NEXT REFUEL SCHED. DATE *****	(b)	
	CORE SIZE (NO. OF ASSEMBLIES) *****	PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) *****					REMAINING CAPACITY (NO. OF ASSEMBLIES) *****	WILL FILL PRESENT AUTH. CAPACITY *****
BIG ROCK POINT 1	84	193	172	21	269	N/S		1986
BROWNS FERRY 1	764	3471	1068	2403		03-85		1985
BROWNS FERRY 2	764	3471	889	61(m)	2582	09-84		1985
BROWNS FERRY 3	764	3471	1768	150(m)	1703	N/S		1985
BRUNSWICK 1	560	(f)	160PWR+656BWR	2116		N/S		1986
BRUNSWICK 2	560		144PWR+564BWR	2208		N/S		1986
COOPER STATION	548	2366	848	1518		09-84		1996
DRESDEN 1	464	672	221	451		N/S		1990
DRESDEN 2	724	2659(c)	2014 (c)	996(c)	6129(c)	09-84		1985
DRESDEN 3	724					N/S		
DUANE H. NOLD	368	2050	576	1474		N/S		1998
FITZPATRICK	560	2244	816	1428		N/S		1991
HATCH 1	560	3021	0	3021		10-84		1999
HATCH 2	560	2750	1284	1466		N/S		1999
HUMBOLDT BAY	172	487	251	236		N/S		
LA CROSSE	72	440	207	233		11-84		1990
LASALLE 1								
LASALLE 2								
MILLSTONE 1	580	2184	1281	903		N/S		1991
MONTICELLO	484	2237	1137	1100		N/S		1991
NINE MILE POINT 1	532	1984	1177	807	1788	N/S		1990
OYSTER CREEK 1	560	1800	1375	425	1225	N/S		1987
PEACH BOTTOM 2	764	2816	1361	1455		N/S		1990
PEACH BOTTOM 3	764	2816	1212	1604		N/S		1991

* BOILING * STATUS OF SPENT FUEL STORAGE CAPABILITY

* WATER *

* REACTORS * (a)

FACILITY *****	(a)				REMAINING CAPACITY IF PENDING REQUEST		(b)	
	CORE SIZE (NO. OF ASSEMBLIES) *****	PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) *****	NO. OF ASSEMBLIES STORED *****	REMAINING CAPACITY (NO. OF ASSEMBLIES) *****	APPROVED (NO. OF ASSEMBLIES) *****	NEXT REFUEL SCHED. DATE *****	WILL FILL AUTH. CAPACITY *****	PRESENT CAPACITY *****
PILGRIM 1	580	2320	1708	62(m)		N/S	1990	
QUAD CITIES 1	724	3657	1730	1927		N/S	2003	
QUAD CITIES 2	724	3897	412	3485		N/S	2003	
SUSQUEHANNA 1	764	2840	0	2840		N/S	1997	
SUSQUEHANNA 2								
VERMONT YANKEE 1	368	2000	1174	826		N/S	1992	
WASHINGTON NUCLEAR*								

INDEPENDENT SPENT FUEL STORAGE INSTALLATIONS(h)

MORRIS OPERATIONS	750 MTU(j)	315	385 MTU(j)	1490 MTU(j)
NFS(i)	250 MTU	170 MTU	80 MTU	

(a) At each refueling outage approximately 1/3 of a PWR core and 1/4 of a BWR core is off-loaded.

(b) Some of these dates have been adjusted by staff assumptions.

(c) This is the total for both units.

(d) Plant not in commercial operation.

(e) Some spent fuel stored at Brunswick.

(f) Authorized a total 2772 BWR and 1232 PWR assemblies for both pools.

(g) Robinson 2 assemblies being shipped to Brunswick for storage.

(h) Capacity is in metric tons of uranium; 1 MTU = 2 PWR assemblies or 5 BWR assemblies.

(i) No longer accepting spent fuel.

(j) Racked for 700 MTU.

(k) Reserved.

(l) This is the station total.

(m) Installed capacity is less than that authorized.

(n) McGuire 1 authorized to accept Oconee fuel assemblies.

N/S = Not Scheduled

(INCLUDES BOTH LICENSED
AND NON-LICENSED UNITS)

REACTOR YEARS OF EXPERIENCE

*****				*****				*****			
YEARS	1ST ELEC GENERATE	UNIT		YEARS	1ST ELEC GENERATE	UNIT		YEARS	1ST ELEC GENERATE	UNIT	
* LICENSED *	10.09	08/01/74	ARKANSAS 1	5.68	12/26/78	ARKANSAS 2		8.22	06/14/76	BEAVER VALLEY 1	
* OPERATING *	21.73	12/08/62	BIG ROCK POINT 1	10.88	10/15/73	BROWNS FERRY 1		10.01	08/28/74	BROWNS FERRY 2	
* ELECTRICAL *	7.97	09/12/76	BROWNS FERRY 3	7.74	12/04/76	BRUNSWICK 1		9.34	04/29/75	BRUNSWICK 2	
* PRODUCING *	9.66	01/03/75	CALVERT CLIFFS 1	7.73	12/07/76	CALVERT CLIFFS 2		9.56	02/10/75	COOK 1	
* UNITS *	6.45	03/22/78	COOK 2	10.31	05/10/74	COOPER STATION		7.59	01/30/77	CRYSTAL RIVER 3	
*****	7.01	08/28/77	DAVIS-BESSE 1	14.39	04/13/70	DRESDEN 2		13.11	07/22/71	DRESDEN 3	
	10.29	05/19/74	DUANE ARNOLD	7.04	08/18/77	FARLEY 1		3.27	05/25/81	FARLEY 2	
	9.58	02/01/75	FITZPATRICK	11.02	08/25/73	FORT CALHOUN 1		7.72	12/11/76	FORT ST VRAIN	
	14.75	12/02/69	GINNA	17.07	08/07/67	HADDAM NECK		9.81	11/11/74	HATCH 1	
	5.94	09/22/78	HATCH 2	11.18	06/26/73	INDIAN POINT 2		8.35	04/27/76	INDIAN POINT 3	
	10.40	04/08/74	KEWAUNEE	16.35	04/26/68	LA CROSSE		1.99	09/04/82	LASALLE 1	
	.37	04/20/84	LASALLE 2	11.81	11/08/72	MAINE YANKEE		3.17	06/30/81	MCGUIRE 1	
	1.28	05/23/83	MCGUIRE 2	13.76	11/29/70	MILLSTONE 1		8.81	11/09/75	MILLSTONE 2	
	13.49	03/05/71	MONTICELLO	14.81	11/09/69	NINE MILE POINT 1		6.38	04/17/78	NORTH ANNA 1	
	4.02	08/25/80	NORTH ANNA 2	11.32	05/06/73	OCONEE 1		10.74	12/05/73	OCONEE 2	
	10.00	09/01/74	OCONEE 3	14.94	09/23/69	OYSTER CREEK 1		12.67	12/31/71	PALISADES	
	10.54	02/18/74	PEACH BOTTOM 2	10.00	09/01/74	PEACH BOTTOM 3		12.12	07/19/72	PILGRIM 1	
	13.82	11/06/70	POINT BEACH 1	12.08	08/02/72	POINT BEACH 2		10.74	12/04/73	PRAIRIE ISLAND 1	
	9.70	12/21/74	PRAIRIE ISLAND 2	12.39	04/12/72	QUAD CITIES 1		12.28	05/23/72	QUAD CITIES 2	
	9.89	10/13/74	RANCHO SECO 1	13.93	09/26/70	ROBINSON 2		7.69	12/25/76	SALEM 1	
	3.25	06/03/81	SALEM 2	17.13	07/16/67	SAN ONOFRE 1		1.95	09/20/82	SAN ONOFRE 2	
	.94	09/25/83	SAN ONOFRE 3	4.11	07/22/80	SEQUOYAH 1		2.69	12/23/81	SEQUOYAH 2	
	8.32	05/07/76	ST LUCIE 1	1.22	06/13/83	ST LUCIE 2		1.79	11/16/82	SUMMER 1	
	12.16	07/04/72	SURRY 1	11.48	03/10/73	SURRY 2		1.79	11/16/82	SUSQUEHANNA 1	
	.16	07/03/84	SUSQUEHANNA 2	10.20	06/19/74	THREE MILE ISLAND 1		8.69	12/23/75	TROJAN	
	11.83	11/02/72	TURKEY POINT 3	11.20	06/21/73	TURKEY POINT 4		11.95	09/20/72	VERMONT YANKEE 1	
	.27	05/27/84	WASHINGTON NUCLEAR 2	23.81	11/10/60	YANKEE-ROWE 1		11.18	06/28/73	ZION 1	
	10.68	12/26/73	ZION 2								

TOTAL 761.82 YRS

*****				*****			
YEARS	1ST ELEC GENERATE	SHUTDOWN DATE	UNIT	YEARS	1ST ELEC GENERATE	SHUTDOWN DATE	UNIT
* PERMANENTLY *	3.80	08/14/64	06/01/68 BONUS	3.04	12/18/63	01/01/67	CVTR
* OR *	18.54	04/15/60	10/31/78 DRESDEN 1	4.44	08/24/63	02/01/68	ELK RIVER
* INDEFINITELY*	6.32	08/05/66	11/29/72 FERMI 1	1.26	05/29/63	09/01/64	HALLAM
* SHUTDOWN *	13.21	04/18/63	07/02/76 HUMBOLDT BAY	12.12	09/16/62	10/31/74	INDIAN POINT 1
* UNITS *	1.19	07/25/66	10/01/67 PATHFINDER	7.76	01/27/67	11/01/74	PEACH BOTTOM 1
*****	2.16	11/04/63	01/01/66 PIQUA	.93	04/21/78	03/28/79	THREE MILE ISLAND 2

TOTAL 74.77 YRS

The total reactor years of experience is as the sum of all calendar days for each unit, from the date that electricity was first generated until a final shutdown date or the status date, whichever comes first, divided by 365.25 days/year. If a date is unknown, the first day of the first month of operation is substituted. Units which have not yet generated electricity but which are licensed are listed but not included in the computation.

 * RESEARCH *
 * REACTORS *

NON-POWER REACTORS IN THE U. S.

STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	LICENSE NUMBER	DATE OF ISSUED	AUTHORIZED POWER LEVEL (KW)
ALABAMA	TUSKEGEE	TUSKEGEE INSTITUTE	AGN-201 #102	50-406	R-122	08-30-74	0.0001
ARIZONA	TUCSON	UNIVERSITY OF ARIZONA	TRIGA MARK I	50-113	R-52	12-05-58	100.0
CALIFORNIA	BERKELEY	UNIVERSITY OF CALIFORNIA, BERKELEY COLLEGE	TRIGA MK. III	50-224	R-101	08-10-66	1000.0
	CANOGA PARK	ROCKWELL INTERNATIONAL CORP.	L-85	50-375	R-188	01-05-72	0.003
	HAWTHORNE	NORTHROP CORP. LABORATORIES	TRIGA MARK F	50-187	R-90	03-04-63	1000.0
	IRVINE	UNIVERSITY OF CALIFORNIA, IRVINE	TRIGA MARK I	50-326	R-116	11-24-69	250.0
	LOS ANGELES	UNIVERSITY OF CALIFORNIA, L.A.	ARGONAUT	50-142	R-71	10-03-60	100.0
	SAN DIEGO	GENERAL ATOMIC COMPANY	TRIGA MARK F	50-163	R-67	07-01-60	1500.0
	SAN DIEGO	GENERAL ATOMIC COMPANY	TRIGA MARK I	50-089	R-38	05-03-58	250.0
	SAN JOSE	GENERAL ELECTRIC COMPANY	NTR	50-073	R-33	10-31-57	100.0
	SAN LUIS OBISPO	CALIFORNIA STATE POLYTECHNIC COLLEGE	AGN-201 #100	50-394	R-121	05-16-73	0.0001
	SAN RAMON	AEROTEST OPERATIONS, INC.	TRIGA (INDUS)	50-228	R-98	07-02-65	250.0
SANTA BARBARA	UNIVERSITY OF CALIFORNIA, SANTA BARBARA	L-77	50-433	R-124	12-03-74	0.01	
COLORADO	DENVER	U.S. GEOLOGICAL SURVEY DEPARTMENT	TRIGA MARK I	50-274	R-113	02-24-69	1000.0
DELAWARE	NEWARK	UNIVERSITY OF DELAWARE	AGN-201 #113	50-098	R-43	07-03-58	0.0001
DIST OF COLUMBIA	WASHINGTON	THE CATHOLIC UNIVERSITY OF AMERICA	AGN-201 #101	50-077	R-31	11-15-67	0.0001
FLORIDA	GAINESVILLE	UNIVERSITY OF FLORIDA	ARGONAUT	50-083	R-56	05-21-59	100.0
GEORGIA	ATLANTA	GEORGIA INSTITUTE OF TECHNOLOGY	AGN-201 #104	50-276	R-111	04-19-68	0.0001
	ATLANTA	GEORGIA INSTITUTE OF TECHNOLOGY	HEAVY WATER	50-160	R-97	12-29-64	5000.0
IDAHO	POCATELLO	IDAHO STATE UNIVERSITY	AGN-201 #103	50-284	R-110	10-11-67	0.0001
ILLINOIS	URBANA	UNIVERSITY OF ILLINOIS	LOPRA	50-356	R-117	12-27-71	10.0
	URBANA	UNIVERSITY OF ILLINOIS	TRIGA	50-151	R-115	07-22-69	1500.0
	ZION	WESTINGHOUSE ELECTRIC CORP.	NTR	50-087	R-119	01-28-72	10.0
INDIANA	LAFAYETTE	PURDUE UNIVERSITY	LOCKHEED	50-182	R-87	08-16-62	10.0
IOWA	AMES	IOWA STATE UNIVERSITY	UTR-10	50-116	R-59	10-16-59	10.0
KANSAS	LAWRENCE	UNIVERSITY OF KANSAS	LOCKHEED	50-148	R-78	06-23-61	250.0
	MANHATTAN	KANSAS STATE UNIVERSITY	TRIGA	50-188	R-88	10-16-62	250.0
MARYLAND	BETHESDA	ARMED FORCES RADIOBIOLOGY RESEARCH INSTITUTE	TRIGA	50-170	R-84	06-26-62	1000.0
	COLLEGE PARK	UNIVERSITY OF MARYLAND	TRIGA	50-166	R-70	10-14-60	250.0

 * RESEARCH *
 * REACTORS *

NON-POWER REACTORS IN THE U. S.

STATE	CITY	LICENSEE	REACTOR TYPE - DOCKET	LICENSE NUMBER	DATE OL ISSUED	AUTHORIZED POWER LEVEL (KW)	
MASSACHUSETTS	CAMBRIDGE	MASSACHUSETTS INSTITUTE OF TECHNOLOGY	HWR REFLECTED	50-J20	R-37	06-09-58	5000.0
	LOWELL	UNIVERSITY OF LOWELL	GE	50-223	R-125	12-24-74	1000.0
	WORCESTER	WORCESTER POLYTECHNIC INSTITUTE	GE	50-134	R-61	12-16-59	10.0
MICHIGAN	ANN ARBOR	UNIVERSITY OF MICHIGAN	POOL	50-002	R-28	09-13-57	2000.0
	EAST LANSING	MICHIGAN STATE UNIVERSITY	TRIGA MARK I	50-294	R-114	03-21-69	250.0
	MIDLAND	DOW CHEMICAL COMPANY	TRIGA	50-264	R-108	07-03-67	100.0
MISSOURI	COLUMBIA	UNIVERSITY OF MISSOURI, COLUMBIA	TANK	50-186	R-103	10-11-66	10000.0
	ROLLA	UNIVERSITY OF MISSOURI	POOL	50-123	R-79	11-21-61	200.0
NEBRASKA	OMAHA	THE VETERANS ADMINISTRATION HOSPITAL	TRIGA	50-131	R-57	06-26-59	18.0
NEW MEXICO	ALBUQUERQUE	UNIVERSITY OF NEW MEXICO	AGN-201M #112	50-252	R-102	09-17-66	0.005
NEW YORK	BRONX	MANHATTAN COLLEGE - PYHSICS DEPT.	TANK	50-199	R-94	03-24-64	0.0001
	BUFFALO	STATE UNIVERSITY OF NEW YORK	PULSTAR	50-057	R-77	03-24-61	2000.0
	ITHACA	CORNELL UNIVERSITY	TRIGA MARK II	50-157	R-80	01-11-62	500.0
	ITHACA	CORNELL UNIVERSITY	ZPR	50-097	R-89	12-11-62	0.1
	NEW YORK	COLUMBIA UNIVERSITY IN THE CITY OF NEW YORK	TRIGA MARK II	50-208	R-128	04-14-77	250.0
	TUXEDO	UNION CARBIDE CORP	POOL	50-054	R-81	09-07-61	5000.0
NORTH CAROLINA	RALEIGH	NORTH CAROLINA STATE UNIVERSITY AT RALEIGH	PULSTAR	50-297	R-120	08-25-72	1000.0
OHIO	COLUMBUS	OHIO STATE UNIVERSITY	POOL	50-150	R-75	02-24-61	10.0
OKLAHOMA	NORMAN	THE UNIVERSITY OF OKLAHOMA	AGN-211 #102	50-112	R-53	12-29-58	0.100
OREGON	CORVALLIS	OREGON STATE UNIVERSITY	TRIGA MARK II	50-243	R-106	03-07-67	1000.0
	PORTLAND	REED COLLEGE	TRIGA MARK I	50-288	R-112	07-02-68	250.0
PENNSYLVANIA	UNIVERSITY PARK	PENNSYLVANIA STATE UNIVERSITY	TRIGA MK. III	50-005	R-2	07-08-55	1000.0
RHODE ISLAND	NARRAGANSETT	RHODE ISLAND NUCLEAR SCIENCE CENTER	GE POOL	50-193	R-95	07-21-64	2000.0
TENNESSEE	MEMPHIS	MEMPHIS STATE UNIVERSITY	AGN-201 #108	50-538	R-127	12-10-76	0.0001
TEXAS	AUSTIN	UNIVERSITY OF TEXAS	TRIGA MARK I	50-192	R-92	08-02-63	250.0
	COLLEGE STATION	TEXAS A&M UNIVERSITY	AGN-201M #106	50-059	R-23	08-26-57	0.005
	COLLEGE STATION	TEXAS A&M UNIVERSITY	TRIGA	50-128	R-83	12-07-61	1000.0
UTAH	PROVO	BRIGHAM YOUNG UNIVERSITY	L-77	50-262	R-109	09-07-67	0.01

 * RESEARCH *
 * REACTORS *

NON - POWER REACTORS IN THE U. S.

STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	LICENSE NUMBER	DATE OF ISSUED	AUTHORIZED POWER LEVEL (KW)
UTAH	SALT LAKE CITY	THE UNIVERSITY OF UTAH	TRIGA MARK I	50-407	R-126	09-30-75	100.0
	SALT LAKE CITY	UNIVERSITY OF UTAH	AGN-201M #107	50-072	R-25	09-12-57	0.005
VIRGINIA	BLACKSBURG	VIRGINIA POLYTECHNIC INSTITUTE	UTR-10	50-124	R-62	12-18-59	100.0
	CHARLOTTESVILLE	UNIVERSITY OF VIRGINIA	CAVALIER	50-396	R-123	09-24-74	0.1
	CHARLOTTESVILLE	UNIVERSITY OF VIRGINIA	POOL	50-062	R-66	06-27-60	2000.0
	LYNCHBURG	BABCOCK & WILCOX COMPANY	LPR	50-099	R-47	09-05-58	1000.0
WASHINGTON	PULLMAN	WASHINGTON STATE UNIVERSITY	TRIGA	50-027	R-76	03-06-61	1000.0
	SEATTLE	UNIVERSITY OF WASHINGTON	ARGONAUT	50-139	R-73	03-31-61	100.0
WISCONSIN	MADISON	UNIVERSITY OF WISCONSIN	TRIGA	50-156	R-74	11-23-60	1000.0
***** * EXPERIMENTAL AND TEST REACTORS * *****							
CALIFORNIA	SAN JOSE	GENERAL ELECTRIC COMPANY	GETR	50-070	TR-1	01-07-59	50,000.0
DIST OF COLUMBIA	WASHINGTON	NATIONAL BUREAU OF STANDARDS	TEST	50-184	TR-5	06-30-70	10,000.0
***** * CRITICAL EXPERIMENT FACILITIES * *****							
NEW YORK	TROY	RENSSELAER POLYTECHNIC INSTITUTE		50-225	CX-22	07-03-64	0.0
VIRGINIA	LYNCHBURG	BABCOCK & WILCOX COMPANY		50-013	CX-10	10-22-58	0.0
WASHINGTON	RICHLAND	BATTELLE MEMORIAL INSTITUTE		50-360	CX-26	11-29-71	0.0

BIBLIOGRAPHIC DATA SHEET

NUREG-0020 Volume 8 Number 9

2 Leave blank

3 TITLE AND SUBTITLE

Licensed Operating Reactors
Status Summary Report

4 RECIPIENT'S ACCESSION NUMBER

5 DATE REPORT COMPLETED

MONTH YEAR
OCTOBER 1984

6 AUTHOR(S)

7 DATE REPORT ISSUED

MONTH YEAR
OCTOBER 1984

8 PERFORMING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)

Division of Budget and Analysis
Office of Resource Management
U. S. Nuclear Regulatory Commission
Washington, DC 20555

9 PROJECT/TASK/WORK UNIT NUMBER

10 FIN NUMBER

11 SPONSORING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)

Division of Budget and Analysis
Office of Resource Management
U. S. Nuclear Regulatory Commission
Washington, DC 20555

12a TYPE OF REPORT

12b PERIOD COVERED (Inclusive dates)

AUGUST 1984

13 SUPPLEMENTARY NOTES

Status Summary Report

14 ABSTRACT (200 words or less)

The OPERATING UNITS STATUS REPORT - LICENSED OPERATING REACTORS provides data on the operation of nuclear units as timely and accurately as possible. This information is collected by the Office of Resource Management from the Headquarters staff of NRC's Office of Inspection and Enforcement, from NRC's Regional Offices, and from utilities. The three sections of the report are: monthly highlights and statistics for commercial operating units, and errata from previously reported data; a compilation of detailed information on each unit, provided by NRC's Regional Offices, IE Headquarters and the utilities; and an appendix for miscellaneous information such as spent fuel storage capability, reactor-years of experience and non-power reactors in the U.S. It is hoped the report is helpful to all agencies and individuals interested in maintaining an awareness of the U.S. energy situation as a whole.

15a KEY WORDS AND DOCUMENT ANALYSIS

15b DESCRIPTORS

16 AVAILABILITY STATEMENT

Unlimited

17 SECURITY CLASSIFICATION

(This report)
Unclassified

18 NUMBER OF PAGES

19 SECURITY CLASSIFICATION

(This page)
Unclassified

20 PRICE

\$

DISTRIBUTION LIST - NRC

INTERNAL DISTRIBUTION

Office of the Commissioners	5
Atomic Safety and Licensing Appeal Panel	3
Advisory Committee on Reactor Safeguards	6
Office of Inspector and Auditor	1
Office of Policy Evaluation	1
Office of the General Counsel	1
Office of Public Affairs	21
Office of Congressional Affairs	3
Office of the Executive Director for Operations	7
Office of Administration	2
Office of the Executive Legal Director	2
Office of Analysis and Evaluation of Operational Data	2
Office of International Programs	3
Office of State Programs	1
Office of Resource Management	19
Office of Nuclear Material Safety and Safeguards	2
- Division of Fuel Cycle and Material Safety	3
- Division of Safeguards	2
Office of Nuclear Reactor Regulation	138
- Division of Engineering	
- Division of Safety Technology	
- Division of Licensing	
- Division of Systems Integration	
- Division of Human Factors Safety	
Office of Nuclear Regulatory Research	4
Office of Inspection and Enforcement	7
- Region I	11
- Region II	10
- Region III	10
- Region IV	10
- Region V	7
	<u>281</u>

EXTERNAL DISTRIBUTION

SPECIAL REQUESTS

Air Force	1
Congress	10
Department of Energy	32
Government Accounting Office	1
Environmental Protection Agency	1
Electric Power Research Institute	1
Argonne National Laboratory	3
Bureau of Mines	1
Department of Agriculture	1
Department of the Commerce	1
Department of the Interior	1
	<u>53</u>

OTHER

GPO Depository	440
GPO Stores	73
National Technical Information Service	25
Subscriptions (NTIS)	250
Colleges and Libraries (including Public Document Rooms)	128
Utilities and Other Requests	227
	<u>1145</u>

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

FIRST CLASS MAIL
POSTAGE & FEES PAID
USNRC
WASH D C
PERMIT No. 987

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300

120555078 77 1 LANING
US NRC
ADM-DIV OF TDC
POLICY & PUB MGT BR-PDR NUREG
W-501
WASHINGTON DC 20555