

DMB016

October 31, 1984

Docket No. 50-321

Mr. J. T. Beckham, Jr.
Vice President - Nuclear Generation
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

Dear Mr. Beckham:

SUBJECT: ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT IMPORTANT
TO SAFETY - REQUEST FOR JUSTIFICATION TO SUPPORT EXTENSION OF
DEADLINE

Re: Edwin I. Hatch Nuclear Plant, Unit No. 1

By letter dated October 19, 1984, you provided information in response to our letter of October 12, 1984 requesting additional information. We have completed our review of that information and find that is not sufficient to support your extension request.

Although you provided information in response to specific questions by the staff in that letter, you did not include any further justification on the basis for your extension request. In particular, in a telecon of October 17, 1984, my staff requested your staff to provide such information, if available, as a part of your October 19, 1984 submittal.

In order to support our review, provide the following information:

- 1) In your July 6, 1984 letter you stated equipment is being replaced rather than being qualified by analysis. Provide a synopsis addressing the number and type of equipment in each category.
- 2) In your July 6, 1984 letter you stated work on installation of the ATTS on Hatch 2 severely impacted this work on Hatch 1. Provide information on the correct status of this design work for Hatch 1 and the specifics of the manpower required to complete the design and installation.
- 3) In your September 11, 1984 letter you stated the maintenance modification originally planned for the outage presented undue demands on personnel resources. For the personnel who would perform the equipment qualification work on Unit 1, provide information on the amount of overtime they worked to support the Unit 2 outage.

8411200037 841031
PDR ADOCK 05000321
P PDR

Mr. J. T. Beckham, Jr.

- 2 -

- 4) Clarify what EQ items other than those associated with ATTS and the hydrogen/oxygen analyzer will require extension.
- 5) Provide any other justification and/or bases which could support your request for extension. In particular, address any item related to procurement lead time, task complications and installation problems.

This information should be submitted to the NRC, on or before November 9, 1984, and signed under oath and affirmation.

Sincerely,

Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

cc: See next page

Distribution:

Docket File
 Reading File
 NRC & L PDRs
 Gray File
 RIngram
 BHermann
 JPartlow
 EJordan
 PMcKee
 OELD
 DEisenhut
 ACRS 10

*See previous white for concurrences.

ORB#3:DL	**ORB#4:DL	** OELD	**AD:OR:DL
BHermann;ef	JFStolz*	WShields	GCLainas
10/29/84	10/25/84	10/25/84	10/25/84

** ORAB	** D:DE	D: <i>DM</i>
	RVollmer	DEisenhut <i>for</i>
10/29/84	10/29/84	10/30/84

Mr. J. T. Beckham, Jr.

- 2 -

- 4) Clarify what EQ items other than those associated with ATTS and the hydrogen/oxygen analyzer will require extension.
- 5) Provide any other justification and/or bases which could support your request for extension. In particular, address any item related to procurement lead time, task complications and installation problems.

This information should be submitted to the NRC, on or before November 1, 1984, and signed under oath and affirmation.

Sincerely,

Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

cc: See next page

Distribution:
Docket File
Reading File
NRC & LIDRs
Gray File
RIngram
BHermann
JPartlow
EJordan
PMcKee
OELD
DEisenhut
ACRS 10

*See previous white for concurrences.

ORB#3:DL	**ORB#4:DL	** OELD	**AD:OR:DL
BHermann;ef	JFStolz*	WShields	GCLainas
10/ /84	10/25/84	10/25/84	10/25/84

<i>[Handwritten Signature]</i> WRAB 10/29/84	<i>[Handwritten Signature]</i> RVollmer 11/25/84	D:DL DEisenhut / /84
--	--	----------------------------

Mr. J. T. Beckham, Jr.

- 2 -

- 4) Clarify what EQ items other than those associated with ATTS and the hydrogen/oxygen analyzer will require extension.
- 5) Provide any other justification and/or bases which could support your request for extension. In particular, address any item related to procurement lead time, task complications and installation problems.

This information should be submitted to the NRC, on or before November 1, 1984, and signed under oath and affirmation.

Sincerely,

Darrell G. Eisenhut, Director
Division of Licensing

cc: See next page

Distribution:
Docket File
Reading File
NRC & L PDRs
Gray File
RIngram
BHermann
JPartlow
EJordan
PMcKee
OELD
DEisenhut
ACRS 10

ORB#3:DL
BHermann;ef
10/20/84

[Signature]
ORB#4:DL
JFStolz
10/25/84

[Signature]
OELD
w. Shiddi
10/29/84

[Signature]
AD:OR:DL
GCLainas
10/25/84

D:DL
DEisenhut
1/84

Hatch 1/2
Georgia Power Company

50-321/366

cc w/enclosure(s):

G. F. Trowbridge, Esq.
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Ruble A. Thomas
Vice President
P. O. Box 2625
Southern Company Services, Inc.
Birmingham, Alabama 35202

Louis B. Long
Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513

Mr. L. T. Gucwa
Georgia Power Company
Engineering Department
P. O. Box 4545
Atlanta, Georgia 30302

Mr. H. C. Nix, Jr. General Manager
Edwin I. Hatch Nuclear Plant
Georgia Power Company
P. O. Box 442
Baxley, Georgia 31513

Regional Radiation Representative
EPA Region IV
345 Courtland Street, N.E.
Atlanta, Georgia 30308

Resident Inspector
U. S. Nuclear Regulatory Commission
Route 1, P. O. Box 279
Baxley, Georgia 31513

Mr. James P. O'Reilly, Regional
Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, S.W.
Atlanta, Georgia 30334

J. Leonard Ledbetter, Commissioner
Department of Natural Resources
270 Washington Street, N.W.
Atlanta, Georgia 30334