DCS No: 11158450336 Date: November 15, 1984

(Reactor Licensees)

## PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-I-84-98

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility: Northeast Utilities

Millstone Unit 2
Waterford, CT
DN 50-336

Millstone Unit 2
Waterford, CT
DN 50-336

Licensee Emergency Classification:

Notification of Unusual Event

Alert
Site Area Emergency
General Emergency
X Not Applicable

Subject: SHUTDOWN IN EXCESS OF 48 HOURS

At 9:32 a.m., 11/15, the reactor tripped from 100% power after the main steam isolation valve (MSIV) for No. 1 Steam Generator failed shut. The MSIV failure was attributed to air-powered actuator seal failure. The resident inspector observed post-trip activities in the control room. No safety problems were identified.

After review of work items which have accumulated during the previous 271 days of continuous operation, the licensee decided to conduct reactor coolant and reactor protection system resistance-temperature-detector response time tests, feedwater heater hydrolazing, and main turbine rebalancing in addition to MSIV repair and checkout. The shutdown duration is expected to exceed 3 days.

The State of Connecticut has been informed.

CONTACT: T. P. Johnson T. Shedlosky E. C. McCabe 215-337-5222 203-447-3179 215-337-5231 DISTRIBUTION: H. St. MNBB Phillips 416 E/W Williste Mail: ADM: DMB Chairman Palladino EDO NRR TE NMSS DOT: Trans only Comm. Zech PA OIA RES Comm. Bernthal MPA AEOD Comm. Roberts ELD Comm. Asselstine ACRS Air Rights INPO----SECY SP NSAC----CA PDR Regional Offices TMI Resident Section 4:09 RI Resident Office 4:11 Licensee:

Region I Form 83 (Rev. July, 1984)

8411200220 841115 PDR I&E PNO-I-84-098 PDR