

WCAP-10637

WESTINGHOUSE CLASS 3
CUSTOMER DESIGNATED DISTRIBUTION

ANALYSIS OF CAPSULES T-330 AND W-290 FROM THE
CONSUMERS POWER COMPANY
PALISADES REACTOR VESSEL
RADIATION SURVEILLANCE PROGRAM

M. K. Kunka
C.A. Cheney

September 1984

Work performed under Shop Order Nos. ENVJ-106 and ENVJ-450

APPROVED:

T. A. Meyer

T. A. Meyer, Manager

Structural Materials and Reliability Technology

Prepared by Westinghouse for the Consumers Power Company

Although information contained in this report is nonproprietary, no distribution shall be made outside Westinghouse or its licensees without the customer's approval.

WESTINGHOUSE ELECTRIC CORPORATION
Nuclear Energy Systems
P.O. Box 355
Pittsburgh, Pennsylvania 15230

8411200379 841031
PDR ADOCK 05000255
P PDR

PREFACE

This report has been technically reviewed and verified.

Reviewer

Sections 1 through 5 and 7

S. E. Yanichko

Section 6

S. L. Anderson

18 June 68
S. L. Anderson

TABLE OF CONTENTS

| Section | Title | Page |
|---------|--|------|
| 1 | SUMMARY OF RESULTS | 1-1 |
| 2 | INTRODUCTION | 2-1 |
| 3 | BACKGROUND | 3-1 |
| 4 | DESCRIPTION OF PROGRAM | 4-1 |
| 5 | TESTING OF SPECIMENS FROM CAPSULES T-330 and W-290 | 5-1 |
| | 5-1. Overview | 5-1 |
| | 5-2. Thermal Monitor Melting | 5-3 |
| | 5-3. Chemical Analysis | 5-4 |
| | 5-4. Charpy V-Notch Impact Test Results | 5-4 |
| | 5-5. Tension Test Results | 5-6 |
| 6 | RADIATION ANALYSIS AND NEUTRON DOSIMETRY | 6-1 |
| | 6-1. Introduction | 6-1 |
| | 6-2. Discrete Ordinates Analysis | 6-1 |
| | 6-3. Neutron Dosimetry | 6-8 |
| | 6-4. Transport Analysis Results | 6-11 |
| | 6-5. Dosimetry Results | 6-21 |
| 7 | REFERENCES | 7-1 |

LIST OF TABLES

| Table | Title | Page |
|-------|--|------|
| 4-1 | Chemical Composition of the Palisades Reactor Vessel Surveillance Materials | 4-4 |
| 5-1 | Results of Chemical Analyses Performed on Palisades Charpy V-Notch Specimens (WT-%) | 5-7 |
| 5-2 | Capsule T-330, Thermal Capsule: Charpy V-Notch Impact Data for the Palisades Intermediate Shell Plate D-3803-1 (Transverse Orientation) | 5-8 |
| 5-3 | Capsule T-330, Thermal Capsule: Charpy V-Notch Impact Data for the Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation) | 5-9 |
| 5-4 | Capsule T-330, Thermal Capsule: Charpy V-Notch Impact Data for the Palisades Pressure Vessel Weld Metal | 5-10 |
| 5-5 | Capsule T-330, Thermal Capsule: Charpy V-Notch Impact Data for the Palisades Pressure Vessel Weld Heat-Affected Zone Metal | 5-11 |
| 5-6 | Capsule T-330, Thermal Capsule: Instrumented Charpy Impact Test Results for Palisades Intermediate Shell Plate D-3803-1 (Transverse Orientation) | 5-12 |

LIST OF TABLES (cont.)

| Table | Title | Page |
|-------|--|------|
| 5-7 | Capsule T-330, Thermal Capsule: Instrumentated Charpy Impact Test Results for Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation) | 5-13 |
| 5-8 | Capsule T-330, Thermal Capsule: Instrumented Charpy Impact Test Results for Palisades Weld Metal | 5-14 |
| 5-9 | Capsule T-330, Thermal Capsule: Instrumented Charpy Impact Test Results for Palisades Weld Heat Affected Zone Metal | 5-15 |
| 5-10 | Capsule W-290, Irradiated Capsule: Charpy V-Notch Impact Data for the Palisades Intermediate Shell Plate D-3803-1 (Transverse Orientation) | 5-16 |
| 5-11 | Capsule W-290, Irradiated Capsule: Charpy V-Notch Impact Data for the Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation) | 5-17 |
| 5-12 | Capsule W-290, Irradiated Capsule: Charpy V-Notch Impact Data for the Palisades Pressure Vessel Weld Metal | 5-18 |
| 5-13 | Capsule W-290, Irradiated Capsule: Charpy V-Notch Impact Data for the Palisades Pressure Vessel Weld Heat-Affected Zone Metal | 5-19 |

LIST OF TABLES (cont.)

| Table | Title | Page |
|-------|---|------|
| 5-14 | Capsule W-290, Irradiated Capsule: Instrumented Charpy Impact Test Results for Palisades Intermediate Shell Plate D-3803-1 (Transverse Orientation) | 5-20 |
| 5-15 | Capsule W-290, Irradiated Capsule: Instrumented Charpy Impact Test Results for Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation) | 5-21 |
| 5-16 | Capsule W-290, Irradiated Capsule: Instrumented Charpy Impact Test Results for Palisades Weld Metal | 5-22 |
| 5-17 | Capsule W-290, Irradiated Capsule: Instrumented Charpy Impact Test Results for Palisades Weld Heat Affected Zone Metal | 5-23 |
| 5-18 | Effect of Irradiation at 1.09×10^{19} ($E > 1$ MeV) on the Notch Toughness Properties of the Palisades Surveillance Vessel Materials | 5-24 |
| 5-19 | Thermal Capsule Tensile Properties for Palisades Surveillance Material | 5-25 |
| 5-20 | Irradiated Capsule Tensile Properties for Palisades Surveillance Material, Irradiated to 1.09×10^{19} n/cm ² | 5-26 |
| 6-1 | 26 Group Energy Structure | 6-5 |

LIST OF TABLES (cont.)

| Table | Title | Page |
|-------|--|------|
| 6-2 | Nuclear Constants for Neutron Flux Monitors Contained in the Palisades Surveillance Capsule | 6-8 |
| 6-3 | Calculated Neutron Energy Spectra Above 0.1 MeV at the Center of Palisades Capsule | 6-13 |
| 6-4 | Spectrum-Averaged Reaction Cross Sections at the Center of Palisades Surveillance Capsules | 6-14 |
| 6-5 | Irradiation History of Palisades Surveillance Capsule W-290 | 6-15 |
| 6-6 | Comparison of Measured and Calculated Fast Neutron Flux Monitor Saturated Activities for Capsule W-290 | 6-22 |
| 6-7 | Results of Fast Neutron Dosimetry for Capsule W-290 | 6-24 |
| 6-8 | Summary of Neutron Dosimetry Results for Capsule W-290 | 6-25 |

LIST OF ILLUSTRATIONS

| Figure | Title | Page |
|--------|---|------|
| 4-1 | Arrangement of Surveillance Capsules in the Palisades Reactor Vessel | 4-5 |
| 4-2 | Diagram Showing Location of Test Specimens, Thermal Monitors, and Dosimetry Monitors in the Palisades Surveillance Capsule Assemblies | 4-6 |
| 4-3 | Palisades Weld Metal Surveillance Test Material Fabrication (From C-E Drawing No. C-245-321-1) | 4-7 |
| 5-1 | Thermal Capsule Charpy V-Notch Impact Properties for Palisades Intermediate Shell Plate D-3803-1 (Transverse Orientation) | 5-27 |
| 5-2 | Thermal Capsule Charpy V-Notch Impact Properties for Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation) | 5-28 |
| 5-3 | Thermal Capsule Charpy V-Notch Impact Properties for Palisades Weld Metal | 5-29 |
| 5-4 | Thermal Capsule Charpy V-Notch Impact Properties for Palisades Weld Heat Affected Zone Metal | 5-30 |
| 5-5 | Thermal Capsule (T-330) Charpy Impact Specimen Fracture Surfaces for Palisades Intermediate Shell Plate D-3803-1 (Transverse Orientation) | 5-31 |

LIST OF ILLUSTRATIONS (cont.)

| Figure | Title | Page |
|--------|---|------|
| 5-6 | Thermal Capsule (T-330) Charpy Impact Specimen Fracture Surfaces for Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation) | 5-32 |
| 5-7 | Thermal Capsule (T-330) Charpy Impact Specimen Fracture Surfaces for Palisades Weld Metal | 5-33 |
| 5-8 | Thermal Capsule (T-330) Charpy Impact Specimen Fracture Surfaces for Palisades Weld Heat Affected Zone Metal | 5-34 |
| 5-9 | Typical Curve for Instrumented Charpy Specimens | 5-35 |
| 5-10 | Irradiated Capsule Charpy V-Notch Impact Properties for Palisades Intermediate Shell Plate D-3803-1 (Transverse Orientation) | 5-36 |
| 5-11 | Irradiated Capsule Charpy V-Notch Impact Properties for Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation) | 5-37 |
| 5-12 | Irradiated Capsule Charpy V-Notch Impact Properties for Palisades Weld Metal | 5-38 |
| 5-13 | Irradiated Capsule V-Notch Impact Properties for Palisades Weld Heat Affected Zone Metal | 5-39 |

LIST OF ILLUSTRATIONS (cont.)

| Figure | Title | Page |
|--------|---|------|
| 5-14 | Irradiated Capsule (W-290) Charpy Impact Specimen Fracture Surfaces for Palisades Intermediate Shell Plate D-3803-1 (Transverse Orientation) | 5-40 |
| 5-15 | Irradiated Capsule (W-290) Charpy Impact Specimen Fracture Surfaces for Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation) | 5-41 |
| 5-16 | Irradiated Capsule (W-290) Charpy Impact Specimen Fracture Surfaces for Palisades Weld Metal | 5-42 |
| 5-17 | Irradiated Capsule (W-290) Charpy Impact Specimen Fracture Surfaces for Palisades Weld Metal Heat Affected Zone Metal | 5-43 |
| 5-18 | Comparison of Actual Versus Predicted 30 ft-lb Transition Temperature Increases for the Palisades Surveillance Weld Material, Based on the Prediction Methods of Regulatory Guide 1.99 Revision 1 | 5-44 |
| 5-19 | Thermal Capsule Tensile Properties for Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation) | 5-45 |
| 5-20 | Thermal Capsule Tensile Properties for Palisades Weld Metal | 5-46 |
| 5-21 | Thermal Capsule Tensile Properties for Palisades Weld Heat Affected Zone Metal | 5-47 |

LIST OF ILLUSTRATIONS (cont.)

| Figure | Title | Page |
|--------|--|------|
| 5-22 | Fractured Thermal Capsule Tensile Specimens of Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation) | 5-48 |
| 5-23 | Fractured Thermal Capsule Tensile Specimens of Palisades Weld Metal | 5-49 |
| 5-24 | Fractured Thermal Capsule Tensile Specimens of Palisades Weld Heat Affected Zone Metal | 5-50 |
| 5-25 | Typical Stress-Strain Curve for Tension Specimens | 5-51 |
| 5-26 | Irradiated Capsule Tensile Properties for Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation) | 5-52 |
| 5-27 | Irradiated Capsule Tensile Properties for Palisades Weld Metal | 5-53 |
| 5-28 | Irradiated Capsule Tensile Properties for Palisades Weld Heat Affected Zone Metal | 5-54 |
| 5-29 | Fractured Irradiated Capsule Tensile Specimens of Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation) | 5-55 |
| 5-30 | Fractured Irradiated Capsule Tensile Specimens of Palisades Weld Metal | 5-56 |

LIST OF ILLUSTRATIONS (cont.)

| Figure | Title | Page |
|--------|---|------|
| 5-31 | Fractured Irradiated Capsule Tensile Specimens of Palisades Weld Heat Affected Zone Metal | 5-57 |
| 6-1 | Palisades Reactor Geometry | 6-2 |
| 6-2A | Plan View of Palisades Wall Capsules | 6-3 |
| 6-2B | Plan View of a Reactor Vessel Surveillance Capsule | 6-4 |
| 6-3 | Calculated Azimuthal Distribution of Maximum Fast Neutron Flux ($E > 1.0$ MEV) within the Pressure Vessel Surveillance Capsule | 6-26 |
| 6-4 | Calculated Radial Distribution of Maximum Fast Neutron Flux ($E > 1.0$ MEV) within the Pressure Vessel | 6-27 |
| 6-5 | Calculated Radial Distribution of Maximum Fast Neutron Flux ($E > 1.0$ MEV) within the Surveillance Capsule | 6-28 |
| 6-6 | Calculated Uranium Saturated Activity within Capsule W-290 | 6-29 |
| 6-7 | Calculated Titanium Saturated Activity within Capsule W-290 | 6-30 |
| 6-8 | Calculated Iron Saturated Activity within Capsule W-290 | 6-31 |
| 6-9 | Calculated Nickel Saturated Activity within Capsule W-290 | 6-32 |
| 6-10 | Calculated Copper Saturated Activity within Capsule W-290 | 6-33 |

SECTION 1
SUMMARY OF RESULTS

The analysis of the material contained in Capsule T-330, the first thermal surveillance capsule removed from the Consumers Power Company's Palisades reactor pressure vessel, led to the following conclusions:

- o The weld and heat-affected zone metal has experienced a 60-70°F shift in the ductile to brittle transition temperatures due to exposure to elevated temperature.

The analysis of the material contained in Capsule W-290, the second irradiated surveillance capsule to be removed from the Consumers Power Company Palisades reactor pressure vessel, led to the following conclusions:

- o The capsule received an average fast neutron fluence ($E > 1.0 \text{ Mev}$) of $1.09 \times 10^{19} \text{ n/cm}^2$.
- o Irradiation of the reactor vessel intermediate shell course plate D-3803-1, to $1.09 \times 10^{19} \text{ n/cm}^2$, resulted in 30 and 50 ft-lb transition temperature increases of 155 and 160°F, respectively, for specimens oriented perpendicular to the principal rolling direction (transverse orientation), and 175°F and 180°F, respectively, for specimens oriented parallel to the principal rolling direction (longitudinal orientation).
- o Weld metal irradiated to $1.09 \times 10^{19} \text{ n/cm}^2$ resulted in 30 and 50 ft-lb transition temperature increase of 290 and 300°F, respectively.
- o The average upper shelf energy of all the surveillance materials remained above 50 ft-lbs, thereby providing adequate toughness for continued safe plant operation.

- o Comparison of the 30 ft-lb transition temperature increases for the Palisades surveillance material with predicted increases using the methods of NRC Regulatory Guide 1.99, Revision 1, shows that the weld metal transition temperature increase was greater than predicted. It is suspected that the relatively high nickel content of the weld metal contributed to the greater than predicted transition temperature increase experienced by the weld metal.

SECTION 2 INTRODUCTION

This report presents the results of the examinations of Capsule T-330, a thermal surveillance capsule, and Capsule W-290, an irradiated surveillance capsule, removed from the Palisades reactor vessel during a Fall of 1983 outage. Throughout the operating life of the Palisades Nuclear Plant the thermal capsule, Capsule T-330, was located above the reactor core and was exposed only to the elevated temperature of reactor operation. Capsule W-290, the second irradiated surveillance capsule to be removed from the Palisades reactor vessel, is part of the continuing program which monitors the effects of neutron irradiation, on the encapsulated materials, under actual operation conditions.

The Palisades nuclear reactor is a pressurized water reactor built by Combustion Engineering Inc. The surveillance program for the reactor pressure vessel was designed by Combustion Engineering Inc. to the requirements of ASTM E185-66. A complete description of the surveillance program has been reported by Combustion Engineering Inc.^[1] This report summarizes the testing of and postirradiation data obtained from Capsules T-330 and W-290 removed from the Palisades reactor vessel, and discusses the analysis of these data. The data are compared to the results of tests performed on unirradiated material as reported by Battelle Columbus Laboratories^[2].

SECTION 3 BACKGROUND

The ability of the large steel pressure vessel containing the reactor core and its primary coolant to resist fracture constitutes an important factor in ensuring safety in the nuclear industry. The beltline region of the reactor pressure vessel is the most critical region of the vessel because it is subjected to significant fast neutron bombardment. The overall effects of fast neutron irradiation on the mechanical properties of low alloy ferritic pressure vessel steels such as SA-302 (Modified) Grade B (base material of the Palisades reactor pressure vessel beltline) are well documented in the literature. Generally, low alloy ferritic materials show an increase in hardness and tensile properties and a decrease in ductility and toughness under certain conditions of irradiation.

A method for performing analyses to guard against fast fracture in reactor pressure vessels has been presented in "Protection Against Non-ductile Failure," Appendix G to Section III of the ASME Boiler and Pressure Vessel Code. The method utilizes fracture mechanics concepts and is based on the reference nil-ductility temperature, RT_{NDT} .

The initial RT_{NDT} is defined as the greater of either the drop weight nil-ductility transition temperature (NDTT per ASTM E-208) or the temperature 60°F less than the 50 ft lb (and 35-mil lateral expansion) temperature as determined from Charpy specimens oriented normal (transverse) to the major working direction of the material. The RT_{NDT} of a given material is used to index that material to a reference stress intensity factor curve (K_{IR} curve) which appears in Appendix G of the ASME Code. The K_{IR} curve is a lower bound of dynamic, crack arrest, and static fracture toughness results obtained from several heats of pressure vessel steel. When a given material is indexed to the K_{IR} curve, allowable stress intensity factors can be obtained for this material as a function of temperature. Allowable operating limits can then be determined utilizing these allowable stress intensity factors.

RT_{NDT} and, in turn, the operating limits of nuclear power plants can be adjusted to account for the effects of radiation on the reactor vessel material properties. The radiation embrittlement or changes in mechanical properties of a given reactor pressure vessel steel can be monitored by a reactor surveillance program, in which a surveillance capsule is periodically removed from the operating nuclear reactor and the encapsulated specimens are tested. The increase in the average Charpy V-notch 30 ft-lb temperature (ΔRT_{NDT}) due to irradiation is added to the original RT_{NDT} to adjust the RT_{NDT} for radiation embrittlement. This adjusted RT_{NDT} (RT_{NDT} initial + ΔRT_{NDT}) is used to index the material to the K_{IR} curve and, in turn, to set operating limits for the nuclear power plant which take into account the effects of irradiation on the reactor vessel materials. RT_{NDT} can also be adjusted by using radiation damage trend curves such as those identified in NRC Regulatory Guide 1.99 Revision 1.

SECTION 4 DESCRIPTION OF PROGRAM

Eight surveillance capsules for monitoring the effects of neutron exposure on the Palisades reactor pressure vessel core region material were inserted in the reactor vessel prior to initial plant startup. Six of these capsules were positioned on the inner wall of the reactor vessel ("wall" capsules), while the other two capsules were positioned closer to the core, on the outer wall of the core support barrel ("accelerated" capsules). Figure 4-1 shows the location of the various irradiation surveillance capsule assemblies within the Palisades pressure vessel.

Two surveillance capsules for monitoring the effects of operating temperature on the Palisades reactor pressure vessel material were also inserted prior to plant startup. In Figure 4-1, note their location in relation to the reactor core.

Capsules T-330 and W-290 were removed after 4.975 effective full power years of plant operation. Per reference (1), the Combustion Engineering description of the Palisades surveillance program, each of these capsules contained Charpy V-notch impact and tensile test specimens (Figure 4-2) from the intermediate shell course plate, from submerged arc weld metal representative of the core region of the reactor vessel, and from the weld heat-affected zone (HAZ) material.

The chemistry of the surveillance materials, as reported by Combustion Engineering⁽¹⁾, are presented in Table 4-1. The chemical analyses reported in Table 4-1 were obtained from unirradiated material used in the surveillance program. The surveillance plate material was cut directly from the intermediate shell course plate, and thus received the same heat treatment. The surveillance material received 1 3/4 hours interstage and 30 hours final heat, at $1150 \pm 25^{\circ}\text{F}^{(1)}$. The base metal test material was fabricated from plate no. D-3803-1. The weld metal test material was fabricated by welding together intermediate shell plate nos. D-3803-1 and D-3803-2. The heat-affected zone

test material was fabricated by welding together intermediate shell plate nos. D-3803-2 and D-3803-3. In their summary report on the Palisades surveillance program⁽¹⁾, Combustion Engineering explains that the root welds, of both the weld and HAZ surveillance material, were manually welded with an 8018-E Class 3 rod (note the backgroove area highlighted in Figure 4-3), and then chipped back after a given amount of face weld was established. The face welds were made by a submerged arc process, using a MIL-B4 electrode and a simultaneous 1/16" diameter Nickel-200 wire feed.

All the plate test specimens represent material taken at least one plate thickness from any water quenched edge. Charpy specimens were machined from the plate in both the longitudinal (major axis of specimen is parallel to the principal rolling direction) and transverse (major axis of the specimen is perpendicular to the principal rolling direction) orientations. Tensile specimens were machined from the plate with the major axis of the specimen parallel to the principal rolling direction. Charpy V-notch and tensile specimens from the heat-affected zone were oriented with the major axis of the specimens transverse to the welding direction. The root of the Charpy specimen notches were centered on the fusion line between the base metal and weld metal. For the weld metal specimens, the Charpy V-notch specimens were oriented with the major axis of the specimen transverse to the welding direction, while the tensile specimens were oriented with the major axis of the specimen parallel to the welding direction.

The flux monitors were fabricated using six materials as neutron threshold detectors -- uranium, sulfur, iron, nickel, copper and titanium. Two sets of flux monitors were installed in each tensile-monitor compartment. One set of flux monitors, consisting of the six different materials, are used to determine the neutron spectrum. Each detector was placed inside a grooved 1/8-inch sheath of 304 stainless steel (plain quartz in the case of sulfur) which is used to identify the material and to facilitate handling. Cadmium covers were used for those materials which have competing thermal activities (i.e., uranium, nickel and copper). The second set of monitors is composed of iron wires placed inside a grooved 1/16-inch sheath of 304 stainless steel, and they serve to evaluate the flux attenuation through the thickness of the Charpy specimen.

The temperature monitor assemblies consist of four separate monitors, each of a different composition and thus having a different melting point. The four alloys and their melting points are:

| | |
|------------------------------|------------------------|
| 92.5% Pb, 5.0% Sn, 2.5% Ag | Melting Point of 536°F |
| 90.0% Pb, 5.0% Sn, 5.0% Ag | Melting Point of 558°F |
| 97.5% Pb, 2.5% Ag | Melting Point of 580°F |
| 97.5% Pb, 0.75% Sn, 1.75% Ag | Melting Point of 590°F |

TABLE 4-1
 CHEMICAL COMPOSITION OF THE
 PALISADES REACTOR VESSEL
 SURVEILLANCE MATERIALS

Chemical Composition (WT-%)
 (Combustion Engineering Analyses⁽¹⁾)

| Element | Base Material, (a) | | | HAZ Weld Material (b) | | Weld Metal (c) | |
|---------|--------------------|----------|----------|-----------------------|------|----------------|------|
| | Plate | Plate | Plate | Root | Face | Root | Face |
| | D-3803-1 | D-3803-2 | D-3803-3 | | | | |
| Si | .23 | .32 | .24 | .24 | .25 | .25 | .22 |
| S | .019 | .021 | .020 | .009 | .010 | .010 | .010 |
| P | .011 | .012 | .010 | .011 | .012 | .011 | .011 |
| Mn | 1.55 | 1.43 | 1.56 | 1.08 | 1.03 | 1.01 | 1.02 |
| C | .22 | .23 | .21 | .098 | .080 | .088 | .086 |
| Cr | .13 | .42 | .13 | .05 | .04 | .05 | .03 |
| Ni | .53 | .55 | .53 | .43 | 1.28 | .63 | 1.27 |
| Mo | .58 | .58 | .59 | .54 | .53 | .55 | .52 |
| Al | .037 | .022 | .037 | Nil | Nil | Nil | Nil |
| V | .003 | .003 | .003 | Nil | Nil | Nil | Nil |
| Cu | .25 | .25 | .25 | .25 | .20 | .26 | .22 |

(a) Used to fabricate base metal test specimens.

(b) Fabricated by welding plate D-3803-2 to plate D-3803-3.

(c) Fabricated by welding plate D-3803-1 to plate D-3803-2.





Figure 4-1 Arrangement of Surveillance Capsules in the Palisades Reactor Vessel




Figure 4-2 Diagram Showing Location of Test Specimens, Thermal Monitors, and Dosimetry Monitors in the Palisades Surveillance Capsule Assemblies




Figure 4-3 Palisades Weld Metal Surveillance
Test Material Fabrication (From C-E
Drawing No. C-245-321-1)

SECTION 5
TESTING OF SPECIMENS FROM CAPSULES T-330 AND W-290

5-1. OVERVIEW

The postirradiation mechanical testing of the thermal and irradiated capsules' Charpy V-notch and tensile specimens was performed at the Westinghouse Research and Development Laboratory, with consultation by Westinghouse Nuclear Energy Systems personnel. Testing was performed in accordance with 10CFR50, Appendices G and H, ASTM Specification E185-82 and Westinghouse Procedures RMFs 8402-0, 8102-0, and 8103-0.

Upon receipt of the capsules at the laboratory, they were opened in accordance with Westinghouse Procedure RMF 8404-0. The specimens and spacer blocks were carefully removed, inspected for identification number, and checked against the master list in C-E's summary report.^[1] No discrepancies were found.

Examination of the four types of low-melting (536, 558, 580 and 590°F) alloys indicated no melting of any of the thermal monitors.

Samples of both the surveillance capsule plate and weld metal materials were chemically analyzed for the elemental content of Cr, Cu, Mn, Mo, and Ni (by an emission spectroscopy inductively coupled plasma method), and for P and Si (through wet analysis techniques).

The Charpy impact tests were performed per ASTM Specification E23-82 and RMF Procedure 8103 on a Tinius-Olsen Model 74, 359J machine. The tup (striker) of the Charpy machine is instrumented with an Effects Technology Model 500 instrumentation system. With this system, load-time and energy-time signals can be recorded in addition to the standard measurement of Charpy energy (E_D). From the load-time curve, the load of general yielding (P_{GY}), the time to general yielding (t_{GY}), the maximum load (P_M), and the time to maximum load (t_M) can be determined. Under some test conditions, a sharp drop in load indicative of fast fracture was observed. The load at which fast

fracture was initiated is identified as the fast fracture load (P_F), and the load at which fast fracture terminated is identified as the arrest load (P_A).

The energy at maximum load (E_M) was determined by comparing the energy-time record and the load-time record. The energy at maximum load is roughly equivalent to the energy required to initiate a crack in the specimen. Therefore, the propagation energy for the crack (E_p) is the difference between the total energy to fracture (E_D) and the energy at maximum load.

The yield stress (σ_y) is calculated from the three point bend formula. The flow stress is calculated from the average of the yield and maximum loads, also using the three point bend formula.

Percentage shear was determined from postfracture photographs using the ratio-of-areas methods in compliance with ASTM Specification A370-77. The lateral expansion was measured using a dial gage rig similar to that shown in the same specification.

Tension tests were performed on a 20,000-pound Instron, split-console test machine (Model 1115) per ASTM Specifications E8-83 and E21-79, and RMF Procedure 8102. All pull rods, grips, and pins were made of Inconel 718 hardened to Rc45. The upper pull rod was connected through a universal joint to improve axially of loading. The tests were conducted at a constant crosshead speed of 0.05 inch per minute throughout the test.

Deflection measurements were made with a linear variable displacement transducer (LVDT) extensometer. The extensometer knife edges were spring-loaded to the specimen and operated through specimen failure. The extensometer gage length is 1.00 inch. The extensometer is rated as Class B-2 per ASTM E83-67.

Elevated test temperatures were obtained with a three-zone electric resistance split-tube furnace with a 9-inch hot zone. All tests were conducted in air.

Because of the difficulty in remotely attaching a thermocouple directly to the specimen, the following procedure was used to monitor specimen temperature.

Chromel-alumel thermocouples were inserted in shallow holes in the center and each end of the gage section of a dummy specimen and in each grip. In test configuration, with a slight load on the specimen, a plot of specimen temperature versus upper and lower grip and controller temperatures was developed over the range room temperature to 550°F (288°C). The upper grip was used to control the furnace temperature. During the actual testing the grip temperatures were used to obtain desired specimen temperatures. Experiments indicated that this method is accurate to plus or minus 2°F.

The yield load, ultimate load, fracture load, total elongation, and uniform elongation were determined directly from the load-extension curve. The yield strength, ultimate strength, and fracture strength were calculated using the original cross-sectional area. The final diameter and final gage length were determined from postfracture photographs. The fracture area used to calculate the fracture stress (true stress at fracture) and percent reduction in area was computed using the final diameter measurement.

5-2. THERMAL MONITOR MELTING

Due to the lack of thermal monitor melting, questions arose as to whether the Palisades reactor was operating at a lower than design temperature, or whether the thermal monitor melting points were other than had been specified. To answer this, a system, consisting of a troughed brass block resting on a hot plate, was rigged for melting the capsule thermal monitors. A thermocouple was placed in the trough with the monitor wire, and upon gradual heating the temperature of visually observable melting was noted. To prevent oxide formation from visually concealing the point of monitor melting, the monitors were coated with flux.

Prior to testing the Palisades thermal monitors, controls were run of calibrated Westinghouse thermal monitors. Two Palisades thermal monitors (536 and 590°F) (from capsule T-330) were then tested. The 590°F monitor melted at its rated temperature. The 536°F monitor melted only upon reaching 572°F, which indicates that the 536°F monitor has a much higher melting point and therefore is not truly a 536°F monitor. A 558°F monitor from capsule W-290 was then tested and resulted in a melting temperature of 590°F. Based on

these test results it appears that a mixup in monitors occurred during the initial loading of the capsules and therefore a reliable estimate of the capsule temperature cannot be determined from the thermal monitors.

5-3. CHEMICAL ANALYSIS

Chemical analyses were performed on fractured Charpy V-notch specimens in order to confirm the chemical composition of the surveillance plate and weld materials. The chemical analysis results are summarized in Table 5-1. The most notable feature of these analyses is the great variance measured in the nickel content, specifically from .95 to 1.60 wt. %. From the high nickel content, it is evident that a Nickel-200 addition was made to the surveillance weldment, and from the nickel variances observed it can be concluded that the rate of Nickel-200 addition was varied during welding.

5-4. CHARPY V-NOTCH IMPACT TEST RESULTS

Capsule T-330:

The results of the Charpy V-notch impact tests performed on the various materials contained in Capsule T-330, the thermal capsule, are presented in Tables 5-2 through 5-9 and Figures 5-1 through 5-4. From the Charpy V-notch plots based on best engineering judgement it appears that the weld and heat-affected zone metals have experienced a 60 to 70°F shift in the ductile to brittle transition temperatures due to exposure to elevated temperature, but no decrease in upper shelf energy.

The fracture appearance of each Charpy specimen from the various materials is shown in Figures 5-5 through 5-8, and show an increasing ductile or tougher appearance with increasing test temperature.

A typical instrumented Charpy curve, representing the curves of both Capsule T-330 and Capsule W-290, is presented in Figure 5-9.

Capsule W-290:

The results of the Charpy V-notch impact tests performed on the various materials contained in Capsule W-290, irradiated at 1.09×10^{19} n/cm², are presented in Tables 5-10 through 5-17 and Figures 5-10 through 5-13. A summary of the transition temperature increases and upper shelf energy decreases for the Capsule W-290 material is shown in Table 5-18.

Irradiation of the vessel intermediate shell course plate D-3803-1 (transverse orientation) to 1.09×10^{19} n/cm² (Figure 5-10) resulted in 30 and 50 ft-lb transition temperature increases of 155 and 160°F, respectively, and an upper shelf energy decrease of 18 ft-lb. Irradiation of the vessel intermediate shell plate material (longitudinal orientation) to 1.09×10^{19} n/cm² (Figure 5-11) resulted in 30 and 50 ft-lb transition temperature increases of 175 and 180°F, respectively, and an upper shelf energy decrease of 43 ft-lb.

Weld metal irradiated to 1.09×10^{19} n/cm² (Figure 5-12) resulted in 30 and 50 ft-lb transition temperature increases of 290 and 300°F, respectively, and an upper shelf energy decrease of 54 ft-lb.

Weld HAZ metal irradiated to 1.09×10^{19} n/cm² (Figure 5-13) resulted in 30 and 50 ft-lb transition temperature increases of 235 and 245°F, respectively, and an upper shelf energy decrease of 44 ft-lb.

The fracture appearance of each irradiated Charpy specimen from the various materials is shown in Figures 5-14 through 5-17 and show an increasing ductile or tougher appearance with increasing test temperature.

Figure 5-18 shows a comparison of the 30 ft-lb transition temperature increases for the various Palisades surveillance materials with predicted increases using the methods of NRC Regulatory Guide 1.99, Revision 1.^[3]

The regulatory curves used for comparison were developed from the average copper and phosphorus contents (averages of the analyses presented in Tables 4-1 and 5-1) of plate D-3803-1 and the weld metal. This comparison shows that the plate transition temperature increases resulting from irradiation to 1.09×10^{19} n/cm² are less than predicted by the Guide for plate D-3803-1. The weld metal transition temperature increase resulting from 1.09×10^{19} n/cm² is greater than predicted by the Guide. This can be explained by the high nickel content of the weld metal. It is widely recognized today that nickel has a profound effect upon the irradiation damage of reactor vessel materials, whereas the current revision of Regulatory Guide 1.99 does not incorporate this important variable.

5-5. TENSION TEST RESULTS

Capsule T-330:

The results of the thermal capsule tension tests performed on plate D-3803-1 (longitudinal orientation) and weld metal are shown in Table 5-19 and Figures 5-19 and 5-20, respectively. These results show that the thermal environment produced little change in the 0.2 percent yield strength of the plate and weld material. Fractured tension specimens for each of the materials are shown in Figures 5-22 through 5-24. A typical stress-strain curve for the tension specimens, representing the curves of both Capsule T-330 and Capsule W-290, is shown in Figure 5-25.

Capsule W-290:

The results of the irradiated capsule tension tests performed on plate D-3803-1 (longitudinal orientation) and weld metal irradiated to 1.09×10^{19} n/cm² are shown in Table 5-20 and Figures 5-26 and 5-27, respectively. These results show that irradiation produced an increase in the 0.2 percent yield strength of approximately 20 ksi for plate D-3803-1 and of approximately 30 ksi for the weld metal. Fractured tension specimens for each of the materials are shown in Figures 5-29 through 5-31.

TABLE 5-1
 Results of Chemical Analyses Performed on Palisades
 Charpy V-notch Specimens (WT-%)

| Charpy Specimen | Cr | Cu | Mn | Mo | Ni | P | Si |
|----------------------|------|-----|------|-----|------|------|-----|
| 37C (Weld Metal | .050 | .25 | 1.28 | .51 | 1.60 | .013 | .20 |
| 341 (Weld Metal) | .056 | .30 | 1.20 | .52 | 1.38 | .014 | .25 |
| 46D (Weld Metal | | | | | | | |
| Portion of HAZ | | | | | | | |
| Specimen) | .050 | .26 | 1.22 | .47 | 1.19 | .015 | .24 |
| 46E (Weld Metal | | | | | | | |
| Portion of HAZ | | | | | | | |
| Specimen) | .050 | .25 | 1.09 | .45 | 0.95 | .014 | .19 |
| 22J (Plate D-3803-1) | .11 | .24 | 1.66 | .45 | 0.53 | .005 | .20 |
| 25J (Plate D-3803-1) | .11 | .24 | 1.61 | .45 | 0.52 | .004 | .24 |

TABLE 5-2

CAPSULE T-330, THERMAL CAPSULE

CHARPY V-NOTCH IMPACT DATA FOR THE PALISADES
INTERMEDIATE SHELL PLATE D-3803-1 (TRANSVERSE ORIENTATION)

| Sample No. | Temperature (°F) | Impact Energy (ft-lb) | Lateral Expansion (mils) | Shear (%) |
|------------|------------------|-----------------------|--------------------------|-----------|
| 22M | -75 | 5 | 6.5 | 5 |
| 22L | -25 | 13 | 18 | 10 |
| 22J | 25 | 28 | 20 | 26 |
| 22E | 50 | 47 | 42.5 | 47 |
| 21L | 60 | 48 | 47.5 | 45 |
| 22B | 77 | 79 | 58 | 50 |
| 22C | 100 | 71 | 60 | 56 |
| 21J | 150 | 82 | 64.5 | 78 |
| 21K | 200 | 112 | 78 | 100 |
| 22D | 250 | 92 | 74 | 100 |
| 22K | 300 | 117 | 80 | 100 |
| 21M | 400 | 110 | 78 | 100 |

TABLE 5-3

CAPSULE T-330, THERMAL CAPSULE

CHARPY V-NOTCH IMPACT DATA FOR THE PALISADES
INTERMEDIATE SHELL PLATE D-3803-1 (LONGITUDINAL ORIENTATION)

| Sample No. | Temperature (°F) | Impact Energy (ft-lb) | Lateral Expansion (mils) | Shear (%) |
|------------|------------------|-----------------------|--------------------------|-----------|
| 13M | -50 | 7 | 9 | 2 |
| 13P | 0 | 13 | 13.5 | 14 |
| 13C | 25 | 39 | 32.5 | 20 |
| 13B | 35 | 50 | 47.2 | 27 |
| 13E | 50 | 65 | 53 | 40 |
| 13J | 77 | 112 | 74.5 | 66 |
| 13K | 150 | 131 | 91.5 | 83 |
| 13Y | 200 | 156 | 87.0 | 100 |
| 13D | 300 | 158 | 77.5 | 100 |
| 13L | 350 | 158 | 85.5 | 100 |
| 13T | 400 | 215 | 67.5 | 100 |

*Specimen 13U was improperly centered on anvil.

TABLE 5-4

CAPSULE T-330, THERMAL CAPSULE

CHARPY V-NOTCH IMPACT DATA FOR THE PALISADES
PRESSURE VESSEL WELD METAL

| Sample No. | Temperature (°F) | Impact Energy (ft-lb) | Lateral Expansion (mils) | Shear (%) |
|------------|------------------|-----------------------|--------------------------|-----------|
| 33M | -100 | 12 | 17 | 18 |
| 33K | - 75 | 45 | 39 | 30 |
| 343 | - 60 | 22 | 26 | 29 |
| 341 | - 50 | 31 | 32 | 37 |
| 33L | - 50 | 23 | 26 | 42 |
| 33P | - 25 | 32 | 28.5 | 40 |
| 342 | 0 | 82 | 65.5 | 60 |
| 33Y | 25 | 93 | 75.5 | 84 |
| 344 | 77 | 79 | 88.5 | 94 |
| 33T | 150 | 120 | 94.5 | 100 |
| 33J | 300 | 122 | 74.5 | 100 |
| 33U | 350 | 155 | 79 | 100 |

TABLE 5-5

CAPSULE T-330, THERMAL CAPSULE

CHARPY V-NOTCH IMPACT DATA FOR THE PALISADES
PRESSURE VESSEL WELD HEAT-AFFECTED ZONE METAL

| Sample No. | Temperature (°F) | Impact Energy (ft-lb) | Lateral Expansion (mils) | Shear (%) |
|------------|------------------|-----------------------|--------------------------|-----------|
| 43D | -75 | 45 | 39 | 3 |
| 42D | -25 | 27 | 27.5 | 14 |
| 42E | -10 | 43 | 41.5 | 34 |
| 44D | 0 | 55 | 47.5 | 44 |
| 43E | 25 | 52 | 47 | 43 |
| 41E | 40 | 88 | 57 | 62 |
| 46E | 50 | 130 | 84 | 88 |
| 44E | 60 | 115 | 81 | 84 |
| 46D | 77 | 70 | 55 | 85 |
| 45E | 150 | 125 | 80.5 | 100 |
| 41D | 225 | 110 | 67 | 100 |
| 45D | 300 | 121 | 77 | 100 |

TABLE 5-6
 CAPSULE T-330, THERMAL CAPSULE
 INSTRUMENTED CHARPY IMPACT TEST RESULTS FOR
 PALISADES INTERMEDIATE SHELL
 PLATE D-3803-1 (TRANSVERSE ORIENTATION)

| Sample Number | Test Temp (F) | Charpy Energy (ft lbs) | Normalized Energies | | | Yield Load (kips) | Time to Yield (uSec) | Maximum Load (kips) | Time to Maximum (uSec) | Fracture Load (kips) | Arrest Load (kips) | Yield Stress (ksi) | Flow Stress (ksi) |
|---------------|---------------|------------------------|---------------------|--------------|-----------|-------------------|----------------------|---------------------|------------------------|----------------------|--------------------|--------------------|-------------------|
| | | | Charpy Ed/A | Maximum Em/A | Prop Ep/A | | | | | | | | |
| 22M | -75 | 5.0 | 40 | 17 | 23 | | 2.60 | 85 | 2.60 | | | | |
| 22L | -25 | 13.0 | 105 | 70 | 34 | 3.30 | 90 | 3.55 | 195 | 3.55 | .25 | 108 | 113 |
| 22J | 25 | 28.0 | 225 | 139 | 87 | 3.10 | 85 | 3.75 | 350 | 3.75 | .70 | 102 | 113 |
| 22E | 50 | 47.0 | 378 | 198 | 180 | 2.95 | 160 | 3.95 | 560 | 3.95 | 1.95 | 97 | 114 |
| 21L | 60 | 48.0 | 387 | 254 | 133 | 2.95 | 85 | 3.95 | 605 | 3.90 | 1.55 | 98 | 115 |
| 22B | 77 | 79.0 | 636 | 307 | 329 | 2.85 | 80 | 4.00 | 725 | 3.85 | 1.95 | 94 | 113 |
| 22C | 100 | 71.0 | 572 | 262 | 309 | 2.60 | 90 | 3.85 | 655 | 3.60 | 1.95 | 86 | 107 |
| 21J | 150 | 82.0 | 660 | 193 | 467 | 2.70 | 80 | 3.60 | 500 | 3.00 | 2.50 | 89 | 104 |
| 21K | 200 | 112.0 | 902 | 258 | 644 | 2.60 | 85 | 3.75 | 655 | | | 86 | 105 |
| 22D | 250 | 92.0 | 741 | 226 | 515 | 2.25 | 50 | 3.50 | 610 | | | 74 | 95 |
| 22K | 300 | 117.0 | 942 | 294 | 648 | 2.10 | 50 | 3.55 | 775 | | | 69 | 93 |
| 21H | 400 | 110.0 | 886 | 249 | 637 | 2.20 | 85 | 3.45 | 675 | | | 73 | 94 |

TABLE 5-7
 CAPSULE T-330, THERMAL CAPSULE
 INSTRUMENTED CHARPY IMPACT TEST RESULTS FOR
 PALISADES INTERMEDIATE SHELL
 PLATE D-3803-1 (LONGITUDINAL ORIENTATION)

| Sample Number | Test Temp (F) | Charpy Energy (ft lbs) | Normalized Energies | | | Yield Load (kips) | Time to Yield (uSec) | Maximum Load (kips) | Time to Maximum (uSec) | Fracture Load (kips) | Arrest Load (kips) | Yield Stress (ksi) | Flow Stress (ksi) |
|---------------|----------------|------------------------|---------------------|--------------|-----------|-------------------|----------------------|---------------------|------------------------|----------------------|--------------------|--------------------|-------------------|
| | | | Charpy Ed/A | Maximum Em/A | Prop Ep/A | | | | | | | | |
| 13M | -50 | 7.0 | 56 | 24 | 32 | | 3.35 | 85 | 3.35 | .10 | | | |
| 13P | 0 | 13.0 | 105 | 38 | 66 | 3.15 | 90 | 3.20 | 125 | 3.10 | .35 | 104 | 105 |
| 13C | 25 | 39.0 | 314 | 201 | 113 | 3.00 | 85 | 4.05 | 485 | 4.05 | .70 | 99 | 117 |
| 13B | 35 | 50.0 | 403 | 162 | 241 | 2.85 | 80 | 3.80 | 410 | 3.75 | 2.15 | 95 | 110 |
| 13E | 50 | 65.0 | 523 | 314 | 209 | 2.90 | 90 | 4.00 | 740 | 3.95 | .90 | 97 | 115 |
| 13J | 77 | 112.0 | 902 | 350 | 552 | 2.80 | 80 | 4.10 | 815 | 3.25 | 1.60 | 93 | 114 |
| 13K | 150 | 131.0 | 1055 | 332 | 723 | 2.45 | 70 | 3.90 | 815 | 2.30 | 1.70 | 81 | 105 |
| 13Y | 200 | 156.0 | 1256 | 323 | 933 | 2.55 | 90 | 3.75 | 825 | | | 85 | 104 |
| 13D | 300 | 158.0 | 1272 | 290 | 982 | 2.40 | 100 | 3.55 | 775 | | | 80 | 99 |
| 13L | 350 | 158.0 | 1272 | 294 | 978 | 2.10 | 45 | 3.45 | 805 | | | 68 | 91 |
| 13T | 400 | 215.0 | 1731 | 285 | 1446 | 2.10 | 60 | 3.50 | 770 | | | 69 | 92 |

TABLE 5-8
 CAPSULE T-330, THERMAL CAPSULE
 INSTRUMENTED CHARPY IMPACT TEST RESULTS FOR
 PALISADES WELD METAL

| Sample Number | Test Temp (F) | Charpy Energy (ft lbs) | Normalized Energies | | | Yield Load (kips) | Time to Yield (uSec) | Maximum Load (kips) | Time to Maximum (uSec) | Fracture Load (kips) | Arrest Load (kips) | Yield Stress (ksi) | Flow Stress (ksi) |
|---------------|----------------|------------------------|---------------------------------------|--------------|-----------|-------------------|----------------------|---------------------|------------------------|----------------------|--------------------|--------------------|-------------------|
| | | | Charpy Ed/A | Maximum Em/A | Prop Ep/A | | | | | | | | |
| | | | ----- (ft-lbs/in ²) ----- | | | | | | | | | | |
| 33M | -100 | 12.0 | 97 | 68 | 29 | 3.65 | 125 | 3.85 | 200 | 3.80 | .30 | 121 | 124 |
| 33K | -75 | 45.0 | 362 | 218 | 144 | 3.35 | 90 | 4.15 | 500 | 4.05 | .15 | 110 | 123 |
| 343 | -60 | 22.0 | 177 | 139 | 38 | 3.35 | 95 | 3.85 | 345 | 3.85 | .45 | 110 | 119 |
| 341 | -50 | 31.0 | 250 | 176 | 74 | 3.25 | 95 | 3.95 | 425 | 3.95 | .50 | 107 | 119 |
| 33L | -50 | 23.0 | 185 | 104 | 82 | 3.25 | 91 | 3.70 | 270 | 3.55 | .55 | 108 | 115 |
| 33P | -25 | 32.0 | 258 | 181 | 77 | 3.15 | 95 | 3.85 | 445 | 3.80 | .75 | 105 | 116 |
| 342 | 0 | 82.0 | 660 | 290 | 371 | 3.10 | 90 | 4.10 | 670 | 3.45 | 1.15 | 102 | 119 |
| 33Y | 25 | 93.0 | 749 | 274 | 474 | 2.95 | 95 | 3.90 | 665 | 3.40 | 2.2 | 98 | 114 |
| 344 | 77 | 79.0 | 636 | 335 | 301 | 2.70 | 85 | 3.80 | 825 | 2.95 | 2.2 | 90 | 108 |
| 33T | 150 | 120.0 | 966 | 300 | 666 | 2.50 | 75 | 3.65 | 770 | | | 83 | 102 |
| 33J | 300 | 122.0 | 982 | 283 | 699 | 2.20 | 75 | 3.40 | 780 | | | 73 | 93 |
| 33U | 350 | 155.0 | 1248 | 280 | 968 | 2.10 | 65 | 3.30 | 775 | | | 70 | 90 |

TABLE 5-9
 CAPSULE T-330, THERMAL CAPSULE
 INSTRUMENTED CHARPY IMPACT TEST RESULTS FOR
 PALISADES WELD HEAT AFFECTED ZONE METAL

| Sample Number | Test Temp (F) | Charpy Energy (ft lbs) | Normalized Energies | | | Yield Load (kips) | Time to Yield (uSec) | Maximum Load (kips) | Time to Maximum (uSec) | Fracture Load (kips) | Arrest Load (kips) | Yield Stress (ksi) | Flow Stress (ksi) |
|---------------|----------------|------------------------|---------------------|--------------|-----------|-------------------|----------------------|---------------------|------------------------|----------------------|--------------------|--------------------|-------------------|
| | | | Charpy Ed/A | Maximum Em/A | Prop Ep/A | | | | | | | | |
| 43D | -75 | 17.0 | 137 | 114 | 13 | 3.55 | 95 | 4.05 | 275 | 4.05 | | 117 | 125 |
| 42D | -25 | 27.0 | 217 | 174 | 44 | 3.40 | 105 | 4.05 | 410 | 4.05 | .35 | 112 | 123 |
| 42E | -10 | 43.0 | 346 | 222 | 125 | 3.30 | 90 | 4.15 | 505 | 4.15 | 1.15 | 110 | 124 |
| 44D | 0 | 55.0 | 443 | 179 | 264 | 3.50 | 105 | 4.15 | 415 | 4.15 | .25 | 116 | 127 |
| 43E | 25 | 52.0 | 419 | 211 | 207 | 3.20 | 90 | 3.90 | 500 | 3.80 | 1.35 | 106 | 118 |
| 41E | 40 | 88.0 | 709 | 347 | 362 | 3.15 | 90 | 4.30 | 770 | 3.75 | 1.75 | 105 | 124 |
| 46E | 50 | 130.0 | 1047 | 326 | 721 | 3.10 | 95 | 4.10 | 750 | 2.15 | 1.40 | 103 | 119 |
| 44E | 60 | 115.0 | 926 | 282 | 644 | 3.15 | 100 | 4.00 | 665 | 2.70 | 1.60 | 103 | 118 |
| 46D | 77 | 70.0 | 564 | 209 | 354 | 3.05 | 85 | 4.00 | 495 | 3.85 | 2.25 | 101 | 117 |
| 45E | 150 | 125.0 | 1007 | 313 | 693 | 2.80 | 85 | 3.75 | 770 | | | 92 | 108 |
| 41D | 225 | 110.0 | 886 | 246 | 640 | 2.45 | 65 | 3.80 | 610 | | | 80 | 103 |
| 45D | 300 | 121.0 | 974 | 312 | 662 | 2.25 | 75 | 3.55 | 820 | | | 74 | 96 |

TABLE 5-10

CAPSULE W-290, IRRADIATED CAPSULE

CHARPY V-NOTCH IMPACT DATA FOR THE PALISADES
INTERMEDIATE SHELL PLATE D-3803-1 (TRANSVERSE ORIENTATION)

| Sample No. | Temperature (°F) | Impact Energy (ft-lb) | Lateral Expansion (mils) | Shear (%) |
|------------|------------------|-----------------------|--------------------------|-----------|
| 25K | 79 | 17 | 16 | 15 |
| 25P | 150 | 23 | 25 | 27 |
| 24M | 175 | 30 | 26.5 | 34 |
| 25J | 200 | 33 | 30 | 41 |
| 25L | 225 | 67 | 62.5 | 76 |
| 24E | 225 | 72 | 61.5 | 79 |
| 25Y | 250 | 84 | 60.5 | 89 |
| 24J | 250 | 76 | 63.5 | 92 |
| 25M | 275 | 78 | 71 | 100 |
| 24K | 300 | 84 | 66.5 | 100 |
| 25T | 350 | 88 | 71 | 100 |
| 25U | 450 | 85 | 68.5 | 100 |

TABLE 5-11

CAPSULE W-290, IRRADIATED CAPSULE

CHARPY V-NOTCH IMPACT DATA FOR THE PALISADES
INTERMEDIATE SHELL PLATE D-3803-1 (LONGITUDINAL ORIENTATION)

| Sample No. | Temperature (°F) | Impact Energy (ft-lb) | Lateral Expansion (mils) | Shear (%) |
|------------|------------------|-----------------------|--------------------------|-----------|
| 164 | 79 | 11 | 12 | 5 |
| 16D | 150 | 20 | 21.5 | 23 |
| 1411 | 150 | 25 | 24.5 | 27 |
| 162 | 175 | 22 | 23 | 29 |
| 163 | 175 | 34 | 31 | 34 |
| 1AT | 200 | 47 | 36 | 39 |
| 1AP | 200 | 49 | 33 | 36 |
| 1AY | 225 | 71 | 59.5 | 67 |
| 165 | 250 | 110 | 75.5 | 89 |
| 166 | 300 | 116 | 80.5 | 100 |
| 161 | 350 | 109 | 84 | 100 |
| 16E | 450 | 112 | 78.5 | 100 |

TABLE 5-12

CAPSULE W-290, IRRADIATED CAPSULE

CHARPY V-NOTCH IMPACT DATA FOR THE PALISADES
PRESSURE VESSEL WELD METAL

| Sample No. | Temperature (°F) | Impact Energy (ft-lb) | Lateral Expansion (mils) | Shear (%) |
|------------|------------------|-----------------------|--------------------------|-----------|
| 34A | 79 | 8 | 8 | 5 |
| 34E | 125 | 10 | 10.5 | 15 |
| 34D | 150 | 18 | 14 | 25 |
| 37L | 175 | 18 | 16 | 24 |
| 37C | 200 | 28 | 22 | 33 |
| 37J | 225 | 45 | 35.5 | 71 |
| 34B | 250 | 36 | 38 | 67 |
| 37D | 275 | 64 | 49 | 89 |
| 37B | 300 | 61 | 49 | 95 |
| 37K | 350 | 72 | 52.5 | 100 |
| 37A | 450 | 67 | 67.5 | 100 |
| 34C | 500 | 52 | 51.5 | 100 |

TABLE 5-13

CAPSULE W-290, IRRADIATED CAPSULE

CHARPY V-NOTCH IMPACT DATA FOR THE PALISADES
PRESSURE VESSEL WELD HEAT-AFFECTED ZONE METAL

| Sample No. | Temperature (°F) | Impact Energy (ft-lb) | Lateral Expansion (mils) | Shear (%) |
|------------|------------------|-----------------------|--------------------------|-----------|
| 426 | 50 | 16 | 12.5 | 16 |
| 457 | 79 | 51 | 36.5 | 45 |
| 427 | 100 | 21 | 20.5 | 32 |
| 453 | 100 | 36 | 27.5 | 28 |
| 425 | 125 | 27 | 10.5 | 34 |
| 456 | 150 | 28 | 25.5 | 41 |
| 4AZ | 150 | 35 | 32.5 | 49 |
| 451 | 175 | 35 | 35 | 59 |
| 4AA | 200 | 62 | 47 | 74 |
| 455 | 250 | 79 | 53 | 91 |
| 454 | 350 | 73 | 60.5 | 100 |
| 452 | 400 | 71 | 60.5 | 100 |

TABLE 5-14
 CAPSULE W-290, IRRADIATED CAPSULE
 INSTRUMENTED CHARPY IMPACT TEST RESULTS FOR
 PALISADES INTERMEDIATE SHELL
 PLATE D-3803-1 (TRANSVERSE ORIENTATION)

| Sample Number | Test Temp (°F) | Charpy Energy (ft lbs) | Normalized Energies | | | Yield Load (kips) | Time to Yield (uSec) | Maximum Load (kips) | Time to Maximum (uSec) | Fracture Load (kips) | Arrest Load (kips) | Yield Stress (ksi) | Flow Stress (ksi) |
|---------------|----------------|------------------------|---------------------------------------|--------------|-----------|-------------------|----------------------|---------------------|------------------------|----------------------|--------------------|--------------------|-------------------|
| | | | Charpy Ed/A | Maximum Em/A | Prop Ep/A | | | | | | | | |
| | | | ----- (ft-lbs/in ²) ----- | | | | | | | | | | |
| 25K | 79 | 17.0 | 137 | 69 | 68 | 3.10 | 85 | 3.40 | 200 | 2.90 | | 102 | 107 |
| 25P | 150 | 23.0 | 185 | 117 | 68 | 3.25 | 95 | 3.80 | 295 | 3.80 | .55 | 107 | 117 |
| 24M | 175 | 30.0 | 242 | 134 | 107 | 3.15 | 90 | 3.90 | 335 | 3.85 | 1.00 | 104 | 117 |
| 25J | 200 | 33.0 | 266 | 144 | 121 | 3.05 | 90 | 3.85 | 360 | 3.85 | 1.60 | 101 | 114 |
| 25L | 225 | 67.0 | 540 | 219 | 320 | 3.15 | 90 | 4.20 | 495 | 3.90 | 3.10 | 104 | 121 |
| 24E | 225 | 72.0 | 580 | 220 | 360 | 3.15 | 85 | 4.15 | 500 | | | 104 | 120 |
| 25Y | 250 | 84.0 | 676 | 212 | 465 | 2.70 | 70 | 4.00 | 495 | | | 90 | 111 |
| 24J | 250 | 76.0 | 612 | 214 | 398 | 2.95 | 85 | 4.05 | 505 | | | 98 | 116 |
| 25M | 275 | 78.0 | 628 | 189 | 439 | 3.05 | 95 | 4.00 | 450 | | | 101 | 117 |
| 24K | 300 | 84.0 | 676 | 214 | 463 | 2.85 | 80 | 4.10 | 500 | | | 95 | 115 |
| 25T | 350 | 88.0 | 709 | 260 | 449 | 2.55 | 65 | 3.95 | 605 | | | 84 | 108 |
| 25U | 450 | 85.0 | 684 | 195 | 490 | 2.45 | 75 | 3.70 | 500 | | | 82 | 102 |

TABLE 5-15
 CAPSULE W-290, IRRADIATED CAPSULE
 INSTRUMENTED CHARPY IMPACT TEST RESULTS FOR
 PALISADES INTERMEDIATE SHELL
 PLATE D-3803-1 (LONGITUDINAL ORIENTATION)

| Sample Number | Test Temp (°F) | Charpy Energy (ft lbs) | Normalized Energies | | | Yield Load (kips) | Time to Yield (uSec) | Maximum Load (kips) | Time to Maximum (uSec) | Fracture Load (kips) | Arrest Load (kips) | Yield Stress (ksi) | Flow Stress (ksi) |
|-----------------|----------------|------------------------|---------------------------|--------------|-----------|-------------------|----------------------|---------------------|------------------------|----------------------|--------------------|--------------------|-------------------|
| | | | Charpy Ed/A | Maximum Em/A | Prop Ep/A | | | | | | | | |
| | | | (ft-lbs/in ²) | | | | | | | | | | |
| 164 | 79 | 11.0 | 89 | 60 | 28 | 3.30 | 95 | 3.60 | 175 | 3.55 | .15 | 110 | 114 |
| 16D | 150 | 20.0 | 161 | 101 | 60 | 3.25 | 90 | 3.85 | 260 | 3.85 | .65 | 107 | 117 |
| 1AU | 150 | 25.0 | 201 | 147 | 54 | 3.20 | 95 | 4.00 | 360 | 3.95 | .25 | 106 | 120 |
| 162 | 175 | 22.0 | 177 | 103 | 74 | 3.15 | 90 | 3.80 | 270 | 3.70 | .85 | 104 | 114 |
| 163 | 175 | 34.0 | 274 | 204 | 70 | 3.00 | 95 | 3.90 | 495 | 3.90 | .75 | 99 | 114 |
| 1A ² | 200 | 47.0 | 378 | 258 | 120 | 3.15 | 95 | 4.20 | 585 | 4.20 | 1.50 | 104 | 122 |
| 1AP | 200 | 49.0 | 395 | 277 | 118 | 2.95 | 85 | 4.10 | 640 | 4.05 | 1.35 | 98 | 117 |
| 1AY | 225 | 71.0 | 572 | 282 | 290 | 2.80 | 80 | 4.05 | 650 | 3.80 | 2.20 | 93 | 114 |
| 165 | 250 | 110.0 | 886 | 292 | 593 | 2.60 | 65 | 4.25 | 650 | 3.50 | 2.95 | 86 | 113 |
| 166 | 300 | 166.0 | 934 | 276 | 658 | 2.75 | 80 | 4.00 | 650 | | | 91 | 112 |
| 161 | 350 | 109.0 | 878 | 258 | 619 | 2.65 | 75 | 4.05 | 605 | | | 87 | 111 |
| 16E | 450 | 112.0 | 902 | 251 | 651 | 2.50 | 70 | 3.85 | 605 | | | 82 | 105 |

TABLE 5-16
 CAPSULE W-290, IRRADIATED CAPSULE
 INSTRUMENTED CHARPY IMPACT TEST RESULTS FOR
 PALISADES WELD METAL

| Sample Number | Test Temp (F) | Charpy Energy (ft lbs) | Normalized Energies | | | Yield Load (kips) | Time to Yield (uSec) | Maximum Load (kips) | Time to Maximum (uSec) | Fracture Load (kips) | Arrest Load (kips) | Yield Stress (ksi) | Flow Stress (ksi) |
|---------------|----------------|------------------------|---------------------------|--------------|-----------|-------------------|----------------------|---------------------|------------------------|----------------------|--------------------|--------------------|-------------------|
| | | | Charpy Ed/A | Maximum Em/A | Prop Ep/A | | | | | | | | |
| | | | (ft-lbs/in ²) | | | | | | | | | | |
| 34A | 79 | 8.0 | 64 | 42 | 22 | 3.50 | 90 | 3.75 | 125 | 3.75 | | 116 | 121 |
| 34E | 125 | 10.0 | 81 | 60 | 20 | 3.40 | 95 | 3.75 | 170 | 3.75 | | 113 | 119 |
| 34D | 150 | 18.0 | 145 | 109 | 36 | 3.55 | 95 | 4.20 | 260 | 4.20 | | 117 | 128 |
| 37L | 175 | 18.0 | 145 | 94 | 51 | 3.60 | 95 | 3.95 | 230 | 3.95 | .25 | 119 | 125 |
| 37C | 200 | 28.0 | 225 | 157 | 68 | 3.45 | 95 | 4.20 | 360 | 4.15 | .65 | 115 | 127 |
| 37J | 225 | 45.0 | 362 | 189 | 173 | 3.50 | 85 | 4.40 | 405 | 4.35 | 3.00 | 116 | 130 |
| 34B | 250 | 36.0 | 290 | 145 | 145 | 3.45 | 85 | 4.15 | 330 | 4.00 | 2.25 | 113 | 125 |
| 37D | 275 | 64.0 | 515 | 203 | 313 | 3.40 | 85 | 4.25 | 445 | | | 112 | 126 |
| 37B | 300 | 61.0 | 491 | 179 | 312 | 3.40 | 85 | 4.15 | 405 | | | 112 | 124 |
| 37K | 350 | 72.0 | 580 | 182 | 398 | 3.30 | 105 | 4.05 | 430 | | | 109 | 121 |
| 37A | 450 | 67.0 | 540 | 170 | 370 | 3.15 | 85 | 3.95 | 400 | | | 104 | 118 |
| 34C | 500 | 52.0 | 419 | 183 | 236 | 3.00 | 85 | 3.75 | 445 | | | 99 | 111 |

TABLE 5-17
 CAPSULE W-290, IRRADIATED CAPSULE
 INSTRUMENTED CHARPY IMPACT TEST RESULTS FOR
 PALISADES WELD HEAT AFFECTED ZONE METAL

| Sample Number | Test Temp (F) | Charpy Energy (ft lbs) | Normalized Energies | | | Yield Load (kips) | Time to Yield (uSec) | Maximum Load (kips) | Time to Maximum (uSec) | Fracture Load (kips) | Arrest Load (kips) | Yield Stress (ksi) | Flow Stress (ksi) |
|---------------|----------------|------------------------|---------------------------------------|--------------|-----------|-------------------|----------------------|---------------------|------------------------|----------------------|--------------------|--------------------|-------------------|
| | | | Charpy Ed/A | Maximum Em/A | Prop Ep/A | | | | | | | | |
| | | | ----- (ft-lbs/in ²) ----- | | | | | | | | | | |
| 426 | 50 | 16.0 | 129 | 104 | 25 | 3.25 | 85 | 3.95 | 260 | 3.95 | | 108 | 120 |
| 457 | 79 | 51.0 | 411 | 222 | 188 | 3.20 | 85 | 4.30 | 495 | 4.20 | .90 | 106 | 124 |
| 427 | 100 | 21.0 | 169 | 108 | 61 | 3.30 | 90 | 3.95 | 270 | 3.95 | .80 | 109 | 120 |
| 453 | 100 | 36.0 | 290 | 237 | 53 | 3.65 | 90 | 4.45 | 500 | 4.35 | | 120 | 134 |
| 425 | 125 | 27.0 | 217 | 134 | 84 | 3.10 | 90 | 3.85 | 335 | 3.80 | .85 | 103 | 115 |
| 456 | 150 | 28.0 | 225 | 138 | 88 | 3.25 | 95 | 4.00 | 335 | 4.00 | 1.35 | 108 | 120 |
| 4A2 | 150 | 35.0 | 282 | 136 | 146 | 3.30 | 95 | 3.95 | 330 | 3.85 | 1.30 | 110 | 121 |
| 451 | 175 | 35.0 | 282 | 133 | 149 | 3.15 | 95 | 3.90 | 335 | 3.85 | 1.65 | 104 | 116 |
| 4AA | 200 | 62.0 | 499 | 252 | 247 | 2.85 | 85 | 3.95 | 605 | 3.80 | 2.15 | 94 | 113 |
| 455 | 250 | 79.0 | 636 | 218 | 418 | 3.15 | 85 | 4.10 | 495 | 3.95 | 3.15 | 105 | 120 |
| 454 | 350 | 73.0 | 588 | 164 | 424 | 2.65 | 75 | 3.85 | 405 | | | 87 | 107 |
| 452 | 450 | 71.0 | 572 | 170 | 401 | 2.30 | 50 | 3.55 | 445 | | | 76 | 96 |

TABLE 5-18
EFFECT OF IRRADIATION AT 1.09×10^{19} ($E > 1$ MeV)
ON THE NOTCH TOUGHNESS PROPERTIES OF THE
PALISADES SURVEILLANCE VESSEL MATERIALS

| Material | Average 30 ft-lb Temp (°F) | | | Average 35 mil Lateral Expansion Temp (°F) | | | Average 50 ft-lb Temp (°F) | | | Average Energy Absorption at Full Shear (ft-lb) | | |
|-------------------------------------|-------------------------------|------------|------------|---|------------|------------|-------------------------------|------------|------------|--|------------|------------------|
| | Unirradiated | Irradiated | ΔT | Unirradiated | Irradiated | ΔT | Unirradiated | Irradiated | ΔT | Unirradiated | Irradiated | Δ (ft-lb) |
| Plate D-3803-1 (Transverse) | 25 | 180 | 155 | 25 | 195 | 170 | 55 | 215 | 160 | 102 | 84 | 18 |
| Plate D-3803-1 (Longitudinal) | 0 | 175 | 175 | 5 | 190 | 185 | 20 | 200 | 180 | 155 | 112 | 43 |
| Weld Metal | -85 | 205 | 290 | -75 | 240 | 315 | -50 | 250 | 300 | 118 | 64 | 54 |
| HAZ Metal | -90 | 145 | 235 | -55 | 150 | 215 | -65 | 180 | 245 | 116 | 72 | 44 |

TABLE 5-19
Thermal Capsule Tensile Properties for Palisades
Surveillance Material

| SAMPLE NUMBER | MATERIAL | TEST | .2% YIELD | ULTIMATE | FRACTURE | FRACTURE | FRACTURE | UNIFORM | TOTAL | REDUCTION |
|------------------|----------|------------------|-----------------|-----------------|-------------|---------------|-----------------|-----------------|-----------------|--------------|
| | | TEMPERATURE F | STRENGTH ksi | STRENGTH ksi | LOAD kip | STRESS ksi | STRENGTH ksi | ELONGATION % | ELONGATION % | in AREA % |
| 1DK | PLATE | 65 | 64.2 | 86.6 | 2.65 | 179.8 | 54.0 | 12.0 | 27.3 | 70 |
| 1DL | PLATE | 120 | 62.1 | 82.5 | 2.45 | 179.0 | 49.9 | 11.4 | 26.2 | 72 |
| 1DJ | PLATE | 550 | 57.0 | 83.5 | 2.80 | 156.4 | 57.0 | 9.9 | 21.3 | 54 |
| 3DK | WELD | -10 | 75.9 | 94.2 | 3.10 | 198.5 | 63.2 | 13.5 | 27.1 | 58 |
| 3DJ | WELD | 74 | 74.4 | 91.7 | 3.25 | 186.4 | 66.2 | 12.0 | 25.5 | 64 |
| 3DL | WELD | 550 | 63.2 | 85.1 | 3.25 | 159.6 | 66.2 | 10.0 | 19.2 | 59 |
| 4DK | HAZ | 25 | 66.7 | 88.6 | 2.85 | 180.0 | 58.1 | 9.9 | 22.7 | 68 |
| *4DJ | HAZ | 74 | 64.7 | 84.5 | | | | 9.9 | | |
| *4DL | HAZ | 550 | 57.4 | 81.5 | | | | 7.8 | | |

* These specimens fractured outside the gage length.

TABLE 5-20

Irradiated Capsule Tensile Properties for Palisades
Surveillance Material, Irradiated to 1.12×10^{19} n/cm²

| SAMPLE NUMBER | MATERIAL | TEST TEMPERATURE F | .2% YIELD STRENGTH ksi | ULTIMATE STRENGTH ksi | FRACTURE LOAD kip | FRACTURE STRESS ksi | FRACTURE STRENGTH ksi | UNIFORM ELONGATION % | TOTAL ELONGATION % | REDUCTION in AREA % |
|------------------|----------|--------------------------|------------------------------|-----------------------------|-------------------------|---------------------------|-----------------------------|----------------------------|--------------------------|---------------------------|
| 1EL | PLATE | 210 | 81.9 | 97.8 | 3.30 | 202.6 | 67.2 | 10.1 | 21.2 | 67 |
| 1EM | PLATE | 245 | 79.5 | 97.8 | 3.30 | 223.9 | 67.2 | 9.9 | 21.0 | 70 |
| 1EK | PLATE | 550 | 73.9 | 96.4 | 3.45 | 224.1 | 70.3 | 9.0 | 19.2 | 69 |
| 3J6 | WELD | 210 | 95.7 | 109.4 | 4.00 | 235.7 | 81.5 | 11.1 | 20.8 | 65 |
| 3J1 | WELD | 300 | 92.7 | 105.9 | 4.00 | 198.9 | 81.5 | 10.2 | 19.8 | 59 |
| 3J7 | WELD | 550 | 87.6 | 104.9 | 4.10 | 187.2 | 83.5 | 8.7 | 17.1 | 55 |
| 4EL | HAZ | 165 | 82.0 | 98.8 | 3.25 | 191.5 | 66.2 | 8.1 | 19.5 | 65 |
| 4EM | HAZ | 225 | 78.9 | 96.8 | 3.35 | 237.5 | 68.2 | 7.1 | 17.5 | 71 |
| 4EK | HAZ | 550 | 73.9 | 94.7 | 3.60 | 172.5 | 73.3 | 6.0 | 14.7 | 57 |




Figure 5-1. Thermal Capsule Charpy V-Notch Impact Properties^{*} for Palisades Intermediate Shell Plate D 3803-1 (Transverse Orientation)




Figure 5-2. Thermal Capsule Charpy V-Notch Impact Properties for Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation)




Figure 5-3. Thermal Capsule Charpy V-Notch Impact Properties⁷ for Palisades Weld Metal




Figure 5-4. Thermal Capsule Charpy V-Notch Impact Properties for Palisades Weld Heat Affected Zone Metal







Figure 5-5. Thermal Capsule (T-330) Charpy Impact Specimen Fracture Surfaces for Palisades Intermediate Shell Plate D-3803-1 (Transverse Orientation)




13M




13P



13C




13B




13E




13J




13K



13Y



13D




13L




13T


Figure 5-6. Thermal Capsule (T-330) Charpy Impact Specimen Fracture Surfaces for Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation)




33M




33K




343



341




33L



33P




342




33Y



344



33T



33J



33U

Figure 5-7. Thermal Capsule (T-330) Charpy Impact Specimen Fracture Surfaces for Palisades Weld Metal





Figure 5-8. Thermal Capsule (T-330) Charpy Impact Specimen Fracture Surfaces for Palisades Weld Heat Affected Zone Metal

Figure 5-9
Typical Curve for Instrumented Charpy Specimens

1
3
J




Figure 5-10. Irradiated Capsule Charpy V-Notch Impact Properties for Palisades Intermediate Shell Plate D-3803-1 (Transverse Orientation)




Figure 5-11. Irradiated Capsule Charpy V-Notch Impact Properties for Palisades Intermediate Shell Plate D-3303-1 (Longitudinal Orientation)




Figure 5-12. Irradiated Capsule Charpy V-Notch Impact Properties for Palisades Weld Metal




Figure 5-13. Irradiated Capsule V-Notch Impact Properties for Palisades Weld Heat Affected Zone Metal










Figure 5-14. Irradiated Capsule Charpy (W-290) Impact Specimen Fracture Surfaces for Palisades Intermediate Shell Plate D-3803-1 (Transverse Orientation)

IMAGE EVALUATION
TEST TARGET (MT-3)






Figure 5-15. Irradiated Capsule (W-290) Charpy Impact Specimen
Fracture Surfaces for Palisades Intermediate Shell Plate
D-3803-1 (Longitudinal Orientation)




Figure 5-16. Irradiated Capsule (W-290) Charpy Impact Specimen Fracture Surfaces for Palisades Weld Metal




Figure 5-17. Irradiated Capsule (W-290) Charpy Impact Specimen Fracture Surfaces for Palisades Weld Metal Heat Affected Zone Metal




Figure 5-18. Comparison of Actual versus Predicted 30 ft-lb Transition Temperature Increases for the Palisades Surveillance Weld Material, Based on the Prediction Methods of Regulatory Guide 1.99 Revision 1





Figure 5-19. Thermal Capsule Tensile Properties for Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation)





Figure 5-20. Thermal Capsule Tensile Properties for Palisades Weld Metal





Figure 5-21. Thermal Capsule Tensile Properties for Palisades Weld Heat Affected Zone Metal



TENSILE SPECIMEN 1DK
Tested at 65°F



TENSILE SPECIMEN 1DL
Tested at 120°F



TENSILE SPECIMEN 1DJ
Tested at 550°F



Figure 5-22. Fractured Thermal Capsule Tensile Specimens of
Palisades Intermediate Shell Plate D-3803-1
(Longitudinal Orientation)



TENSILE SPECIMEN 3DK
Tested at -10°F




TENSILE SPECIMEN 3DJ
Tested at 74°F




TENSILE SPECIMEN 3DL
Tested at 550°F



Figure 5-23. Fractured Thermal Capsule Tensile Specimens of Palisades Weld Metal



TENSILE SPECIMEN 4DK
Tested at 25°F



TENSILE SPECIMEN 4DJ
Tested at 74°F




TENSILE SPECIMEN 4DL
Tested at 550°F



Figure 5-24. Fractured Thermal Capsule Tensile Specimens of Palisades Weld Heat Affected Zone Metal

FIGURE 5-25
Typical Stress-Strain Curve for Tension Specimens







Figure 5-26. Irradiated Capsule Tensile Properties for Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation)





Figure 5-27. Irradiated Capsule Tensile Properties for Palisades Weld Metal






Figure 5-28. Irradiated Capsule Tensile Properties for Palisades Weld Heat Affected Zone Metal



TENSILE SPECIMEN 1EL
Tested at 210°F



TENSILE SPECIMEN 1EM
Tested at 245°F



TENSILE SPECIMEN 1EK
Tested at 550°F



Figure 5-29. Fractured Irradiated Capsule Tensile Specimens of Palisades Intermediate Shell Plate D-3803-1 (Longitudinal Orientation)



TENSILE SPECIMEN 3J6
Tested at 210°F



TENSILE SPECIMEN 3J1
Tested at 300°F



TENSILE SPECIMEN 3J7
Tested at 550°F




Figure 5-30. Fractured Irradiated Capsule Tensile Specimens
of Palisades Weld Metal



TENSILE SPECIMEN 4EL
Tested at 165°F



TENSILE SPECIMEN 4EM
Tested at 225°F



TENSILE SPECIMEN 4EK
Tested at 550°F



Figure 5-31. Fractured Irradiated Capsule Tensile Specimens
of Palisades Weld Heat Affected Zone Metal

SECTION 6

RADIATION ANALYSIS AND NEUTRON DOSIMETRY

6-1. INTRODUCTION

Knowledge of the neutron environment within the pressure vessel/surveillance capsule geometry is required as an integral part of LWR pressure vessel surveillance programs for two reasons. First, in the interpretation of radiation-induced properties changes observed in materials test specimens the neutron environment (fluence, flux) to which the test specimens were exposed must be known. Second in relating the changes observed in the test specimens to the present and future condition of the reactor pressure vessel, a relationship must be established between the environment at various positions within the reactor vessel and that experienced by the test specimens. The former requirement is normally met by employing a combination of rigorous analytical techniques and measurements obtained with passive neutron flux monitors contained in the surveillance capsule. The latter information is derived solely from bench-marked analyses.

This section describes a discrete ordinates S_n transport analysis performed for the Palisades reactor to determine the fast neutron ($E > 1.0$ MeV) flux and fluence as well as the neutron energy spectra within the reactor vessel and surveillance capsule. The analytical data were then used to develop a lead factor for use in relating neutron exposure of the pressure vessel to that of the surveillance capsule. Based on spectrum-averaged reaction cross sections derived from this calculation, the analysis of the neutron dosimetry contained in Capsule W-290 is discussed and comparisons with analytical predictions are presented.

6.2. DISCRETE ORDINATES ANALYSIS

A plan view of Palisades reactor geometry at core midplane is shown in Figure 6-1. Since the reactor exhibits 1/8 th core symmetry, only a zero to 45 degree sector is depicted. Six wall capsules attached to the reactor vessel are included in the design to constitute the reactor vessel surveillance




Figure 6-1. Palisades Reactor Geometry




Figure 6-2A. Plan View of Pallsades Wall Capsules




Figure 6-2B. Plan View of a Reactor Vessel Surveillance Capsule

TABLE 6-1
26 GROUP ENERGY STRUCTURE

| <u>Group</u> | <u>Lower Energy (MeV)</u> | <u>Group</u> | <u>Lower Energy (MeV)</u> |
|--------------|-------------------------------|--------------|-------------------------------|
| 1 | 14.19 ^(a) | 25 | 0.183 |
| 2 | 12.21 | 26 | 0.111 |
| 3 | 10.00 | | |
| 4 | 8.61 | | |
| 5 | 7.41 | | |
| 6 | 6.07 | | |
| 7 | 4.97 | | |
| 8 | 3.68 | | |
| 9 | 3.01 | | |
| 10 | 2.73 | | |
| 11 | 2.47 | | |
| 12 | 2.37 | | |
| 13 | 2.35 | | |
| 14 | 2.23 | | |
| 15 | 1.92 | | |
| 16 | 1.65 | | |
| 17 | 1.35 | | |
| 18 | 1.00 | | |
| 19 | 0.821 | | |
| 20 | 0.743 | | |
| 21 | 0.608 | | |
| 22 | 0.498 | | |
| 23 | 0.369 | | |
| 24 | 0.298 | | |

a. The upper energy of group 1 is 17.33 MeV.

program. A plan view of the surveillance capsules attached to the reactor vessel is shown in Figure 6-2A. As seen in Figure 6-2B, the stainless steel capsule holder is basically a 1.503-inch by 2.178-inch rectangular tube with a 0.12 inch wall. The monitors are embedded in carbon steel.

From a neutronic standpoint, the surveillance capsule structures are significant. In fact, as is shown later, they have a marked effect on the distributions of neutron flux and energy spectra in the water annulus between the core barrel and the reactor vessel. Thus, in order to properly ascertain the neutron environment at the test specimen locations, the capsules themselves must be included in the analytical model. Use of at least a two-dimensional computation is therefore mandatory.

In the analysis of the neutron environment within the Palisades reactor geometry, predictions of neutron flux magnitude and energy spectra were made with the DOT^[4] two-dimensional discrete ordinates code. The radial and azimuthal distributions were obtained from an R, θ computation wherein the geometry shown in Figure 6-1 was described in the analytical model.

The R, θ analyses employed 26 neutron energy groups and a P₃ expansion of the scattering cross sections. The cross sections used in the analyses were obtained from the SAILOR cross section library^[5] which was developed specifically for light water reactor applications. The neutron energy group structure used in the analysis is listed in Table 6-1.

A key input parameter in the analysis of the integrated fast neutron exposure of the reactor vessel is the core power distribution. For this analysis, Palisades Cycle 5 power distributions were employed. These input distributions include rod-by-rod spatial variations for all peripheral fuel assemblies.

Having the results of the R, θ calculation and an axial peaking factor, three-dimensional variations of neutron flux may be approximated by assuming that the following relation holds for the applicable regions of the reactor.

$$\phi(R,Z,\theta,E_g) = \phi(R,\theta,E_g) \times 1.2 \quad (6-1)$$

where

$\phi(R,Z,\theta,E_g)$ = neutron flux at point R,Z, θ within energy group g

$\phi(R,\theta,E_g)$ = neutron flux at point R, θ within energy group g
obtained from the R, θ calculation

1.2 = axial peaking factor for the midplane of the core

6-3. NEUTRON DOSIMETRY

The passive neutron flux monitors included in Capsule W-290 of Palisades are listed in Table 6-2. The first five reactions in Table 6-2 are used as fast neutron monitors to relate neutron fluence ($E > 1.0$ MeV) to measured material property changes.

TABLE 6-2
NUCLEAR CONSTANTS FOR NEUTRON FLUX MONITORS CONTAINED IN
THE PALISADES SURVEILLANCE CAPSULE

| <u>Monitor Material</u> | <u>Reaction of Interest</u> | <u>Target Weight Fraction</u> | <u>Product Half-life</u> | <u>Fission Yield (%)</u> |
|----------------------------|---|-------------------------------|--------------------------|--------------------------|
| Copper ^(a) | $\text{Cu}^{63} (n, \alpha) \text{Co}^{60}$ | 0.6917 | 5.27 years | |
| Iron | $\text{Fe}^{54} (n, p) \text{Mn}^{54}$ | 0.0585 | 314 days | |
| Nickel ^(a) | $\text{Ni}^{58} (n, p) \text{Co}^{58}$ | 0.6777 | 71.4 days | |
| Uranium-238 ^(a) | $\text{U}^{238} (n, f) \text{Cs}^{137}$ | 1.0 | 30.2 years | 6.3 |
| Titanium | $\text{Ti}^{46} (n, p) \text{Sc}^{46}$ | 0.0825 | 83.8 days | |
| Uranium | $\text{U}^{238} (n, f) \text{Cs}^{137}$ | 1.0 | 30.2 years | 6.3 |

a. Denotes that monitor is cadmium-shielded

The relative locations of the various monitors within the surveillance capsule are shown in Figure 6-2.

The use of passive monitors such as those listed in Table 6-2 does not yield a direct measure of the energy-dependent flux level at the point of interest. Rather, the activation or fission process is a measure of the integrated effect that the time- and energy-dependent neutron flux has on the target material over the course of the irradiation period. An accurate assessment of the average neutron flux level incident on the various monitors may be derived from the activation measurements only if the irradiation parameters are well known. In particular, the following variables are of interest.

- o The operating history of the reactor
- o The energy response of the monitor
- o The neutron energy spectrum at the monitor location
- o The physical characteristics of the monitor

The analysis of the passive monitors and subsequent derivation of the average neutron flux requires completion of two operations. First, the disintegration rate of product isotope per unit mass of monitor must be determined. Second, in order to define a suitable spectrum-averaged reaction cross section, the neutron energy spectrum at the monitor location must be calculated.

The specific activity of each of the monitors is determined using established ASTM procedures. [7,8,9,10,11] Following sample preparation, the activity of each monitor is determined by means of a lithium-drifted germanium, Ge(Li), gamma spectrometer. The overall standard deviation of the measured data is a function of the precision of sample weighing, the uncertainty in counting, and the acceptable error in detector calibration. For the samples removed from Palisades, the overall 2σ deviation in the measured data is determined to be plus or minus 10 percent. The neutron energy spectra are determined analytically using the method described in paragraph 6-1.

Having the measured activity of the monitors and the neutron energy spectra at the locations of interest, the calculation of the neutron flux proceeds as follows. The reaction product activity in the monitor is expressed as

$$R = \frac{N_0}{A} f_1 Y \int_E \sigma(E) \phi(E) dE \sum_{j=1}^n \frac{P_j}{P_{\max}} (1 - e^{-\lambda_j t}) e^{-\lambda_d t} \quad (6-2)$$

where

- R = induced product activity
- N_0 = Avogadro's number
- A = atomic weight of the target isotope
- f_1 = weight fraction of the target isotope in the target material
- Y = number of product atoms produced per reaction
- $\sigma(E)$ = energy dependent reaction cross section
- $\phi(E)$ = energy dependent neutron flux at the monitor location with the reactor at full power
- P_j = average core power level during irradiation period j
- P_{max} = maximum or reference core power level
- λ = decay constant of the product isotope
- t_j = length of irradiation period j
- t_d = decay time following irradiation period j

Because neutron flux distributions are calculated using multigroup transport methods and, further, because the prime interest is in the fast neutron flux above 1.0 MeV, spectrum-averaged reaction cross sections are defined such that the integral term in equation (6-2) is replaced by the following relation.

$$\int_E \sigma(E)\phi(E)dE = \bar{\sigma} \phi (E > 1.0 \text{ MeV})$$

where

$$\bar{\sigma} = \frac{\int_0^{\infty} \sigma(E)\phi(E)dE}{\int_{1.0 \text{ MeV}}^{\infty} \phi(E)dE} = \frac{\sum_{g=1}^N \sigma_g \phi_g}{\sum_{g=g_{1.0 \text{ MeV}}}^N \phi_g}$$

Thus, equation (6-2) is rewritten

$$R = \frac{N_0}{A} f_1 Y \bar{\sigma} \phi (E > 1.0 \text{ MeV}) \sum_{j=1}^N \frac{P_j}{P_{max}} (1 - e^{-\lambda t_j}) e^{-\lambda t_d}$$

or, solving for the neutron flux,

$$\phi(E > 1.0 \text{ MeV}) = \frac{R}{\frac{N_0}{A} f_1 \gamma \bar{\sigma} \sum_{j=1}^n \frac{P_j}{P_{\max}} (1 - e^{-\lambda t_j}) e^{-\lambda t_d}} \quad (6-3)$$

The total fluence above 1.0 MeV is then given by

$$\Phi(E > 1.0 \text{ MeV}) = \phi(E > 1.0 \text{ MeV}) \sum_{j=1}^n \frac{P_j}{P_{\max}} t_j \quad (6-4)$$

where

$$\sum_{j=1}^n \frac{P_j}{P_{\max}} t_j = \begin{array}{l} \text{total effective full power seconds of reactor} \\ \text{operation up to the time of capsule removal} \end{array}$$

6-4. TRANSPORT ANALYSIS RESULTS

Results of the S_n transport calculations for the Palisades reactor are summarized in Figures 6-3 through 6-10 and in Tables 6-3 and 6-4. In Figure 6-3, the calculated maximum neutron flux levels at the surveillance capsule centerline, pressure vessel inner radius, 1/4 thickness location, and 3/4 thickness location are presented as a function of azimuthal angle. The influence of the surveillance capsules on the fast neutron flux distribution is clearly evident. In Figure 6-4, the radial distribution of maximum fast neutron flux ($E > 1.0 \text{ MeV}$) through the thickness of the reactor pressure vessel is shown.

Figure 6-5, presents the radial variations of fast neutron flux within surveillance capsule W-290. This data, in conjunction with the maximum vessel flux, are used to develop a lead factor for capsule W-290. Here the lead factor is defined as the ratio of the fast neutron flux ($E > 1.0$ MeV) at the capsule center to the maximum fast neutron flux at the pressure vessel inner radius. The lead factor for Capsule W-290 is 1.28.

Figures 6-6 through 6-10 present the calculated variation of fast neutron flux monitor saturated activity within capsule W-290.

TABLE 6-3
 CALCULATED NEUTRON ENERGY SPECTRA ABOVE 0.1 MeV AT
 THE CENTER OF PALISADES CAPSULE

| Group No. | ϕ (n/cm ² -sec) | GROUP No. | ϕ (n/cm ² -sec) |
|-----------|---------------------------------|-----------|---------------------------------|
| 1 | 3.71×10^7 | 14 | 3.11×10^9 |
| 2 | 1.35×10^8 | 15 | 7.70×10^9 |
| 3 | 4.55×10^8 | 16 | 8.24×10^9 |
| 4 | 8.26×10^8 | 17 | 1.13×10^{10} |
| 5 | 1.38×10^9 | 18 | 1.67×10^{10} |
| 6 | 3.24×10^9 | 19 | 1.04×10^{10} |
| 7 | 4.47×10^9 | 20 | 5.21×10^9 |
| 8 | 7.83×10^9 | 21 | 1.48×10^{10} |
| 9 | 5.67×10^9 | 22 | 1.04×10^{10} |
| 10 | 4.26×10^9 | 23 | 1.31×10^{10} |
| 11 | 4.79×10^9 | 24 | 1.16×10^{10} |
| 12 | 2.38×10^9 | 25 | 1.45×10^{10} |
| 13 | 6.40×10^8 | 26 | 1.41×10^{10} |

TABLE 6-4
SPECTRUM-AVERAGED REACTION CROSS SECTIONS AT THE
CENTER OF PALISADES SURVEILLANCE CAPSULES

| Reaction | a $\bar{\sigma}$ (barns) |
|--|-----------------------------|
| Fe ⁵⁴ (n,p) Mn ⁵⁴ | 0.12700 |
| Cu ⁶³ (n, α) Co ⁶⁰ | 0.00129 |
| Ni ⁵⁸ (n,p) Co ⁵⁸ | 0.16130 |
| Ti ⁴⁶ (n,p) Sc ⁴⁶ | 0.02300 |
| U ²³⁸ (n,f) Cs ¹³⁷ | 0.43700 |

a.
$$\bar{\sigma} = \frac{\int_0^{\infty} \sigma(E)\phi(E)dE}{\int_{1 \text{ MeV}}^{\infty} \phi(E)dE}$$

TABLE 6-5
IRRADIATION HISTORY OF PALISADES
SURVEILLANCE CAPSULE W-290

| Month | Year | P_j (MW) | P_{max} (MW) | P_j/P_{max} | Irradiation Time (Days) | Decay time ^(a) (Days) |
|-------|------|---------------|-------------------|---------------|----------------------------|-------------------------------------|
| 12 | 1971 | 26 | 2530 | .010 | 1 | 4561 |
| 1 | 1972 | 209 | 2530 | .083 | 31 | 4530 |
| 2 | 1972 | 24 | 2530 | .009 | 29 | 4501 |
| 3 | 1972 | 332 | 2530 | .131 | 31 | 4470 |
| 4 | 1972 | 722 | 2530 | .285 | 30 | 4440 |
| 5 | 1972 | 0 | 2530 | .000 | 31 | 4409 |
| 6 | 1972 | 951 | 2530 | .376 | 30 | 4379 |
| 7 | 1972 | 900 | 2530 | .356 | 31 | 4348 |
| 8 | 1972 | 1065 | 2530 | .421 | 31 | 4317 |
| 9 | 1972 | 681 | 2530 | .269 | 30 | 4287 |
| 10 | 1972 | 983 | 2530 | .388 | 31 | 4256 |
| 11 | 1972 | 767 | 2530 | .303 | 30 | 4226 |
| 12 | 1972 | 1440 | 2530 | .569 | 31 | 4195 |
| 1 | 1973 | 897 | 2530 | .355 | 31 | 4164 |
| 2 | 1973 | 0 | 2530 | .000 | 28 | 4136 |
| 3 | 1973 | 1424 | 2530 | .563 | 31 | 4105 |
| 4 | 1973 | 2152 | 2530 | .851 | 30 | 4075 |
| 5 | 1973 | 1321 | 2530 | .522 | 31 | 4044 |
| 6 | 1973 | 2192 | 2530 | .866 | 30 | 4014 |
| 7 | 1973 | 2062 | 2530 | .815 | 31 | 3983 |
| 8 | 1973 | 640 | 2530 | .253 | 31 | 3952 |
| 9 | 1973 | 0 | 2530 | .000 | 30 | 3922 |
| 10 | 1973 | 0 | 2530 | .000 | 31 | 3891 |
| 11 | 1973 | 0 | 2530 | .000 | 30 | 3861 |
| 12 | 1973 | 0 | 2530 | .000 | 31 | 3830 |

a. Decay time is referenced to 6/27/84.

TABLE 6-5 (Cont)
IRRADIATION HISTORY OF PALISADES
SURVEILLANCE CAPSULE W-290

| Month: | Year | P_j (MW) | P_{max} (MW) | P_j/P_{max} | Irradiation Time (Days) | Decay Time ^(a) (Days) |
|--------|------|---------------|-------------------|---------------|----------------------------|-------------------------------------|
| 1 | 1974 | 0 | 2530 | .000 | 31 | 3799 |
| 2 | 1974 | 0 | 2530 | .000 | 28 | 3771 |
| 3 | 1974 | 0 | 2530 | .000 | 31 | 3740 |
| 4 | 1974 | 0 | 2530 | .000 | 30 | 3710 |
| 5 | 1974 | 0 | 2530 | .000 | 31 | 3679 |
| 6 | 1974 | 0 | 2530 | .000 | 30 | 3649 |
| 7 | 1974 | 0 | 2530 | .000 | 31 | 3618 |
| 8 | 1974 | 0 | 2530 | .000 | 31 | 3587 |
| 9 | 1974 | 0 | 2530 | .000 | 30 | 3557 |
| 10 | 1974 | 384 | 2530 | .152 | 31 | 3526 |
| 11 | 1974 | 8 | 2530 | .003 | 30 | 3496 |
| 12 | 1974 | 0 | 2530 | .000 | 31 | 3465 |
| 1 | 1975 | 0 | 2530 | .000 | 31 | 3434 |
| 2 | 1975 | 0 | 2530 | .000 | 28 | 3406 |
| 3 | 1975 | 0 | 2530 | .000 | 31 | 3375 |
| 4 | 1975 | 1263 | 2530 | .499 | 30 | 3345 |
| 5 | 1975 | 1699 | 2530 | .672 | 31 | 3314 |
| 6 | 1975 | 1115 | 2530 | .441 | 30 | 3284 |
| 7 | 1975 | 1338 | 2530 | .529 | 31 | 3253 |
| 8 | 1975 | 874 | 2530 | .346 | 31 | 3222 |
| 9 | 1975 | 1277 | 2530 | .505 | 30 | 3192 |
| 10 | 1975 | 1450 | 2530 | .573 | 31 | 3161 |
| 11 | 1975 | 1597 | 2530 | .631 | 30 | 3131 |
| 12 | 1975 | 598 | 2530 | .236 | 31 | 3100 |
| 1 | 1976 | 0 | 2530 | .000 | 31 | 3069 |
| 2 | 1976 | 0 | 2530 | .000 | 29 | 3040 |
| 3 | 1976 | 0 | 2530 | .000 | 31 | 3009 |

a. Decay time is referenced to 6/27/84.

TABLE 6-5 (Cont)
IRRADIATION HISTORY OF PALISADES
SURVEILLANCE CAPSULE W-290

| Month | Year | P_j (MW) | P_{max} (MW) | P_j/P_{max} | Irradiation Time (Days) | Decay Time ^(a) (Days) |
|-------|------|---------------|-------------------|---------------|----------------------------|-------------------------------------|
| 4 | 1976 | 0 | 2530 | .000 | 30 | 2979 |
| 5 | 1976 | 707 | 2530 | .279 | 31 | 2948 |
| 6 | 1976 | 2086 | 2530 | .825 | 30 | 2918 |
| 7 | 1976 | 11 | 2530 | .005 | 31 | 2887 |
| 8 | 1976 | 1636 | 2530 | .647 | 31 | 2856 |
| 9 | 1976 | 1961 | 2530 | .775 | 30 | 2826 |
| 10 | 1976 | 1605 | 2530 | .634 | 31 | 2795 |
| 11 | 1976 | 1507 | 2530 | .595 | 30 | 2765 |
| 12 | 1976 | 2063 | 2530 | .816 | 31 | 2734 |
| 1 | 1977 | 1870 | 2530 | .739 | 31 | 2703 |
| 2 | 1977 | 2133 | 2530 | .843 | 28 | 2675 |
| 3 | 1977 | 1983 | 2530 | .784 | 31 | 2644 |
| 4 | 1977 | 2008 | 1530 | .794 | 30 | 2614 |
| 5 | 1977 | 1360 | 2530 | .538 | 31 | 2583 |
| 6 | 1977 | 2173 | 2530 | .859 | 30 | 2553 |
| 7 | 1977 | 1975 | 2530 | .780 | 31 | 2522 |
| 8 | 1977 | 1438 | 2530 | .567 | 31 | 2491 |
| 9 | 1977 | 1880 | 2530 | .743 | 30 | 2461 |
| 10 | 1977 | 2153 | 2530 | .851 | 31 | 2430 |
| 11 | 1977 | 1954 | 2530 | .772 | 30 | 2400 |
| 12 | 1977 | 2176 | 2530 | .860 | 31 | 2369 |
| 1 | 1978 | 343 | 2530 | .135 | 31 | 2338 |
| 2 | 1978 | 0 | 2530 | .000 | 28 | 2310 |
| 3 | 1978 | 0 | 2530 | .000 | 31 | 2279 |
| 4 | 1978 | 482 | 2530 | .191 | 30 | 2249 |
| 5 | 1978 | 1206 | 2530 | .477 | 31 | 2218 |
| 6 | 1978 | 1574 | 2530 | .622 | 30 | 2188 |

a. Decay time is referenced to 6/27/84.

TABLE 6-5 (Cont)
IRRADIATION HISTORY OF PALISADES
SURVEILLANCE CAPSULE W-290

| Month | Year | P_j (MW) | P_{max} (MW) | P_j/P_{max} | Irradiation Time (Days) | Decay Time ^(a) (Days) |
|-------|------|---------------|-------------------|---------------|----------------------------|-------------------------------------|
| 7 | 1978 | 1603 | 2530 | .633 | 31 | 2157 |
| 8 | 1978 | 1254 | 2530 | .496 | 31 | 2126 |
| 9 | 1978 | 680 | 2530 | .269 | 30 | 2096 |
| 10 | 1978 | 1454 | 2530 | .575 | 31 | 2065 |
| 11 | 1978 | 2249 | 2530 | .889 | 30 | 2035 |
| 12 | 1978 | 1092 | 2530 | .432 | 31 | 2004 |
| 1 | 1979 | 2275 | 2530 | .899 | 31 | 1973 |
| 2 | 1979 | 2229 | 2530 | .881 | 28 | 1945 |
| 3 | 1979 | 2277 | 2530 | .900 | 31 | 1914 |
| 4 | 1979 | 1835 | 2530 | .725 | 30 | 1884 |
| 5 | 1979 | 764 | 2530 | .302 | 31 | 1853 |
| 6 | 1979 | 1695 | 2530 | .670 | 30 | 1823 |
| 7 | 1979 | 2163 | 2530 | .855 | 31 | 1792 |
| 8 | 1979 | 1979 | 2530 | .782 | 31 | 1761 |
| 9 | 1979 | 410 | 2530 | .162 | 30 | 1731 |
| 10 | 1979 | 0 | 2530 | .000 | 31 | 1700 |
| 11 | 1979 | 0 | 2530 | .000 | 30 | 1670 |
| 12 | 1979 | 0 | 2530 | .000 | 31 | 1639 |
| 1 | 1980 | 0 | 2530 | .000 | 31 | 1608 |
| 2 | 1980 | 0 | 2530 | .000 | 29 | 1579 |
| 3 | 1980 | 0 | 2530 | .000 | 31 | 1548 |
| 4 | 1980 | 0 | 2530 | .084 | 30 | 1518 |
| 5 | 1980 | 213 | 2530 | .084 | 31 | 1487 |
| 6 | 1980 | 2164 | 2530 | .855 | 30 | 1457 |
| 7 | 1980 | 1516 | 2530 | .599 | 31 | 1426 |
| 8 | 1980 | 1706 | 2530 | .674 | 31 | 1395 |
| 9 | 1980 | 1763 | 2530 | .697 | 30 | 1365 |

a. Decay time is referenced to 6/27/84.

TABLE 6-5 (Cont)
IRRADIATION HISTORY OF PALISADES
SURVEILLANCE CAPSULE W-290

| Month | Year | P_j (MW) | P_{max} (MW) | P_j/P_{max} | Irradiation Time (Days) | Decay Time ^(a) (Days) |
|-------|------|---------------|-------------------|---------------|----------------------------|-------------------------------------|
| 10 | 1980 | 2201 | 2530 | .870 | 31 | 1334 |
| 11 | 1980 | 0 | 2530 | .000 | 30 | 1304 |
| 12 | 1980 | 1194 | 2530 | .472 | 31 | 1273 |
| 1 | 1981 | 2336 | 2530 | .923 | 31 | 1242 |
| 2 | 1981 | 2426 | 2530 | .959 | 28 | 1214 |
| 3 | 1981 | 2449 | 2530 | .968 | 31 | 1183 |
| 4 | 1981 | 2390 | 2530 | .945 | 30 | 1152 |
| 5 | 1981 | 2200 | 2530 | .870 | 31 | 1122 |
| 6 | 1981 | 2089 | 2530 | .826 | 30 | 1092 |
| 7 | 1981 | 799 | 2530 | .316 | 31 | 1061 |
| 8 | 1981 | 1084 | 2530 | .428 | 31 | 1030 |
| 9 | 1981 | 0 | 2530 | .000 | 30 | 1000 |
| 10 | 1981 | 0 | 2530 | .000 | 31 | 969 |
| 11 | 1981 | 0 | 2530 | .000 | 30 | 939 |
| 12 | 1981 | 0 | 2530 | .000 | 31 | 908 |
| 1 | 1982 | 1217 | 2530 | .481 | 31 | 877 |
| 2 | 1982 | 246 | 2530 | .097 | 28 | 849 |
| 3 | 1982 | 907 | 2530 | .359 | 31 | 818 |
| 4 | 1982 | 0 | 2530 | .000 | 30 | 788 |
| 5 | 1982 | 481 | 2530 | .190 | 31 | 757 |
| 6 | 1982 | 2203 | 2530 | .871 | 30 | 727 |
| 7 | 1982 | 753 | 2530 | .298 | 31 | 696 |
| 8 | 1982 | 0 | 2530 | .000 | 31 | 665 |
| 9 | 1982 | 2129 | 2530 | .841 | 30 | 635 |
| 10 | 1982 | 2222 | 2530 | .878 | 31 | 604 |
| 11 | 1982 | 2484 | 2530 | .982 | 30 | 574 |
| 12 | 1982 | 2471 | 2530 | .977 | 31 | 543 |

a. Decay time is referenced to 6/27/84.

TABLE 6-5 (Cont)
IRRADIATION HISTORY OF PALISADES
SURVEILLANCE CAPSULE W-290

| Month | Year | P_j (MW) | P_{max} (MW) | P_j/P_{max} | Irradiation Time (Days) | Decay Time ^(a) (Days) |
|-------|------|---------------|-------------------|---------------|----------------------------|-------------------------------------|
| 1 | 1983 | 2324 | 2530 | .918 | 31 | 512 |
| 2 | 1983 | 2468 | 2530 | .975 | 28 | 484 |
| 3 | 1983 | 2470 | 2530 | .976 | 31 | 453 |
| 4 | 1983 | 2345 | 2530 | .927 | 30 | 423 |
| 5 | 1983 | 2222 | 2530 | .878 | 31 | 392 |
| 6 | 1983 | 2367 | 2530 | .936 | 30 | 362 |
| 7 | 1983 | 2222 | 2530 | .878 | 31 | 331 |
| 8 | 1983 | 684 | 2530 | .270 | 31 | 300 |
| 9 | 1983 | 0 | 2530 | .000 | 16 | 284 |

$$EFPS = 1.57 \times 10^8 \text{ sec}$$

$$EFPY = 4.975$$

a. Decay time is referenced to 6/27/84.

In order to derive neutron flux and fluence levels from the measured disintegration rates, suitable spectrum-averaged reaction cross sections are required. The neutron energy spectrum calculated to exist at the center of Palisades capsule is listed in Table 6-3. The associated spectrum-averaged cross sections for each of the fast neutron reactions are given in Table 6-4.

6-5. DOSIMETRY RESULTS

The irradiation history of the Palisades reactor up to the time of removal of Capsule W-290 is listed in Table 6-5. Comparisons of measured and calculated saturated activity of the flux monitors contained in Capsule W-290 based on the irradiation history shown in Table 6-5 are given in Table 6-6. The fast neutron ($E > 1.0$ MeV) flux and fluence levels derived for Capsule W-290 are presented in Table 6-7.

An examination of Table 6-7 shows that the fast neutron flux ($E > 1.0$ MeV) derived from the five threshold reactions ranges from 6.48×10^{10} to 7.84×10^{10} n/cm²-sec, a total span of 30 percent. It may also be noted that the calculated flux value of 8.32×10^{10} n/cm²-sec exceeds all of the measured values, with calculation to experimental ratios ranging from 1.06 to 1.28.

Comparisons of measured and calculated current fast neutron exposures for Capsule W-290 as well as for the inner radius of the pressure vessel are presented in Table 6-8. Measured values are given based on the Fe⁵⁴(n,p) Mn⁵⁴ reaction alone as well as for the average of all five threshold reactions. Based on the average data given in Table 6-8, the best estimate exposure of Capsule W-290 is

$$\Phi_T = 1.09 \times 10^{19} \text{ n/cm}^2 \text{ (E > 1 MeV)}$$

In addition, a fast neutron flux check was made of a fractured Charpy V-notch specimen from the thermal capsule, Capsule T-330. This analysis showed that Capsule T-330 was exposed to only a very minimal level of fast neutron flux, six orders of magnitude less than the exposure of Capsule W-290.

TABLE 6-6
COMPARISON OF MEASURED AND CALCULATED FAST NEUTRON FLUX
MONITOR SATURATED ACTIVITIES FOR CAPSULE W-290

| | Reaction and Z Location | R Location (CM) | Activity ($\frac{dis/s}{g}$) | Saturated Activity | |
|--------|----------------------------|--------------------|-----------------------------------|--|-------------------------------------|
| | | | | ($\frac{dis/s}{g}$) Capsule W-290 | ($\frac{dis/s}{g}$) Calculated |
| | $Cu^{63}(n,d)Co^{60}$ | | | | |
| Top | 84-1751 | 215.42 | 2.32E+05 | 6.87E+05 | |
| Middle | 84-1762 | 215.42 | 2.39E+05 | 7.08E+05 | |
| Bottom | 84-1773 | 215.42 | 2.07E+05 | 6.13E+05 | |
| | | | Average | 6.69E+05 | 7.11E+05 |
| | $Fe^{54}(n,p)Mn^{54}$ | | | | |
| | 84-1748 | 215.42 | 1.88E+06 | 5.76E+06 | |
| | 84-1754 | 215.42 | 1.77E+06 | 5.43E+06 | |
| | 84-1753 | 215.42 | 1.85E+06 | 5.67E+06 | |
| Top | 84-1754 | 215.42 | 1.89E+06 | 5.80E+06 | |
| | 84-1755 | 215.42 | 1.75E+06 | 5.37E+06 | |
| | 84-1756 | 215.42 | 1.95E+06 | 5.98E+06 | |
| | 84-1759 | 215.42 | 1.88E+06 | 5.76E+06 | |
| | 84-1763 | 215.42 | 1.86E+06 | 5.70E+06 | |
| | 84-1764A | 215.42 | 1.86E+06 | 5.70E+06 | |
| Middle | 84-1765 | 215.42 | 1.75E+06 | 5.37E+06 | |
| | 84-1766 | 215.42 | 1.91E+06 | 5.86E+06 | |
| | 84-1767 | 215.42 | 1.66E+06 | 5.09E+06 | |
| | 84-1770 | 215.42 | 1.39E+06 | 4.26E+06 | |
| | 84-1774 | 215.42 | 1.67E+06 | 5.12E+06 | |
| | 84-1764B | 215.42 | 1.66E+06 | 5.09E+06 | |
| Bottom | 84-1776 | 215.42 | 1.57E+06 | 4.81E+06 | |
| | 84-1777 | 215.42 | 1.74E+06 | 5.34E+06 | |
| | 84-1778 | 215.42 | 1.47E+06 | 4.51E+06 | |
| | | | Average | 5.37E+06 | 6.89E+06 |

TABLE 6-6 (Cont)
 COMPARISON OF MEASURED AND CALCULATED FAST NEUTRON FLUX
 MONITOR SATURATED ACTIVITIES FOR CAPSULE W-290

| Reaction and Z Location | R Location (CM) | Activity ($\frac{dis/s}{g}$) | Saturated Activity | |
|----------------------------|--------------------|-----------------------------------|--|-------------------------------------|
| | | | ($\frac{dis/s}{g}$) Capsule W-290 | ($\frac{dis/s}{g}$) Calculated |
| $Ni^{58}(n,p)Co^{58}$ | | | | |
| Top | 84-1750 | 3.06E+06 | 7.72E+07 | |
| Middle | 84-1761 | 3.05E+06 | 7.70E+07 | |
| Bottom | 84-1772 | 2.90E+06 | 7.32E+07 | |
| | | | Average | 7.58E+07 |
| | | | | 9.43E+07 |
| $U^{238}(n,f)Cs^{137}$ | | | | |
| Top | 84-1749 | 5.56E+05 | 5.52E+06 | |
| Bottom | 84-1771 | 5.36E+05 | 5.32E+06 | |
| | | | Average | 5.42E+06 |
| | | | | 5.79E+06 |
| $Tl^{46}(n,p)Sn^{46}$ | | | | |
| Top | 84-1747 | 1.10E+05 | 1.78E+06 | |
| Middle | 84-1758 | 1.06E+05 | 1.71E+06 | |
| Bottom | 84-1769 | 1.01E+05 | 1.63E+06 | |
| | | | Average | 1.71E+06 |
| | | | | 2.07E+06 |

TABLE 6-7
RESULTS OF FAST NEUTRON DOSIMETRY FOR CAPSULE W-290

| Reaction | $\left(\frac{dis/s}{g}\right)$ | | $\phi (E > 1.0 \text{ Mev})$ (n/cm ² -sec) | | $\phi (E > 1.0 \text{ Mev})$ (n/cm ²) | |
|---|--------------------------------|----------------------|--|-----------------------|--|-----------------------|
| | Measured | Calculated | Measured | Calculated | Measured | Calculated |
| Fe ⁵⁴ (n,p)Mn ⁵⁴ | 5.37x10 ⁶ | 6.89x10 ⁶ | 6.48x10 ¹⁰ | 8.32x10 ¹⁰ | 1.02x10 ¹⁹ | 1.31x10 ¹⁹ |
| Cu ⁶³ (n, α)Co ⁶⁰ | 6.69x10 ⁵ | 7.11x10 ⁵ | 7.84x10 ¹⁰ | 8.32x10 ¹⁰ | 1.23x10 ¹⁹ | 1.31x10 ¹⁹ |
| Ni ⁵⁸ (n,p)Co ⁵⁸ | 7.58x10 ⁷ | 9.43x10 ⁷ | 6.68x10 ¹⁰ | 8.32x10 ¹⁰ | 1.05x10 ¹⁹ | 1.31x10 ¹⁹ |
| Ti ⁴⁶ (n,p)Sc ⁴⁶ | 1.71x10 ⁶ | 2.07x10 ⁶ | 6.68x10 ¹⁰ | 8.32x10 ¹⁰ | 1.08x10 ¹⁹ | 1.31x10 ¹⁹ |
| U ²³⁸ (n,f)Cs ^{137(a)} | 4.77x10 ⁶ | 5.79x10 ⁶ | 6.85x10 ¹⁰ | 8.32x10 ¹⁰ | 1.07x10 ¹⁹ | 1.31x10 ¹⁹ |
| | | | | Average | 1.09x10 ¹⁹ | |

a. U²³⁸ adjusted saturated activity has been multiplied by 0.88 to correct for 350 ppm U²³⁵ impurity.


TABLE 6-8
SUMMARY OF NEUTRON DOSIMETRY RESULTS FOR CAPSULE W-290


| <u>Location</u> | Current ϕ ($E > 1.0$ mev) (n/cm^2) | | EOL ϕ ($E > 1.0$ mev) (n/cm^2) | |
|-----------------|---|-----------------------|---|-----------------------|
| | <u>Measured</u> | <u>Calculated</u> | <u>Measured</u> | <u>Calculated</u> |
| Capsule W-290 | 1.09×10^{19} | 1.31×10^{19} | | |
| Vessel IR | 8.52×10^{18} | 1.02×10^{19} | 5.48×10^{19} | 6.56×10^{19} |
| Vessel 1/4T | 5.37×10^{18} | 6.45×10^{18} | 3.45×10^{19} | 4.15×10^{19} |
| Vessel 3/4T | 9.93×10^{17} | 1.19×10^{18} | 6.39×10^{18} | 7.65×10^{18} |


Note: EOL fluences are based on operation at 2530 MWt for 32 effective full-power years.


NEUTRON FLUX (N/CM²-SEC)


1.00E+12
 7.00E+11
 5.00E+11
 3.00E+11
 2.00E+11
 1.00E+11
 7.00E+10
 5.00E+10
 3.00E+10
 2.00E+10
 1.00E+10
 7.00E+09
 5.00E+09
 3.00E+09
 2.00E+09
 1.00E+09


















8/28/89



SECTION 7
REFERENCES

1. Groeschel, R. C., Summary Report on Manufacture of Test Specimens and Assembly of Capsules for Irradiation Surveillance of Palisades Reactor Vessel Materials, CE Report No. P-NLM-019, April 1, 1971.
2. Perrin, J. S., Farmelo, D. R. Jung, R. G., and Fromm, E. O., "Palisades Pressure Vessel Irradiation Capsule Program: Unirradiated Mechanical Properties", August 25, 1977.
3. Regulatory Guide 1.99, Revision 1, "Effects of Residual Elements on Predicted Radiation Damage to Reactor Vessel Materials," U.S. Nuclear Regulatory Commission, April 1977.
4. Soltesz, R. G., Disney, R. K., Jedruch, J., and Zeigler, S. L., "Nuclear Rocket Shielding Methods, Modification, Updating and Input Data Preparation. Vol. 5 - Vol. 5, August 1970.
5. SAILOR RSIC Data Library Collection "DLC-76," Coupled, Self-shielded, 47 Neutron, 20 Gamma-ray, P3, Cross Section Library for Light Water Reactors."
6. Benchmark Testing of Westinghouse Neutron Transport Analysis Methodology - to be published.
7. ASTM Designation E261-77, Standard Practice for Measuring Neutron Flux, Fluence, and Spectra by Radioactivation Techniques," in ASTM Standards (1981), Part 45, Nuclear Standards, pp. 915-926, American Society for testing and Materials, Philadelphia, Pa., 1981.
8. ASTM Designation E262-77, "Standard Method for Measuring Thermal Neutron Flux by Radioactivation Techniques," in ASTM Standards (1981), Part 45, Nuclear Standards, pp. 927-935, American Society for Testing and Materials, Philadelphia, Pa., 1981.

9. ASTM Designation E263-77, "Standard Method for Measuring Fast-Neutron Flux by Radioactivation of Iron," in ASTM Standards (1981), Part 45, Nuclear Standards, pp. 936-941, American Society for testing and Materials, Philadelphia, PA., 1981.
10. ASTM Designation E481-78, "Standard Method of Measuring Neutron-Flux Density by Radioactivation of Cobalt and Silver," in ASTM Standards (1981), Part 45, Nuclear Standards, pp. 1063-1070, American Society for Testing and Materials, Philadelphia, Pa., 1981.
11. ASTM Designation E264-77, "Standard Method for Measuring Fast-Neutron Flux by Radioactivation of Nickel," in ASTM Standards (1981), Part 45, Nuclear Standards, pp. 942-945, American Society for Testing and Materials, Philadelphia, Pa., 1981.

ATTACHMENT II

PALISADES REACTOR PRESSURE VESSEL WELDS

2 PAGES

Palisades RPV Welds

| <u>WELD SEAM</u> | <u>LOCATION</u> | <u>WELD DEPOSIT</u> |
|------------------|---|--|
| 1-112 A/C | Upper Shell Long. Seams | RACO 3 #W5214 Linde 1092 #3617 Ni-200 #N-7753A E8018 Electrodes CBBF, JBFG (repair) |
| 2-112 A/C | Intermediate Shell Long. Seams | RACO 3 #W5214 Linde 1092 #3617 Ni-200 #N-7753A E8018 Electrodes (none) |
| 3-112 A/C | Intermediate Shell Long. Seams | RACO 3 #W5214 Linde 1092 #3692 RACO 3 #348009 Linde 1092 #3692 Ni-200 #N-7753A E8018 Electrode CBBF (repair) |
| 7-112 | Upper Shell to Flange Girth Seam | RACO 3 #W5214 Linde 1092 #3692 RACO 3 #348009 Linde 1092 #3692 ^{g.807.} #348009 Ni-200 #N-7753A and #N-98674 E8018 Electrode COGG (backweld) E8018 Electrode DAGG (weld grindout) |
| 8-112 | Upper to Intermediate Shell Girth Seam | RACO 3 #348009 Linde 1092 #3692 Ni-200 #N-98674 E8018 Electrode 7B-47B, COFC (back weld) |
| 9-112 | Intermediate to Lower Shell Girth Seam | MIL-B4 Mod. #27204 Linde 1092 #3714 E8018 Electrode JBFG (back weld) MIL-B4 Mod. #27204 Linde 124 #3687 (weld repair) E8018 Electrode LODG (first layer and back weld) (weld repair) |
| 10-112 | Lower Shell to Bottom Head Girth Seam | MIL-B4 Mod. #27204 Linde 1092 #3714 E8018 Electrode HAEG (first layer and back weld) |
| 12-112 | Seal Ledge to Flange Seam | RACO 3 #W5214 Linde 1092 #3617 E7018 Electrode HOHF (back weld and fillet) E7018 Electrode ABCG (ledge ring repair) |

Palisades RPV Welds

| <u>WELD SEAM</u> | <u>LOCATION</u> | <u>WELD DEPOSIT</u> |
|------------------|---|---|
| 1-113 A/F | Bottom Head Torus Long. Seams | E8018 Electrode 6M108 E8018 Electrode 7048 (weld repair) |
| 4-113 | Bottom Head Dome to Torus Girth Seam | MIL-B4 Mod. #12420 Linde 1092 #3708 E8018 Electrode CBB4 (back weld) |
| 1-118 A/F | Closure Head Torus Long. Seams | RACO 3 #W5214 Linde 1092 #3617 Ni-200 #N-7753A |
| 6-118 A/B | Closure Head Girth Seams | MIL-B4 Mod. #12420 Linde 1092 #3708 E8018 Electrode CBBF (back weld) |
| - | Surveillance Program Weld | RACO 3 #3277 Linde 1092 #3833 Ni-200 #N-0591A (face weld only) E8018 Electrode HADH (back weld, base metal repair) |