

Log # TXX-4153
File # 10010
TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

April 18, 1984


Mr. S. B. Burwell
Licensing Project Manager
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 AND 50-446
FSAR AMENDMENT 47 DESCRIPTION

Dear Mr. Burwell:

Attached is a table providing the description of Amendment 47, dated April 16, 1984.

Sincerely,



J. S. Marshall

RWH/grr
Attachment

cc - H. C. Schmidt
J. J. Stefano
G. S. Keeley (w/Amendment)

B411210002 B40418
PDR ADDCK 05000445
A PDR

CPSES/FSAR

AMENDMENT 47 DESCRIPTION

<u>SECTION</u>	<u>DESCRIPTION OF CHANGE</u>
1.3	Corrects a QA deficiency w.r.t. material composition of piping.
2.3	Provides update to description of operational meteorological system.
T2.3	"
T3.11B	Removes reference to limit switches for spec. MS-20.B.2. Provides update to HELB table.
EQR T4-1	Provides update to Environmental Qualification table.
EQR T5-1	"
EQR T5-2	Provides update to the postulated environment for N16 detectors.
7.5	Provides correction to source range channel number.
8.3	Provides clarification of criteria for running power cable with control cable.

CPSSES/FSAR

SECTION

DESCRIPTION OF CHANGE

9.4F

Provides correction of start signal for electrical area fan coil units.

9.5

Deletes reference to ORC Chairman.

Provides update to include a fire protection exemption request for sprinkler system in cable spreading room.

15.1

Refer to EQR T5-2, 1st paragraph.

II.B

Provides correction to key operated switch.

T032.110

Refer to 7.5.

Deleted "recorders" from table for SG water level and CST water level.