

LIC-92-016R

ENCLOSURE 3

SPECTRA GENERATION

9208070244 920731
PDR ADDCK 05000285
P PDR

**SOIL VARIATION ANALYSES
AND
GENERATION OF IN-STRUCTURE
RESPONSE SPECTRA
FOR
FORT CALHOUN UNIT 1**

Prepared for the
US Nuclear Regulatory Commission

Prepared by
Omaha Public Power District

July 1992

TABLE OF CONTENTS

	<u>Page</u>
TABLE OF CONTENTS	i
LIST OF TABLES	iii
LIST OF FIGURES	iv
EXECUTIVE SUMMARY	1
1.0 INTRODUCTION	2
2.0 SOIL-STRUCTURE INTERACTION ANALYSES PARAMETERS	4
2.1 Control Motion Response Spectra	4
2.2 Control Motion Time Histories	4
2.3 Development of Soil Properties for the SSI Soil Variation Analyses	4
2.4 Development of Soil Properties Uncertainty Factor	5
2.5 Structural Models	6
3.0 ANALYSES METHODOLOGY	9
3.1 Determination of Foundation Input Motions	9
3.2 Determination of Impedance Functions	9
3.3 SSI Response Computation	10
4.0 ANALYSIS RESULTS	11
4.1 Generation of Raw In-Structure Response Spectra, SSE	12
4.2 Enveloping and Broadening of Response Spectra, SSE	12
4.3 Generation of In-Structure Response Spectra, OBE	13
5.0 SUMMARY	14
6.0 REFERENCES	15
TABLES	17-25
FIGURES	26-43
APPENDIX A: In-Structure Response Spectra, Auxiliary Building/ Containment Structure/Internal Structure, SSE Case A1-A48	

APPENDIX B:	In-Structure Response Spectra, Intake Structure, SSE Case	B1-B9
APPENDIX C:	In-Structure Response Spectra, Auxiliary Building/ Containment Structure Internal Structure/, OBE Case	C1-C48
APPENDIX D:	In-Structure Response Spectra, Intake Structure, OBE Case	D1-D9
APPENDIX E:	Structural Properties Variation Study	E1-E6
APPENDIX F:	Soil-Structure-Interaction Damping Study	F1-F4

LIST OF TABLES

- 2.1 Strain-Compatible Soil Properties
- 2.2 Auxiliary Building/Containment /Internal Structure Stiffness Properties
- 2.3 Auxiliary Building/Containment /Internal Structure Mass Properties
- 2.4 Auxiliary Building/Containment/internal Structure Fixed-Base Frequencies and Modes
- 2.5 Intake Structure Stiffness Properties
- 2.6 Intake Structure Mass Properties
- 2.7 Intake Structure Fixed-Base Frequencies and Modes
- 4.1 Frequency Points for In-Structure Response Spectra
- 4.2 Auxiliary Building/Containment /Internal Structure and Intake Structure Elevations for Response Spectra Generation

LIST OF FIGURES

- 2.1 Design Basis Housner Ground Response Spectra for Fort Calhoun Station, Unit 1
- 2.2 Comparison of Design Basis Ground Response Spectrum and Enveloping Time History Response Spectrum, North-South Direction, 2% Damping
- 2.3 Comparison of Design Basis Ground Response Spectrum and Enveloping Time History Response Spectrum, North-South Direction, 5% Damping
- 2.4 Comparison of Design Basis Ground Response Spectrum and Enveloping Time History Response Spectrum, North-South Direction, 7% Damping
- 2.5 Comparison of Design Basis Ground Response Spectrum and Enveloping Time History Response Spectrum, East-West Direction, 2% Damping
- 2.6 Comparison of Design Basis Ground Response Spectrum and Enveloping Time History Response Spectrum, East-West Direction, 5% Damping
- 2.7 Comparison of Design Basis Ground Response Spectrum and Enveloping Time History Response Spectrum, East-West Direction, 7% Damping
- 2.8 Comparison of Design Basis Ground Response Spectrum and Enveloping Time History Response Spectrum, Vertical Direction, 2% Damping
- 2.9 Comparison of Design Basis Ground Response Spectrum and Enveloping Time History Response Spectrum, Vertical Direction, 5% Damping
- 2.10 Comparison of Design Basis Ground Response Spectrum and Enveloping Time History Response Spectrum, Vertical Direction, 7% Damping
- 2.11 Sketch of Auxiliary Building/Containment/Internal Structure Mathematical Model
- 2.12 Sketch of Intake Structure Mathematical Model
- 4.1 Comparison of Free-Field versus Auxiliary/Containment/Internal Structure Basemat Response Spectrum- Horizontal Direction, 2% Damping
- 4.2 Comparison of Free-Field versus Auxiliary/Containment/Internal Structure Basemat Response Spectrum- Vertical Direction, 2% Damping
- 4.3 Comparison of Upper Bound and Lower Bound Raw Response Spectra, Auxiliary/Containment/Internal Structure, North-South Direction, 2% Damping

- 4.4 Comparison of Upper Bound and Lower Bound Raw Response Spectra, Auxiliary/Containment/Internal Structure, East-West Direction, 2% Damping
- 4.5 Comparison of Free-Field versus Intake Structure Elevation 985 ft. Response Spectrum- Horizontal Direction, 2% Damping
- 4.6 Comparison of Free-Field versus Intake Structure Elevation 985 ft. Response Spectrum- Vertical Direction, 2% Damping

EXECUTIVE SUMMARY

This report describes the soil-structure interaction (SSI) soil variation analyses performed for the Class I structures (Auxiliary Building/ Internal Structure/ Containment Structure and Intake Structure) at Omaha Public Power District's (OPPD) Fort Calhoun Station, Unit 1. The objective of these analyses was to incorporate effects due to uncertainties in soil properties into the in-structure response spectra developed for the plant. The analyses in this report complement those performed previously - and reviewed by the NRC Staff- using best estimate soil properties.

The soil variation analyses were performed considering a $\pm 30\%$ variation in soil shear moduli from the Best Estimate (BE) case. This variation factor is based on Fort Calhoun-specific soil data reported in the plant's Updated Safety Analysis Report (USAR). Soil-Structure Interaction (SSI) analyses were performed using Upper Bound (UB, +30% variation factor) and Lower Bound (LB, -30% variation factor) soil properties.

The SSI soil variation analyses were performed using the same soil-structure models and analysis procedures previously used for the BE analyses, modified as appropriate to incorporate the new soil properties. The analysis methodology consists of frequency domain analyses in which the site-pile foundation system is modeled by a series of frequency-dependent impedance functions representing the stiffness and damping characteristics of the Fort Calhoun site.

Analyses results were generated in the form of acceleration time histories and then converted to acceleration response spectra generated at locations and damping values consistent with those reported previously for the BE analyses. The final broadened response spectra to be used for design and analysis are given by the envelop of the UB and LB response spectra and the $\pm 15\%$ broadened BE spectra.

The SSI analyses were performed for the Safe Shutdown Earthquake (SSE). The Operating Basis Earthquake (OBE) responses were obtained by applying suitable scaling factors to the SSE response envelopes. The in-structure response spectra plots are contained in Appendices A through D. Parametric studies, performed to support licensing of the response spectra, are described in Appendices E and F.

1.0 INTRODUCTION

This report describes the soil-structure interaction (SSI) soil variation analyses performed for the Class I structures (Auxiliary Building/ Internal Structure/ Containment Structure and Intake Structure) at Fort Calhoun Station, Unit 1. The objective of these analyses was to incorporate effects due to uncertainties in soil properties into the in-structure response spectra developed for the plant as part of the Alternate Seismic Criteria (ASC) for Fort Calhoun. The analyses reported in this report complement those performed previously using best estimate soil properties and documented in Reference 1.

The soil variation analyses were performed using a $\pm 30\%$ variation in soil shear moduli from the Best Estimate (BE) case. The $\pm 30\%$ variation is based on Fort Calhoun-specific soil data, as described in Section 2.4 of this report. Throughout this report, the +30% variation analysis case is called the Upper Bound (UB) case and the -30% variation analysis is called the Lower Bound (LB) case.

The free-field control motions used as input to the SSI evaluations consist of a set of three time history components, one for each of the three mutually orthogonal earthquake directions. This set of time histories is the same set that had been used in the previous SSI evaluations for the best estimate case (Reference 1). The response spectra of each of the three time histories envelop the Fort Calhoun Design Basis ground motion response spectra.

The UB and LB SSI soil variation analyses were performed using the same SASSI/CLASSI soil-structure models previously used for the BE analyses, modified as appropriate to incorporate the new soil properties. The SSI models are described in detail in Reference 1. SSI analyses parameters used in the soil variation analyses are described in Section 2.0. The analysis methodology consists of frequency domain analyses performed using a substructuring technique. In this approach, the site-pile foundation system is modeled by a series of frequency-dependent impedance functions representing the stiffness and damping characteristics of the Fort Calhoun foundation system. These impedance functions are subsequently combined with the dynamic properties of the Fort Calhoun structures to produce earthquake response time histories. A detailed discussion of the analysis methodology is described in Section 3.0 of this report.

The SSI analyses generated acceleration time histories that were converted to acceleration response spectra at various locations throughout the Auxiliary/Containment/Internal Structure and Intake Structure models. Response spectra were generated at the base of each of these structures and at major floor elevations. These locations are consistent with the locations reported previously in Reference 1. Response spectra were generated at four damping values (2, 3, 5, and 7 % damping ratios for the SSE and 1, 2, 4,

and 5% damping ratios for OBE). A discussion of the results of the analyses is provided in Section 4.0 of this report. A summary is given in Section 5.0. The final enveloped and broadened in-structure response spectra plots are contained in Appendices A through D. Parametric studies, performed to support licensing of the response spectra, are described in Appendices E and F.

2.0 SOIL-STRUCTURE INTERACTION ANALYSES PARAMETERS

2.1 Control Motion Response Spectra

The control motion used in the SSI soil variation analyses is defined by the Fort Calhoun design basis ground response spectra shown in Figure 2.1. The design basis ground response spectra are of the modified Housner shape anchored to 0.17g (horizontal direction) peak ground acceleration for the Maximum Hypothetical Earthquake (MCE), also called Safe Shutdown Earthquake (SSE), and 0.08g (horizontal direction) peak ground acceleration for the Design Earthquake (DE), also called Operating Basis Earthquake (OBE). The vertical direction peak ground acceleration is 2/3 of the horizontal direction.

2.2 Control Motion Time Histories

The control motion time histories consist of a set of three mutually orthogonal and statistically independent components - two horizontal and one vertical. These acceleration time histories constitute the free-field input ground motions used for the SSI analyses. The acceleration time histories have 20 seconds duration and were developed in accordance with Reference 4. To ensure that there is no deficiency in power over any frequency range, Power Spectral Density (PSD) functions were developed, as documented in Reference 2. The time histories, associated response spectra and PSD's have been previously reviewed by the NRC staff, as documented in Reference 3. Figures 2.2 through 2.10 show the response spectrum of these time histories, compared with the design basis Housner spectrum, for 2, 5, and 7% damping, for the horizontal and vertical directions.

2.3 Development of Soil Properties for the SSI Soil Variation Analyses

The Fort Calhoun site consists of approximately 60 feet of silty sands and fine sands overlying limestone bedrock. The site can be characterized as a relatively shallow site. Original surface elevation ranged from +997 to +1004 feet. Bedrock elevation varied from approximately 931 feet to 935 feet (Reference 5).

For purposes of SSI analysis, each layer in the soil profile is defined by the following parameters: soil shear moduli, material hysteretic damping (expressed as viscous damping ratio), Poisson's ratio and soil mass density. Best estimate values of soil properties characterizing the site were previously developed using Fort Calhoun-specific geotechnical and geophysical data (References 5,7) supplemented with data in Reference 6. The development of these soil parameters for the BE analysis case is described in Reference 1.

Reference 1 has been previously reviewed by the NRC staff (Reference 3).

For the SSI soil variation analyses, the BE low-strain soil parameters described in Reference 1 were appropriately modified to incorporate effects due to uncertainties in the soil shear moduli, as follows:

- a. The low-strain UB soil shear moduli for each soil layer were obtained by multiplying the BE shear moduli values by a factor of 1.3. The resulting UB soil column profile was analyzed using the SHAKE computer program to obtain strain-compatible (or high-strain) properties. The modulus reduction (G/G_{max}) versus strain relationship previously used in the BE analyses is also used for the UB soil profile. The resulting high-strain soil column profile is compatible with the level of motion specified for Fort Calhoun.
- b. A similar approach was followed for development of the LB soil column profile; in this case, the low-strain BE soil shear moduli properties were scaled by a factor of 0.7. Table 2.1 summarizes the strain-compatible soil properties obtained from the SHAKE analyses and used for the BE, UB, and LB SSI analyses.
- c. Strain-compatible damping ratios were also obtained for each soil layer. The same damping ratio versus strain relationship previously used for the BE analysis was used for the UB and LB SHAKE analyses. The damping ratios for all three cases are also shown in Table 2.1. As can be seen, the damping ratios for the UB are lower than the BE and for the LB are higher than the BE. This is because the strains within the soil profile are different for each of the three cases. Conservatively, in the SASSI analyses, the BE damping ratios are also used for the LB SASSI analyses.
- d. The UB and LB profiles obtained as discussed above were used together with the pile foundation system configuration to develop site-specific impedance function, for use in the SSI evaluations, as described in Section 3.0.

2.4 Development of Soil Properties Uncertainty Factor

As discussed in Section 2.3, an uncertainty factor of $\pm 30\%$ of the best-estimate low-strain shear modulus values has been applied to the Fort Calhoun soil variation analyses. This factor has been derived on the basis of available site-specific geotechnical information collected as part of the site investigations performed during plant design and construction. Reference 5, Appendix C, reports that a total of 95 borings were drilled at the site. Of these, 19 borings drilled underneath the major structures contain detailed Standard

Penetration Tests (SPT) data. In each boring, SPT tests were performed at depth intervals of 5 feet, from the ground surface to bedrock elevation (thirteen tests per boring on the average). Based on existing relationships correlating SPT blow count data with low-strain shear modulus (Reference 6), a statistical evaluation of the SPT blow count data was performed and a coefficient of variation of 0.2 was obtained for the soil shear moduli at Fort Calhoun. This is consistent with the results of geophysical tests performed at the site (Reference 7) which support a variation in shear modulus of $\pm 15\%$ to 20%.

In addition, the variability in soil properties at the Fort Calhoun site has been substantially reduced as a result of the extensive treatment of the soils at the site at the time of pile installation. This is documented in the plant's USAR, Section 5.7 and Appendices C and D (Reference 5). Reference 5, Section 5.7, reports that a statistical analysis (performed after pile installation and densification of the site) of 696 SPT results indicated that the average relative density for the entire area is not less than 85% at an overall confidence level of 96.5%.

Based on the discussion above, an uncertainty band of $\pm 30\%$ of the best estimate shear modulus is considered to conservatively bound the potential variation in soil properties at the Fort Calhoun site.

2.5 Structural Models

The structural models used for the SSI soil variation analyses were the same models developed for the previous SSI evaluations for the BE case. The development of the structural models is described in detail in Reference 1 and associated calculations (References 13 and 14). The structural models have been previously reviewed by the NRC Staff (References 2, 3). For purposes of completeness of this report, a brief description of the models is provided next.

Auxiliary Building/Containment Building/Internal Structure Model

The Auxiliary Building/Containment Building and Internal Structure are founded on a common basemat which is supported on 803 steel piles driven to bedrock. The Auxiliary Building includes the control room, spent fuel storage pool, safety injection and refueling water storage tank, and emergency diesel generator rooms. The Containment Building includes the Containment Shield and the Internal concrete structures. Other than sharing a common basemat, these three structures are structurally separate from each other. For this reason, separate "stick" models are developed for each, connected only at the basemat level.

The Auxiliary Building, Containment Shield and Internal Structure model is a three-dimensional stick model consisting of elastic beam elements with lumped masses at major floor elevations. Each beam element represents the stiffness of a section of the structure between two floors and is located at the center of rigidity of that section. The stiffness properties of each beam element are given by the section's axial (A_z) and shear areas (A_x, A_y), moments of inertia about the horizontal axes (I_{xx}, I_{yy}) and torsional constant about the vertical axis (J_{zz}). The mass of each floor consists of the mass of the concrete floor slab itself, heavy equipment, storage tanks and contained liquid, steel platforms, and one-half of the concrete walls above and below the particular floor. In addition, to account for other light equipment, piping, and miscellaneous structural steel, a distributed weight of 20 psf is uniformly distributed over the area of each floor. The calculated total mass is lumped at the center of mass of the particular floor elevation. Rigid links connect the centers of mass with the centers of rigidity at each floor elevation. Thus, the model captures torsional effects due to eccentricities that exist between the center of mass and center of rigidity. The development of the Auxiliary Building/Containment/Internal Structure is documented in References 1 and 13. Figure 2.11 shows a sketch of the mathematical model. Tables 2.2 and 2.3 tabulate the stiffness and mass properties of the Auxiliary Building/Containment/ Internal Structure model. Consistent with previous BE case evaluations for the SSE, structural damping of 7% of critical was used in the UB and LB SSI analyses.

Fixed-base frequencies for the first ten modes (without SSI effects), corresponding mass participation factors and modes description are shown in Table 2.4. Forty modes were used in the actual SSI analyses, with cumulative mass participation of over 90% in each direction.

Intake Structure Model

The Intake Structure is located east of the Auxiliary and Containment Building alongside the Missouri River. The lower part of the structure is of concrete shear wall construction and the upper part is of steel frame construction. The foundation mat is supported on 64 piles driven to bedrock. The development of the Intake Structure stick model followed similar procedures as the Auxiliary Building/Containment/Internal Structure model. The development of the Intake Structure model is documented in References 1 and 14. A sketch of the stick model is shown in Figure 2.12. Stiffness and mass properties are summarized in Tables 2.5 and 2.6, respectively. Fixed-base frequencies for the first ten modes (without SSI effects), corresponding mass participation factors and mode description are shown in Table 2.7. Twenty modes were used in the actual SSI

analyses, with cumulative mass participation of over 90% in each direction.

3.0 ANALYSIS METHODOLOGY

The analysis approach used for the SSI soil variation analyses is consistent with the approach previously used for the SSI best estimate analyses and described in Reference 1. The SSI analyses are performed in the frequency domain using a substructuring approach. In the substructuring approach, the SSI problem is broken down into three steps, as follows:

3.1 Step 1: Determination of the Foundation Input Motions

This is also called the scattering problem and consist of the determination of the motions of the foundation alone, without including the effects of the superstructure. For a surface-founded foundation system and for vertically propagating shear and compressional wave field, the foundation input motions are identical to the free-field motions. This is the case for the application to Fort Calhoun, i.e.: the wave field consist of vertically propagating shear and compressional waves and the foundation is assumed to be surface founded, with no deamplification of the motion over the embedment depth due to spatial variation considerations. Thus, the foundation input motions correspond to the free-field motions and are applied at the foundation elevation of the structures, in the free field. This is also in accordance with the recommendations of Revision 1 of the SRP.

3.2 Step 2: Determination of Impedance Functions

These are the complex and frequency-dependent force-displacement relationships of the soil-pile foundation system. Foundation impedance functions were calculated for the UB and the LB cases using the existing BE case SASSI three-dimensional models of the soil-pile foundation system of the Auxiliary/Containment/ Internal Structure and the Intake Structure. These soil-pile foundation models were modified as appropriate to reflect the new UB and LB soil properties. Changes to the BE case SASSI models consisted of incorporating the UB and LB strain-compatible soil properties obtained from the SHAKE analyses, as described in Section 2.3. ABB Impell's version of SASSI (Reference 8), verified for nuclear safety-related work, was used for the impedance functions computation. SASSI is a program developed specifically for SSI applications.

Separate analyses were performed for computation of impedance functions for the UB and LB cases and for each, the Auxiliary Building/Containment/ Internal Structure and the Intake Structure. Thus, there were four separate SASSI models used for impedance computation. The impedance functions are described by 6 x 6 component (horizontal translations, vertical translation, rocking about both horizontal axes and torsion) complex and frequency-

dependent matrices describing the stiffness and damping characteristics of the soil-pile foundation system. The real part of the complex terms of the matrix represent the stiffness of the soil-pile-group foundation system and the imaginary part represents the damping of the system. A 6 x 6 matrix is generated for each impedance frequency.

The SASSI models used for impedance computation incorporate the piles driven to bedrock and capped to the concrete basemat. There are 803 piles for the Auxiliary Building/Containment/Internal Structure foundation and 64 piles for the Intake Structure foundation. For purposes of impedance computation, the foundation basemats are considered to be rigid. This enables the entire pile foundation system to be represented by a 6 x 6 component impedance matrix at each frequency, as previously discussed. The assumption of rigid basemat is appropriate because there are numerous walls that stiffen the basemat in the out-of-plane direction. Also, since some separation between the bottom of the basemat and the soil is possible over time, the basemats are assumed not to be in contact with the soil and, therefore, its contribution to the impedance is conservatively neglected, i.e.: the basemat impedance is not added to the pile impedance.

3.3 Step 3: SSI Response Computation

Solution of the coupled (soil-pile foundation-structure) system of equations of motion using the results from Steps 1 and 2, and the fixed-base dynamic properties of the superstructures produces structural responses. These are in the form of acceleration time histories at specified locations throughout the structural model. The CLASSI program (Reference 9) module SSIN is used in this step to compute time histories of response using a frequency domain analysis approach. A total of 4096 points are used in the Fourier decomposition. The response acceleration time histories are calculated at a time step of 0.01 seconds. The response acceleration time histories are used to obtain floor response spectra at 2, 3, 5, and 7% damping ratios using the program RESPEC (10).

Consistent with the BE analyses, the models of the superstructures include rigid links extending from the centers of mass to the locations farthest away from the centers of mass, locations at which the contributions from rocking and torsion would be the largest. Response spectra generated at these locations are enveloped and these enveloped spectra constitute the response spectra applicable to the entire floor at a particular elevation.

4.0 ANALYSES RESULTS

This section contains the results of the SSI soil variation studies. UB and LB SSI analyses were performed for both, the Auxiliary/Containment/ Internal Structure and the Intake Structure. Results were obtained in the form of absolute acceleration time histories at various locations throughout the models. The acceleration time histories were then used to generate in-structure response spectra. The analyses procedure and results are documented in Reference 11 for the Auxiliary Building/Containment/ Internal Structure and Reference 15 for the Intake Structure. A summary of the results is provided below.

Auxiliary Building/Containment/Internal Structure

Examination of the response spectra obtained from the SSI analyses indicates that the in-structure response spectra are heavily influenced by the dynamic response amplification of the soil column overlying bedrock, with some lesser influence from the pile system. This is true in particular for the horizontal direction. The horizontal resonant frequencies of the combined soil-pile-structure system are about 2.3, 2.7 and 1.9 Hz for the BE, UB and LB, respectively and are dominated by the soil column response frequency. As expected, the in-structure spectra amplifies over the range of frequencies noted above. This is shown in Figure 4.1 which shows a comparison of the 2% damped response spectra of the free-field input ground motion (time history and Housner design basis) and the response spectrum obtained at basemat elevation from the SSI analyses (envelope of BE, UB and LB). The amplification seen for the Fort Calhoun site is consistent with amplification factors found for shallow sites (Reference 12). The pile system has a larger influence in the vertical direction; the combined soil-pile vertical resonant frequencies are 4.3 and 15.3 Hz for the BE case, 4.8 and 17.4 Hz for the UB case and 3.6 and 12.6 Hz for the LB case. Figure 4.2 shows a similar comparison for the vertical direction.

Intake Structure

The Intake Structure response spectra exhibits similar overall response characteristics as the Auxiliary/Containment/Internal Structure. That is, the Intake Structure response spectra is also heavily influenced by the dynamic response amplification of the soil column overlying the bedrock. The horizontal resonant frequencies of the combined soil-pile-structure system are about 3.2, 3.8 and 2.5 Hz for the BE, UB and LB, respectively. These frequencies are higher than those seen for the Auxiliary/ Containment/ Internal Structure because of the shorter depth of the soil column in the case of the Intake Structure due to its larger embedment depth. Figure 4.5 shows a comparison of the 2% damped response spectra of the free-field input ground motion and the response spectrum obtained at an elevation close to the basemat from the SSI analyses (envelope of BE, UB and LB). Figure 4.6 shows a similar comparison for the vertical direction.

4.1 Generation of In-Structure Raw Response Spectra, SSE

In-structure response spectra were computed at 88 frequency points, in excess of those recommended in the SRP, and distributed evenly along a logarithmic scale. The frequency points at which spectral ordinates are calculated are tabulated in Table 4.1 for the Auxiliary/Containment/Internal Structure. For the Intake Structure, some of frequency points in Table 4.1 are changed to incorporate the structure's own fixed-base frequencies. The frequency points meet the frequency intervals recommended in the SRP. Response spectra were calculated at four damping values (2, 3, 5, and 7%).

In-structure response spectra for both the UB and LB were generated at building elevations consistent with the previous BE case analysis. These elevations are described in Table 4.2. At each elevation, response spectra were generated at the center of mass and at building corner locations furthest away from the center of mass, typically four to six locations, in order to capture the maximum contributions from rocking and torsion response. The group of response spectra at each floor elevation were then enveloped to create a single spectra set applicable to that particular elevation.

Typical 2% damped curves of the enveloped raw response spectra, obtained for the UB and LB for the Auxiliary/Containment/Internal structure, are shown in Figures 4.3 and 4.4 for the north-south and east-west directions, respectively. As can be seen from figures 4.3 and 4.4 spectral peaks are controlled by the UB case. Also, from comparison of spectral peaks in Figures 4.3 (north-south), and 4.4 (east-west), larger amplitudes in the spectral peak is observed for the east-west compared to the north-south direction. This is in part related to the larger amplitudes of the east-west input motion, where, as shown in Figures 2.1 (free-field north-south, 2% damped) and 2.4 (free-field east-west, 2% damped), the amplitudes of the input spectrum are larger for the east-west than for the north-south directions, at the frequencies of the soil-structure system. Similar trends apply for the Intake Structure.

The UB and LB spectra were further enveloped with the enveloped spectra for the BE case, (with a $\pm 15\%$ broadening factor), and then smoothed to produce the final spectra.

4.2 Enveloping and Broadening of Design Response Spectra, SSE

As discussed above, the final broadened in-structure response spectra consist of an envelope of the following:

- The BE response spectra, broadened by a factor of $\pm 15\%$. This broadening factor accounts for uncertainties other than soil property related uncertainties;
- The UB response spectra, obtained from the soil variation studies, and;
- The LB response spectra, obtained from the soil variation studies.

The enveloped and broadened spectra were further smoothed by hand to produce the final SSE response spectra, contained in Appendices A and B of this report for the Auxiliary Building/Containment/Internal Structure and the Intake Structure, respectively.

4.3 Generation of In-Structure Response Spectra, OBE

The development of response spectra for the OBE is based on the SSE response envelopes appropriately scaled to reflect the OBE/SSE peak ground acceleration ratio and other effects such as lower structural and soil damping and possible frequency shifts due to smaller strains within the soil profile.

The ratio between OBE and SSE free-field input is 0.47 (0.08g/0.17g). However, as discussed above, when OBE responses are obtained by scaling of SSE responses, this ratio is typically higher, primarily because of the lower damping in the OBE analysis. In order to derive an appropriate (and bounding) ratio for scaling SSE responses to obtain OBE response spectra for Fort Calhoun, a review of the SSE and OBE in-structure response spectra peaks was made for the BE case analyses (Reference 1). Based on this review, OBE to SSE ratios of 0.6 or less were observed. The ratio is less than 0.6 in most cases, particularly in the vertical direction. Based on this review, a factor of 0.6 was selected to conservatively scale the amplitudes of the SSE response envelopes. In addition, a frequency shift of 7% was obtained from the SHAKE soil column OBE analyses with respect to the SSE soil column analysis. Therefore, the scaled OBE curves were further broaden by 7% to the higher frequency side. The OBE procedure and OBE response envelopes are documented in Reference 15 for the Intake Structure and 16 for the Auxiliary/Containment/Internal Structure. The final OBE response spectra are contained in Appendices C and D of this report for the Auxiliary Building/Containment/Internal Structure and the Intake Structure, respectively.

5.0 SUMMARY

This section summarizes the results of the SSI soil variation studies. UB and LB SSI analyses were performed using the same models and analyses methods used previously for the BE case analyses. An uncertainty variation factor of $\pm 30\%$ of the best-estimate properties was applied to the soil shear modulus to develop new properties used in the SSI variation analyses. New SSE response spectra were generated by enveloping the response spectra obtained from UB and LB analyses and the BE analyses broadened by $\pm 15\%$. The OBE response spectra were obtained by scaling the SSE response spectra by a factor of 0.6 and additional broadening equal to 7% to the higher frequency side of the spectral peak. The final set of response spectra for the Class I structures are contained in Appendices A through D of this report.

6.0 REFERENCES

- 1.0 "Generation of In-Structure Response Spectra for Fort Calhoun Station, Unit 1". Report Prepared for the Nuclear Regulatory Commission by Omaha Public Power District, January 1989. (ABB Impell Report No.01-1390-1711, Rev.0)
- 2.0 "Response to NRC Questions on Fort Calhoun's Refined Seismic Spectra". Report Prepared for the Nuclear Regulatory Commission by Omaha Public Power District, October 1990. (ABB Impell Report No. 01-1390-1830, Rev.0).
- 3.0 Safety Evaluation by the Office of Nuclear Reactor Regulation Related to the Alternate Seismic Criteria and Methodologies, Omaha Public Power District, Fort Calhoun Station, Unit 1. Docket No 50-285, Enclosures 1 and 2, June 17, 1991.
- 4.0 U.S. Nuclear Regulatory Commission Standard Review Plan, NUREG-0800, Revisions 1 and 2.
- 5.0 Updated Safety Analysis Report (USAR) for Fort Calhoun Station, Unit 1, Revision 7/87.
- 6.0 Seed, H.B., Wong, R., Idriss, I.M., Tokimatsu, T., "Moduli and Damping Factors for Dynamic Analysis of Cohesionless Soils". EERC Report 84-14, September 1984.
- 7.0 Preliminary Safety Analysis Report, Fort Calhoun Station, Unit 2. Omaha Public Power District.
- 8.0 ABB Impell Corporation Computer Program SASSI, Version 4.0
- 9.0 ABB Impell Corporation Computer Program CLASSI, Version 0.0
- 10.0 ABB Impell Corporation Computer Program RESPEC, Version 1.0
- 11.0 ABB Impell Corporation Calculation: "SSI Analyses for the Auxiliary/Internal/Containment Structure". Calculation No. A-01, Rev.0, Project 0139-00378/00398, July 1992.
- 12.0 Engineering Model of Earthquake Ground Motion for Eastern North America. EPRI Report NP-6074, October 1988.
- 13.0 ABB Impell Corporation Calculation: "Model Development of Auxiliary, Containment and Internal Buildings". Calculation No. AUX-01, Rev.0, Job No. 1390-027-1355.
- 14.0 ABB Impell Corporation Calculation: "Intake Structure Model". Calculation No. INT-01, Rev.0, Job No. 1390-027-1355.

- 15.0 ABB Impell Corporation Calculation: "SSI Analyses for the Intake Structure", Calculation No. I-01, Rev.0, Project 0139-00378/00398, July 1992.
- 16.0 ABB Impell Corporation Calculation: "OBE Response Spectra for the Auxiliary/Internal/Containment Structure". Calculation No. A-02, Rev.0, Project 0139-00378/00398, July 1992.

TABLE 2.1
STRAIN-COMPATIBLE SOIL PROPERTIES (SHAKE PROFILE)
SAFE SHUTDOWN EARTHQUAKE

Layer No.	Thickness (ft)	Unit Weight (pcf)	Best Estimate			Upper Bound			Lower Bound		
			S-Wave Velocity V _s (ft/sec)	Shear Modulus G (ksf)	Damping Ratio	S-Wave Velocity V _s (ft/sec)	Shear Modulus G (ksf)	Damping Ratio	Wave Velocity V _s (ft/sec)	Shear Modulus G (ksf)	Damping Ratio
1	2.5	115	317	358	0.037	364	474	0.032	261	294	0.046
2	2.5	115	408	534	0.049	539	789	0.043	336	433	0.057
3	2.5	115	429	754	0.054	1000	0.048	376	506	0.063	
4	2.5	115	497	991	0.067	672	1172	0.051	404	584	0.068
5	2.5	124	505	997	0.060	1203	1303	0.053	413	656	0.071
6	2.5	128	535	1103	0.062	1495	1495	0.054	434	724	0.074
7	5.0	128	507	994	0.072	1543	1543	0.063	404	639	0.068
8	5.0	124	539	1120	0.074	1523	1523	0.066	431	714	0.069
9	5.0	124	567	1240	0.075	1690	1690	0.068	455	798	0.068
10	5.0	124	592	1246	0.078	1626	1741	0.071	456	801	0.092
11	5.0	124	577	1281	0.080	1741	1741	0.073	459	811	0.095
12	5.0	124	551	1169	0.086	1619	1619	0.077	472	718	0.105
13	5.0	124	565	1231	0.086	1668	1717	0.076	442	754	0.106
14	5.0	130	565	1291	0.088	1986	1986	0.077	442	797	0.108
15	5.0	130	579	1352	0.088	1992	1992	0.077	450	819	0.109
Rock	...										

Poisson's Ratio (all layers) = 0.475

Elevation at top of profile = 994 ft.

TABLE 2.2
AUXILIARY BUILDING/CONTAINMENT/INTERNAL STRUCTURE STIFFNESS PROPERTIES

ELEVATIONS (FT)	BLDG.	AXIAL AREA A_x (Ft ²)	SHEAR AREA A_y (Ft ²)	SHEAR AREA A_z (Ft ²)	Mom. of INERTIA I_{xx} (Ft ⁴)	Mom. of INERTIA I_{yy} (Ft ⁴)	Mom. of INERTIA I_{zz} (Ft ⁴)
1044 to 1083	AUX.	450	354	97	281565	328863	1174991
1044 TO 1057	"	1117	606	511	4907144	1510073	6926157
1036 TO 1044	"	2557	1229	1318	19579039	19701249	14987791
1025 TO 1036	"	4447	2187	2260	33910292	29770067	26566505
1007 TO 1025	"	5609	2980	2630	37690000	33970000	25750000
984 TO 1007	"	6591	3519	3072	41340000	41640000	28430000
1056.5 TO 1038.5	INT.	671	212	458	487422	262222	552982
1038.5 TO 1013	"	1382	567	825	678822	645312	686091
1013 TO 994	"	1689	927	1245	722342	621119	745569
1118 TO 991	CONT.	1394	742	742	4526287	2263144	2263144

TABLE 2.3
AUXILIARY BUILDING/CONTAINMENT/INTERNAL STRUCTURE MASS PROPERTIES

Mass Point	Node #	Elev. (FT)	BLDG	M _x (K-S ²)/FT	M _y (K-S ²)/FT	M _z (K-S ²)/FT	M _{xx} K-S ² -FT	M _{yy} K-S ² -FT	M _{zz} K-S ² -FT
MA1	2	1083	AUX.	100.9	100.9	100.9	55027	194925	242719
MA2	12	1057	"	167.0	167.0	167.0	123970	784522	907651
MA3	22	1044	"	195.0	195.0	195.0	1237043	966631	2193570
MA4	42	1036	"	303.8	303.8	293.1	2219362	1593247	3810090
MA5	72	1025	"	574.8	574.8	555.6	3276540	2287913	5551136
MA6	102	1007	"	945.5	945.5	882.95	5811746	4179269	9962859
MI1	32	1056.5	INT.	41.8	41.8	41.8	26129	28245	52669
MI2	52	1045	"	46.9	46.9	46.9	34210	39438	73694
MI3	82	1038.5	"	114.2	114.2	114.2	58537	67836	118714
MI4	112	1013	"	270.8	270.8	270.8	165720	187918	316850
MC1	62	1118	CON.	273.6	273.6	273.6	204308	204308	650863
MC2	92	1099	"	330.6	330.6	330.6	424677	424677	1009021
MC3	122	1045	"	335.2	335.2	335.2	601716	601716	1036850
Foundation		989'	Aux/Int/Cont	3116.1	3116.1	3208.9	13,391,025	9,522,791	22,643,089
TOTAL			"	6816.2	6816.2	6816.6			

TABLE 2.4

AUXILIARY/CONTAINMENT/INTERNAL STRUCTURE
FIXED-BASE FREQUENCIES AND MODES

Mode No.	Frequency (Hz)	Cumulative Mass Participation Factors (%)			Description of Mode 1,2
		X-Dir. (NS)	Y-Dir. (EW)	Z-Dir. (V)	
1	6.2	11	11	0	C, Mixed X-Y
2	6.2	22	22	0	C, Mixed X-Y
3	6.9	22	36	0	A, Y (@ 1083)
4	11.8	22	36	9	C, Torsion
5	13.3	51	36	0	A, X (Main)
6	14.9	56	36	0	I, X (Main)
7	15.4	57	70	0	A, Y (Main)
8	16.3	60	71	0	I, Y & Torsion
9	16.8	60	71	25	C, Vertical
10	17.0	61	78	25	I, Y & Torsion

(1) A = Auxiliary Building
I = Internal Structure
C = Containment Shield

(2) X = NS Direction
Y = EW Direction

Note: Only first ten modes listed. Forty modes were used in the analysis, with cumulative MPFs of over 90% in each direction

TABLE 2.5
INTAKE STRUCTURE STIFFNESS PROPERTIES

ELEVATIONS (FT)	AXIAL AREA A_x (Ft ²)	SHEAR AREA A_y (Ft ²)	SHEAR AREA A_z (Ft ²)	Mom. of INERTIA I_{xx} (Ft ⁴)	Mom. of INERTIA I_{yy} (Ft ⁴)	Mom. of INERTIA I_{zz} (Ft ⁴)
1024.5 TO 1035.63	3.624	0.0827	0.177	2320.73	4534.75	324.0
1014.5 TO 1024.50	3.624	0.1016	0.209	2320.73	4534.75	311.3
1007.5 TO 1014.50	244	160	84	128980	310004	299450
993.5 TO 1007.50	1795	691	1105	1189591	1547984	1682029
985.0 TO 993.50	1595	537	1057	1064568	1371371	1503321
974.6 TO 985.50	1529	485	1044	1103883	1114197	1309460

TABLE 2.6
INTAKE STRUCTURE MASS PROPERTIES

Node #	Elev. (FT)	M _x (K-S ² /FT)	M _y (K-S ²)/FT	M _z (K-S ²)/FT	M _{xx} K-S ² -FT	M _{yy} K-S ² -FT	M _{zz} K-S ² -FT
82	1035.63	4.43	4.43	4.43	14110	4130.1	5525.2
72	1024.50	5.81	5.81	5.81	2638.3	7570.5	16122.0
52	1007.50	94.00	94.90	94.00	47082.7	74408.4	114197.2
42	993.50	100.00	100.00	100.00	57911.7	80748.7	136760.7
32	985.00	78.50	78.50	78.5	51451.8	65129.9	115558.3
Basemat	974.67	279.5	279.50	279.50	153548.8	144719.5	289486.3
TOTAL		562.24	562.24	562.24			

TABLE 2.7
INTAKE STRUCTURE
FIXED-BASE FREQUENCIES AND MODES

Mode No.	Frequency (Hz)	Cumulative Mass Participation Factors (%)			Description of Mode ^{1,2}
		X-Dir. (NS)	Y-Dir. (EW)	Z-Dir (V)	
1	5.6	4	0	0	X @ SF
2	7.9	4	4	0	Y @ SF
3	8.4	4	4	0	Torsion @ SF
4	12.9	5	4	0	X @ SF
5	18.5	5	5	0	Y @ SF
6	20.6	5	5	0	Torsion @ SF
7	22.3	88	5	0	X (Main)
8	30.8	90	75	1	Y (Main)
9	36.3	93	88	1	Y
10	47.6	98	89	34	Vertical (Main)

(1) X = NS Direction
 Y = EW Direction
 SF = Steel Frame

Note: Only first ten modes listed. Twenty modes were used in the analysis, with cumulative MPFs of over 90% in each direction

TABLE 4.1
FREQUENCY POINTS FOR IN-STRUCTURE RESPONSE SPECTRA

0.2000	0.3000	0.4000	0.5000	0.6000	0.7000	0.8000	0.9000	1.0000	1.1000
1.2980	1.3000	1.4000	1.5000	1.6000	1.7000	1.8000	1.9000	2.0000	2.1000
2.2000	2.3000	2.4000	2.5000	2.6000	2.7000	2.8000	2.9000	3.0000	3.1500
3.3000	3.4500	3.6000	3.8000	4.0000	4.2000	4.4000	4.6000	4.8000	5.0000
5.2500	5.5000	5.7500	6.0000	6.2500	6.5000	6.7500	6.9000	7.0000	7.2500
7.5000	7.7500	8.0000	8.5000	9.0000	9.5000	10.0000	10.5000	11.0000	11.5000
11.8000	12.0000	12.5000	13.0000	13.3000	13.5000	14.0000	14.5000	15.0000	15.4000
16.0000	16.3000	17.0000	18.0000	19.7000	20.0000	21.3000	21.8000	22.0000	25.0000
25.6000	28.0000	29.6000	31.0000	33.5000	34.0000	35.0000	40.0000		

TABLE 4.2
AUXILIARY BUILDING CONTAINMENT INTERNAL STRUCTURE
ELEVATIONS FOR RESPONSE SPECTRA GENERATION

AUXILIARY BUILDING MODEL		INTERNAL STRUCTURE MODEL		CONTAINMENT SHIELD MODEL	
Elevation (ft.)	Location	Elevation (ft.)	Location	Elevation (ft.)	Location
989	Basemat	994	Basemat	991	Basemat
1007	Ground Floor	1013	Ground Floor	1045	Midheight of Shell
1025	Operating Floor	1038.5	Mezzanine Floor	1099	Polar Crane Support
1036	Operating Floor	1045	Operating Floor	1118.2	Dome and Ring
1044	Roof 1	1056.5	Operating Floor		
1057	Roof 2				
1083	Roof 3				

INTAKE STRUCTURE

Elevation (ft.)	Location
985	Mezzanine Floor
1007.5	Operating Floor
1024.5	Crane Level




FIGURE 2.1 DESIGN BASIS HOUSNER GROUND RESPONSE SPECTRA FOR FORT CALHOUN STATION, UNIT 1




FIGURE 2.2 COMPARISON OF DESIGN BASIS GROUND RESPONSE SPECTRUM AND ENVELOPING TIME HISTORY RESPONSE SPECTRUM, NORTH-SOUTH DIRECTION, 2% DAMPING




FIGURE 2.3 COMPARISON OF DESIGN BASIS GROUND RESPONSE SPECTRUM AND ENVELOPING TIME HISTORY RESPONSE SPECTRUM, NORTH-SOUTH DIRECTION, 5% DAMPING




FIGURE 2.4 COMPARISON OF DESIGN BASIS GROUND RESPONSE SPECTRUM AND ENVELOPING TIME HISTORY RESPONSE SPECTRUM, NORTH-SOUTH DIRECTION, 7% DAMPING




FIGURE 2.5 COMPARISON OF DESIGN BASIS GROUND RESPONSE SPECTRUM AND ENVELOPING TIME HISTORY RESPONSE SPECTRUM, EAST-WEST DIRECTION, 2% DAMPING




FIGURE 2.6 COMPARISON OF DESIGN BASIS GROUND RESPONSE SPECTRUM AND ENVELOPING TIME HISTORY RESPONSE SPECTRUM, EAST-WEST DIRECTION, 5% DAMPING




FIGURE 2.7 COMPARISON OF DESIGN BASIS GROUND RESPONSE SPECTRUM AND ENVELOPING TIME HISTORY RESPONSE SPECTRUM, EAST-WEST DIRECTION, 7% DAMPING




FIGURE - 3 COMPARISON OF DESIGN BASIS GROUND RESPONSE SPECTRUM AND ENVELOPING TIME HISTORY RESPONSE SPECTRUM, VERTICAL DIRECTION, 2% DAMPING




FIGURE 2.9 COMPARISON OF DESIGN BASIS GROUND RESPONSE SPECTRUM AND ENVELOPING TIME HISTORY RESPONSE SPECTRUM, VERTICAL DIRECTION, 5% DAMPING




FIGURE 2.10 COMPARISON OF DESIGN BASIS GROUND RESPONSE SPECTRUM AND ENVELOPING TIME HISTORY RESPONSE SPECTRUM, VERTICAL DIRECTION, 7% DAMPING





FIGURE 2.11 SKETCH OF AUXILIARY BUILDING/CONTAINMENT/INTERNAL STRUCTURE MATHEMATICAL MODEL




FIGURE 2.12 SKETCH OF INTAKE STRUCTURE MATHEMATICA[®] MODEL,




FIGURE 4.1 COMPARISON OF FREE-FIELD VERSUS AUXILIARY/CONTAINMENT/INTERNAL STRUCTURE BASEMAT RESPONSE SPECTRUM - HORIZONTAL DIRECTION, 2% DAMPING




FIGURE 4.2 COMPARISON OF FREE-FIELD VERSUS AUXILIARY/CONTAINMENT/INTERNAL STRUCTURE BASEMAT RESPONSE SPECTRUM - VERTICAL DIRECTION, 2% DAMPING




FIGURE 4.3 COMPARISON OF UPPER BOUND AND LOWER BOUND RAW RESPONSE SPECTRA, AUXILIARY/CONTAINMENT/INTERNAL STRUCTURE, NORTH SOUTH DIRECTION, 2% DAMPING




FIGURE 4.4 COMPARISON OF UPPER BOUND AND LOWER BOUND RAW RESPONSE SPECTRA, AUXILIARY/CONTAINMENT/INTERNAL STRUCTURE, EAST-WEST DIRECTION, 2% DAMPING




FIGURE 4.5 COMPARISON OF FREE-FIELD VERSUS INTAKE STRUCTURE EL. 985' RESPONSE SPECTRUM - HORIZONTAL DIRECTION, 2% DAMPING






FIGURE 4.6 COMPARISON OF FREE-FIELD VERSUS INTAKE - 'RUCTURE EL. 985' RESPONSE SPECTRUM - VERTICAL DIRECTION, 2% DAMPING

APPENDIX A


**FORT CALHOUN STATION, UNIT 1
IN-STRUCTURE RESPONSE SPECTRA
AUXILIARY BUILDING/ CONTAINMENT STRUCTURE/
INTERNAL STRUCTURE
SAFE SHUTDOWN EARTHQUAKE
(48 pages; this cover page not included)**




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 989'-0" AUXILIARY BUILDING		
SAFE SHUTDOWN EARTHQUAKE BY ADP DATE 7-1-92	CHRD Ams DATE 7/1/92	STRETCH NO.	




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 989'-0" AUXILIARY BUILDING	
BY ADL DATE 7-1-92 CHKD AWD DATE 07/01/02	SKETCH NO. 1004	




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		SAFE SHUTDOWN EARTHQUAKE		VERTICAL SPECTRA AT ELEVATION 989'-0" AUXILIARY BUILDING		
BY ADG	DATE 7-1-92	CHRD ADG	DATE 07/01/92	SKECH NO.	REV.	




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1007'-0" AUXILIARY BUILDING	
SAFE SHUTDOWN EARTHQUAKE		SKETCH NO.	REV.
BY AME DATE 7-1-92	CHKD BY (initials) DATE 6/17/92		:




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1 SAFE SHUTDOWN EARTHQUAKE	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1007'-0" AUXILIARY BUILDING	
BY AME DATE 7-1-92	CHRD AW DATE 07/01/92	SKETCH NO. REV.




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		VERTICAL SPECTRA AT ELEVATION 1007'-0" AUXILIARY BUILDING		
SAFE SHUTDOWN EARTHQUAKE	BY PPE DATE 7-1-92	CHKD BY DATE 07/01/92	SKETCH NO.	





OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1025'-0" AUXILIARY BUILDING		
SAFE SHUTDOWN EARTHQUAKE BY [Signature] DATE 7-1-92	CHND [Signature] DATE 7-1-92	SKETCH NO.	REV.



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1025'-0" AUXILIARY BUILDING		
SAFE SHUTDOWN EARTHQUAKE	BY PTE DATE 7-1-92	CHND Amd DATE 07/01/92	SKETCH NO.	



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	VERTICAL SPECTRA AT ELEVATION 1025'-0" AUXILIARY BUILDING		
SAFE SHUTDOWN EARTHQUAKE BY AME DATE 7-1-92 CHRD AME DATE 07/01/92	SKETCH NO.	REV.	




HORIZONTAL (NORTH-SOUTH) DIRECTION
AT ELEVATION 1036'-0"
AUXILIARY BUILDING


SKETCH NO.

REV. D-77C DATE 7-1-92 CRED. AND DATE 1/11/72


OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1
SAFE SHUTDOWN EARTHQUAKE




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1036'-0" AUXILIARY BUILDING	
SAFE SHUTDOWN EARTHQUAKE		
By [Signature] DATE 7-1-92	CHRD Am. DATE 07/01/92	SKETCH NO. [] REV. []




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		SAFE SHUTDOWN EARTHQUAKE		VERTICAL SPECTRA AT ELEVATION 1036'-0" AUXILIARY BUILDING	
BY <i>mc</i>	DATE 7-1-92	CHKD <i>ATW</i>	DATE 07/01/92	SKETCH NO.	REV.







OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1044'-0" AUXILIARY BUILDING		
SAFE SHUTDOWN EARTHQUAKE BY MDC DATE 7-1-92 CHRD AND DATE 07/01/92	SKETCH NO.	REV.	



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1044'-0" AUXILIARY BUILDING	
SAFE SHUTDOWN EARTHQUAKE		
BY <i>[Signature]</i> DATE 7-1-92	CHKD <i>[Signature]</i> DATE 7/1/92	SKETCH NO. <i>[Signature]</i> REV. <i>[Signature]</i>



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	VERTICAL SPECTRA AT ELEVATION 1044'-0"	REV.
SAFE SHUTDOWN EARTHQUAKE	AUXILIARY BUILDING	
BY JMC DATE 7-1-92 CHRD Awd DATE 07/01/72	SKETCH NO.	




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1957'-0" AUXILIARY BUILDING		
SAFE SHUTDOWN EARTHQUAKE	SKETCH NO.	REV.		


BY *me* DATE 7-1-92 CHKD AND DATE 07/01/92

SKETCH NO.


REV.




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1057'-0" AUXILIARY BUILDING	
SAFE SHUTDOWN EARTHQUAKE		
BY <i>A.M.C.</i> DATE 7-1-92	CHKD <i>A.M.C.</i> DATE 07/01/72	SKETCH NO. _____ REV. _____




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	VERTICAL SPECTRA AT ELEVATION 1057'-0" AUXILIARY BUILDING		
SAFE SHUTDOWN EARTHQUAKE BY ANE DATE 7-1-92 CMKD MM DATE 07/01/92	SKETCH NO.	REV.	




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1083'-0" AUXILIARY BUILDING		
SAFE SHUTDOWN EARTHQUAKE BY [Signature] DATE 7-1-92	CHKD BY [Signature] DATE 07/01/92	BREACH NO. [] REV. []	



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1083'-0" AUXILIARY BUILDING	
SAFE SHUTDOWN EARTHQUAKE BY AND DATE 7-1-92 CHRO AND DATE 07/01/92	SKETCH NO. REV.	



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1 SAFE SHUTDOWN EARTHQUAKE	VERTICAL SPECTRA AT ELEVATION 1083'-0" AUXILIARY BUILDING	
BY <i>[Signature]</i> DATE 7-1-92	CHEK'D <i>[Signature]</i> DATE 07/01/92	SKETCH NO. <i>[Redacted]</i> REV. <i>[Redacted]</i>



OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1


SAFE SHUTDOWN EARTHQUAKE


BY RPTC DATE 7-1-92 CHRD AMN DATE 07/01/92

HORIZONTAL (NORTH-SOUTH) DIRECTION
AT ELEVATION 994'-0"
INTERNAL STRUCTURE


SKETCH NO.

REV.







OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 994'-0" INTERNAL STRUCTURE		
SAFE SHUTDOWN EARTHQUAKE	SKETCH NO.	REV.		
BY ERIC DATE 7-1-92	CHKD BY DATE 07/01/92			



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		VERTICAL SPECTRA AT ELEVATION 994'-0" INTERNAL STRUCTURE	
SAFE SHUTDOWN EARTHQUAKE			
By D.D.C.	DATE 7-1-92	CHENG P-W	DATE 6-7-91 / 12




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1013'-0" INTERNAL STRUCTURE		
SAFE SHUTDOWN EARTHQUAKE	BY <i>[Signature]</i> DATE 7-1-91	CHND BY <i>[Signature]</i> DATE 07/01/91	STRETCH NO. <i>[Signature]</i>	





OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1013'-0" INTERNAL STRUCTURE	
SAFE SHUTDOWN EARTHQUAKE		REV.	
BY Ane	DATE 7-1-92	CHKD BY	DATE 07/01/92
		SKETCH NO.	







OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	VERTICAL SPECTRA AT ELEVATION 1013'-0" INTERNAL STRUCTURE	
SAFE SHUTDOWN EARTHQUAKE		
BY DPC DATE 7-1-92 DRAWN DATE 07/01/92	SKETCH NO.	REV.




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1038'-6" INTERNAL STRUCTURE	
SAFE SHUTDOWN EARTHQUAKE		
BY DTM DATE 7-1-92	CHMD AWW DATE 07/01/92	SKETCH NO. : REV. :





OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1038'-6" INTERNAL STRUCTURE		
SAFE SHUTDOWN EARTHQUAKE	BY <i>[Signature]</i> DATE 7-1-92	CHRD DRAW DATE 07/01/92	





OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	VERTICAL SPECTRA AT ELEVATION 1038'-6" INTERNAL STRUCTURE	
SAFE SHUTDOWN EARTHQUAKE		
BY A722 DATE 7-1-92 CHKD MM DATE 7/1/12	STRETCH NO.	REV. 1





OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1045'-0" INTERNAL STRUCTURE	
SAFE SHUTDOWN EARTHQUAKE		
BY AME DATE 7-1-92 CHRD AME DATE 6/1/1/92	SKETCH NO. : REV. :	




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1 SAFE SHUTDOWN EARTHQUAKE	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1045'-0" INTERNAL STRUCTURE	
BY AMT DATE 7-1-92 CHRD AR DATE 07/01/92	SKETCH NO	REV




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	VERTICAL SPECTRA AT ELEVATION 1045'-0" INTERNAL STRUCTURE	
SAFE SHUTDOWN EARTHQUAKE		
BY <i>[Signature]</i> DATE 7-1-92	CHKD <i>[Signature]</i> DATE 07/01/92	SKETCH NO. <i>[Signature]</i> REV. <i>[Signature]</i>





OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1056'-6" INTERNAL STRUCTURE		
SAFE SHUTDOWN EARTHQUAKE	BY PME DATE 7-1-92	CHKD AND DATE 7/01/12	



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1056'-6" INTERNAL STRUCTURE	
SAFE SHUTDOWN EARTHQUAKE		
BY <i>AHC</i> DATE 7-1-92	CHKD <i>AHC</i> DATE 7-1-92	STRETCH NO. <i>1</i>





OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1 SAFE SHUTDOWN EARTHQUAKE	VERTICAL SPECTRA AT ELEVATION 1056'-6" INTERNAL STRUCTURE	
BY <u>APM</u> DATE 7-1-92	CMD A <u>AMM</u> DATE 07/01/92	SKETCH NO. <u> </u> REV. <u> </u>




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 991'-0" CONTAINMENT STRUCTURE		
SAFE SHUTDOWN EARTHQUAKE BY ADP DATE 7-1-92 CHND AWW DATE 07/11/92	SKETCH NO.	REV.	

A37 oE A48



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 991'-0" CONTAINMENT STRUCTURE			
SAFE SHUTDOWN EARTHQUAKE	BY <i>[Signature]</i> DATE 7-1-92	CHKD BY <i>[Signature]</i> DATE 07/01/92	SKETCH NO.:	REV.:




OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1

SAFE SHUTDOWN EARTHQUAKE

BY AME DATE 7-1-92


CHRD BY AME DATE 07/01/92


VERTICAL SPECTRA
AT ELEVATION 991'-0"
CONTAINMENT STRUCTURE





REVISION NO.


REV:





OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1045'-0" CONTAINMENT STRUCTURE		
SAFE SHUTDOWN EARTHQUAKE		SKETCH NO.	REV.	
BY ADR	BATE 7-1-92	CHRD AWD DATE 07/01/92		




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1045'-0" CONTAINMENT STRUCTURE	
SAFE SHUTDOWN EARTHQUAKE BY PDC DATE 7-1-92 CHND A/E DATE 7/1/72	SKETCH NO. JMV	





OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	VERTICAL SPECTRA AT ELEVATION 1045'-0" CONTAINMENT STRUCTURE	
SAFE SHUTDOWN EARTHQUAKE		
By AME DATE 7-1-92 CHMB Ame DATE 07/01/92	SKETCH NO. _____	Page _____




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1099'-0" CONTAINMENT STRUCTURE		
SAFE SHUTDOWN EARTHQUAKE			
BY <u>AMC</u> DATE 7-1-92	CHKD BY <u>AMC</u> DATE 07/01/92	SKETCH NO.	REV.








OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1099'-0" CONTAINMENT STRUCTURE	
SAFE SHUTDOWN EARTHQUAKE		
BY APAC DATE 7-1-92	CHRD Ann DATE 07/01/92	SKETCH NO. : REV. :





OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		VERTICAL SPECTRA AT ELEVATION 1099'-0" CONTAINMENT STRUCTURE	
SAFE SHUTDOWN EARTHQUAKE			
BY ADP DATE 7-1-92	CHND AWW DATE 07/01/92	SKETCH NO.	TRV



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1118'-2" CONTAINMENT STRUCTURE	
SAFE SHUTDOWN EARTHQUAKE		
BY <u>ATM</u> DATE 7-1-92	CHKD <u>AMW</u> DATE 7/01/92	SKETCH NO. : <u>REV. :</u>




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1 SAFE SHUTDOWN EARTHQUAKE	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1118'-2" CONTAINMENT STRUCTURE	
BY <u>APM</u> DATE <u>7-1-92</u>	CHKD BY <u>APM</u> DATE <u>07/01/92</u>	SKETCH NO. <u></u> REV. <u></u>



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	VERTICAL SPECTRA AT ELEVATION 1118'-2" CONTAINMENT STRUCTURE		
SAFE SHUTDOWN EARTHQUAKE	BY R.P.M. DATE 7-1-92	CHKD BY M.W. DATE 07/01/93	SKETCH NO. REV.
			

APPENDIX B

**FORT CALHOUN STATION, UNIT 1
IN-STRUCTURE RESPONSE SPECTRA
INTAKE STRUCTURE
SAFE SHUTDOWN EARTHQUAKE
(9 pages; this cover page not included)**



OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1

SAFE SHUTDOWN EARTHQUAKE


BY ADP DATE 7-17-92


CHND A-4 DATE 7/17/92

HORIZONTAL (NORTH-SOUTH) DIRECTION
AT ELEVATION 985'-0"
INTAKE STRUCTURE

SKETCH NO.

REV.





OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1

SAFF SHUTDOWN EARTHQUAKE


BY AME DATE 7-17-92 CHD BY AME DATE 7/17/92

HORIZONTAL (EAST-WEST) DIRECTION
AT ELEVATION 985'-0"
INTAKE STRUCTURE

SKETCH NO

REV





OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1

SAFE SHUTDOWN EARTHQUAKE


BY Ane DATE 7-17-92


CHND BY Mm DATE 7/17/92

VERTICAL SPECTRA
AT ELEVATION 985'-0"
INTAKE STRUCTURE


SKETCH NO

REV







OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1007'-6" INTAKE STRUCTURE		
SAFE SHUTDOWN EARTHQUAKE	SKETCH NO.	REV.	
BY AME DATE 7-17-92	CHKD BY DATE 7/17/92		



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1007'-6" INTAKE STRUCTURE		1st fl
SAFE SHUTDOWN EARTHQUAKE	BY Amc DATE 7-17-92	CHMB Amc DATE 7/17/92	
SKECH NO.			



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	VERTICAL SPECTRA AT ELEVATION 1007'-6" INTAKE STRUCTURE		PREV.
SAFE SHUTDOWN EARTHQUAKE	BY AAE DATE 7-17-92	CPWD BYN DATE 7/17/92	



OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1

SAFE SHUTDOWN EARTHQUAKE

BY

DATE

7-17-92

CHED


DATE


7/17/72

HORIZONTAL (NORTH-SOUTH) DIRECTION
AT ELEVATION 1024'-6"
INTAKE STRUCTURE


SKETCH NO.

REV.






OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1024'-6" INTAKE STRUCTURE		
SAFE SHUTDOWN EARTHQUAKE	BY ATC DATE 7-17-92	ENR'D BY DATE 7/12/92	STRETCH RD REV.




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	VERTICAL SPECTRA AT ELEVATION 1024'-6" INTAKE STRUCTURE	
SAFE SHUTDOWN EARTHQUAKE		
BY ADP DATE 7-17-92 CHND MN DATE 7/17/92	SKETCH NO. [REDACTED]	REV. [REDACTED]

APPENDIX C


**FORT CALHOUN STATION, UNIT 1
IN-STRUCTURE RESPONSE SPECTRA
AUXILIARY BUILDING/ CONTAINMENT STRUCTURE/
INTERNAL STRUCTURE
OPERATING BASIS EARTHQUAKE
(48 pages; this cover page not included)**



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 989'-0" AUXILIARY BUILDING	
OPERATING BASIS EARTHQUAKE		
BY APC DATE 7-17-92	CHND DATE 7/17/92	SKETCH NO. REV.



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 989'-0" AUXILIARY BUILDING		
OPERATING BASIS EARTHQUAKE			
BY AME DATE 7-17-92	ENR'D BY DATE 7/17/92	STRETCH NO	REV



OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1

OPERATING BASIS EARTHQUAKE


BY AME DATE 7-17-92


CHRD Ame DATE 7/17/92

SKETCH NO.

VERTICAL SPECTRA
AT ELEVATION 989'-0"
AUXILIARY BUILDING

REV:






OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	
OPERATING BASIS EARTHQUAKE	
BY AME DATE 7-17-92	CHED BY DATE 7/17/92


HORIZONTAL (NORTH-SOUTH) DIRECTION
AT ELEVATION 1007'-0"
AUXILIARY BUILDING

SKETCH NO.

REV.










OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	OPERATING BASIS EARTHQUAKE
BY Amc DATE 7-17-92	CHRD Amc DATE 7/17/92

VERTICAL SPECTRA
AT ELEVATION 1007'-0"
AUXILIARY BUILDING





OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1025'-0" AUXILIARY BUILDING		
OPERATING BASIS EARTHQUAKE			
BY DPL DATE 7-17-92	CHRD AND DATE 7/17/92	SKETCH NO.	REV.





OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1
OPERATING BASIS EARTHQUAKE
BY *[Signature]* DATE 7-17-92 | CHRB APPROVED DATE 7/17/92

HORIZONTAL (EAST-WEST) DIRECTION
AT ELEVATION 1025'-0"
AUXILIARY BUILDING


STRETCH ROD

REV F








OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	VERTICAL SPECTRA AT ELEVATION 1025'-0" AUXILIARY BUILDING	
BY Amc DATE 7-17-92 CHND BY Amc DATE 7/17/92	SKETCH NO. : REV. :	




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1036'-0" AUXILIARY BUILDING			
BY Ame	DATE 7-17-92	CHKD	DATE 7/17/92		SERIAL NO.







OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1044'-0" AUXILIARY BUILDING	
BY AME DATE 7-17-92 CHRD AND DATE 7/17/92	SKETCH NO. []	REV. []



OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1

OPERATING BASIS EARTHQUAKE


BY MTC DATE 7-17-92


CHRD MW DATE 7/17/92

HORIZONTAL (EAST-WEST) DIRECTION
AT ELEVATION 1044'-0"
AUXILIARY BUILDING

STRETCH NO.

TYP








OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1
OPERATING BASIS EARTHQUAKE
BY *[Signature]* DATE 7-17-92 [CHRD] BY *[Signature]* DATE 7/17/92


VERTICAL SPECTRA
AT ELEVATION 1044'-0"
AUXILIARY BUILDING

SKETCH NO. *[Signature]* DRAWN BY *[Signature]*













OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		VERTICAL SPECTRA AT ELEVATION 1057'-0" AUXILIARY BUILDING	
BY AME DATE 7-17-92	CHND BY ME DATE 7/17/92	SKETCH NO.	REV.







C21 of C48



OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1

OPERATING BASIS EARTHQUAKE


BY ANG DATE 7-17-92


CHND AND DATE 7/17/92

HORIZONTAL (NORTH-SOUTH) DIRECTION
AT ELEVATION 994'-0"
INTERNAL STRUCTURE


DRAWING NO.

REV.





C23 oE C48



OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1

OPERATING BASIS EARTHQUAKE


BY *[Signature]* DATE 7-17-12 CHMB *[Signature]* DATE 7/17/12

VERTICAL SPECTRA
AT ELEVATION 994'-0"
INTERNAL STRUCTURE


SHEET NO.

REV.






OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1013'-0" INTERNAL STRUCTURE	
OPERATING BASIS EARTHQUAKE		
BY AME DATE 7-17-92	COMD AME DATE 7-17-92	REV. 1




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION + ELEVATION 1883'-0" INTERNAL STRUCTURE		
OPERATING BASIS EARTHQUAKE	BY LINE DATE 7-17-92	CHMD A.W. DATE 7/17/92	


C26 oE C48





OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	VERTICAL SPECTRA AT ELEVATION 1013'-0" INTERNAL STRUCTURE		
OPERATING BASIS EARTHQUAKE BY Amec DATE 7-17-92 DRAWN AND DATE 7/17/12	SKETCH NO.	REV.	




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1038'-4" INTERNAL STRUCTURE	
OPERATING BASIS EARTHQUAKE			
BY /P/C	DATE 7-17-92	CONE	DATE 7/17/92 WITCH 800








OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1045'-0" INTERNAL STRUCTURE		
OPERATING BASIS EARTHQUAKE BY ANE DATE 7-17-92 CWD JMW DATE 7/17/92	SKETCH NO.	REV.	



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1045'-0" INTERNAL STRUCTURE	
OPERATING BASIS EARTHQUAKE			
BY AHC DATE 7-17-92	CHNG BYV DATE 7/17/92	SKETCH NO	REV







OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	
OPERATING BASIS EARTHQUAKE	
BY DMC DATE 7-17-92	CHND BY M. DATE 7/17/92


VERTICAL SPECTRA
AT ELEVATION 1045'-0"
INTERNAL STRUCTURE

SKETCH NO.


REV.








OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1056'-6" INTERNAL STRUCTURE	
OPERATING BASIS EARTHQUAKE		
BY DSE DATE 7-17-92 CHD BY DATE 7/17/92	SKETCH NO	REV



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	VERTICAL SPECTRA AT ELEVATION 1956'-6" INTERNAL STRUCTURE	
OPERATING BASIS EARTHQUAKE		
BY DMC DATE 7-17-72	CMD A/W DATE 7/17/72	SKETCH NO. REV.




OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1
OPERATING BASIS EARTHQUAKE


BY DATE 7-17-92 CHND BY DATE 7/17/92

HORIZONTAL (NORTH-SOUTH) DIRECTION
AT ELEVATION 991'-0"
CONTAINMENT STRUCTURE


STRETCH NO.

REV.





OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 991'-0" CONTAINMENT STRUCTURE		
BY: JMC DATE 7-17-92	CHED Rev'd DATE 7/17/92	SKETCH NO.	REV.



OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1


OPERATING BASIS EARTHQUAKE

BY AME DATE 7-17-92


CHND AME DATE 7/17/92

VERTICAL SPECTRA
AT ELEVATION 991'-0"
CONTAINMENT STRUCTURE








OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1045'-0" CONTAINMENT STRUCTURE		
BY DPLC	DATE 7-17-92	CHND BY M.D. DATE 7/17/92	SKETCH NO.	




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1045'-0" CONTAINMENT STRUCTURE	
OPERATING BASIS EARTHQUAKE			
BY DPC	DATE 7-17-92	CMB	AMW DATE 7/17/92
		SKETCH NO.	REV.







OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1 OPERATING BASIS EARTHQUAKE	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1099'-0" CONTAINMENT STRUCTURE	
BY APE DATE 7-17-92 LCRD AND DATE 7/17/92	STRETCH NO. REV.	

C43 of C48




OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1000'-0" CONTAINMENT STRUCTURE		
OPERATING BASIS EARTHQUAKE			
BY DATE 7-17-92	CHD BY DATE 7/17/92	REF ID: 17.0	REV. V





OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1118'-2" CONTAINMENT STRUCTURE		
OPERATING BASIS EARTHQUAKE BY MRC DATE 7-17-92	CHED BY DATE 1/17/92	SKETCH NO	



OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1

OPERATING BASIS EARTHQUAKE


BY AME DATE 7-17-92

CMMB AND DATE 7/17/92

DRIVEN BY


HORIZONTAL (EAST-WEST) DIRECTION
AT ELEVATION 1118'-2"
CONTAINMENT STRUCTURE








APPENDIX D

**FORT CALHOUN STATION, UNIT 1
IN-STRUCTURE RESPONSE SPECTRA
INTAKE STRUCTURE
OPERATING BASIS EARTHQUAKE
(9 pages; this cover page not included)**












OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (NORTH-SOUTH) DIRECTION AT ELEVATION 1007'-6" INTAKE STRUCTURE		
BY AME DATE 7-17-92 CHED AME DATE 7/17/72	STRETCH RD	TRIV	



OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1	HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1007'-6" INTAKE STRUCTURE		
BY AME DATE 7-17-92	CHRD AME DATE 7/17/92	STRETCH NO	REV





OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1


OPERATING BASIS EARTHQUAKE

BY ADP DATE 7-17-92

CHD Ams DATE 7/17/92


HORIZONTAL (NORTH-SOUTH) DIRECTION
AT ELEVATION 1024'-6"
INTAKE STRUCTURE





OMAHA PUBLIC POWER DISTRICT FORT CALHOUN STATION, UNIT 1		HORIZONTAL (EAST-WEST) DIRECTION AT ELEVATION 1024'-6" INTAKE STRUCTURE	
REV 10C DATE 7-17-92	CHM# Amw DATE 7/17/72	REVISION NO.	REV





OMAHA PUBLIC POWER DISTRICT
FORT CALHOUN STATION, UNIT 1

OPERATING BASIS EARTHQUAKE


BY P.M.C. DATE 7-17-92

CHND A.W. DATE 7/17/92

SKETCH NO.

VERTICAL SPECTRA
AT ELEVATION 1024'-6"
INTAKE STRUCTURE

REV.



APPENDIX E

**FORT CALHOUN STATION, UNIT 1
STRUCTURAL PROPERTIES VARIATION STUDIES
(6 pages; this cover page not included)**

E1.0 INTRODUCTION

This Appendix describes the parametric analyses performed to assess the effect of variation in structural properties on the in-structure response spectra developed for Fort Calhoun Station.

E2.0 ANALYSIS MODEL

The analysis model used for the parametric evaluations consisted of a three-dimensional soil-springs soil-structure interaction model and is briefly described below.

The soil spring constants used to represent the site/foundation characteristics correspond to the design basis constants contained in the plant's USAR (Reference E-1). The soil spring constants in the plant's USAR are based on results from in-situ tests of the combined soil-pile system, performed at the Fort Calhoun site at the time of plant construction.

The structural properties in the SSI model correspond to the updated three-dimensional model of the Auxiliary Building/Containment/ Internal Structure developed as part of the Alternate Seismic Criteria (ASC), and used in the ASC SASSI/CLASSI SSI calculations (Reference E-2). Thus, the structural model is an updated three-dimensional representation of the Fort Calhoun structures.

Two SSI analysis were performed using the same soil-spring constants, but varying the stiffness properties of the superstructure. The first analysis used design-basis values to calculate the elastic shear stiffness of the building walls. In the second analysis, the elastic stiffness values are multiplied by a factor of 0.6. This factor represents a reasonable range of structural stiffness degradation, and is based, in part, on review, by others, of shear wall test data (Reference E-3). The actual range of variation is likely to be less, because stiffness degradation due to cracking is counteracted by the stiffness increase due to concrete aging.

The SSI analyses were performed using the north-south free-field time history used in the SASSI/CLASSI ASC SSI evaluations (Reference E-2). The model and analyses results are described in Reference E-4.

E3.0 ANALYSES RESULTS

Results were generated in the form of response spectra at various locations throughout the Auxiliary Building/Containment/Internal structure model. These are shown in Figures E-3.1 through E-3.4.

Comparison of in-structure response spectra with and without variation of structural stiffness properties indicates that relatively large changes in structural-related stiffness causes only a minor effect on the overall SSI system response. This is because the response for a soil site such as Fort Calhoun's is dominated by the coupled soil-structure frequency.

E4.0 SUMMARY

This appendix describes the parametric evaluations performed to assess the effects of changes in structural stiffness properties. A soil-springs model is used for the SSI evaluations. The model of the building structures is the detailed three-dimensional model used in the ASC SSI evaluations. Results of the analyses indicate that relatively large variation in structural stiffness properties has a negligible effect on the in-structure response spectra for Fort Calhoun.

E5.0 REFERENCES

- E-1 Updated Safety Analysis Report (USAR) for Fort Calhoun Station, Unit 1, Revision 7/87.
- E-2 "Generation of In-Structure Response Spectra for Fort Calhoun Station, Unit 1". Report Prepared for the Nuclear Regulatory Commission by Omaha Public Power District, January 1989. (ABB Impell Report No.01-1390-1711, Rev.0)
- E-3 Moehle, J. P., Sozen, M. A., Tang, H. T. "Concrete Wall Stiffness: Calculation Versus Measurement". Paper IX/2 presented at the Third Symposium on Current Issues Related to Nuclear Power Plant Structures, Equipment and Piping. December 1990.
- E-4 ABB Impell Corporation Calculation: "Structural Stiffness Properties Variation Study". Calculation No. 0139-00378-03, Rev.0, Project 0139-00378, April 1992.




FIGURE E-3.1 COMPARISON OF RESPONSE SPECTRA (5% DAMPING) ELASTIC STIFFNESS VS 0.6 ELASTIC STIFFNESS,
ELEV. 1044 FT AUXILIARY BUILDING




FIGURE E-3.2 COMPARISON OF RESPONSE SPECTRA (5% DAMPING) ELASTIC STIFFNESS VS 0.6 ELASTIC STIFFNESS,
ELEV. 1083 FT AUXILIARY BUILDING




FIGURE 7-3.3 COMPARISON OF RESPONSE SPECTRA (5% DAMPING) ELASTIC STIFFNESS VS 0.6 ELASTIC STIFFNESS, ELEV. 1056 FT INTERNAL STRUCTURE




FIGURE E-3.4 COMPARISON OF RESPONSE SPECTRA (2% DAMPING) ELASTIC STIFFNESS VS 0.6 ELASTIC STIFFNESS,
ELEV. 1118 FT CONTAINMENT BUILDING

APPENDIX F

**FORT CALHOUN STATION, UNIT 1
SOIL-STRUCTURE INTERACTION DAMPING STUDY**
(4 pages; not including this cover page)

F1.0 INTRODUCTION

At the September 5, 1991 meeting with the NRC Staff, OPPD was requested to provide clarification on how radiation damping is considered in the SSI analysis methodology. Specifically, OPPD was requested to estimate the amount of radiation damping due to the piles and to clarify that the contribution of the basemat impedance is not added to the pile impedance (Open Item 4b, Reference F-1). This Appendix describes the parametric soil-structure interaction (SSI) analysis performed to address this open item.

F2.0 RADIATION DAMPING: ANALYSIS MODEL AND RESULTS

To estimate the amount of radiation damping in the Fort Calhoun soil-pile foundation system, as calculated by the SASSI/CLASSI model used for the Alternate Seismic Criteria (ASC) SSI calculations, a free-vibration analysis was performed. The SSI analysis model used corresponds to the "best estimate" case model described in Reference F-1. In this model best estimate soil properties were used and a SASSI model of the pile-foundation system was developed to generate impedance functions. The SASSI-generated impedance functions are combined with the dynamic properties of the superstructure and the input time history to produce structural responses throughout the structure using the CLASSI program.

The analysis approach consisted of applying a very short duration (0.2 seconds) acceleration pulse to the model and determining the free-vibration response time history at the basemat location. The total damping in the system was estimated from the logarithmic decay of the basemat response by using the following standard expression:

$$\xi = \frac{a_n - a_{n+1}}{2\pi a_{n+1}} \times 100$$

The decay function of the response at the basemat location is shown in Figure F2.1. This response and expression (1) are used to calculate the total damping in the SSI system. The estimated total damping as given by expression (1) is 13.1%. Assuming that the total damping is the sum of the radiation and material portions, the radiation damping portion can be estimated by subtraction of the material damping from the total damping. The average material damping from the soil column analysis is 6.3% (Reference F-1).

damping due to actual embedment has not been considered (the analysis model is surface founded). The free-vibration analysis and results are documented in Reference F-2.

F3.0 IMPEDANCE COMPUTATION

As described in the main body of this report, the analysis model used for impedance computation is a three dimensional SASSI model. This model incorporates the site configuration, layering and soil properties as well as the pile system configuration and properties. Separate SASSI models were developed for the Auxiliary/Containment/Internal Structure and the Intake Structure. The basemat in these SASSI models is not explicitly modeled, but is considered rigid for purposes of condensing the entire pile-foundation system to a 6 x 6 matrix (at each frequency) which characterizes the force-displacement relationships of the foundation system. Thus, impedance contribution from the basemat is conservatively neglected and therefore pile impedance is not added to the basemat impedance. The approach used for impedance computation considers that the basemat, over time, may separate from the soil surface.

F4.0 SUMMARY

This appendix describes the analytical study performed to determine the amount of radiation damping in the SSI model used to develop in-structure response spectra for Fort Calhoun. Based on free-vibration analysis results, the total critical damping ratio in the SSI system is estimated at 13.1%. Since material damping ratio is approximated as 6.3%, the radiation damping portion is estimated to be 6.8% of critical.

In addition, the modeling approach used for computation of impedance functions conservatively neglects the impedance contribution from the basemat and is based only on the pile contribution, i.e.: the basemat impedance is not added to the pile impedance.

F5.0 REFERENCES

- F-1 "Generation of In-Structure Response Spectra for Fort Calhoun Station, Unit 1". Report Prepared for the Nuclear Regulatory Commission by Omaha Public Power District, January 1989. (ABB Impell Report No.01-1390-1711, Rev.0)

F-2 ABB Impell Corporation Calculation: "Radiation Damping Study".
Calculation No. FV-1, Rev.0, Project 0139-00378, April 1992.






FIGURE F-2.1 FREE VIBRATION RESPONSE AT BASEMAT ELEVATION AUXILIARY/CONTAINMENT INTERNAL STRUCTURE SSI MODEL

LIC-92-016R

ENCLOSURE 4

SURVEILLANCE TEST

SE-ST-CONT-001

4.0 EQUIPMENT LIST

4.1 Tools

- Feeler Gauge
- Flashlight
- 6-foot folding rule or tape measure
- Binoculars (optional)
- Camera (optional)

4.2 Parts

None required

5.0 PRECAUTIONS AND LIMITATIONS

- 5.1 A radiation work permit (RWP) shall be issued to cover work in radiation controlled areas.
- 5.2 Follow precautions and instructions stated on the RWP.
- 5.3 Follow recommendations in OPPD Safety Manual.
- 5.4 All anomalies and deficiencies shall be reported immediately to the immediate Supervisor, the System Engineer, the Shift Supervisor, and noted on the Comment Sheet/Chronological Log. An immediate check shall be made to verify Limiting Conditions for Operation, per Technical Specifications, have not been exceeded.
- 5.5 If required by the immediate Supervisor, an Incident Report shall be initiated to report any anomalies or deficiencies. The Station Incident Report number shall be recorded on the Comment Sheet/Chronological Log.
- 5.6 No maintenance shall be conducted within this Surveillance Test, other than that specifically directed by this procedure.
- 5.7 A Maintenance Work Request (MWR) shall be initiated to correct any reported deficiency. The MWR number shall be referenced on the Comment Sheet/Chronological Log.
- 5.8 If satisfactory results cannot be achieved during performance of this procedure, notify immediate Supervisor and proceed as directed.

CONTAINMENT INSPECTION

SAFETY RELATED

2-25-901.0 PURPOSE

- 1.1 The purpose of this Surveillance Test is to obtain visual evidence of any significant structural deterioration of the accessible interior and exterior surfaces of the containment structure.
- 1.2 This test shall be performed prior to the Type A Test contained in Surveillance Test SS-ST-ILRT-0001 (ST-CONT-7-F.1), Containment Integrated Leak Rate Test.
- 1.3 This test satisfies the general inspection requirements of Technical Specification, Section 3.5, Item (2)b.

2.0 REferences

- 2.1 Technical Specification, Section 3.5, Item (2)b, Containment Tests-Pretest Requirements
- 2.2 PED Quality Procedure QP-8 (GSE Administrative Procedure A-8), Control of Deficiencies and Corrective Action
- 2.3 Surveillance Test SS-ST-ILRT-0001 (ST-CONT-7-F.1), Containment Integrated Leak Rate Test.
- 2.4 Drawing 11405-A-5, Primary Plant Basement Floor Plan (File No. 12162)
- 2.5 Drawing 11405-A-6, Primary Plant Ground Floor Plan (File No. 12163)
- 2.6 Drawing 11405-A-7, Primary Plant Intermediate Operating Floor Plans (File No. 12164)
- 2.7 Drawing 11405-A-8, Primary Plant Operating Floor Plan (File No. 12165)
- 2.8 Drawing 11405-A-10, Primary Plant Section A-A (File No. 12170)

3.0 DEFINITIONS

- * QCR# - Quality Control Inspection Report Number. This is a unique number assigned to an inspection report written by Quality Control Inspectors.

ST for SE

Sys Engr. Donal G Flory

FC/ST/57A

As Supv. Sys Engr. KL KringFile RAB

RO

2617 1252

SE-ST-CANT-001

QDP-20
Attachment 12QA Record
PERMANENT RETENTIONInitials: SLS Date 4/18/88Report No. 88-3711System or Component CONT. BLDG.

QC LOG


Document Number: ST. CONT. STitle: CONTAINMENT INSPECTIONLocation: Room 5Date/Time: 10-17-88Craftsman: PANDEINFORMATION

Type of Inspection:

VT PT MT UT/UT UT RT/I Mech. Elec. Surv.

Other:

<input checked="" type="checkbox"/>	[]	[]	[]	[]	[]	[]	[]	[]	[]	[]
NDE	Fire	Close	Hydro	Leak	Equip.	Person.	Oper-	Rad		
Report Barrier	Out			Check	Cals.	Qual.	ability	Waste		

Description: VERTICAL CRACK ABOUT 5' INSIDE FROM WALL AND
ABOUT 5' ABOVE FLOOR. CONTAINMENT ALSO HAS GENERAL
CRACKING. CREEP & SHRINKAGE IN VARIOUS LOCATIONS WIDTH 1/2"Acceptable Corrective Action Required Notified: Name: Sam Pande Date: 10-17-88 Time: 1600Corrective Action: ENVELOPE EVALUATION SUBMITTED 11/19/88 BY SLQC Log # 88-4176Acceptable

Sketch if Required:

Tom Maring 10-16-88
QC Inspector Date Time
Tom Sullivan
Lead QC Inspector
R/Sgt
Supervisor - Quality Control
Fox

- 5.9 If the procedure becomes contaminated or damaged, the "Lead Man" or designee shall ensure that all data, verifications, and other pertinent information is transcribed to another copy of the procedure, which will become the official copy.
- 5.10 All initials/signature shall be those of person(s) actually performing the work. The person completing the Surveillance Test shall sign and date.
- 5.11 All personnel participating in the performance of this test shall enter their printed name, signature and initials on the Surveillance Test Signature Sheet.
- 5.12 During the performance of this test, any step or data entry that is not applicable shall be identified by "N/A," initialed, dated and an explanation provided on the Comment Sheet/Chronological Log.
- 5.13 Performance of this procedure requires a knowledgeable member of System Engineering, Special Services or Design Engineering in the Civil or Structural disciplines.
- 5.14 Performance of this procedure requires one or more Quality Control Inspectors certified Level II in VT-3 inspection.

6.0 INITIAL CONDITIONSINITIALS/DATE

NOTE: Initial conditions need not be performed in numerical sequence.

- 6.1 Compare procedure revision date with current revision of Master Procedure.

Master Procedure Rev. No. RO

DY7
8-19-90, 2-19-90
DY7

INITIALS/DATE

NOTE: A review of previous containment inspections is necessary during the pre-job briefing. The last performance of this test shall be attached to this test for reference and comparison of conditions.

- 6.2 A prejob briefing has been conducted prior to the start of this test. ALL personnel participating in the performance of this test have read AND understand the procedure and have completed the Surveillance Test Signature Sheet.

SAB 12-20-90

- 6.3 Work is covered by Radiation Work Permit(s).

/ RWP No. 90-0164 (AUX SPECIAL)

DYI 12-19-90

RWP No. 90-0165 See Comments DA7 12-23-90

DA7 12-19-90

✓ RWP No. 90-0106 (AUX ROUTINE)

DA7 12-19-90

- 6.4 Radiation Protection (RP) notified in time to provide coverage for areas requiring full time coverage or entrance into "high" or "very high" radiation areas.

AA 12-19-90
RP

- 6.5 Security notified in time to allow entrance to areas or access to areas locked.

JC 12-19-90
Security

- 6.6 The Plant is in a Refueling Shutdown condition.

L 12/20/90
Shift Supv

- 6.7 Chemistry has performed an analysis of an air sample from the stressing gallery and has authorized personnel entry.

Confined Space Entry
Permit No. 1 N/A

Kirk 12/20/90
Chemistry

INITIALS/DATE

- 6.8 The Shift Supervisor has granted approval and released equipment necessary to perform this test.

L.L.S.
Shift Sup Sig

0837 12/05/80
Time Date

7.0 PROCEDURE

NOTE: The containment areas may be inspected in any logical sequence.

7.1 Perform a thorough visual inspection of all accessible surfaces (interior and external) of the containment structure as listed on the attached Containment Integrity Inspection Worksheets to discover evidence of any significant structural deterioration which may affect the containment's structural integrity or leak tightness. See Section 9.0 for complete definition.

7.2 Record the inspection results on the Containment Integrity Inspection Worksheet as follows:

7.2.1 If evidence of significant structural deterioration is discovered:

- A. Describe the found condition in the "Structural Condition" block next to the appropriate "Room/Area" on the Containment Integrity Inspection Worksheet.
- B. Record location of condition as to elevation and distance from a stationary, known object (wall, pump, penetration, etc.) in the "Location" block on the Containment Integrity Inspection Worksheet.
 - (1) Any sketches, photographs or supplemental sheets that are required shall have this procedure number, date of inspection, location, room/area and signature of the inspector.
 - (2) These items will be attached to this procedure and shall be retained as part of the test record.
- C. QC record the Quality Control Report Number (QCR#) in the "QCR/MWR" block on the Containment Integrity Inspection Worksheet for all inspections completed.

- 7.2.1 D. The Engineer shall initiate a Maintenance Work Request (MWR) and record the MWR number in the "QCR/MWR" block on the Containment Integrity Inspection Worksheet.
- E. QC and engineer shall initial and date for each inspection in the "Initials/Date" block on the Containment Integrity Inspection Worksheet.
- 7.2.2 If no evidence of structural deterioration is noted:
- A. Make a statement in the "Structural Condition" block on the Containment Integrity Inspection Worksheet that explains the results.
- B. "N/A" the "Location" block on the Containment Integrity Inspection Worksheet.
- C. "N/A" the MWR# in the "QCR/MWR" block on the Containment Integrity Inspection Worksheet.
- D. QC record the Quality Control Report Number (QCR#) in the "QCR/MWR" block on the Containment Integrity Inspection Worksheet for all inspections completed.
- E. QC and Engineer shall initial and date for each inspection in the "Initials/Date" block on the Containment Integrity Inspection Worksheet.

8.0 RESTORATION

INITIALS/DATE

8.1 If required, all evidence of structural degradation has been evaluated and, if required the appropriate corrective action has been initiated in accordance with PED Quality Procedure QP-8.

N/A DFT, 2-23-90
DFT See S. Bottom comments

8.2 If required, all corrective action resulting from this inspection has been reported in the Type "A" Test Report.

N/A DFT, 2-23-90
See 6 in comments

2617 1221
FORT CALHOUN STATION
SURVEILLANCE TEST

SE-ST-CONT-0001
PAGE 7 OF 18

INITIALS/DATE

- 8.3 The Shift Supervisor has been notified
the test is complete.

M. Mammen
Shift Sup Sig

1325 12-23-90
Time Date

- 8.4 The Surveillance Test Signature Sheet
contains the printed name, signature and
initials of all persons whose signature
or initials appears within this
procedure.

- 8.5 Test is complete

DST 12-23-90
Donald S. Ryb, 12-23-90
Signature

9.0 ACCEPTANCE CRITERIA

Any evidence of structural deterioration which may affect either the containment structural integrity or leak-tightness, as defined below, has been noted for evaluation.

Significant structural deterioration can be defined as measurable structural deterioration that when it is compared with past containment inspections, there is strong evidence of an increase structural deterioration which could affect the containment's structural integrity or leak-tightness. Evidence is cosmetic or superficial deterioration, unless determined by sound engineering judgement, is not considered to be significant structural deterioration.

10.0 TEST RECORD

This entire procedure, plus any sketches, photographs, the last performance of this test, and supplemental sheets acquired or developed during the conduct of this inspection.

11.0 REVIEW

11.1 The Supervisor-Systems Engineering is responsible for ensuring the completed Surveillance Test is reviewed in a timely manner and is forwarded to the Administrative department for retention.

11.2 The Supervisor-Systems Engineering must review and certify the adequacy of this Surveillance Test.

11.3 The Manager-PED Civil Engineering is responsible for comparing the results of this inspection with the results of the previous inspections to determine if an increase in the structural deterioration has occurred.

11.3.1 If the structural deterioration has increased, the Manager-PED Civil Engineering shall assure that corrective actions have been initiated.

ATTACHMENT 1
AREA LOCATION AND ENTRANCE REQUIREMENTS

Page 1 of 3

CAUTION

The atmosphere in confined spaces may not be suitable for human occupation.

NOTE: Protective clothing requirements can change daily.
Consult RP prior to entry into any room.

NOTE: RP may wish to monitor all activities. Consult RP prior to start for restrictions or special conditions.

NOTE: Call security at extension 6657 for entry into security locked areas. Follow instructions given by security officer.

ROOM/AREA

Room 20 El. 989'	Aux Bldg Non-RCA, downstairs from Room 57	Key Card Access Only
Room 57 El. 1013' - 1025'	Aux Bldg Non-RCA, Upper and Lower Levels, enter through Room 56W	Key Card Access Only
Room 81 El. 1036'	Aux Bldg Non-RCA, off Turbine Deck	Key Card Access Only
Room 65 El. 1009' - 1037'	Aux Bldg Non-RCA, Upper and Lower Levels, enter through Room 66 or through Room 65/DG1 Bay	Key Card, Security to unlock door
Room 66 El. 1009'	Aux Bldg Non-RCA enter outside roll up door or through Room 65	Key Card, Security to unlock door
Tendon Tunnel El. 991'	Enter through door in Room 22, or through floor hatch in Room 66	Key Card, Security to unlock door, Chemistry to take air samples
Outdoors West of Room 66	Ground Level and up, binoculars are suggested	Site Access
Aux Bldg Roof El. 1057' - 1083'	Enter through Room 82 (Mechanical Equipment Room off of Turbine Deck, ladder at M & 26 (1036)) NW corner	Key Card, Security to unlock hatch

ATTACHMENT 1
AREA LOCATION AND ENTRANCE REQUIREMENTS

Page 2 of 3

CAUTION

The atmosphere in confined spaces may not be suitable for human occupation.

NOTE: Protective clothing requirements can change daily.
Consult RP prior to entry into any room.

NOTE: RP may wish to monitor all activities. Consult RP prior to start for restrictions or special conditions.

NOTE: Call security at extension 6657 for entry into security locked areas. Follow instructions given by security officer.

ROOM/AREA

Containment Dome El. 1119'	Enter same as Aux Bldg Roof, go to ladder to Aux Bldg Roof over Fuel Handling, ladder to dome NW side of Containment	Key Card, Security to unlock hatch, and latter gates
Room 5 El. 989'	Aux Bldg RCA, enter through Corridor 4	RWP, High Rad Key, RP,
Room 12 El. 989'	Aux Bldg RCA, enter through Corridor 4	RWP, RP,
Room 13 El. 989'	Aux Bldg RCA, enter through Corridor 4	RWP, RP,
Room 14 El. 989'	Aux Bldg RCA, enter through Corridor 4	RWP, RP,
Room 15A El. 989'	Aux Bldg RCA, enter through Corridor 4	RWP, RP,
Room 58 El. 1012'	Aux Bldg RCA, Aux Bldg Side PAL	RWP, RP,
Room 59 El. 1007'	Aux Bldg RCA, enter through Corridor 26	RWP, RP,

2617 1225

FORT CALHOUN STATION
SURVEILLANCE TESTSE-ST-CONT-0001
PAGE 11 OF 18ATTACHMENT 1
AREA LOCATION AND ENTRANCE REQUIREMENTS

Page 3 of 3

NOTE: Protective clothing requirements can change daily.
Consult RP prior to entry into any room.

NOTE: RP may wish to monitor all activities. Consult RP prior to start for restrictions or special conditions.

NOTE: Call security at extension 6657 for entry into security locked areas. Follow instructions given by security officer.

ROOM/AREA

Room 60 El. 1007'	Aux Bldg RCA, enter through Corridor 26	RWP, RP,
Room 61 El. 1007'	Aux Bldg RCA, enter through Corridor 26	RWP, RP, High Rad Key
Room 62 El. 1007'	Aux Bldg RCA, enter through Room 69 (El. 1025') down ladder at T and 3b SW corner	RWP, RP, hatch key, Chemistry to take air samples
Room 69 El. 1025'	Aux Bldg RCA, upstairs	RWP, RP,
Room 71 El. 1025'	Aux Bldg RCA, enter through Room 69 SE corner	RWP, RP, I&C Cage Key
Containment El. 995'	Enter through PAL door, check in with senior RP at desk	RWP, RP, High Rad Key
Containment El. 1017'	Enter through P'L door, check in with senior RP at desk	RWP, RP, High Rad Key
Containment El. 1045'	Enter through PAL door, check in with senior RP at desk	RWP, RP, High Rad Key
Containment El. 1060'	Enter through PAL door, check in with senior RP at desk	RWP, RP, High Rad Key
Polar Crane El. 1099' to Apex	Binoculars are recommended	Respirator required if on Polar Crane walkway

2617 1226

CONTAINMENT INTEGRITY INSPECTION WORKSHEET

ROOM/AREA	STRUCTURAL CONDITION	LOCATION	QCR/MHR	INITIALS/DATE
Room 65 Ventilation Enclosure Dwg: 11405-A-6&7	No SIGNIFICANT STRUCTURAL DETERIORATION. APPEARANCE IS GOOD.	N/A	QCR# 90-0444 MHR# N/A	QC 12-21-90 ENGR
Room 66 Equipment Hatch Enclosure Dwg: 11405-A-7	No SIGNIFICANT STRUCTURAL DETERIORATION. CRISTEVED HUMIDOUS STAINS FROM VARIOUS SPILLED COATINGS	N/A	QCR# 90-0444 MHR# N/A	QC 12-21-90 ENGR
Tendon Tunnel	No SIGNIFICANT STAIN DETERIORATION OBSERVED. ITEMS NOTED IN PREVIOUS INSPECTION & FROM PREVIOUS EXCERPTIONS. MARKED & DATED SOME PREVIOUSLY IDENTIFIED WATER TRACES TO VERIFY NO INCREASE IN CRACK WIDTH. --- COULD BE FAULT	1/30/90 MARKED	QCR# 90-0444 MHR# N/A	QC 12-22-90 ENGR
Room 58 Per Air Lock (PAL) Dwg: 11405-A-6	No SIGNIFICANT STAIN. DETERIORATION OBSERVED. APPEARANCE IS GOOD. WALL PARTIALLY COVERED BY KREACUTE.	N/A	QCR# 90-0444 MHR# N/A	QC 12-23-90 ENGR
Room 59 Pipe Penetration Room Dwg: 11405-A-7	No SIGNIFICANT STRUCTURAL DETERIORATION.	N/A	QCR# 90-0444 MHR# N/A	QC 12-21-90 ENGR
Room 60 Sampling Room Dwg: 11405-A-6	No SIGNIFICANT STRUCTURAL DETERIORATION. OBSERVED ONE 1/4" ANCHOR HOLE ABOUT 18" ABOVE J8-3444 (SUB E/2/90) (TOP HOLE)	J8-3444	QCR# 90-0444 MHR# N/A	QC 12-21-90 ENGR
Room 61 Valve Room Dwg: 11405-A-6	No SIGNIFICANT STRUCTURAL DETERIORATION. APPEARANCE IS GOOD	N/A	QCR# 90-0444 MHR# N/A	QC 12-21-90 ENGR

→ TO TUNNEL CONTINU

MARKEDED & DATED SIX (6) NEW ITEMS: SEEPAGE,
MINOR CRACKS & PREVIOUSLY PATCHED AREA.

VARIOUS SEEPAGE STAINS, MINOR IN NATURE, NOTED FROM
PREVIOUS REPORTS. SEEPAGE STILL ACTIVE.
NON STAIN ITEM: ~~SEEPAGE~~ SPILAGE STAIN ON 460' ELEC. DISCONNECT AT
BOTTOM OF ACCESS Hatch LADDER.

FC/STI/57A

CONTAINMENT INTEGRITY INSPECTION WORKSHEET

ROOM/AREA	STRUCTURAL CONDITION	LOCATION	QCR/HOUR	INITIALS/DATE
Room 62 Ion Exchange Room Dwg: 11405-A-6	No significant structural deterioration observed. Appearance is good.	N/A	QCR# 90-0722 HWR# N/A	SCB/12-21-90
Room 69 Ventilation Equipment Room Dwg: 11405-A-7	No significant structural deterioration observed. Misc. oil or grease stains. Port observed SE of Cox N-68. Minor staining or eve. inc. holes observed.	SE of Cox N-68	QCR# 90-0744 HWR# N/A	SCB/12-21-90
Room 71 I&C Instrument Shop Dwg: 11405-A-7	No significant structural deterioration observed. Misc. grease stains.	N/A	QCR# 90-0744 HWR# N/A	SCB/12-21-90
Containment Outdoors West of Room 66 Dwg: 11405-A-6	No significant structural deterioration observed. Observed same electrical boxes & conduit stubs-outs described in previous inspection (10-89).	N/A	QCR# 90-0744 HWR# N/A	SCB/12-21-90
Auxiliary Building Roof Dwg: 11405-A-8	No significant deterioration observed. Cosmetic surface cracking at 180° south at succesive section at angles for equip hatch, 12' 6" above 6' above roof of rm 66. 12' high cracked is ① cont'	SE 42290 180° SOUTH	QCR# 90-0744 HWR# N/A	SCB/12-20-90
Containment Dome Dwg: 11405-A-13	No significant deterioration observed. Observed cosmetic flaking of roof coating at base of dome. No lightning rod missing top of pestle at base of rod.	- H. E. 400	QCR# 90-0744 HWR# N/A	SCB/12-20-90

Containment
Cosmetic repairs in vicinity.
} about 3' long, evidence of previous

West side & ladder to dome: 2' x 2" surface
spill w/ exposed rusted mesh. Item reported
in previous report, no visible change.

General: tendon grease around circumference
cosmetic at various locations, bird nests
up under studding gallery canopy.
FC/ST/57A

270° west
strength of
ladder.

R0

2617 1227

CONTAINMENT INTEGRITY INSPECTION WORKSHEET 1

ROOM/AREA	STRUCTURAL CONDITION	LOCATION	QC/RMR	INITIALS/DATE
Room 5 Heat Exchanger and Pump Room Dwg: 11405-A-5	No significant structural deterioration observed. Minor paint flaking noted to CQC R-5C + TMC $\frac{1}{2}$ " of expansion anchors from previous support, south of CQC R-5C.	CQC R-5C	QCR# 10-0944 MHR# N/A QC ENGR	SAC 12-21-90
Room 12 Letdown Heat Exchanger Dwg: 11405-A-5	No significant structural deterioration observed. Observed 8 grouted anchor holes; 4 & 8" above floor; 4 & 8" above floor.	4' x 8' above floor.	QCR# 10-0972 MHR# N/A QC ENGR	C-32nd 12-22-90 SAC 12-22-90
Room 13 Mechanical Penetration Dwg: 11405-A-5	No significant structural deterioration observed. Appearance is good Sub 316/30	N/A	QCR# 10-0944 MHR# N/A QC ENGR	SAC 12-21-90
Room 14 Shutdown Heat Exchanger Dwg: 11405-A-5	No significant structural deterioration observed. Wall has been painted; appearance is good. Cracks reported in previous report not visible.	N/A	QCR# 10-0912 MHR# N/A QC ENGR	C-32nd 12-22-90 SAC 12-22-90
Room 15a Valve Room Dwg: 11405-A-5	No significant structural deterioration observed. Observed items noted in previous report QC RG-3715 NOTED two (2) abandoned $\frac{1}{2}$ " x CEA 5; 1/2" above ceiling. Support has been removed.	12" above floor	QCR# 10-0972 MHR# N/A QC ENGR	C-32nd 12-22-90 SAC 12-22-90

CONTAINMENT INTEGRITY INSPECTION WORKSHEET

ROOM/AREA	STRUCTURAL CONDITION	LOCATION	QCR/MWR	INITIALS/DATE
Room 20 Lower Electrical Penetration Dwg: 11405-A-5	No SIGNIFICANT STRUCTURAL DETERIORATION OBSERVED. OBSERVED PREVIOUSLY REPORTED ELEC BOX ENBEDDED AT SW CORNER + 2 ELEC BOXES, SAME LOC. ABOVE IT 3' ABOVE FLOOR.	SW CORNER WEST OF CAC 2:	QCR# 90-07404 MWR# N/A	SHB 12-21-90 QC SHB 12-21-90 ENGR
Room 57 Mid Electrical Penetration Dwg: 11405-A-6	No SIGNIFICANT STRUCTURAL DETERIORATION OBSERVED. APPEARANCE IS GOOD.	N/A	QCR# 90-07404 MWR# N/A	SHB 12-21-90 QC SHB 12-21-90 ENGR
Room 57 Upper Electrical Penetration Dwg: 11405-A-7	No SIGNIFICANT STRUCTURAL DETERIORATION OBSERVED. SAME ELECTRICAL PLATES REPORTED IN PREVIOUS INSPECTION.	N/A	QCR# 90-07404 MWR# N/A	SHB 12-21-90 QC SHB 12-21-90 ENGR
Room 81 Condensate Ser. Water Room Dwg: 11405-A-8	No SIGNIFICANT STRUCTURAL DETERIORATION. APPEARANCE IS GOOD	N/A	QCR# 90-07404 MWR# N/A	SHB 12-21-90 QC SHB 12-21-90 ENGR

2617 1229

CONTAINMENT INTEGRITY INSPECTION WORKSHEET

ROOM/AREA	STRUCTURAL CONDITION	LOCATION	QCR# MNR	INITIALS/DATE
CONTAINMENT ELEVATION: 995 ft. Dug: 11405-A-5	NO SIGNIFICANT STRUCTURAL DEGRADATION OBSERVED. SPILLS FROM FLUID LEAK AT COL 14' OLD FLUID STAINS BETWEEN COL'S 10-11/ MINOR PAINT PEELING	COL 14' COL 10-11	QCR# 20-1001/ MNR# N/A	CBBR/ QC 1223-90 ENGR SNG 1223-90
CONTAINMENT ELEVATION: 1013 ft. Dug: 11405-A-6	NO SIGNIFICANT STRUCTURAL DEGRADATION OBSERVED. OBSERVED PEELING POINT ABOVE PAC DOOR, ABOUT 20' HIGH. POINT ON LINER ATTACHED TO 51-6A TANK ABOUT 2 FT ABOVE FLOOR.	ABOUT PAC DOOR. 51-6A TANK	QCR# 20-1001/ MNR# N/A	CBBR/ QC 1223-90 ENGR SNG 1223-90
CONTAINMENT ELEVATION: 1045 ft. Dug: 11405-A-7	NO SIGNIFICANT STRUCTURAL DEGRADATION OBSERVED. PEELED PAINT ON COL'S / 3W/4 (SEVEN) HVAC DUCT) (EAST).	COLS / 3W/4 HVAC DUCT) (EAST).	QCR# 20-1001/ MNR# N/A	CBBR/ QC 1223-90 ENGR SNG 1223-90
CONTAINMENT ELEVATION: 1060 ft. Dug: 11405-A-8	NO SIGNIFICANT STRUCTURAL DEGRADATION OBSERVED. MINOR PEELING POINT AT 235° AZIMUTH (SW), SOUTH OF VENT DUCT.	235° AZ (SW)	QCR# 20-1001/ MNR# N/A	CBBR/ QC 1223-90 ENGR SNG 1223-90
POLAR CRANE AREA AND UPWARDS	NO SIGNIFICANT STRUCTURAL DEGRADATION OBSERVED. PEELED POINT AT 90° AZIMUTH (EAST) + AT 315° AZIMUTH (NW)	90° AZ + 315°	QCR# 20-1001/ MNR# N/A	CBBR/ QC 1223-90 ENGR SNG 1223-90

2517 1231

FORT CALHOUN STATION
SURVEILLANCE TEST

SE-ST-CONT-0001
PAGE 17 OF 18

~~SURVEILLANCE TEST SIGNATURE TEST~~

All persons participating in the performance of this test shall enter their printed name, signature and initials below.

NAME (PRINT)	SIGNATURE	INITIALS
STEVEN H. BOTTUM	Steven H. Bottum	SHB
DONALD G. FLEGLE	Donald G. Flegle	DGF
STEPHEN P. SMITH	Stephen P. Smith	SPS
CAMERON McDRIE	Cameron McDrie	CMDR
Bruce Renard	Bruce Renard	BR
Z. Hobson	Z. Hobson	ZH
JACOB	JACOB	J
Al Clark	Al Clark	A

2617 1232

FORT CALHOUN STATION
SURVEILLANCE TEST

SE-ST-CONT-0001
PAGE 18 OF 18

COMMENT SHEET/CHRONOLOGICAL LOG

- (1) INSPECTED CONTAINMENT OUT OF DOORS : ITEMS "CONT. OUTDOORS...EN 66"; AIRPORT BLDG ROOF; CMAT DOME — 2/20/90 1300-1600 hrs.
- (2) INSPECTION OF NON-RCA ROOMS 81, 57(2), 20, 65, 66 + RCA ROOMS 59, 60, 61, 5, 13, 69, 71 — 2/21/90 0700-1400 hrs.
- (3) INSPECTION OF RCA BLDG BLDG ROOMS: 15a, 14, 12, 62, TENDON TUNNEL — 2/22/90 0730-1500 hrs.
- (4) Q-2340 RWP 205 replaced RWP-0165 for Containment Special Areas -D87
- (5) INSPECTED RM 58 (PAK 0001) + CONTAINMENT INTERIOR: 994', 1013', 1045', 1060', CRANE TO APEX. — 2/23/90 0730-1200 hrs.
- (6) No corrective actions required for Type A report

SUMMARY COMMENT: NO SIGNIFICANT STRUCTURAL DETERIORATION WAS OBSERVED. COSMETIC ITEMS HAVE BEEN NOTED. THE SYSTEM ENGINEER MAY REVIEW THESE ITEMS + ISSUE COSMETIC MUR'S AS DEEMED APPROPRIATE. NO MUR'S FOR SIGNIFICANT STRUCTURAL DETERIORATION WERE WRITTEN. S.H. BOTTMAN 2/23/90

2617 1233

FC-1115
Rev. 2 ISSUED 07-01-89

SURVEILLANCE TEST BACK SHEET

Documentation for Completion/Postponement
of Scheduled Surveillance Tests

This form is to be attached to each Surveillance Test prior to test issuance and performance. (Ref. SO-G-23, Section 3.8.)

PROCEDURE: SF-ST-COAT-0001

DATE SCHEDULED: _____
REFUELING

SURVEILLANCE TEST POSTPONEMENT EXPLANATION

N/A 02/7 2-23-90

Expected Completion Date: N/A 02/7 2-23-90

First Line Supervisor: N/A 02/7 2-23-90

A copy of FC-1115, with postponement explanation and expected completion date shall be DELIVERED to the STA Surveillance Test Drop Box on the Scheduled Due Date. (Ref. SO G-23, Section 4.3.2.)

Feb 23, 1990
Date Surveillance Test Completed
Donald H. Fly / Kenneth R. King 2/25/90
First Line Supervisor or System Engineer

NOTE: Signature denotes proper review in accordance with SO-G-23, Section 4.5.

FC-1115 form shall remain attached to the Surveillance Test Procedure.

Completed Surveillance Tests shall be DELIVERED to the STA Surveillance Test Drop Box by the Lead Craft.

2617 1234

SE-ST-CONT-0001

ST-CONT-5-1

**Fort Calhoun Station Unit No. 1
SURVEILLANCE TEST
ST-CONT-5**

Containment Inspection

QA Record
TEMPORARY RETENTION
for 5 years until <u>Nov 1993</u>
Initials <u>RCM</u> , Date <u>12-16-88</u>

Surveillance Test Procedure
Section F. <u>1</u>
Due Date: <u>10-17-84</u>
Month No. <u>October</u>

A. PURPOSE

1. To obtain visual evidence of any significant structural deterioration of the containment structure.
2. To effect the necessary corrective action if deterioration is noted.

B. REFERENCES

1. Technical Specifications, Paragraph 3.5(1)b.

C. EQUIPMENT/MATERIAL

1. Feeler gauge.
2. Flashlight.

D. PREREQUISITES

INITIALS/DATE

1. Verify that the latest revision of this procedure is being used.

ST for QC

QC Tech

Mgr. QA &

QC

File R-M

 * PROCEDURE *
 * REVISION VERIFICATION *
 *
 * Master Revision No. R8 *
 * Signature Tom Sutliff *
 * Date 10-16-88 *
 *

FC/ST/04

OCT 07 1988

R8 10-07-88

D. PREREQUISITES (Continued)INITIALS/DATE

2. Conduct a prejob briefing on this surveillance test prior to performance of the test. Personnel responsible for performance of the test should review the procedure to ensure they understand what is to be done, and review completed ST-CONT-5 from previous outage.

JK 110-14-88
Xesp. Craft
First-Line
Supervisor

3. The plant is in a refueling shutdown condition.

JK 110-14-88

COPY
4 A radiation work permit has been obtained for
containment entry, and Auxiliary building entries.
BY RECORDS MANAGEMENT

(General Ac. Inspector)
JEP

JK 110-14-88

E. PRECAUTIONS

1. Use normal plant safety practices.

JK

F. TEST PROCEDUREINITIALS/DATE

1. Containment Inspection

Frequency: Each refueling and before the start of ST-CONT-7 test.

Responsibility: Quality Control/Engineering

a. Initial Conditions

- (1) Qualified individual from Technical Services or GSE Engineering to accompany Q.C. Inspector. Individual should be structural or civil engineer.
- (2) Notify QC prior to start of this procedure.

b. Test Procedure

- (1) Perform a thorough visual inspection of all accessible exterior surfaces of the containment structure from the locations listed below. This inspection is to uncover evidence of any significant structural deterioration which may affect the containment's structural integrity or leak tightness.

NOTE: If there is evidence of significant structural deterioration, measure, sketch and describe this information in Section C and compare the deterioration with the records of the past containment inspections to determine if an increase in the structural deterioration has occurred.

NOTE: If any evidence of significant structural deterioration is noted, corrective action must be initiated.

NOTE: Any structural deterioration and resulting corrective action must be reported in the "Type A" test report.

- (a) Room 57 levels 1013' and 1025'.
QC Loc 38-3720

LAM 110-1488
QC

GShandor 10/14/88
Engineering

- (b) Room 59
QC Loc 38-3558

LAM 110-1488
QC

GShandor 10/14/88
Engineering

2617 1237

SE - STCONT-0001

ST-CONT-5-4

F.1 TEST PROCEDURE (Continued)

Room 66

- (d) Outdoor on the ground level west of Room 66.

QC Log # 88-3722

INITIALS/DATE

LAM 110-16-88
QC

GPande 110/16/88
Engineering

LAM 110-16-88
QC

GPande 110-16-88
Engineering

LAM 110-16-88
QC

GPande 110/16/88
Engineering

LAM 110-15-88
QC

GPande 110/15/88
Engineering

LAM 110-15-88
QC

GPande 110/15/88
Engineering

LAM 110-15-88
QC

GPande 110/16/88
Engineering

LAM 110-14-88
QC

GPande 110-14-88
Engineering

LAM 110-17-88
QC

GPande 110/17/88
Engineering

2617 1238

SE-ST-CONT-000

ST-CONT-5-5

F.1 TEST PROCEDURE (Continued)

(k) Room 5

QC Log # 88-3711

INITIALS/DATE

LAM 110-16-88
QC

CPande 10/16/88
Engineering

(l) Room 12

QC Log # 88-3712

LAM 110-14-88
QC

CPande 110-14-88
Engineering

(m) Room 13

QC Log # 88-3713

LAM 110-14-88
QC

CPande 110-14-88
Engineering

COPY
BY RECORDING INSTRUMENT

(n) Room 14

88-3714
QC Log # 88-3714
145

LAM 110-15-88
QC

CPande 110-15-88
Engineering

(o) Room 15a

QC Log # 88-3715

LAM 110-16-88
QC

CPande 110-16-88
Engineering

(p) Room 22

QC Log # 88-3717

LAM 110-16-88
QC

CPande 110-16-88
Engineering

(q) Room 23

QC Log # 88-3718

LAM 110-16-88
QC

CPande 110-16-88
Engineering

(r) Room 58

QC Log # 88-3857

LAM 110-16-88
QC

CPande 110-16-88
Engineering

(s) Room 60

QC Log # 88-3859

LAM 110-14-88
QC

CPande 110-14-88
Engineering

(t) Room 61

QC Log # 88-3721

LAM 110-14-88
QC

CPande 110-14-88
Engineering

FC/ST/04

ISSUED

OCT 07 1988

R8 10-07-88

ST-CONT-5-6

F.1 TEST PROCEDURE (Continued)

QC LOC # 88-5407

(u) Room 62

LAm QC 12-9-88

INITIALS/DATE

LAm 110-16-88

QC

SF Pande 10/16/88

Engineering

LAm 110-16-88

QC

SF Pande 10/16/88

Engineering

(v) Room 65

QC LOC # 88-3855

(w) Room 65

QC LOC # 88-3722

BY RECORDS MANAGEMENT

QC LOC # 88-3854

(x) Room 65

QC LOC # 88-3854

- (2) Perform a thorough visual inspection of all accessible interior surfaces of the containment liner from the locations listed below.

NOTE: If there is evidence of significant structural deterioration, measure, sketch and describe this information in Section C and compare the deterioration with the records of the past containment inspections to determine if an increase in the structural deterioration has occurred.

NOTE: If an evidence of significant structural deterioration is noted, corrective action must be initiated.

NOTE: Any structural deterioration and resulting corrective action must be reported in the "Type A" test reported.

(a) Elevation 995'

QC LOC # 88-3725

LAm 110-16-88

QC

SF Pande 10/16/88

Engineering

(b) Elevation 1013'

QC LOC # 88-3851

LAm 110-16-88

QC

SF Pande 10/16/88

Engineering

2617 1240

SE-ST-CNT-0001

ST-CNT-5-7

F.1 TEST PROCEDURE(Continued)

(c) Elevation 1045'

QC Log # 88-3852

INITIALS/DATE

1AM 10-16-88

QC

C.Pande

10-16-88

Engineering

C.Pande 10-16-88

1AM 10-16-88

QC

C.Pande 10/16/88

Engineering

(d) Elevation 1060'

QC Log # 88-3852

(e) Polar Crane

QC Log # 88-3852

C. REMARKS:

NOTE ~~**~~

~~DUE TO THE VERY HIGH RADIATION LEVEL IN
ROOM 62 HEALTH PHYSICS DEPT. WOULD NOT ALLOW
FOR CONTAINMENT BLOCK INSPECTION IN THAT AREA.~~

~~INSPECTION OF CONTAINMENT WALL MADE 12-9-88; NO DISCREPANCIES.~~ ~~C.T. Manning
12-9-88~~

~~ALL DISCREPANCIES NOTED ON QC LOG~~ ~~C.T. Manning QC
C.Pande 12-9-88~~

~~REPORTS 88-3711 THROUGH 88-3726 AND
ATTACHED VISUAL EXAMINATION REPORTS. ENGINEERING
EVALUATION SUBMITTED TO ENGINEERING FOR DISPOSITION.
M.O.'S TO BE WRITTEN BY CHEMISTS FOR ANY REQUIRED
REPAIRS. 10/19/88~~

Test Completed By: C.Pande Date/Time 10-17-88 / 1600
Engineering QC

C.T. Manning Date/Time 10-17-88 / 1600
QC

Room 62 completed 12-9-88 CH

QDP-20
Appendix L

REQUEST FOR ENGINEERING EVALUATION

DESCRIPTION:

ATTACHED ARE COPIES OF ALL QC INSPECTION REPORTS
COVERING THE ST-CONT-5 INSPECTION. PLEASE ADVISE
THE QUALITY CONTROL DEPARTMENT IF INSPECTION
RESULTS ARE ACCEPTABLE. IF REPAIRS ARE
REQUIRED, PLEASE INITIATE MAINTENANCE ORDER TO
COVER THE WORK. INFO COPIES OF QC LOG # 88-3711, ¹¹⁵
3712, 3713, 3714, 3715, 3717, 3719, 3720, 3721, 3722, 3723, 3724, 3725, 3726,
^{3851 thru 3860}

REQUESTOR: J. Wynn DATE: 11/19/88

(FORWARD TO PRODUCTION ENGINEERING)

INSPECTION CRITERIA/DISPOSITION:

THE CONTAINMENT INSPECTION DONE PER ST-CONT-5 INDICATES
THAT THE STRUCTURAL INTEGRITY OF THE CONTAINMENT STRUCTURE
IS NOT DEGRADED NOR IN JEOPARDY. THE VISUAL INSPECTION
DID INDICATE SOME HAIRLINE CRACKS OF CREEP AND SHRINKAGE
TYPE. WE INTEND TO MONITOR CRACK PROPAGATION IN ROOM
22, 23 AND THE TENDON GALLERY ON AN ANNUAL BASIS AND
WILL CONSIDER THE USE OF MECHANICAL STAGES SHOULD THE
SITUATION CONTINUE TO DEVELOP.

WRITTEN BY: G. Prude, 12/12/88
ENGINEER DATEAPPROVED BY: H. H. Hennerson
PRODUCTION ENGINEERING

J. Wynn
QC INSPECTOR
Ode
LEAD QC INSPECTOR

12-13-88
DATE
12-14-88
DATE

2617 1242

SE-ST-CONT-0001

QDP-20
Attachment 12QA Record
PERMANENT RETENTIONInitials: 110 Date: 4/19/88 Report No. PP-3712System or Component CWST. QL2G

QC LOG

Document Number: ST-CONT-5Title: CONTAINMENT WSPLocation: Rm 12Date/Time: 10/17/88Craftsman: PADE**INFORMATION**

Type of Inspection:

VT PT MT UT/T UT RT/I Mech. Elect. Surv.

Other: NDE Fire Close Hydro Leak Equip. Person. Oper- Rad
 Report Barrier Out Check Cals. Qual. ability Wastes

Description: INSPECTION OF CONTAINMENT WALL IN Rm. 12
SHOWS 1/4" CREEP AND 1/2" LANKAGE CRACKS FROM BOTTOM OF
WALL TO 4' TD 5' UPWARD, MOSTLY VERTICAL 1/32" DEEP
BY RECORDS (HARD COPY)

Acceptable Corrective Action Required Notified: Name: San Dade Date: 10-17-88 Time: 1600Corrective Action: Engineering Evaluation Submitted 4/19/88, R. S. S.QC Log # 88-4176

Acceptable []

Sketch if Required:

John McGaugh 10-14-88
 QC Inspector Date Time

Tom Sullivan
 Lead QC Inspector

Ed Sypa
 Supervisor - Quality Control
 for

QA Record
PERMANENT RETENTION
Initials: JL Date: 4/19/88

Report No. 88 3713

QC LOG

System or Component CONT. BLDG.Document Number: ST. CONT-5Title: CONTAINMENT INS.Location: Rm. BDate/Time: 10:00 AMCraftsman: PANDEINFORMATIONType of Inspection: VT PT MT UT/T UT RT/I Mech. Elec. Surv.

Other:

<input checked="" type="checkbox"/>	[]	[]	[]	[]	[]	[]	[]	[]	[]
NDE	Fire	Close	Hydro	Leak	Equip.	Person.	Oper-	Rad	
Report Barrier	Out			Check	Cals.	Qual.	ability	Waste	

Description: INSPECTION OF CONTAINMENT WALL IN RM. B SHOWS
OILY SUBSTANCE RUNNING DOWN CONTAINMENT WALL
AT PENETRATION M-13, DROPPING FROM PENETRATION M-18
WHICH IS ABOVE. DROPPING IS EXCESSIVE.

Acceptable Corrective Action Required Notified: Name: Sam Panes Date: 10-17-88 Time: 1600Corrective Actions: ENGINEERING EVALUATION SUBMITTED 4/19/88

QC LOG # SA-4176

Acceptable []

Sketch if Required:

JL
JL Murray 10-17-88,
QC Inspector Date Time
Tom Sullivan
Lead QC Inspector

165 yrs
Supervisor - Quality Control
FZ

2617 1244

QDP-20
Attachment 12

QA Record
PERMANENT RETENTION
Initials: JPS Date: 11/19/88

Report No. 88 3720System or Component CONT PLOG,

QC LOG

Document Number: ST-CONT-5Title: CONTAINMENT INS.Location: Rm. 51Date/Time: 10-14-88Craftsman: PANDEINFORMATION

Type of Inspection:

<input checked="" type="checkbox"/>	[]	[]	[]	[]	[]	[]	[]	[]	[]
VT	PT	MT	UT/T	UT	RT/I	Mech.	Elec.	Surv.	

Other: _____

<input checked="" type="checkbox"/>	[]	[]	[]	[]	[]	[]	[]	[]	[]
NDE	Fire	Close	Hydro	Leak	Equip.	Person.	Oper-	Rad	
Report Barrier	Out			Check	Cals.	Qual.	ability	Waste	

Description: THREE 6"X3" PLATES OR COVERS FOR CONDUIT
ARE EXPOSED ON CONTAINMENT WALL.
CONDUIT CONTAINS WIRES THAT EXTEND THRU CONT.
WALL (NEAR PENETRATION E-1) ALSO ONE AT OPPOSITE
END OF ROOM!

BY Engineering ManagementAcceptable Corrective Action Required Notified: Name: San Pande Date: 10-17-88 Time: 1607Corrective Action: Engineering Evaluation Submitted, JPS 11/19/88QC Log # 88-9176

Acceptable []

Sketch if Required:

L. M. May 10-1988
 QC Inspector Date Time
Tom Sullivan
 Lead QC Inspector

F.

J. W. S.
 Supervisor - Quality Control

2617 1245

QDP-20
Attachment 12

QA Record
PERMANENT RETENTION
Initials: SLT Date: 11/4/95

Report No. 88-3721

System or Component: ~~cont. page~~

QC Log

Document Number: ST-COIT-5

Title: CONTAINMENT WSO.

Location: Box 61

Date/Time: 10-14-88

Craftsman: PANDE

INFORMATION

Type of Inspection:

VT PT MT UT/T UT RT/I Mech. Elec. Surv. ONLY

Others:

NDE [] [] [] [] [] [] [] []
Report Barrier Fire Close Hydro Leak Equip. Person. Oper- Rad
Out Check Cals. Qual. ability Waste

Description: VISUAL INSPECTION OF COUPLING BLDG IN ROOM 61
SHOWS CONNECTION OF ROOM WALL AND CONTAINMENT
JAW AT DOORWAY EXHIBITS GREASY SUBSTANCE LEAKING
FROM SEALANT. NO MAJOR DISCREPANCIES

Acceptable

Corrective Action Required

Notified: Name: John Date: 1/2 Time: 8:00

Corrective Action:

SAN PEDRO NOTIFIED 10-17-94 C 1600
LAW ENFORCEMENT SUPERVISOR H/19/95
QC LOG #B-476

Acceptable [initials]

Sketch if Required:

21

L.C. Miller 10-14-88
QC Inspector Date Time
C. Fellow
Lead QC Inspector
R. Hayes
Supervisor - Quality Control

QA Record
PERMANENT RETENTIONInitials: LL Date: 10/19/88 Report No. 88 3-24System or Component CONT. BLDG.

QC LOG

Document Number: ST-CNT-5Title: CONTAINMENT INS.Location: RM 81Date/Time: 10-14-88Craftsman: PANDE / EVAINFORMATION

Type of Inspection:

[] [] [] [] [] [] [] []
 VT PT MT UT/T UT RT/I Mech. Elec. Surv.

C
BY RECORDS

[] [] [] [] [] [] [] []
 NOB Fire Close Hydro Leak Equip. Person. Oper- Rad
 Report Barrier Out Check Cals. Qual. ability Waste

Description: VISUAL INSPECTION OF RM. 81 SHOWS

(2" X 3" PLATE EXPOSED. APPEARS TO BE CONDUIT IN
DRYWALL APPROX. 15' ABOVE 1036 BL. + LEAK DOOR #
1034-17

Acceptable Corrective Action Required Notified: Name: Sam Panos Date: 10-17-88 Time: 1600Corrective Action: ENGINEERING EVALUATION SUBMITTED 10/15/88 10/18/88BL Log # 92-4176

Acceptable []

Sketch if Required:

LJ Murray 10-14-88 0800
QC Inspector Date TimeTom Sullivan
Lead QC InspectorL/KS
F2 Supervisor Quality Control

2617 1247

SE-ST-COK/F0001

QDP-20
Attachment 12QA Record
PERMANENT RETENTIONInitials: SP Date: 10/17/86Report No. 28-3858System or Component CONT. WALL

QC LOG

Document Number: ST-CONT-STitle: CONTAINMENT 1 SP.Location: ROOM 59Date/Time: 10/17/86 08:35Craftsman: PANDE

Type of Inspection:

 VT PT MT UT/UT RT/I Mach. Elec. Surv.

Other:

<input type="checkbox"/>											
NDE	Fire	Close	Hydro	L	<	Equip.	Person.	Oper-	Rad		
Report Barrier	Out			C	Check	Cals.	Qual.	ability	Waste		

Description: VISUAL INSPECTION OF RM. 59 SHOWS NO
DISCREPANCIES TO CONTAINMENT WALLNOTE: NEW PAINT APPLIEDCorrective Action Required: NAIssued: Name: SPDate: 10/17/86 Time: 08:35Corrective Action: NAAcceptable: NA

Sketch if Required:

SPL. Mallya NO-481
QC Inspector Date TimeD. Linn
Lead QC InspectorE. S.
FZ Supervas. - Quality Control

E 17 1248

QDP-20

Attachment 12

QA Record
PERMANENT RETENTION

Initials: JAS Date: 4/18/89Report No. 88-3857System or Component: CONT. BLDG.

QC LOG

Document Number: ST-COINT-STitle: CONTAINMENT INSP.Location: BU. 60Date/Time: 10-14-88 /Craftsman: PANDE


INFORMATION

Type of Inspection: VT [] [] [] [] [] [] [] []PT [] MT [] UT/T [] UT/I [] Mech. Elec. Surv.

ONLY

Other: ✓ [] [] [] [] [] [] [] []

NDE [] Fire [] Close [] Hydro [] Leak [] Equip. [] Person. [] Oper- [] Rad [] Report Barrier [] Out [] Check [] Cals. [] Qual. [] ability [] Waste []

Description: CONTAINMENT WALL INSPECTION SHOWS IT IS
IN GOOD CONDITIONNOTE: NEW PAINTAcceptable ✓ ✓/ASCorrective Action Required ✓Notified: Name: 4/18 Date: 4/18 Time: 4/18

Corrective Action:

N/A

Acceptable []

Sketch if Required:

N/A

L. Murray 10-14-88
QC Inspector Date 10-14-88

R. Pescane
Lead QC Inspector

F. J. K. K.
Supervisor - Quality Control

QA Record
PERMANENT RETENTION
Initials: SJS Date: 11/14/88

Report No. SD 3714System or Component CANT. BLDG.,
QC LOGDocument Number: SR-COVT. STitle: CONTAINMENT INSPLocation: Rm 14Date/Time: 11/14/88 /Craftsman: PANDEINFORMATIONType of Inspection: VT PT MT UT/UT RT/I ONLY Mech. Elec. Surv.Other: NDE Fl. a Close Hydro leak Equip. Person. Oper- Rad
 Report Barrier Cut ack Cals. Qual. ability Wasta

Description: VISUAL INSPECTION SHOWS, HORIZONTAL CRACK, ABOUT 6' 4" FROM FLOOR; ABOUT 6" LONG & 1/16" WIDE. IT IS CRACKED. AREA LOOKS TO HAVE BEEN GROUTED AT SOME TIME. VERTICAL CRACK STILL EXISTS FROM PREVIOUS INSPECTION.

Acceptable Corrective Action Required Notified: Name: Sam Pande Date: 10-17-88 Time: 1600Corrective Action: Engineering Evaluation Submitted 11/19/88 by SJS
QC LOG # 88-4176Acceptable

Sketch if Required:

J.C. Murray 10-15-88
QC Inspector Date Time
Jim Sullivan
Lead QC Inspector
E.H. Dyer
Supervisor - Quality Control
PSC

2617 1250

SE-ST-CONT-0001

ODP-20

Attachment 12

QA Record
PERMANENT RETENTIONInitials: ED Date: 10/15/88 Report No. 88 3723System or Component CONT. BLDG.

QC LOG

Document Number: ST-CONT-5Title: CONTAINMENT INS.Location: BN. 69Date/Time: 10-15-88Craftsman: PANDEINFORMATION

Type of Inspection:

VT PT MT UT/UT RT/I Mech. Elec. Surv.

Other:

<input checked="" type="checkbox"/>	NDE	<input type="checkbox"/>	Fire	<input type="checkbox"/>	Close	<input type="checkbox"/>	Hydro	<input type="checkbox"/>	Leak	<input type="checkbox"/>	Equip.	<input type="checkbox"/>	Person.	<input type="checkbox"/>	Oper-	<input type="checkbox"/>	Rad
<input checked="" type="checkbox"/>	Refort Barrier	<input type="checkbox"/>	Out	<input type="checkbox"/>	Check	<input type="checkbox"/>	Cals.	<input type="checkbox"/>	Qual.	<input type="checkbox"/>	ability	<input type="checkbox"/>	Waste	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Description: VISUAL INSPECTION OF RM 69 SHOWS OIL DRIPPING DOWN THE SIDE OF CONTAINMENT WALL ACROSS FROM RM. 62. VERY HEAVY POLLAGE NOTE: REMAINDER OF ROOM SHOWS LESSER OIL MARKS ON REMAINDER OF AREA

Acceptable Corrective Action Required Notified: Name: JL Date: 10/15/88 Time: 10:00Corrective Action: See Power MFG ID 10-17-88 @ 1600

ENGINEERING EVALUATION INITIATED 10/15/88
OIL LOG # 88-4176 R/W/DO

Acceptable

Sketch if Required:

JLK. Makare, 10-15-88,
QC Inspector Date TimeJim Sullivan
Lead QC InspectorJL
Supervisor - Quality Control

2017 1251

SE-ST-CANT-0001

QDP-20
Attachment 12QA Record
PERMANENT RETENTIONInitials: PL Date: 10/15/89Report No. 28-3860System or Component CONT-BLDG.

QC LOG

Document Number: ST-CANT-STitle: CONTAINMENT INSPLocation: 100' E OF CONTAINMENT BLDG.Date/Time: 10/15/89 /Craftsman: PrideType of Inspection: VT PT MT UT/T UT RJ/I Mech. Elec. Surv.Other: NDE Fire Close Hydro Leak Equip. Person. Oper- Rad
 Report Barrier Out Check Cals. Qual. ability WastaDescription: VISUAL EXAMINATION SHOWS NO DISCREPANCIES AND
AUX. BLDG. ROOF.AUX. ROOF EL 10B3' WIRE MESH ON CONTAINMENT WALL
AT ACCESS LADDER IS SHOWING THRU CONCRETE
THIS CONDITION MAY BE OF SOME CONCERNAcceptable FA ✓ NDCorrective Action Required R/ANotified: Name: KA Date: 10/15/89 Time: 1400Corrective Action: COPY TO QA BY RECORDS MANAGEMENTAcceptable KA

Sketch if Required:

L. Malone 10/15/89
QC Inspector Date Time

R. Malone
Lead QC Inspector

W.S.
Supervisor - Quality Control

QA Record
PERMANENT RETENTION

Initials: WS Date: 11/19/98

Report No. 3715

System or Component Cont. SLDX

QC LOG

Document Number: ST-CONT-5

Title: CONTAINMENT INS.

Location: Rm 15A

Date/Time: 11/19/98

Craftsman: PANDE

INFORMATION

Type of Inspection: VT PT MT UT/T UT RT/I Mech. Elec. Surv.

Other: NDE Fire Close Hydro Leak Equip. Person. Oper- Rad
 Report Barrier Out Check Cals. Qual. ability Wastes

Description: SHRINKAGE CRACKS NEAR BOTTOM OF CONTAINMENT
 WALL (GENERAL) WITH HEAVY OILY LIQUID LEAKING FROM TOP OF
 ROOF. PAINT PEELING FROM FLASHING PLATE IN CORNER
 OF ROOF. SHRINKAGE CRACKS ARE 6 1/32" IN WIDT

Acceptable

Corrective Action Required

Notified: Name: Sam Pandey Date: 10-17-98 Time: 1600

Corrective Action: Engineering Evaluation Submitted 11/19/98, WS
AC LOG #9176

Acceptable []

Sketch if Required:

L. M. Khan 10/16/98
 QC Inspector Date Time
Tom Sullivan
 Lead QC Inspector

WS
 Supervisor - Quality Control
 Fde

QA Record
PERMANENT RETENTION

Initials: JAS Date: 4/19/88 Report No. 88 3717

System or Component CONT. BLDG.

QC LOG

Document Number: ST-CO-N-5

Title: CONTAINMENT INSP

Location: Rooms 22

Date/Time: 4/24/88

Craftsman: Pawde

INFORMATION

Type of Inspection:

VT PT MT UT/T UT RT/I Mech. Elec. Surv.

Other:

NDE Fire Close Hydro Leak Equip. Person. Oper- Rad
Report Barrier Out Check Cals. Qual. ability Waste

Description: VISUAL INSPECTION OF CONTAINMENT WALL SHOWS CRACK EXTENDS THE TOTAL LENGTH OF EXPOSED CONTAINMENT WALL AT 9' ABOVE FLOOR ELEVATION AND ABOUT 1/32" WIDE

ALSO NOTED CRACK AROUND HATCHWAY TO THE TUNNEL WHICH IS APPROX. 1/32" WIDE

Acceptable

Corrective Action Required

Notified: Name: Sullivan Date: 4/17/88 Time: 1600

Corrective Action: Engineering Evaluation Submitted 4/17/88

QC Log # 88-4176

Acceptable

Sketch if Required:

Jim Sullivan 4/17/88
QC Inspector Date Time

Jim Sullivan
Lead QC Inspector

R. K. Goss
Supervisor - Quality Control
FBI

2617 1255

QCP-20
Attachment 12

QA Record
PERMANENT RETENTION

Initials: JK Date: 4/9/00

Report No. 88-3718

QC LOG System or Component CANT. BLDG.

Document Number: ST-CONT-5

Title: CONTAINMENT INSPECTION

Location: 123

Date/Time: 10-16-88, 0230

Craftsman: P. A. J. DE

INFORMATION

Type of Inspection:

VT PT MT UT/T UT RT/I QM&V [] Mech. Elec. Surv.

Other: _____

[] [] [] [] [] [] [] [] []
NDE Fire Close Hydro Leak Equip. Person. Oper- Rad
Report Barrier Out Check Cals. Qual. ability Waste

Description: VISUAL INSPECTION OF CONTAINMENT WALL IN RM 23
SHOWS 3 LARGE CRACKS

① 34" LONG 1/32" WIDE VERTICAL
② 91" LONG 1/32" WIDE VERTICAL
③ 21'-9" LONG 1/32" WIDE HORIZONTAL

LARGE CRACK THAT HAS BEEN SEEPAGE IS 7'10" ABOVE FLOOR EL. THIS CRACK IS BEHIND
BEAM PLATE FOR PIPE SUPPORT # SIS-44A (SLINGER) ALSO AN 8' CRACK IS LOCATED
UNDER EHV 383-3B AND WHERE EHV 383-3B ENTERS THE CONTINUOUS WALL; SAME FOR EHV 381-4A

Acceptable

Corrective Action Required

Notified: Name: Sam Poole Date: 10-17-88 Time: 1600

Corrective Action: ENGINEERING EVALUATION SUBMITTED 11/5/04 11/12/03

01 Log #3476

Acceptable []

Sketch if Required:



7' 10" ABOVE FLOOR

L. M. Munro 10-10-88,
QC Inspector Date Time

Tom Sulli
Lead QC Inspector

Supervisor - Quality Control

QA Record

PERMANENT RETENTION

Initials: RJS Date: 11/19/88Report No. 88 3722System or Component CONT. BLDG.

QC LOG

Document Number: ST-CONT-5Title: CONTAINMENT INSPECTIONLocation: RM 660 (OUTSIDE CONT.)Date/Time: 10-17-88 / 10/16Craftsman: PANDEINFORMATION

Type of Inspection:

VT PT MT UT/T UT RT/I ONLY Mech. Elec. Surv.

Other:

NDE Fire Close Hydro Leak Equip. Person. Oper- Rad
 Report Barrier Out Check Cals. Qual. ability Wastes

Description: VISUAL EXAMINATION SHOWS 3 EXPOSED PLATES, POSSIBLY FROM CONDUIT LOCATED AT CORNER NEAR LOADING DOCK (1 IS 30 FT UP). ALSO FOUND 3 EXPOSED WIRES FROM POSSIBLY A METER OR REFRIGERATED GATE TRIM. TWO (X) SQUARE HOLES 3" TO 4" DEEP ABOUT 7' UP FROM BOTTOM OF OUTSIDE WALL.

Acceptable []

Corrective Action Required Notified: Name: Sam Pande Date: 10-17-88 Time: 1600Corrective Action: ENGINEERING EVALUATION SUBMITTED 8/17/88QC LOG # 88-4176

Acceptable []

Sketch if Required:

Jim Sullivan 10/16/88QC Inspector Date 10/16/88 TimeJim Sullivan
Lead QC InspectorL.W. Sauer
Supervisor - Quality Control

Fse

2617 1257

QA Record
PERMANENT RETENTION
Initials: SLT Date: 10/16/88

Report No. 88-3725System or Component Containment BLDG.

QC LOG

Document Number: ST-CNT-5Title: CONTAINMENT INSP.Location: EL. 995 CONTAINMENTDate/Time: 10-16-88Craftsman: PANDE**INFORMATION**

Type of Inspection:

VT PT MF UT/T UT RT/I Mech. Elec. Surv.

Other: _____

NDE Fire Close Hydro Leak Equip. Person. Oper- Rad
 Report Barrier Out Check Cals. Qual. ability Waste

Description: ANNUAL INSPECTION OF CONTAINMENT BLDG. AT 995'
EL. SHOWS SIGNIFICANT AMOUNT OF OIL LEAKAGE AT
PENETRATION AREA NEAR M-10, M9, & M-12. ORIGIN
OF OIL IS INDETERMINATE.

Acceptable J/ACorrective Action Required J/ANotified: Name: Sam Pande Date: 10-17-88 Time: 1600Corrective Action: Engineering Evaluation submitted 4/19/88, J/A

QC LOG 88-4126

Acceptable []

Sketch if Required:

John Manay 10-16-88
QC Inspector Date TimeTom Sullivan
Lead QC InspectorJ/K/S
Supervisor - Quality Control

F2

JDP-20
Attachment 12QA Record
PERMANENT RETENTIONInitials: JAD Date: 4/16/81 Report No. 88-3851System or Component CONT. BLDG.

QC LOG

Document Number: ST-CONT-5Title: CONTAINMENT INSP.Location: CONTAINMENT EL. 1013'Date/Time: 4/16/81Craftsman: PANDA

INFORMAT...

Type of Inspection:

 VT PT MT UT/T UT RT/I Mech. Elec. Surv. ONLYOther: NDE Fire Close Hydro Leak Equip. Person. Oper. Rad
 Report Barrier, Out Check Cals. Qual. ability WasteDescription: VISUAL INSPECTION OF THE 1013' EL. OF INSIDE
OF CONTAINMENT SHOWS ONLY GENERAL PAINT PEELING
NO DAMAGE NOTED.Acceptable JADCorrective Action Required N/ANotified: Name: N/ADate: N/A Time: N/ACorrective Action: N/AAcceptable N/A

Sketch if Required

N/AJ. D. Brown 110-16-81
QC Inspector Date TimeP. Feuvre
Lead QC InspectorJ. Bryan
For Supervisor - Quality Control

2617 1259

SE-ST-CNT-000.1

QD7-20

Attachment 12

QA Record
PERMANENT RETENTIONInitials: LS Date: 11/15/88Report No. BB-3852System or Component COT: BLDG

QC LOG

Document Number: ST-CNT-5Title: CONTAINMENT INS.Location: CNT. EL. 1045, 1060, POLAR CRANEDate/Time: 10/16/88Craftsman: PANDEINFORMATION

Type of Inspection:

VT PT MT UT/T UT RT/I Mech. Elec. Surv.

Other:

NDE Fire Close Hydro Leak Equip. Person. Oper-
 Report Barrier Out Clock Cals. Qual. ability Waste

Description: VISUAL INSPECTION OF CONTAINMENT LINER AT E-1045,
 EL. 1060, AND POLAR CRANE SHOWS NO DISCREPANCIES.
 ONLY GENERAL PAINT PEELING
BY RECORDS MANAGEMENT

Acceptable 11/15Corrective Action Required N/ANotified: Name: N/ADate: N/A Time: N/ACorrective Action: N/AAcceptable N/A

Sketch if Required:

N/AD.G. Murray 11/16/88

QC Inspector Date Time

G. Johnson

Lead QC Inspector

L. Higgin

Supervisor - Quality Control

2617 1260

SE-ST-COJT-0001

QDP-20
Attachment 12QA Record
PERMANENT RETENTIONInitials: SLB Date: 4/16/88Report No. 38-3853System or Component Containment
QC LOGDocument Number: ST-COJT-STitle: CONTAINMENT INS.Location: CONTAINMENT DOMEDate/Time: 4/16/88Craftsman: PANPE**INFORMATION**

Type of Inspection:

VT PT MT UT/UT RT/I Mech. Elec. Surv.

Other:


NDE Fire Close Hydro Leak Equip. Person. Oper- Rad
 Report Barrier Out Check Cals. Qual. ability Waste

Description: Inspection of containment dome shows no discrepanciesAcceptable: ✓Corrective Action Required: NoneNotified: Name: N/ADate: N/A Time: N/A

Corrective Action:

Acceptable: ✓

Sketch if Required:



L. Manig / 4-16-88
 QC Inspector Date Time

G. Ellmore
 Lead QC Inspector

J. B. /
 Supervisor - Quality Control

2617 1261

QDP-20
Attachment 12

QA Record
PERMANENT RETENTION
Initials: <u>JL</u> Date: <u>11/16/88</u>

Report No. 88-3854System or Component CNT. BLDG.

QC LOG

Document Number: ST-CNT-5Title: CONTAINMENT INS.Location: Rm. 71Date/Time: 10:16:88 /Craftsman: PANDE

INFORMATION

Type of Inspection:

VT PT MT UT/T UT RT/I Mech. Elec. Surv.


ONLY

Other: NDE Fire Close Hydro Leak Equip. Person. Oper- Rad
 Report Barrier Out Check Cals. Qual. ability Waste

Description: VISUAL INSPECTION OF CONTAINMENT BLDG. IN
Room 71 shows NO DISCREPANCIES

Acceptable S/ACorrective Action Required /ANotified: Name: N/ADate: N/A Time: N/ACorrective Action: N/AAcceptable [initials]

Sketch if Required:



L.G. Manning 11/16/88 /
 QC Inspector Date Time

J. Pekom
 Lead QC Inspector

J. H. Kryza
 Supervisor - Quality Control
 For

QA Record
PERMANENT RETENTION
Initials: RLS Date: 4/16/88

Report No. 88 3857System or Component CONT. ISLOG.

QC LOG

Document Number: ST-CONT-5Title: CONT. INSPLocation: Rm. 58Date/Tire: 10-16-88Craftsman: PANDEINFORMATION

Type of Inspection:

VT PT MT UT/T UT RT/I Mech. Elac. Surv.

ONLY

Other:

NDE Fire Close Hydro Leak Equip. Person. Oper- Rad
Report Barrier Out Check Cals. Qual. ability Waste

Description: VISUAL INSPECTION OF RM. 58 SHOWS IN GOOD CONDITION.NOTE: CONTAINMENT WALL PARTIALLY COVERED BY Herculite FOR ANTI-COMMUNICANT REASONS.Acceptable ✓Corrective Action Required ✓Notified: Name: N/ADate: 4/16 Time: 4/16Corrective Action: /n/aAcceptable ✓

Sketch if Required:

N/A

L. M. Mann 10-16-88
QC Inspector Date Time

G. Feuer
Lead QC Inspector

F. D. G.
Supervisor - Quality Control

QA Record
PERMANENT RETENTION
Initials: JL Date: 11/19/88

Report No. 58 3726System or Component CONT. BLDG

QC LOG

Document Number: ST-COIT-5Title: CONTAINMENT INSPECTIONLocation: TENDON GALLERYDate/Time: 10-17-88 /Craftsman: Pause

Min UTM. NAD 83

Type of Inspection: VT [] [] [] [] [] [] [] []ONLY

VT PT HT UT/T UT RT/I Mech. Elec. Surv.

Other: ✓ [] [] [] [] [] [] [] []NDE Fire Close Hydro Leak Equip. Person. Oper- Rad
Report Barrier Out Check Cals. Qual. ability WasteDescription: INSPECTION OF TENDON GALLERY SHOWS:

6' B CRACK AT CE 9. AA 004, SAME AT CE 143 AA 359, A 6' 8" LONG CRACK AT CE 121 AA 372, SAME AT CE 22 AA 209. CRACK WITH WATER SEEPAGE AT CE 182 AA 388, LOCATION 304B - 7' CRACK, 4' JOURNAL 207A - 1' CRACK & 13' CRACK, LOC 103B 7' VERTICAL CRACK, 6' HORIZONTAL CRACK AT SOUND BOX 7' ABOVE FLOOR. LOCATED 2024 7' VERTICAL CRACK. 7' CRACK AT LOCATIONS 2011, 2017 2014 2010. DOWNTURN SEEN AT JOURNAL 1125 ALSO LEAKING. GREASE CAR AT LOCATION 1093 Q° A2. JOURNAL 1075 7' VERT. CRACK. BORON LEAKAGE NEAR DOORWAY. THESE AREAS ARE THE MOST PROFOUND. EVIDENCE OF SOME CRACKS HAD BEEN REHEARD IN PAST. ALL CRACKS MAXIMIZE 1' 8" WIDE

Acceptable []Corrective Action Required []Notified: Name: Sam Pause Date: 10-17-98 Time: 1600Corrective Action: ENGINEERING EVALUATION SCHEDULED 10/15/98, 4/18/98QC LNR # 89-4176Acceptable []

Sketch if Required:

John Mann /10-17-88/
QC Inspector Date Time

Tom Sullivan
Lead QC Inspector

W.S. Sauer
Supervisor - Quality Control
FOL

2617 1265

SE-ST-CONT-0001

QDP-20

Attachment 12

QA Record

PERMANENT RETENTION

Initials: MR Date: 12/1/88Report No. 88-5407System or Component CONT. BLDG.

QC LOG

Document Number: ST-CONT-5Title: CONTAINMENT INSP.Location: AUX BLDGData Examiner: ██████████ Date: 1/4/90Craftsman: PANDEType of Inspection: INT VT PT MT UT UT RT/I Mech. Elec. Surv.Other: NDT NDE Fire Close Hydro Leak Equip. Person. Oper- Rad
 Report Barrier Out Check Cals. Qual. ability WasteDescription: INSPECTION OF CONTAINMENT VALVE IN ROOM #62
SHOWS NO DISCREPANCIESAcceptable

BY REC'D

Corrective Action Required Notified: Name: SAM PANDE Date: 12-9-88 Time: 1525Corrective Action: NONE C.P. 12/9/88Acceptable

Sketch if Required:

12/9/88, 1510

QC Inspector Date Time

Robert P. Brown
Lead QC Inspector

Supervisor - Quality Control

TANK ENTRY PERMIT #1

- A. A prejob briefing has been conducted in accordance with Standing Order C-45 step 1.6.2. Standing Order G-41 has been reviewed by the job foreman/supervisor. Attachment A is completed. SHB 12-22-90
- B. Flush tank as required to achieve as low as reasonably achievable exposure. (N/A if not applicable.) N/A D87 12-19-90
- C. Pump or drain tank to the lowest practical level. (N/A if not applicable.) N/A D87 12-19-90
- D. Tag out the tank to be entered.
- Tank Number Stressing Gallery
- Tag Number _____ D87 12-19-90
- E. Remove the manway cover from the tank. Karl 12/20/90
- F. Sample the atmosphere of the tank to ensure that combustible gases are less than 10% and oxygen is 19.5% or greater. Karl 12/20/90
- NOTE: Another Tank Entry Permit shall be filled out if the atmospheric conditions of the tank may have changed (i.e., welding in tank or the tank has been closed and re-opened). 2/21/90
- Combustible Gases 0.0 % 0.0%
Oxygen 21.0 % 21.1%
- G. This Tank Entry Permit expires after Job completion. Karl 12/20/90
- H. Constant oxygen and/or combustible gas monitoring (during personnel entries) is required. YES NO Karl 12/20/90
- I. Forced ventilation is recommended for entry. (Circle one). Yes No Karl 12/20/90

2617 1267

FORT CALHOUN STATION
GENERAL FORM

SE-ST-CONT-000

FC-62
R4 ISSUED 06-01-89
PAGE 2 OF 3

- J. R.P. samples the contents in the tank, survey the tank and record the result. (N/R if not required).

CLOSED OFF/DATE

Contents NA
 Surveys ≈ 4kcpm
Area posted CA

QWL 1260/90
R.P. 26K 2/22/90

- K. Obtain a Radiation Work Permit for entry of the tank. (NR if not required).

RWP No. Contact RP for appropriate RW#

QWL 1260/90
R.P.

- L. Assign an individual to be the station watch outside the tank to render assistance to the individual entering the tank. Individual assigned has located the nearest Gaitronics in order to have direct communication with the control room in case of an emergency. This individual shall maintain personnel accountability and have (✓) verbal _____ line of sight) contact with personnel working inside of the tank. (Job foreman/supervisor will determine contact requirements.)

SHB 12-22-90

- M. Post Tank Entry Permit at access to tank.

SHB 12-22-90

2617 1268

FORT CALHOUN STATION
GENERAL FORM

SF-ST-CONT-0001

FC-62

R4 ISSUED 06-01-89

PAGE 1 OF 3

ATTACHMENT A

Tank Number 5 Stressing gallery

Briefing was conducted by Steven H. Botten 1130, 12-22-90
Signature Time Date

Personnel Briefed:

** If additional personnel were briefed at a later date, annotate person who performed briefing in remarks section. Ensure the person performing the briefings as reviewed step B of this tank entry permit.

Remarks: WORK COMPLETED ON 2-22-90. SHB

LIC-92-016R

ENCLOSURE 5

HVAC DESIGN BASIS VS ASCM

COMPARISON OF HVAC DESIGN CRITERIA

CRITERIA:	DESIGN BASIS	ASCM*
Restraint Spacing	8'-0"	Limited by Stress
Seismic Acceleration Rigid Non-rigid	H=0.311g, V=0.129g USAR Spectra	Per appropriate FRS based on calculated frequency
Normal Allowables	1.0*Working Stress	1.0*Working Stress
Upset (OBE) Allowables	1.33*Normal	1.0*Normal
Emergency Allowables	Not Defined	1.33*Normal
Faulted (SSE) Allowables Cold Formed Hot Rolled	0.9*Yield 0.9*Yield	1.60*Normal 1.0*Yield
Seismic Loads	Horiz + Vert	SRSS(X, Y, Z)

*Comparison is for Qualification by "Analysis" method only since other methods in ASCM are not addressed by Design Basis.