

UNITED STATES
NUCLEAR REGULATORY COMMISSION

REGION IV

611 RYAN PLAZA DRIVE, SUITE 400
ARLINGTON, TEXAS 76011-9064

AUG - 3 1992


Docket Nos. 50-445
50-446
License No. NPF-87
Construction Permit No. CPPR-127

TU Electric
ATTN: W. J. Cahill, Jr., Group Vice President
Nuclear Engineering and Operations
Skyway Tower
400 North Olive Street, L.B. 81
Dallas, Texas 75201

Gentlemen:

This is in reference to your program for testing and installation of Thermo-Lag fire barrier material in your Unit 2 facility. We request that you review the attached questions concerning the testing and installation criteria used for this material and inform us of the results of your review. This information is needed to assist us in our review of the acceptability of thermolag installations. Should you have any questions concerning this request, please contact me or Mr. T. P. Gwynn of my staff.

Sincerely,


Bill Beach, Director
Division of Reactor Projects

9208100102 920803
PDR ADOCK 05000445
P PDR

JE01

TU Electric

-2-

cc:

TU Electric

ATTN: Roger D. Walker, Manager of
Regulatory Affairs for Nuclear
Engineering Organization

Skyway Tower

400 North Olive Street, L.B. 81
Dallas, Texas 75201

Juanita Ellis

President - CASE

1426 South Polk Street

Dallas, Texas 75224

GDS Associates, Inc.

Suite 720

1850 Parkway Place

Marietta, Georgia 30067-8237

TU Electric

Bethesda Licensing

3 Metro Center, Suite 610

Bethesda, Maryland 20814

Jorden, Schulte, and Burchette

ATTN: William A. Burchette, Esq.

Counsel for Tex-La Electric

Cooperative of Texas

1025 Thomas Jefferson St., N.W.

Washington, D.C. 20007

Newman & Holtzinger, P.C.

ATTN: Jack R. Newman, Esq.

1615 L. Street, N.W.

Suite 1000

Washington, D.C. 20036

Department of Labor & Standards

ATTN: G. R. Bynog, Program Manager/
Chief Inspector

Boiler Division

P.O. Box 12157, Capitol Station

Austin, Texas 78711

Honorable Dale McPherson

County Judge

P.O. Box 851

Glen Rose, Texas 76043

TU Electric

-3-

Texas Radiation Control Program Director
1100 West 49th Street
Austin, Texas 78756

Owen L. Thero, President
Quality Technology Company
Lakeview Mobile Home Park, Lot 35
4793 E. Loop 820 South
Fort Worth, Texas 76119

TU Electric

-4-

AUG - 3 1992

bcc to DMB (1E01) - DRP

bcc distrib. by RIV:

J. L. Milhoan
 DRP
 Lisa Shea, RM/ALF, MS: MNBB 4503
 DRSS-FIPS
 Project Engineer (DRP/B)
 DRS
 R. Wise
 T. Gwynn

Resident Inspector (2)
 Section Chief (DRP/B)
 MIS System
 RSTS Operator
 RIV File
 Chief, Technical Support Section
 J. Gagliardo

RIV:AC	C:PSS/DRS	C:PSB/DRP	DD:DRP	DD:DRP
RWise <i>RW</i>	JEGagliardo	LAYandell	TPGwynn	ABBeach
7/31/92	7/1/92	7/1/92	8/3/92	8/3/92

bcc to DMS (IE01) - DRP

bcc distrib. by RIV:

J. L. Milhuan
 DRP
 Lisa Shea, RM/ALF, MS: MNBB 4503
 DRSS-FIPS
 Project Engineer (DRP/B)
 DRS
 R. Wise
 T. Gwynn

Resident Inspector (?)
 Section Chief (DRP/B)
 MIS System
 RSTS Operator
 RIV File
 Chief, Technical Support Section
 J. Gagliardo

RIV:AC	C:PSS/DRS	C:PSB/DRP	DD:DRP	D:DRP
RWise <i>RW</i>	JEGagliardo	LAYandell <i>lay</i>	TPGwynn	ABBeach
7/31/92	7/31/92	8/3/92	8/3/92	8/3/92

NRC Region IV Questions Concerning ThermoLag Installation In Unit 2

- a) What acceptance criteria are being used for the corner gap width of Thermo-Lag fire barrier envelopes?
- b) Is this criteria different from the acceptance criteria used for Unit 1 installations? If yes, please explain.
- c) What was the corner gap width acceptance criteria used to fabricate the test assemblies used at Omega Point Labs? Is this criteria different from that used in the unit 1 & 2 installations? If yes, please explain.
- d) Do you have QA/QC data relative to the actual installed corner gap width in the tested assemblies, and as installed in Unit 1 and Unit 2?
- e) What type filler material is used for filling the gaps during installation? Was the same type filler material used in Unit 1 and in the assemblies tested at Omega Point Labs?