APPENDIX A

NOTICE OF VIOLATION

Baltimore Gas and Electric Company Docket/License: Calvert Cliffs Units 1 and 2

50/317: DPR-53 50/318: DPR-69

As a result of the inspection conducted on December 18, 1984 - January 22, 1985, and in accordance with the NRC Enforcement Policy, (10 CFR2 Appendix C) the following violation was identified:

Technical Specification 6.12 "High Radiation Area", states in part "a. high radiation area in which the intensity of radiation is greater than 100 mrem/hr but less than 1000 mrem/hr shall be barricaded and conspicuously posted as a High Radiation Area and".

Contrary to the above, on January 14, 1985 the Unit 1, five foot West Penetration area contained staging with a ladder which provided access to a high radiation area which was not barricaded nor conspicuously posted as a high radiation area.

This is a Severity Level IV Violation (Supplement IV).

Pursuant to the provisions of 10 CFR2.201, Baltimore Gas and Electric Company is hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including : (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.