

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
631 PARK AVENUE
KING OF PRUSSIA, PENNSYLVANIA 19406

7/12/83

Bill Dicks

We have some inspectors at TMI-1 going through the Leak Rate Test records. They will be finished in about four weeks and we will have a report a few weeks after that.

I told Ben Hays what we are doing. He said he had discussed this matter with the other three Commissioners and they did not seem to be very concerned. He is not including this item in his investigation of the Hartman allegations unless, of course, we find some clear problems.

Tom Murley

cc: V. Stello
H. Denton

8. Examination of TMI-1 Reactor Coolant Inventory Surveillance Test Results

a. Allegations

None

b. Findings

- Four examples of water additions to the TMI-1 Makeup Tank, during the performance of a Reactor Coolant System Leak Rate Test without computer input, were identified in an analysis of 1200 test records for the period April 26, 1978 to December 31, 1978. The dates of these incidents and the personnel involved showed no consistent pattern. [C19]

c. Conclusions

None