PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-IV-84-25

This preliminary notification constitutes EAP! Y notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by NRC staff on this date.

FACILITY: Omaha Public Power District

Fort Calhoun Station

Docket 50-285 Blair, Nebraska Licensee Emergency Classification: Notification of Unusual Event

Site Area Emergency

General Emergency X Not Applicable

SUBJECT: PRESSURIZER SPRAY VALVE FLANGE LEAK

On Sunday, November 18, 1984, the licensee identified increased leakage from the Reactor Coolant System (RCS) on the pressurizer spray valve flange. An increase in iodine activity was noted in the containment atm sphere during the normal shutdown preparation. The plant was shutdown the evening of November 18, for repair of the leakage. The licensee is planning a 10-day to 2-week outage for maintenance work. The licensee plans a press release the morning of November 19, 1984. The SRI is onsite following licenses activities during normal plant shutdown and cooldown.

Region IV received notification of the event from the Headquarters Duty Officer at 9:30 p.m., CST, November 18, 1984.

The licensee plans a press release Monday morning November 19, 1984. The NRC does not plan a news release.

The state of Nebraska has been notified.

CONTACT: D. R. Hunter, 728-8103

L. A. Yandell, 864-3982

Chmn Palladino Comm. Zech Comm. Roberts Comm. Asselstine Comm. Bernthal SECY ACRS	PA MPA	Phillips /:2/p NRR DCS  Air Rights /: SP	OIA AEOD VIB	Willste 1/30p NMSS RES	MAIL: DOT: Trans Only-NA DMB (Original) INPO 1:460 NSAC 1:450
CA PDR Regions:				Licensee: (Reactor Licens	ees)

RPB2 ORHunter:gb 11/19/84

DRP&EP DR RPDenise' 11/19/84

PAO CEWisner 11/19/84

PCheck 11/19/84

RDMartin 11/19/84

8411260286 841119 PDR 1&E PNC-IV-84-025