



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401-1927
Telephone (612) 330-5500

August 6, 1992


Prairie Island Technical Specifications
Section 6.7.A.3

US Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
Docket Nos. 50-282 License Nos. DPR-42
50-306 DPR-60

Monthly Operating Report
July, 1992

Attached is the Monthly Operating Report for July, 1992 for the Prairie Island
Generating Plant.


Thomas M Parker
Manager
Nuclear Support Service

TMP/jlk

C: Director, Office of Resource Management
Regional Administrator-III, NRC
NRR Project Manager, NRC
NRC Resident Inspector
State of Minnesota - Kris Sanda

Attachment

9208120162 920731
PDR ADDCK 05000282
R PDR

JE24

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-282
UNIT PRAIRIE ISLAND
DATE AUGUST 4, 1972
COMPLETED BY DA. DUGSTAD
TELEPHONE 612-388-1121-4376

 JULY 1972

<u>DA.</u>	<u>AVERAGE DAILY POWER LEVEL (MWE-NET)</u>
1	515
2	519
3	517
4	518
5	518
6	518
7	516
8	515
9	514
10	515
11	511
12	516
13	517
14	515
15	515
16	515
17	514
18	517
19	513
20	517
21	514
22	516
23	517
24	519
25	517
26	516
27	515
28	514
29	515
30	514
31	514

AVERAGE LOADS ABOVE 503 MWE-NET ARE DUE
TO COOLER CONDENSER CIRCULATING WATER

