

PDR

U-0725
0982-L
L30-84(08-06)-L

CHOKSHI
201-1

ILLINOIS POWER COMPANY



CLINTON POWER STATION, P.O. BOX 678, CLINTON, ILLINOIS 61727

August 6, 1984

Docket No. 50-461

Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Subject: Clinton Power Station Unit 1
Documentation Review, Containment Liner/Pedestal

Dear Mr. Schwencer:

In accordance with Illinois Power letter U-0572 from G. E. Wuller to C. O. Thomas of the NRC dated, October 29, 1982, an independent review of 25% of the fabrication/erection documentation of the reactor vessel pedestal/containment liner for Clinton Power Station Unit 1 has been completed. The review, conducted by an authorized nuclear inspector employed by the Hartford Steam Boiler Inspection and Insurance Company, revealed that no major nonconformances were found. Twenty-six minor nonconforming conditions were identified. They have since been dispositioned.

Based on the small number of minor nonconformances found in the large number of documents examined, we believe that the 25% review level is sufficient to establish that the documentation is satisfactory. The results of the independent review are available for your examination. Should you have any questions, please contact me.

Sincerely yours,

Daniel I. Herborn
Director - Nuclear Licensing
and Configuration
Nuclear Station Engineering

DIH/JBC/lm

cc: B. L. Siegel, NRC Clinton Licensing Project Manager
NRC Resident Office
Regional Administrator, Region III, USNRC
Illinois Department of Nuclear Safety

DESIGNATED ORIGINAL

Certified By B. Siegel

8503140190 840806
PDR ADOCK 05000461
A PDR