Docket No. 50-354

Mr. R. L. Mittl, General Manager Nuclear Assurance & Regulation Public Service Electric & Gas Company P. O. Box 570, T22A Newark, New Jersey 07101

Dear Mr. Mittl:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - OUALITY ASSURANCE (QA)

The staff has reviewed Amendments 8 and 9 to the Hope Creek Final Safety Analysis Report to determine if these two most recent amendments degraded the QA program previously found acceptable. In the course of our review, we found instances where additional information is needed to assure ourselves that the QA program has not been degraded. Accordingly, you are requested to provide responses to the review comments noted in the Enclosure.

Please inform the NRC Project Manager of your response schedule for this request for additional information.

Sincerely,

A. Schwencer, Chief Licensing Branch No. 2 Division of Licensing

Enclosure: As stated

cc: See next page

Distribution: Docket File NRC PDR Local PDR PRC System NSIC LB#2 Reading EHylton DWagner **JPartlow** BGrimes 8503140238 850307 PDR ADOCK 05000354 EJordan Dewey, OELD ACRS (16) PDR JSpraul, QAB LR#2/DL/PM L.B#2/02/BC DWagner:1b ASchwencer 03/ 7/85 7/85 03/



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

MAR 7 1985

Docket No. 50-354

Mr. R. L. Mittl, General Manager Nuclear Assurance & Regulation Public Service Electric & Gas Company P. O. Box 570, T22A Newark, New Jersey 07101

Dear Mr. Mittl:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - QUALITY ASSURANCE (QA)

The staff has reviewed Amendments 8 and 9 to the Hope Creek Final Safety Analysis Report to determine if these two most recent amendments degraded the QA program previously found acceptable. In the course of our review, we found instances where additional information is needed to assure ourselves that the QA program has not been degraded. Accordingly, you are requested to provide responses to the review comments noted in the Enclosure.

Please inform the NRC Project Manager of your response schedule for this request for additional information.

Sincerely,

Martin

A. Schwencer, Chief Licensing Branch No. 2 Division of Licensing

Enclosure: As stated

cc: See next page

Hope Creek

Mr. R. L. Mittl, General Manager Nuclear Assurance & Regulation Public Service Electric & Gas Company P. O. Box 570 T22A Newark, New Jersey 07101

cc:

Troy B. Conner, Jr. Esquire Conner & Wetterhahn 1747 Pennsylvania Aveneu N.W. Washington, D.C. 20006

Richard Fryling, Jr., Esquire Associate General Solicitor Public Service Electric & Gas Co. P. O. Box 570 T5E Newark, New Jersey 07101

Mr. R. Blough Resident Inspector U.S.N.R.C. P. O. Box 241 Hancocks Bridge, New Jersey 08038

Richard F. Engel Deputy Attorney General Division of Law Environmental Protection Section Richard J. Hughes Justice Complex CN-112 Trenton, New Jersey 08625

Mr. Robert J. Touhey, Acting Director DNREC - Division of Environmental Control 89 Kings Highway P. O. Box 1401 Dover, Delaware 19903

Mr. R. S. Salvesen General Manager-Hope Creek Operation Public Service Electric & Gas Co. P.O. Box A Hancocks Bridge, New Jersey 08038

Mr. B. A. Preston Project Licensing Manager Public Service Electric & Gas Co. P. O. Box 570 T22A Newark, New Jersey 07101

Susan C. Remis Division of Public Interest Advocacy New Jersey State Department of the Public Advocate Richard J. Hughes Justice Complex CN-850 Trenton, New Jersey C8625 Gregory Minor Richard Hubbard Dale Bidenbauh MHB Technical Associates 1723 Hamilton Avenue, Suite K San Jose, California 95125

Office of Legal Counsel Department of Natural Resources and Environmental Control 89 Kings Highway P.O. Box 1401 Dover, Delaware 19903

Mr. K. W. Burrowes, Project Engineer Bechtel Power Corporation 50 Beale Street P. O. Box 3965 San Francisco, California 94119

Mr. J. M. Ashley Senior Licensing Engineer c/o PSE&G Company Bethesda Office Center, Suit 550 4520 East-West Highway Bethesda, Maryland 20814

Mr. A. E. Giardino Manager - Quality Assurance E&C Public Service Electric & Gas Co. P. O. Box A Hancocks Bridge, New Jersey 08038

HOPE CREEK GENERATING STATION

REQUEST FOR ADDITIONAL INFORMATION

QUALITY ASSURANCE (QA)

FSAR Amendment 8 (page 1.8-11) added the words underlined below to PSE&G's commitment to Regulatory Guide 1.26: "In addition, items designated 'R' in Table 3.2-1 will be included in the QA program during operation to the extent required by Regulatory Guide 1.143. Regulatory Guide 1.143, "Design Guidance for Radioactive Waste Management Systems, Structures, and Components Installed in Light-Water-Cooled Nuclear Power Plants," addresses QA for design and construction, but it does not address QA for operations. Identify what QA measures will be applied to items designated "R" in Table 3.2-1 during the operations phase of the Hope Creek Generating Station.

FSAR Amendment 9 addresses PSE&G's QA program for fire protection in several locations:

a) Page 20 of Table 11.1-1, describing differences from SRP acceptance criteria, states: "...certain fire system components purchased and installed prior to July 1, 1978, such as the fire water storage tanks, the tank heaters and associated controls, and the valve pit heaters are excluded from the 'F' program."

b) Section 9.5.1.1.19 on page 9.5.12, discussing the QA program for Bechtel's responsibilities, says the same thing.

c) Comment 61, added to page 40 of Table 3.2-1, states: "'F' Program is not retroactive to components purchased and installed prior to July 1, 1978. Fire water storage tanks, the tank heaters and associated controls, and the valve pit unit heaters are excluded from the 'F' program."

Clarify that each of these statements refers to the design and construction phase, and identify what QA measures will be applied to these items during the operations phase.

FSAR Amendment 9 (page 33 of Table 3.2-1) changed the seismic category of the unit vent stacks from I to NA and the corresponding QA requirements from Y (10 CFR 50, Appendix B) to N (QA requirements not applicable). Justify or eliminate these changes.

2.

3.

1.