

November 9, 1984

50-267

MEMORANDUM FOR: James R. Miller, Chief
ORB-3, NRR

FROM: Eric H. Johnson, Chief
RPB-1, RIV

SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY FR NOTICE - NOTICE
OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

Public Service Company of Colorado, Docket No. 50-267, Fort St. Vrain
Nuclear Generating Station, Platteville, Colorado

Date of application for amendment: August 23, 1984

Brief description of amendment: The amendment adds a surveillance requirement to the Technical Specifications related to the investigation and evaluation of steam generator tube leaks. An expanded, more detailed basis was provided by letter dated October 12, 1984.

Date of issuance: November 9, 1984

Effective date: November 9, 1984

Amendment No.: 45

Facility Operating License No. DPR-34. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register : 9/29/84; 49FR38408

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated November 9, 1984.

No significant hazards consideration comments received: 1.0

8411260583 841109
PDR ADOCK 05000267
P PDR

H005
1/0

Local Public Document Room location: Greeley Public Library, City Complex
Building, Greeley, Colorado

Original Signed By
E. H. Johnson

Eric H. Johnson, Chief
Reactor Project Branch 1

cc: P. C. Wagner
E. M. Haycraft
T. G. Colburn
G. C. Lainas
P. Kreutzer

DRS&P:LA
EMHaycraft
10/30/84

aw
RPB-1:PM
PCWagner
10/5/84

REI
RPB-1:SC
REIreland
11/5/84

EHJ
RPB-1:BC
EHJohnson
11/8/84

WLB
RIVAtty
WLBrown
11/9/84

RPD
D/DRS&P
RPDenise
11/9/84