



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

NORTH ATLANTIC ENERGY SERVICE CORPORATION, ET AL.*

DOCKET NO. 50-443

SEABROOK STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 12
License No. NPF-86

1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the North Atlantic Energy Service Corporation (NAESCO) (the licensee), acting for itself and as agent and representative of the 11 other utilities listed below and hereafter referred to as licensees, dated March 20, 1992, as supplemented on June 19, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

*North Atlantic Energy Service Corporation is authorized to act as agent for the North Atlantic Energy Corporation, the Canal Electric Company, The Connecticut Light and Power Company, EUA Power Corporation, Hudson Light & Power Department, Massachusetts Municipal Wholesale Electric Company, Montaup Electric Company, New England Power Company, New Hampshire Electric Cooperative, Inc., Taunton Municipal Light Plant, The United Illuminating Company, and Vermont Electric Generation and Transmission Cooperative, Inc., and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-86 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 12, and the Environmental Protection Plan contained in Appendix B are incorporated into Facility License No. NPF-86. NAESCO shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance. The upgrades and enhancements associated with replacement of the RTD Bypass System in this amendment will be implemented prior to entry into Mode 3 during restart from the second refueling outage. The resistance thermal detector cross-calibration and response time tests, and a reactor coolant system leak test can be completed following entry into Mode 3. Additionally, a flow calorimetric measurement will be performed upon achieving stable full power operation. All other testing required to demonstrate proper operation of modified components will be completed prior to entry into Mode 3.

FOR THE NUCLEAR REGULATORY COMMISSION



Victor Nerses, Acting Director
Project Directorate I-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 10, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 12

FACILITY OPERATING LICENSE NO. NPF-86

DOCKET NO. 50-443

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. Overlap pages have been provided.

<u>Remove</u>	<u>Insert</u>
2-4	2-4
2-5	2-5
2-7	2-7
2-8	2-8
2-10	2-10
3/4 2-10	3/4 2-10
3/4 3-9	3/4 3-9
3/4 3-13	3/4 3-13
B 3/4 2-4	B 3/4 2-4

SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

2.2 LIMITING SAFETY SYSTEM SETTINGS

REACTOR TRIP SYSTEM INSTRUMENTATION SETPOINTS

2.2.1 The Reactor Trip System Instrumentation and Interlock Setpoints shall be set consistent with the Trip Setpoint values shown in Table 2.2-1.

APPLICABILITY: As shown for each channel in Table 3.3-1.

ACTION:

- a. With a Reactor Trip System Instrumentation or Interlock Setpoint less conservative than the value shown in the Trip Setpoint column but more conservative than the value shown in the Allowable Value column of Table 2.2-1, adjust the Setpoint consistent with the Trip Setpoint value.
- b. With the Reactor Trip System Instrumentation or Interlock Setpoint less conservative than the value shown in the Allowable Value column of Table 2.2-1, either:
 1. Adjust the Setpoint consistent with the Trip Setpoint value of Table 2.2-1 and determine within 12 hours that Equation 2.2-1 was satisfied for the affected channel, or
 2. Declare the channel inoperable and apply the applicable ACTION statement requirement of Specification 3.3.1 until the channel is restored to OPERABLE status with its Setpoint adjusted consistent with the Trip Setpoint value.

$$\text{Equation 2.2-1} \quad Z + R + S \leq TA$$

Where:

Z = The value from Column Z of Table 2.2-1 for the affected channel,

R = The "as measured" value (in percent span) of rack error for the affected channel,

S = Either the "as measured" value (in percent span) of the sensor error, or the value from Column S (Sensor Error) of Table 2.2-1 for the affected channel, and

TA = The value from Column TA (Total Allowance) of Table 2.2-1 for the affected channel.

TABLE 2.2-1
 REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

FUNCTIONAL UNIT	TOTAL ALLOWANCE (TA)	Z	SENSOR ERROR (S)	TRIP SETPOINT	ALLOWABLE VALUE
1. Manual Reactor Trip	N.A.	N.A.	N.A.	N.A.	N.A.
2. Power Range, Neutron Flux					
a. High Setpoint	7.5	4.56	0	<109% of RTP*	<111.1% of RTP*
b. Low Setpoint	8.3	4.56	0	<25% of RTP*	<27.1% of RTP*
3. Power Range, Neutron Flux, High Positive Rate	1.6	0.5	0	<5% of RTP* with a time constant >2 seconds	<6.3% of RTP* with a time constant >2 seconds
4. Power Range, Neutron Flux, High Negative Rate	1.6	0.5	0	<5% of RTP* with a time constant >2 seconds	<6.3% of RTP* with a time constant >2 seconds
5. Intermediate Range, Neutron Flux	17.0	8.41	0	<25% of RTP*	<31.1% of RTP*
6. Source Range, Neutron Flux	17.0	10.01	0	<10 ⁵ cps	<1.6 x 10 ⁵ cps
7. Overtemperature ΔT	6.5	3.5	1.7** +0.5**	See Note 1	See Note 2
8. Overpower ΔT	4.9	2.2	1.7	See Note 3	See Note 4
9. Pressurizer Pressure - Low	3.12	0.86	0.99	>1945 psig	>1,931 psig
10. Pressurizer Pressure - High	3.12	1.00	0.99	<2385 psig	<2,398 psig

*RTP = RATED THERMAL POWER

**The sensor error for T_{avg} is 1.7 and the sensor error for Pressurizer Pressure is 0.5. "As measured" sensor errors may be used in lieu of either or both of these values, which then must be summed to determine the overtemperature ΔT total channel value for S.

TABLE 2.2-1 (Continued)
REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TOTAL ALLOWANCE (TA)</u>	<u>Z</u>	<u>SENSOR ERROR (S)</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
11. Pressurizer Water Level - High	8.0	4.20	0.84	<92% of instrument span	<93.75% of instrument span
12. Reactor Coolant Flow - Low	2.5	1.9	0.6	>90% of loop design flow ^a	>89.3% of loop design flow ^a
13. Steam Generator Water Level Low - Low	14.0	12.53	0.55	>14.0% of narrow range instrument span	>12.6% of narrow range instrument span
14. Undervoltage - Reactor Coolant Pumps	15.0	1.39	0	>10,200 volts	>9,822 volts
15. Underfrequency - Reactor Coolant Pumps	2.9	0	0	>55.5 Hz	>55.3 Hz
16. Turbine Trip					
a. Low Fluid Oil Pressure	N.A.	N.A.	N.A.	>500 psig	>450 psig
b. Turbine Stop Valve Closure	N.A.	N.A.	N.A.	>1% open	>1% open
17. Safety Injection Input from ESF	N.A.	N.A.	N.A.	N.A.	N.A.

^aLoop design flow = 95,700 gpm

TABLE 2.2-1 (Continued)
 REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

FUNCTIONAL UNIT	TOTAL ALLOWANCE (TA)	Z	SENSOR ERROR (S)	TRIP SETPOINT	ALLOWABLE VALUE
18. Reactor Trip System Interlocks					
a. Intermediate Range Neutron Flux, P-6	N.A.	N.A.	N.A.	$>1 \times 10^{-10}$ amp	$>6 \times 10^{-11}$ amp
b. Low Power Reactor Trips Block, P-7					
1) P-10 input	N.A.	N.A.	N.A.	$<10\%$ of RTP*	$<12.1\%$ of RTP*
2) P-13 input	N.A.	N.A.	N.A.	$<10\%$ RTP* Turbine Impulse Pressure Equivalent	$<12.3\%$ RTP* Turbine Impulse Pressure Equivalent
c. Power Range Neutron Flux, P-8	N.A.	N.A.	N.A.	$<50\%$ of RTP*	$<52.1\%$ of RTP*
d. Power Range Neutron Flux, P-9	N.A.	N.A.	N.A.	$<20\%$ of RTP*	$<22.1\%$ of RTP*
e. Power Range Neutron Flux, P-10	N.A.	N.A.	N.A.	$>10\%$ of RTP*	$>7.9\%$ of RTP*
f. Turbine Impulse Chamber Pressure, P-13	N.A.	N.A.	N.A.	$<10\%$ RTP* Turbine Impulse Pressure Equivalent	$<12.3\%$ RTP* Turbine Impulse Pressure Equivalent
19. Reactor Trip Breakers	N.A.	N.A.	N.A.	N.A.	N.A.
20. Automatic Trip and Interlock Logic	N.A.	N.A.	N.A.	N.A.	N.A.

*RTP = RATED THERMAL POWER

TABLE 2.2-1 (Continued)

TABLE NOTATIONS

NOTE 1: OVERTEMPERATURE ΔT

$$\Delta T \frac{(1 + \tau_1 S)}{(1 + \tau_2 S)} \frac{(1)}{(1 + \tau_3 S)} \leq \Delta T_0 \{K_1 - K_2 \frac{(1 + \tau_4 S)}{(1 + \tau_5 S)} [T \frac{(i)}{(1 + \tau_6 S)} - T'] + K_3(P - P') - f_1(\Delta T)\}$$

Where: ΔT = Measured ΔT by RTD Instrumentation;
 $\frac{1 + \tau_1 S}{1 + \tau_2 S}$ = Lead-lag compensator on measured ΔT ;
 τ_1, τ_2 = Time constants utilized in lead-lag compensator for ΔT , $\tau_1 \geq 8$ s,
 $\tau_2 \leq 3$ s;
 $\frac{1}{1 + \tau_3 S}$ = Lag compensator on measured ΔT ;
 τ_3 = Time constants utilized in the lag compensator for ΔT , $\tau_3 = 0$ s;
 ΔT_0 = Indicated ΔT at RATED THERMAL POWER;
 K_1 = 1.0995;
 K_2 = 0.0112/ $^{\circ}$ F;
 $\frac{1 + \tau_4 S}{1 + \tau_5 S}$ = The function generated by the lead-lag compensator for T_{avg}
dynamic compensation;
 τ_4, τ_5 = Time constants utilized in the lead-lag compensator for T_{avg} , $\tau_4 \geq 33$ s,
 $\tau_5 \leq 4$ s;
 T = Average temperature, $^{\circ}$ F;
 $\frac{1}{1 + \tau_6 S}$ = Lag compensator on measured T_{avg} ;
 τ_6 = Time constant utilized in the measured T_{avg} lag compensator, $\tau_6 = 0$ s;

TABLE 2.2-1 (Continued)

TABLE NOTATIONS

NOTE 1: (Continued)

$T' \leq 588.5^{\circ}\text{C}$ (Nominal T_{avg} at RATED THERMAL POWER);

$K_3 = 0.000519/\text{psig}$;

$P =$ Pressurizer pressure, psig;

$P' = 2235$ psig (Nominal RCS operating pressure);

$S =$ Laplace transform operator, s^{-1} ;

and $f_1(\Delta I)$ is a function of the indicated difference between top and bottom detectors of the power-range neutron ion chambers; with gains to be selected based on measured instrument response during plant start-up tests so that:

- (1) For $q_t - q_b$ between -35% and $+8\%$, $f_1(\Delta I) = 0$, where q_t and q_b are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and $q_t + q_b$ is total THERMAL POWER in percent of RATED THERMAL POWER;
- (2) For each percent that the magnitude of $q_t - q_b$ exceeds -35% , the ΔT Trip Setpoint shall be automatically reduced by 1.09% of its value at RATED THERMAL POWER; and
- (3) For each percent that the magnitude of $q_t - q_b$ exceeds $+8\%$, the ΔT Trip Setpoint shall be automatically reduced by 1.00% of its value at RATED THERMAL POWER.

NOTE 2: The channel's maximum Trip Setpoint shall not exceed its computed Trip Setpoint by more than 2.5% of ΔT span.

TABLE 2.2-1 (Continued)
 TABLE NOTATIONS (Continued)

NOTE 3: OVERPOWER ΔT

$$\Delta T \frac{(1 + \tau_1 S)}{(1 + \tau_2 S)} \frac{(1)}{(1 + \tau_3 S)} \leq \Delta T_0 \left\{ K_4 - K_5 \frac{(\tau_7 S)}{(1 + \tau_7 S)} \frac{(1)}{(1 + \tau_6 S)} T - K \left[T \frac{(1)}{(1 + \tau_6 S)} - T'' \right] - f_2(\Delta I) \right\}$$

Where: ΔT = As defined in Note 1,

$\frac{1 + \tau_1 S}{1 + \tau_2 S}$ = As defined in Note 1,

τ_1, τ_2 = As defined in Note 1,

$\frac{1}{1 + \tau_3 S}$ = As defined in Note 1,

τ_3 = As defined in Note 1,

ΔT_0 = As defined in Note 1,

K_4 = 1.09,

K_5 = 0.02/°F for increasing average temperature and 0 for decreasing average temperature,

$\frac{\tau_7 S}{1 + \tau_7 S}$ = The function generated by the rate-lag compensator for T_{avg} dynamic compensation,

τ_7 = Time constants utilized in the rate-lag compensator for T_{avg} , $\tau_7 \geq 10$ s,

$\frac{1}{1 + \tau_6 S}$ = As defined in Note 1,

τ_6 = As defined in Note 1,

TABLE 2.2-1 (Continued)
TABLE NOTATIONS (Continued)

NOTE 3: (Continued)

$$K_6 = 0.001386/^{\circ}\text{F for } T > T'' \text{ and } K_6 = 0 \text{ for } T \leq T'',$$

$$T = \text{As defined in Note 1,}$$

$$T'' = \text{Indicated } T_{\text{avg}} \text{ at RATED THERMAL POWER (Calibration temperature for } \Delta T \text{ instrumentation, } \leq 588.5^{\circ}\text{F),}$$

$$S = \text{As defined in Note 1, and}$$

$$f_2(\Delta I) = 0 \text{ for all } \Delta I.$$

NOTE 4: The channel's maximum Trip Setpoint shall not exceed its computed Trip Setpoint by more than 2.0% of ΔT span.

POWER DISTRIBUTION LIMITS

3/4.2.4 QUADRANT POWER TILT RATIO

LIMITING CONDITION FOR OPERATION

3.2.4 The QUADRANT POWER TILT RATIO shall not exceed 1.02.

APPLICABILITY: MODE 1, above 50% of RATED THERMAL POWER*.

ACTION:

With the QUADRANT POWER TILT RATIO determined to exceed 1.02:

- a. Within 2 hours reduce THERMAL POWER at least 3% from RATED THERMAL POWER for each 1% of indicated QUADRANT POWER TILT RATIO in excess of 1 and similarly reduce the Power Range Neutron Flux-High Trip Setpoints within the next 4 hours.
- b. Within 24 hours and every 7 days thereafter, verify that $F_Q(Z)$ (by F_{xy} evaluation) and $F_{\Delta H}^N$ are within their limits by performing Surveillance Requirements 4.2.2.2 and 4.2.3.2. THERMAL POWER and setpoint reductions shall then be in accordance with the ACTION statements of Specifications 3.2.2 and 3.2.3.

SURVEILLANCE REQUIREMENTS

4.2.4.1 The QUADRANT POWER TILT RATIO shall be determined to be within the limit above 50% of RATED THERMAL POWER by:

- a. Calculating the ratio at least once per 7 days when the alarm is OPERABLE, and
- b. Calculating the ratio at least once per 12 hours during steady-state operation when the alarm is inoperable.

4.2.4.2 The QUADRANT POWER TILT RATIO shall be determined to be within the limit when above 75% of RATED THERMAL POWER with one Power Range channel inoperable by using the movable incore detectors to confirm indicated QUADRANT POWER TILT RATIO at least once per 12 hours by either:

- a. Using the four pairs of symmetric thimble locations or
- b. Using the movable incore detection system to monitor the QUADRANT POWER TILT RATIO subject to the requirements of Specification 3.3.3.2.

*See Special Test Exceptions Specification 3.10.2.

POWER DISTRIBUTION LIMITS

3/4.2.5 DNB PARAMETERS

LIMITING CONDITION FOR OPERATION

3.2.5 The following DNB-related parameters shall be maintained within the the follow ; limits:

- a. Reactor Coolant System $T_{avg} \leq 594.3^{\circ}F$
- b. Pressurizer Pressure ≥ 2205 psig*
- c. Reactor Coolant System flow, $\geq 392,000$ gpm**

APPLICABILITY: MODE 1.

ACTION:

With any of the above parameters exceeding its limit, restore the parameter to within its limit within 2 hours or reduce THERMAL POWER to less than 5% of RATED THERMAL POWER within the next 4 hours.

SURVEILLANCE REQUIREMENTS

4.2.5.1 Each of the parameters shown above shall be verified to be within its limits at least once per 12 hours.

4.2.5.2 The RCS flow rate indicators shall be subjected to CHANNEL CALIBRATION at least once per 18 months.

4.2.5.3 The RCS total flow rate shall be determined by a precision heat balance measurement to be within its limit prior to operation above 95% of RATED THERMAL POWER after each fuel loading. The provisions of Specification 4.0.4 are not applicable for entry into MODE 1.

*Limit not applicable during either a THERMAL POWER ramp in excess of 5% of RATED THERMAL POWER per minute or a THERMAL POWER step in excess of 10% of RATED THERMAL POWER.

**Includes a 2.4% flow measurement uncertainty.

TABLE 4.3-1

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>ANALOG CHANNEL OPERATIONAL TEST</u>	<u>TRIP ACTUATING DEVICE OPERATIONAL TEST</u>	<u>MODES FOR WHICH ACTUATION SURVEILLANCE LOGIC TEST IS REQUIRED</u>
1. Manual Reactor Trip	N.A.	N.A.	N.A.	R(13)	N.A. 1, 2, 3*
2. Power Range, Neutron Flux					
a. High Setpoint	S	D(2, 4), M(3, 4), Q(4, 6), R(4, 5)	Q(16)	N.A.	N.A. 1, 2
b. Low Setpoint	S	R(4)	S/U(1)	N.A.	N.A. 1***, 2
3. Power Range, Neutron Flux, High Positive Rate	N.A.	R(4)	Q(16)	N.A.	N.A. 1, 2
4. Power Range, Neutron Flux, High Negative Rate	N.A.	R(4)	Q(16)	N.A.	N.A. 1, 2
5. Intermediate Range, Neutron Flux	S	R(4, 5)	S/U(1)	N.A.	N.A. 1***, 2
6. Source Range, Neutron Flux	S	R(4, 5)	S/U(1), Q(9, 16)	N.A.	N.A. 1**, 3, 4, 5
7. Overtemperature ΔT	S	R	Q(16)	N.A.	N.A. 1, 2
8. Overpower ΔT	S	R	Q(16)	N.A.	N.A. 1, 2
9. Pressurizer Pressure--Low	S	R	Q(16, 17)	N.A.	N.A. 1
10. Pressurizer Pressure--High	S	R	Q(16, 17)	N.A.	N.A. 1, 2
11. Pressurizer Water Level--High	S	R	Q(16)	N.A.	N.A. 1
12. Reactor Coolant Flow--Low	S	R	Q(16)	N.A.	N.A. 1

SEABROOK - UNIT 1

3/4 3-10

TABLE 4.3-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

FUNCTIONAL UNIT	CHANNEL CHECK	CHANNEL CALIBRATION	ANALOG CHANNEL OPERATIONAL TEST	TRIP ACTUATING DEVICE OPERATIONAL TEST	ACTUATION LOGIC TEST	MODES FOR WHICH SURVEILLANCE IS REQUIRED
13. Steam Generator Water Level-- Low-Low	S	R	Q(16, 17)	N.A.	N.A.	1, 2
14. Undervoltage - Reactor Coolant Pumps	N.A.	R	N.A.	Q(16)	N.A.	1
15. Underfrequency - Reactor Coolant Pumps	N.A.	R	N.A.	Q(16)	N.A.	1
16. Turbine Trip						
a. Low Fluid Oil Pressure	N.A.	R	N.A.	S/U(1, 10)	N.A.	1
b. Turbine Stop Valve Closure	N.A.	R	N.A.	S/U(1, 10)	N.A.	1
17. Safety Injection Input from ESF	N.A.	N.A.	N.A.	R	N.A.	1, 2
18. Reactor Trip System Interlocks						
a. Intermediate Range Neutron Flux, P-6	N.A.	R(4)	R	N.A.	N.A.	2**
b. Low Power Reactor Trips Block, P-7	N.A.	R(4)	R	N.A.	N.A.	1
c. Power Range Neutron Flux, P-8	N.A.	R(4)	R	N.A.	N.A.	1
d. Power Range Neutron Flux, P-9	N.A.	R(4)	R	N.A.	N.A.	1

TABLE 4.3-1 (Continued)

TABLE NOTATIONS (Continued)

- (12) Number not used.
- (13) The TRIP ACTUATING DEVICE OPERATIONAL TEST shall independently verify the OPERABILITY of the undervoltage and shunt trip circuits for the Manual Reactor Trip Function. The test shall also verify the OPERABILITY of the Bypass Breaker trip circuit(s).
- (14) Local manual shunt trip prior to placing breaker in service.
- (15) Automatic undervoltage trip.
- (16) Each channel shall be tested at least every 92 days on a STAGGERED TEST BASIS.
- (17) These channels also provide inputs to ESFAS. Comply with the applicable MODES and surveillance frequencies of Specification 4.3.2.1 for any portion of the channel required to be OPERABLE by Specification 3.3.2.

INSTRUMENTATION

3/4.3.2 ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.2 The Engineered Safety Features Actuation System (ESFAS) instrumentation channels and interlocks shown in Table 3.3-3 shall be OPERABLE with their Trip Setpoints set consistent with the values shown in the Trip Setpoint column of Table 3.3-4.

APPLICABILITY: As shown in Table 3.3-3.

ACTION:

- a. With an ESFAS Instrumentation or Interlock Trip Setpoint trip less conservative than the value shown in the Trip Setpoint column but more conservative than the value shown in the Allowable Value column of Table 3.3-4, adjust the Setpoint consistent with the Trip Setpoint value.
- b. With an ESFAS Instrumentation or Interlock Trip Setpoint less conservative than the value shown in the Allowable Value column of Table 3.3-4, either:
 1. Adjust the Setpoint consistent with the Trip Setpoint value of Table 3.3-4, and determine within 12 hours that Equation 2.2-1 was satisfied for the affected channel, or
 2. Declare the channel inoperable and apply the applicable ACTION statement requirements of Table 3.3-3 until the channel is restored to OPERABLE status with its Setpoint adjusted consistent with the Trip Setpoint value.

Equation 2.2-1

$$Z + R + S \leq TA$$

Where:

Z = The value from Column Z of Table 3.3-4 for the affected channel,

R = The "as measured" value (in percent span) of rack error for the affected channel,

S = Either the "as measured" value (in percent span) of the sensor error, or the value from Column S (Sensor Error) of Table 3.3-4 for the affected channel, and

TA = The value from Column TA (Total Allowance) of Table 3.3-4 for the affected channel.

- c. With an ESFAS instrumentation channel or interlock inoperable, take the ACTION shown in Table 3.3-3.

POWER DISTRIBUTION LIMITS

BASES

3/4.2.2 and 3/4.2.3 HEAT FLUX HOT CHANNEL FACTOR and NUCLEAR ENTHALPY RISE HOT CHANNEL FACTOR (Continued)

$F_{\Delta H}^N$ will be maintained within its limits provided Conditions a. through d. above are maintained. The relaxation of $F_{\Delta H}^N$ as a function of THERMAL POWER allows changes in the radial power shape for all permissible rod insertion limits.

Fuel rod bowing reduces the value of DNBR. Credit is available to offset this reduction in the generic margin. The generic margins, totaling 9.1% DNBR completely offset any rod bow penalties. This margin includes the following:

- a. Design limit DNBR of 1.30 vs. 1.28,
- b. Grid spacing (K_g) of 0.046 vs. 0.059,
- c. Thermal diffusion coefficient of 0.038 vs. 0.059,
- d. DNBR multiplier of 0.86 vs. 0.88, and
- e. Pitch reduction.

The applicable values of rod bow penalties are referenced in the FSAR.

When an F_Q measurement is taken, an allowance for both experimental error and manufacturing tolerance must be made. An allowance of 5% is appropriate for a full-core map taken with the Incore Detector Flux Mapping System, and a 3% allowance is appropriate for manufacturing tolerance.

The Radial Peaking Factor, $F_{xy}(Z)$, is measured periodically to provide assurance that the Hot Channel Factor, $F_Q(Z)$, remains within its limit. The F_{xy} limit for RATED THERMAL POWER (F_{xy}^{RTP}) as provided in the CORE OPERATING LIMITS REPORT per Specification 6.8.1.6 was determined from expected power control maneuvers over the full range of burnup conditions in the core.

When RCS $F_{\Delta H}^N$ is measured, no additional allowances are necessary prior to comparison with the established limit or a measurement error of 4% for $F_{\Delta H}^N$ has been allowed for in determination of the design DNBR value.

3/4.2.4 QUADRANT POWER TILT RATIO

The purpose of this specification is to detect gross changes in core power distribution between monthly incore flux maps. During normal operation the QUADRANT POWER TILT RATIO is set equal to zero once acceptability of core peaking factors has been established by review of incore maps. The limit of 1.02 is established as an indication that the power distribution has changed enough to warrant further investigation.

POWER DISTRIBUTION LIMITS

BASES

3/4.2.5 DNB PARAMETERS

The limits on the DNB-related parameters assure that each of the parameters is maintained within the normal steady-state envelope of operation assumed in the transient and accident analyses. The limits are consistent with the initial FSAR assumptions and have been analytically demonstrated adequate to maintain a minimum DNBR of 1.30 throughout each analyzed transient. Operating procedures include allowances for measurement and indication uncertainty so that the limits of 594.3°F for T_{avg} and 2205 psig for pressurizer are not exceeded.

The measurement error of 2.4% for RCS total flow rate is based upon performing a precision heat balance and using the result to normalize the RCS flow rate indicators. Potential fouling of the feedwater venturi which might not be detected could bias the result from the precision heat balance in a nonconservative manner. Therefore, a penalty of 0.1% for undetected fouling of the feedwater venturi is applied. Any fouling which might bias the RCS flow rate measurement greater than 0.1% can be detected by monitoring and trending various plant performance parameters. If detected, action shall be taken before performing subsequent precision heat balance measurements, i.e., either the effect of the fouling shall be quantified and compensated for in the RCS flow rate measurement or the venturi shall be cleaned to eliminate the fouling.

The 12-hour periodic surveillance of these parameters through instrument readout is sufficient to ensure that the parameters are restored within their limits following load changes and other expected transient operation.

The periodic surveillance of indicated RCS flow is sufficient to detect only flow degradation which could lead to operation outside the specified limit.