

Duke Power Company
Catawba Nuclear Generation Department
4800 Concord Road
York, SC 29745

M.S. TUCKMAN
Vice President
(803)831-3205 Office
(803)831-3426 FAX



DUKE POWER

August 5, 1992

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Subject: Catawba Nuclear Station, Unit 2
Docket No. 50-414
Twenty-third Quarterly Update to Startup Report

In accordance with Section 6.9.1.3 of the Catawba Nuclear Station Technical Specifications, find attached the twenty-third quarterly update to the Unit 2 Startup Report. As indicated in the report, all testing is complete.

Very truly yours,

M. S. Tuckman

CRL/23STUPSR

Attachment

xc: S. D. Ebnetter
Regional Administrator, Region II

R. E. Martin, ONRR

W. T. Orders
Senior Resident Inspector

140029

9208140200 920805
PDR ADOCK 05000414
R PDR

STARTUP REPORT QUARTERLY UPDATE
CATAWBA UNIT 2 CYCLE 1
August 5, 1992

TESTING COMPLETED DURING QUARTER

The 2A Diesel Generator piping was modified and tested. Vibration levels on the 2A Diesel Generator now meet the acceptance criteria.

STATUS OF TESTING NOT COMPLETE

All testing is complete.