

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) DIABLO CANYON UNIT 1	DOCKET NUMBER (2) 0 5 0 0 0 1	PAGE (3) 1 OF 1
---	----------------------------------	--------------------

TITLE (4)  
SEALED SOURCE SURVEILLANCE TEST NOT PERFORMED WITHIN SPECIFIED TIME PERIOD

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)							
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES			DOCKET NUMBER(S)				
0	2	0	5	8	5	8	5	0	1	0	0	0	5	0	0	0

OPERATING MODE (9) 1	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)				
POWER LEVEL (10) 0 0 6	20.402(b)	20.406(c)	50.73(a)(2)(iv)	73.71(b)	OTHER (Specify in Abstract below and in Text, NRC Form 366A)
	20.406(a)(1)(i)	50.36(c)(1)	50.73(a)(2)(v)	73.71(c)	
	20.406(a)(1)(ii)	50.36(c)(2)	50.73(a)(2)(vii)		
	20.406(a)(1)(iii)	50.73(a)(2)(i)	50.73(a)(2)(viii)(A)		
	20.406(a)(1)(iv)	50.73(a)(2)(ii)	50.73(a)(2)(viii)(B)		
	20.406(a)(1)(v)	50.73(a)(2)(iii)	50.73(a)(2)(x)		

LICENSEE CONTACT FOR THIS LER (12)	
NAME DAVID P. SISK, REGULATORY COMPLIANCE ENGINEER	TELEPHONE NUMBER 8 1 0 1 5 5 1 9 1 5 1 - 1 7 1 3 1 5 1 1

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)										
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS	

SUPPLEMENTAL REPORT EXPECTED (14) <input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE) <input checked="" type="checkbox"/> NO	EXPECTED SUBMISSION DATE (15) MONTH:    DAY:    YEAR:
--	--

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On February 5, 1985, with Unit 1 in Mode 1 (power operation), an internal chemistry and radiation protection (CARP) audit of the radioactive source controls program determined that the 6-month leak test on a 400 microcurie Cesium-137 check source (source Number 400) was not performed within the time requirements (due September 11, 1983) of Radiation Control Procedure RCP D-10, "Handling and Accountability of Radioactive Sources," and Technical Specification 4.7.8.1.2, Item a.1. The sealed source was subsequently leak-tested on February 5, 1985, and found to have no leaks.

The cause of this event was the incorrect classification of the sealed source as "exempt" on the hard copy and computer tracking records prepared by plant technical personnel.

The internal audit consisted of an inventory of all radioactive sources and the check against applicable testing requirements. Only source Number 400 (as described above) was found to be unsatisfactory.

To prevent recurrence, the applicable records have been corrected. In addition, sources requiring leak tests will be segregated in special manual and computer files. Also, CARP personnel are receiving radioactive source control training with particular emphasis on the requirements of Procedure RCP D-10.

This event had no safety consequences and in no way affected the health and safety of the public.

IE 22  
1/1

# PACIFIC GAS AND ELECTRIC COMPANY

PG&E

77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 910-372-6587

JAMES D. SHIFFER  
VICE PRESIDENT  
NUCLEAR POWER GENERATION

March 5, 1985

PGandE Letter No.: DCL-85-094

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Re: Docket No. 50-275, OL-DPR-80  
Diablo Canyon Unit 1  
Licensee Event Report 85-010-00  
Sealed Source Surveillance Test Not Performed  
Within Specified Time Period


Gentlemen:

Pursuant to 10 CFR 50.73(a)(2)(i)(B), PGandE is submitting the enclosed Licensee Event Report concerning an event in which the surveillance test of a sealed source was not performed within the technical specification frequency requirements.

This event has in no way affected the public's health and safety.

Kindly acknowledge receipt of this material on the enclosed copy of this letter and return it in the enclosed addressed envelope.

Sincerely,

  
for J. D. Shiffer

Enclosure

cc: J. B. Martin  
Service List

IE22  
1/1