

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of

Duquesne Light Company  
(Beaver Valley Power Station, Unit No. 1)

)  
) Docket No. 50-334  
)

APPLICATION FOR AMENDMENT  
TO OPERATING LICENSE


Pursuant to Section 50.90 of the regulations of the U. S. Nuclear Regulatory Commission (the "Commission"), Duquesne Light Company ("DLC"), holder of Operating License No. DPR-66, hereby requests that the Technical Specifications set forth in Appendix A to that license be amended to require a minimum of two operating reactor coolant loops during Mode 3 operation.

The proposed technical specification change is set forth in Attachment A to this Application. A safety evaluation is set forth in Attachment B. Based on the guidance provided by the Commission, the proposed changes have been determined to be safe and involve no significant hazards consideration in accordance with 10CFR 50.92.

WHEREFORE, Applicant respectfully requests that Appendix A to Operating License No. DPR-66 be amended in the form attached hereto as Attachment A.

Duquesne Light Company

By

  
J. J. Carey  
Vice President, Nuclear

Subscribed and sworn to before me

on this 19th day of November, 1984

Sheila M. Fattore

SHEILA M. FATTORE, NOTARY PUBLIC  
SHIPPENSBORO, BEAVER COUNTY  
MY COMMISSION EXPIRES SEPT. 15, 1985  
Member, Pennsylvania Association of Notaries

8411270254 841114  
PDR ADOCK 05000334  
P PDR