



**GULF STATES UTILITIES COMPANY**

POST OFFICE BOX 2951 • BEAUMONT, TEXAS 77704  
AREA CODE 713 838-6631

November 16, 1984  
RBG-19365  
File Nos. G9.5


Mr. Harold E. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Mr. Denton:

River Bend Station Unit 1  
Docket No. 50-458

This letter is Gulf States Utilities (GSU) response to your October 17, 1984 request for additional information concerning River Bend Station shear reinforcement design. Please find enclosed forty (40) copies of GSU's response to items 1 through 4. These responses were discussed with your Mr. H. Polk on October 23, 1984. If you have any additional questions please contact us.

Sincerely,



J. E. Booker  
Manager-Engineering,  
Nuclear Fuels & Licensing  
River Bend Nuclear Group

*JEB/JAE/BEH/lp*

Attachment

cc: D. G. Eisenhut

8411270323 841116  
PDR ADOCK 05000458  
A PDR

3001  
11

RESPONSE TO QUESTIONS RAISED BY THE NRC  
ON REACTOR SHIELD BUILDING SHEAR REINFORCEMENT

Item 1

The demand for shear reinforcing in the shield building was reduced, not as a result of the concrete fill in 1981, but because the thermal conditions were redefined in 1980.

The original design (performed in 1974) assumed the accident condition peak pool temperature, 185°F, as the temperature in the annulus between the containment and the shield building. The design assumed, conservatively, a straight line temperature gradient zone 185°F inside of the shield building to 68°F on the outside soil (below el 95 ft 0 in.). Also, the foundation mat surface temperature at the shield building was conservatively assumed to be 90°F.

A revision to this design, performed in 1980 (prior to the 1981 decision on placing concrete fill between the shield building and containment) was based on a revised annulus space temperature of 170°F (see Attachment 1). The design used a 24-hour gradient, 153°F to 68°F, as a governing case (see Attachment 1) for the shield building below el 95 ft 0 in. (exposed to soil). Also, the surface temperature of the foundation mat at the shield building was revised to 153°F. This increase in the foundation mat surface temperature, combined with the reduction in the inside face design temperature of the shield building resulted in shears near the base of the shield building (el 70 ft 0 in. to el 79 ft) which were lower than the capacity of concrete, thus requiring no shear reinforcement.

Calculation No. 201.120-067, Revision 1 (Attachment 2), shows that the shield building design (prior to the concrete fill) is adequate without the shear reinforcement shown, as required by the 1974 calculations.

Item 2

Calculation No. 201.120-067, Revision 0 (1976), calculated shear reinforcement at el 70 ft 0 in. prior to the addition of the concrete fill to be .569 sq in. (see Attachment 3). This calculation was updated to include the boundary conditions from Calculation No. 201.120-096. Calculation No. 201.120-067, Revision 1 (Attachment 2), shows that no shear reinforcement at el 70 ft 0 in. is required.

With the addition of the concrete fill, the shield building and containment act compositely with the fill. To resist shear forces in this section, shear bars were added to the concrete fill, assuming that the Z bars in the shield building do not contribute to the shear resistance. This was done in Calculation No. 210.120-126, Revision 0, and for an additional load case in Calculation No. 201.120-126, Revision 1 (see Attachment 4).

Item 3


The out-of-plane shear forces in shell structures are the most critical at the structural and loading discontinuities. For the shield building, this occurred at the junction with the mat at el 70 ft 0 in. (before the concrete fill was added) and at the top of the annulus fill at el 95 ft 0 in. with the concrete fill in place.

The shield building is analyzed using the SHELL-1 computer code. The output of this analysis includes shear forces at approximately every 1 ft 0 in. elevation. This output is reviewed to ensure that the most critical sections are evaluated.

Item 4

Attachment 5 provides the results of the evaluation for loads at el 95 ft 0 in. from Calculation No. 201.120-126.

Attachments



46 1510

K-E 10 X 10 TO THE CENTIMETER  
HELIOPHILIC & ESSENCE CO. MADE IN U.S.A.

## CALCULATION SHEET

STONE &amp; WEBSTER ENGINEERING CORPORATION

ATTACHMENT 2  
P1 OF 3

A5010.61

J.O./W.O./CALCULATION NO.	REVISION	PAGE
12210.201.120-067	1	236
PREPARED/DATE	REVIEWER/CHECKER/DATE	INDEPENDENT REVIEWER/DATE
D.Frouello / 5-29-84	A.Payne, began 5-29-84	A.Payne began 5-29-84
SUBJECT/TITLE	QA CATEGORY/CODE CLASS	
SHIELD Building - SHEAR @ BASE	I	

SHEAR - MAXIMUM AT BASE EL 70'-0"FOR UNCRACKED CASE (REF. P 62)

LOAD CASE	$N_x (^k/ft)$	$Q_x (^k/ft)$	$M_x (^k'-ft)$	
7 + SSE @ 0°	-20.22	16.75	+29.8	[CASE II]
10.2 - SSE @ 0°	+26.80	8.56	+66.8	
10.3 + SSE @ 0°	-9.46	-14.23	+24.8	
10.3 + SSE @ 180°	-177.21	-28.79	-73.1	[CASE I]

FOR CRACKED CONCRETE (REF P. 134)

LOAD CASE	$N_x (^k/ft)$	$Q_x (^k/ft)$	$M_x (^k'-ft)$	
10.2 - SSE @ 0°	16.49	4.59	+52.1	[CASE III]
10.3 + SSE @ 90°	-93.34	-10.5	-0.6	
10.3 + SSE @ 180°	-166.92	-14.39	-36.4	

NOTE: CRACKED CASES DO NOT INCLUDE SOIL PRESSURE - SOIL PRESSURE EXERTS A POSITIVE SHEAR AT THE BASE OF THE SHIELD BUILDING.

TO FIND SHEAR DUE TO SOIL PRESSURE ONLY, REF TO P. 111

$$10.2 (- SSE) \text{ WITH SOIL} \quad Q_s = 15.65^k/ft$$

$$10.2 (- SSE) \text{ w/out soil} \quad Q_s = 0.70^k/ft$$

$$\text{DIFFERENCE} \quad Q_s = 14.95^k/ft \quad (\text{SOIL ONLY})$$

## CALCULATION SHEET

STONE &amp; WEBSTER ENGINEERING CORPORATION

ATTACHMENT 2  
P 2 OF 3

▲5010.61

PREPARER/DATE	J.O./W.O./CALCULATION NO.	REVISION	PAGE
D. J. Morelli / 5-29-84	12210-201, 120-067	1	237
SUBJECT/TITLE	REVIEWER/CHECKER/DATE	INDEPENDENT REVIEWER/DATE	
SHIELD BUILDING - SHEAR @ BASE		A. Ruyter Koen 5-29-84	
		X QA CATEGORY/CODE CLASS	
		I	

SHEAR - EL 70'-0" (CONT)


CASE III BECOMES  $Q_s = 4.59 + 14.95 = 19.54 \text{ k/ft}$

SRV LOADS (SEE ATTACH IV)

$$N_s = \pm 18.6 \text{ k/ft} \quad Q_s = \pm 1.87 \text{ k/ft} \quad M_s = \pm 132 \text{ k'-ft/ft}$$

LOCA LOADS (SEE ATTACH II)

$$N_s = \pm 1.13 \text{ k/ft} \quad Q_s = \pm .08 \text{ k/ft} \quad M_s = \pm 0.5 \text{ k'-ft/ft}$$

SHEAR STRESSES REF ACI 318-71 CHPT. 11

$$\text{FOR } M(+), d = 25''$$

$$\text{FOR } M(-), d = 27''$$

$$b = 12''$$

$$F_c' = 3000 \text{ psi}$$

CASE I  $N_s = -177.21 + 18.6 + 1.13 = -157.5 \text{ k/ft}$

$$Q_s = -28.79 - 1.87 - .08 = 30.74 \text{ k/ft}$$

$$N_m = \frac{V}{\phi b d} = \frac{30740}{.85(12)(27)} = 112 \text{ psi}$$

ACI 318-71 EQ 11-6

$$N_c = \pm \left( 1 + 0.0005 \frac{N_u}{A_g} \right) \sqrt{F_c} = 2 \left[ 1 + 0.0005 \left( \frac{157500}{12(30)} \right) \right] \sqrt{3000} = 133 \text{ psi}$$

$N_c > N_m$  OK NO SHEAR REINF. REQ'D

## CALCULATION SHEET

STONE &amp; WEBSTER ENGINEERING CORPORATION

ATTACHMENT 2  
P 3 of 3

PREPARER/DATE		J.O./W.O./CALCULATION NO.	REVISION	PAGE
D.L.Wallace	5-29-84	12210.201.120-067	2	238
SUBJECT/TITLE		REVIEWER/CHECKER/DATE	INDEPENDENT REVIEWER/DATE	
		A.Paynter 5-29-84	A.Paynter 5-29-84	I
SHIELD BUILDING - SHEAR @ BASE			QA CATEGORY/CODE CLASS	

SHEAR - EL 70'-0" (CONT)SHEAR STRESSES (CONT)

$$\text{CASE II} \quad N_s = -20.22 + 18.6 + 1.13 = -0.49$$

$$Q_s = 16.75 + 1.87 + .08 = 18.7^k/\text{ft}$$

$$N_m = \frac{18700}{.85(12)(25)} = 73.3 \text{ psi}$$

$$N_c = 2\sqrt{3000} = 109.5 \text{ psi}$$

$N_c > N_m \therefore \text{NO SHEAR REINF REQ'D}$

$$\text{CASE III} \quad N_s = 16.49 + 18.6 + 1.13 = 36.22^k/\text{ft}$$

$$Q_s = 19.54 + 1.87 + .08 = 21.49^k/\text{ft}$$

$$N_m = \frac{21490}{.85(12)(25)} = 84.3 \text{ psi}$$

ACI 318-71 Eq 11-8  
 $N_c = 2 \left( 1 + .002 \frac{N_s}{A_g} \right) \sqrt{F_c}$

$$= 2 \left( 1 + .002 \left( \frac{36220}{12(30)} \right) \right) \sqrt{3000} = 87.5 \text{ psi}$$

$N_c > N_m \therefore \text{NO SHEAR REINF REQ'D}$

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEETATTACHMENT 3  
Page No. 739 P.10F3  
Preliminary 126  
Item 201.120-067

1 Client G. S. U. Location RIVERBEND #1 Est. No. J.O. No. 12210  
 2 Subject ANALYSIS & DESIGN OF SHIELD FLG. Date 7-26-76 By J.L.A.  
 3 CHECK WALL FOR CONST. LOADS Checked 8-9-76 By MTS. L.W.  
 4 Based on AT WALL - MAT JUNCTION Revised B.  
 5 TRY # 8 @ 1'-8" C/C (vertically)

$$8 \quad A_v = 50 \frac{bws}{f_y} = \frac{50 \times 12 \times 20}{40,000} = 0.3 \text{ in}^2$$

$$10 \quad < 0.79 \text{ in}/\text{ft} \text{ O.K.}$$

$$11 \quad (\text{ACI } 318-71, \text{ Eq. 11-1})$$

$$14 \quad A_v = \frac{(u_u - u_d) bwd}{f_y (\sin \alpha + \cos \alpha)} \quad (\text{ACI } 318-71, \text{ Eq. 11-14})$$

$$15 \quad = \frac{(127.46 - 83.77) 12 \times 25.46}{40,000 \times \sqrt{2}}$$

$$16 \quad = 0.236 \text{ in}^2$$

$$17 \quad < 0.79 \text{ in}^2 \text{ (actual O.K.)}$$

$$18 \quad \text{used}$$

26 Note - 1. Smaller size bars can be used  
 27 but to maintain consistency use  
 28 6, # 8 @ 20" c/c. (vertical spacing)

33 2. SEE SKETCH ON PAGE 26 of  
 34 CALC. NO. 201.120-020

40 REV. 1  
 41 SUPERSEDED BY 236-238

1 Client G. S. U Location P.R #1 Est. No J.O. No. 12210  
 2 Subject Analysis & Design of Shield Boring Date 8-6-76 By X1.1.  
 3 Checked 8-9-76 By MJShae  
 4 Based on LOADING 6 Revised By  
 5 +ve Radial Shear w/o SRV LOAD

$$Q_E = 26.0 \text{ k/ft}$$

$$N_E = 51.0 \text{ k/ft}$$

$$V_c = 2 \left( 1 + \frac{0.002(-51000)}{12 \times 30} \right) \sqrt{3000}$$

$$= 78.51 \text{ psf}$$

$$V_u = \frac{26}{0.85 \times 12 \times 25.46} = 100.12 \text{ psf.} \\ > V_c$$

+ve Radial Shear w/o SRV

$$Q_E = 23.0 \text{ k/ft}$$

$$N_E = 37.2 \text{ k/ft}$$

$$V_c = 2 \left( 1 + \frac{0.002(-37.2)}{12 \times 30} \right) \sqrt{3000}$$

$$= 86.91 \text{ psf}$$

$$V_u = \frac{23}{0.85 \times 12 \times 25.46} = 85.57 \\ \leq V_c$$

O.K.

SUPERSEDED BY 236-238

L REV. 1

1 Client F.C.D Location R.P. = 1 Est. No. J.O. No. 12212  
 2 Subject Lateral earth pressure at Sld Fld Fldg. Date 8-6-76 By G.A.  
 3 Checked 8-9-76 By MJS/ak  
 4 Based on OF D11(G 10 Revised By  
 5 Negative Radial Shear w/ SRV shear used

$$Q_{\xi} = -56.3 \text{ k/ft}$$

$$N_{\xi} = 44.0 \text{ k/ft}$$

$$V_c = 2(1 + \frac{0.02(-44000)}{12 \times 30}) \sqrt{3000}$$

$$= 82.77 \text{ ft-si.}$$

$$V_u = \frac{56.3}{0.85 \times 12 \times 25.46}$$

$$= 216.8 \text{ ft-si.}$$

$$V_u - V_c = 134.03 \text{ ft-si.}$$

$$Av = \frac{134.03 \times 12 \times 20}{40000 \sqrt{2}} \quad \text{Act 218-71}$$

$$= 0.569 \text{ in.}$$

$\angle 0.79^{\circ}$  provided.

O.K.

REV. 1

SUPERSEDED BY 236-238

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

ATTACHMENT 4  
P1069

▲ 5010.65

2MF	1-5-82 CALCULATION IDENTIFICATION NUMBER API 1/22/82			
J.O. OR W.O. NO. 12210	DIVISION & GROUP ST/ST. M.	CALCULATION NO. 201.120-126	OPTIONAL TASK CODE	PAGE 302

8.6

SHEAR REINFORCING DESIGN

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEETATTACHMENT 4  
P 2 OF 9

▲5010.86

YMF		1-5-82	CALCULATION IDENTIFICATION NUMBER		APL 1/22/82	PAGE 303
J.O. OR W.O. NO.		DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE		
12210		ST/ST. M	201.120-126			
SHEAR FORCE SUMMARY						
LOADING COMBINATION	ELEV.	M <sub>x1</sub>	N <sub>x1</sub>	Q <sub>x1</sub>	COMMENTS	
SERVICE LOADS (ASME 4)	70'	-1248.6	-250.8	-133.0		
	75'	-481.8	-221.8	-95.1		
	83'	-312.5	-198.7	-29.1		
10.1 SEA	70'	-1336.9 - 996.0 -	-292.7 - 233.4 -	-215.8 - 184.5 -	+SSE, SUMMER -SSE, " ", WINTER	
	75'	-538.4 - 324.0 -	-260.4 - 203.9 -	-126.5 - 107.2 -	+SSE, SUMMER -SSE, " ", WINT	
	83'	- 81.4 + 485.9 -	-231.3 + 102.8 -	-16.3 + 18.5 -	+SSE, SUMMER -SSE, " ", WINT	
10.3 LT.DBA	70'	-1439.3 - 234.9 -1510.5	-214.8 + 43.4 -214.8	-191.4 - 107.7 -191.4	6 HR " " 24 "	
	75'	-663.4 + 147.8 -422.7	-203.5 + 47.5 -203.5	-117.1 - 50.9 -118.9	6 HR " " 24 HR	
	83'	-	-	-	6 HR 24 HR	
11.3 L.T. D.BA. FACTORED LOADS	70'	-876.1	-25.4	-148.4		
	75'	-302.6	-19.1	-81.4		
	83'	+ 4.4	-9.2	-5.7		


STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

ATTACHMENT 4  
P 3 OF 9

▲ 5010.65

GMI 7		8/10/81	CALCULATION IDENTIFICATION NUMBER	API 9/24/81	PAGE 304
J.O. OR W.O. NO. 12210	DIVISION & GROUP ST/ ST. M.	CALCULATION NO. 201.120-126	OPTIONAL TASK CODE		

ASSUMED SHEAR REINFORCEMENT



PLAN

TRY:

#8's @ 6" c/c VERTICALLY EL 40' TO EL 74'  
# 6's @ 12" c/c " EL 74' TO EL 80'

GRADE 40 BARS

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

ATTACHMENT  
P 4 OF 9

▲ 5010.85

2m7		1-5-82	CALCULATION IDENTIFICATION NUMBER API 1/22/82	
J.O. OR W.O. NO. 12210	DIVISION & GROUP ST/ST.M	CALCULATION NO. 201.120-126	OPTIONAL TASK CODE	PAGE 305

SERVICE LOAD SHEAR DESIGN

FOR SECTIONS IN COMPRESSION

(CC-3431.3)

$$V_{c1} \leq \phi [9\sqrt{f'_c} + 2500 P (N_u d / M')] \quad \text{FOR } M' \geq 0$$

$$V_{c2} \leq \phi [2 (1 + .0005 N_u A_g) \sqrt{f'_c}] \quad \text{FOR } M' < 0$$

$$V_{c3} \leq \phi 3.5 \sqrt{f'_c} \sqrt{1 + .002 N_u / A_g} \quad \text{FOR } M' < 0$$

WHERE  $\phi = 0.67$  WHEN THERMAL LOADS INCLUDED

$$M' = M_u - N_u [(4t - d) / 8]$$

$$t = 90"$$

d: distance from compression fiber to tension centroid  
 $\approx 90" - 4" = 83" = 6.92"$   
 centroid of containment shell + stiffeners

$$\therefore M' = M_u - N_u [(4(4.5) - 6.92) / 8]$$

$$= M_u - 2.885 N_u$$

$$A_g \approx 90(12) = 1080 \text{ in}^2$$

$$\epsilon \approx \frac{18 + 14.85}{1080} = .0304$$

$$\therefore @ 40' \quad M' = 1248.6 - 2.885(250.8) = 525 \text{ F-K}$$

$$V_{c1} = .67 \left[ (1.9) \sqrt{3000} + 2500 (.0304) \left[ (133)(6.92) / 525 \right] \right]$$

159.0 PSI

$$\text{OR } V_{c2} = .67 (2) \left[ 1 + .0005 \frac{250,800}{1080} \right] \sqrt{3000}$$

= 81.9 PSI

$$\text{BUT } V_{c3} \leq .67 (3.5) \sqrt{3000} \sqrt{1 + .002 \frac{250,800}{1080}}$$

$\leq \underline{\underline{155.4 \text{ PSI}}} \quad \leftarrow$

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

ATTACHMENT 4

P 5 OF 9

▲ 5010.65

J.M.Z 1-5-BZ CALCULATION IDENTIFICATION NUMBER API 1/22/82			
J.O. OR W.O. NO. 12210	DIVISION & GROUP ST/ST.M	CALCULATION NO. 201-120-126	OPTIONAL TASK CODE  PAGE 306

5       $v_u = v_w/bd$       (CC-3522)

HERE, ASSUME  $d = 53"$ , AS SHEAR REINF. CAN ONLY  
BE ADDED TO THE FIX REGION

10       $\therefore d = 60" - 4" = 53"$   
E STIFF. + CTMT CENTRAL

12       $\therefore v_u = \frac{133,000}{12(53)} = \underline{\underline{209.1 \text{ PSI}}}$

15       $v_u - v_c = 209.1 - 155.4 = 53.4 \text{ PSI}$

18       $A_{sr} = 2(v_u - v_c) b s / f_y$       WHERE  $s \leq .5d$

20       $b = 21"$

21       $s = 6"$

23       $A_{sr} = 2(53.4)(21)(6)/40,000 = \underline{\underline{0.34 \text{ in}^2}}$

25       $A_{sr} = 0.49 \text{ in}^2 > 0.34 \text{ in}^2 \quad \therefore \text{OK}$

28      E 45'       $M' = 431.8 - 2.805(221.8) = 91.9$

31       $\therefore v_{c1} = 434.4$

33       $v_{c2} = 80.9$

35       $v_{c3} = \underline{\underline{152.6 \text{ PSI}}} \leftarrow$

38       $v_u = \underline{\underline{149.5 \text{ PSI}}}$

40       $v_u - v_c < 0 \quad \therefore \text{NO ADD'L SHEAR REINF REQ'D}$

## CALCULATION SHEET

P. 6 OF 9

▲ 5010.65

<u>JMF</u>	1-5-82	CALCULATION IDENTIFICATION NUMBER API 1/22/82		PAGE <u>307</u>
J.O. OR W.O. NO. 12210	DIVISION & GROUP ST/ST. M	CALCULATION NO. 201.120-126	OPTIONAL TASK CODE	

FACTORED LOAD SHEAR DESIGN

FOR SECTIONS IN COMPRESSION

[CC-3421.4.1(b)]

$$V_{c_1} = 1.9\sqrt{f'_c} + 2500 P \left( \frac{V_w d}{M'} \right)$$

$$V_{c_2} = 2 \left( 1 + 0.0005 \frac{N_u}{A_g} \right) \sqrt{f'_c}$$

$$V_{c_3} = 3.5 \sqrt{f'_c} \sqrt{1 + 0.002 \frac{N_u}{A_g}}$$

FOR SECTIONS IN TENSION

$$V_c = 2.0 \sqrt{f'_c} \left( 1 + 0.002 \frac{N_u}{A_g} \right)$$

[CC-3421.4.1(c)]

N<sub>u</sub> NEGATIVE

C-40' CHECK THE FOLLOWING 2 COMBINATIONS

M <sub>u</sub>	-1336.9	-876.1
N <sub>u</sub>	-292.7	-25.4
V <sub>u</sub>	-115.8	-148.4

(a)  $M' = 1336.9 - (2.085)(292.7) = 492.5$

$$V_{c_1} = 334.5$$

$$V_{c_2} = 124.4$$

$$V_{c_3} = \underline{\underline{238.1 \text{ PSI}}} \leftarrow$$

$$V_u = V_u / .85 b d \quad (\text{CC-3521.2.1})$$

$$= \underline{\underline{399.2 \text{ PSI}}}$$

$$V_u - V_c = \underline{\underline{161.1 \text{ PSI}}}$$

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

ATTACHMENT 4

P. 7 OF 9

▲ 5010.85

J.M.Y		1-5-82	CALCULATION IDENTIFICATION NUMBER API 1/22/82	
J.O. OR W.O. NO. 12210	DIVISION & GROUP ST/ST.M	CALCULATION NO. 201.120-126	OPTIONAL TASK CODE	PAGE 308

6 (b)  $M' = 816.1 - (2.885)(25.4) = 802.8$

7  $N_c = 201.3$

8  $N_{c2} = 110.8$

9  $N_{c3} = \underline{196.2 \text{ PSI}} \leftarrow$

10  $N_u = \underline{244.5 \text{ PSI}}$

11  $N_u - N_c = \underline{78.3 \text{ PSI}}$

12  $\therefore \text{USE } \underline{161.1 \text{ PSI}}$

13  $A_n = (N_u - N_c) b s / \bar{e}_y \quad (\text{cc-3521.2.3})$

14  $= (161.1)(21)(6) / 40,000 = 0.51 \text{ in}^2$

15 #8 PROVIDED =  $0.49 \text{ in}^2 > 0.51 \text{ in}^2$

16  $\therefore \text{OK.}$

17 ~~E75~~ CHECK THE FOLLOWING 2 COMBINATIONS

$M_u$	-538.4	+147.6
$N_u$	-260.4	+47.5
$V_u$	-126.5	-50.9

18 (a)  $M' = 538.4 - 2.885(260.4) = -212.9 < 0$

19  $\therefore N_{c3} = \underline{233.4 \text{ PSI}}$

20  $N_u = \underline{234.0 \text{ PSI}}$

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

ATTACHMENT 4  
P 8 OF 9

▲ 5010.85

1-5-82 CALCULATION IDENTIFICATION NUMBER APE 1/22/82				PAGE 209
J.O. OR W.O. NO. 12210	DIVISION & GROUP ST/ST.M.	CALCULATION NO. 201.180-126	OPTIONAL TASK CODE	

5       $V_u \cdot V_c = 0.6$

8      (b)       $V_c = 2.0 \sqrt{3000} \left( 1 + 0.002 \frac{-14,500}{1080} \right)$   
 9                  = 99.9 PSI

12       $V_u = \underline{\underline{94.2 \text{ PSI}}}$

15       $V_u \cdot V_c < 0$

19       $\therefore A_v = \frac{(0.6)(21)(12)}{40,000} : 0.004 \text{ in}^2 \quad (\text{NEGLIGIBLE})$

22       $\therefore \#6$ 'S PROVIDED OK.

26      @ 83' - ALL OK BY INSPECTION

32       $\therefore$  SHEAR REINFORCING AS PROPOSED  
 33      ON Pg 304 IS O.K.

## CALCULATION SHEET

STONE &amp; WEBSTER ENGINEERING CORPORATION

ATTACHMENT 4 P. 9 of 9

A5010.61

PREPARED/DATE	J.O./W.O./CALCULATION NO.	REVISION	PAGE
JM Freedland 11/1/83	12210-201.170-126	1	A28
SUBJECT/TITLE	REVIEWER/CHECKER/DATE	INDEPENDENT REVIEWER/DATE	QA CATEGORY/CODE CLASS
			I

## SHEAR IN CONCRETE FILL @ EL 20'

$$\begin{aligned}N_x &= -215.7 \text{ kip} \\M_x &= -1458.9 \text{ ft-kip} \\Q_x &= -241.2 \text{ kip}\end{aligned}$$

From Pg 5 305 &amp; 307

$$\begin{aligned}M' &= M_u - 2.885 N_u = 1458.9 - (2.885)(215.7) \\&= 1136.6 \text{ ft-kip}\end{aligned}$$

$$\begin{aligned}V_{c1} &= 1.9\sqrt{3000} + 2500(0.0304) \left( \frac{(241.2)(6.92)}{1136.6} \right) \\&= 215.7 \text{ PSI}\end{aligned}$$



$$\begin{aligned}V_{c2} &= 2 \left( 1 + 0.005 \frac{215.700}{1080} \right) \sqrt{3000} \\&= 120.5 \text{ PSI}\end{aligned}$$

$$\begin{aligned}V_{c3} &= 3.5\sqrt{3000} \sqrt{1 + 0.002 \left( \frac{215.700}{1080} \right)} \\&= \underline{\underline{226.8 \text{ PSI}}}\end{aligned}$$

$$V_u = \frac{241.200}{12(53)(.05)} = \underline{\underline{446.2 \text{ PSI}}} \quad \textcircled{1}$$

$$V_u - V_c = 230.5 \text{ PSI}$$

$$A_{st} \cdot (230.5)(21)(6) / 40,000 = 0.73 \text{ in}^2$$

$$\#8 \text{ PROVIDED} = 0.99 \text{ in}^2 > 0.73 \text{ in}^2$$

∴ OK

① CHECKER'S NOTE: ACTUALLY  $N_u$  WILL BE LESS  
AS  $D = 83"$ ; BUT  $D$  OF 53" IS  
USED SINCE ONLY THE STIRRUPS  
IN THE CONCRETE FILL ARE ACCOUNTED  
FOR DFK

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

ATTACHMENT 5

P1 OF 3

▲ 5010.85

9/11/7		1-6-82 CALCULATION IDENTIFICATION NUMBER API 1/22/82		PAGE 310
J.O. OR W.O. NO. 12210	DIVISION & GROUP ST/ST. M	CALCULATION NO. 301-120-126	OPTIONAL TASK CODE	

6 CHECK SHEAR AT EL 95' ON SHIELD BUILDING

LOAD CASE	M <sub>x1</sub>	N <sub>x1</sub>	Q <sub>x1</sub>	
10.2 6 HR	-254.8	2.8	21.0	← TENSION ②
	250.4	-169.4	14.8	
24 HR	247.8	4.2	19.8	
	242.9	-188.2	16.2	
ASME 4	50.4	-10.8	5.8	← COMPRESSION SPECIAL
	-39.6	-112.2	3.2	CASE ③
	-35.0	-37.0	2.4	
	-24.2	-138.4	-0.2	
11.3	275.5	-65.8	21.4	← COMPRESSION ①
10.1 + SSE, SUMMER	234.7	16.9	19.8	← TENSION ⑤
	237.5	-156.3	14.6	
	219.3	-9.3	16.4	
	222.1	-182.5	14.2	

FOR SECTION IN COMPRESSION - CASE ①

$$V_{C_1} = 1.9 \sqrt{f'_c} + 2500 P_w \frac{V_{ad}}{M_m} \quad (\text{ACI } 11.4.2 \& 11.4.3)$$

$$M_m = M_u - N_u \left( \frac{4h-d}{8} \right)$$

$$\text{OR } V_{C_2} = 2 \left( 1 + .0005 \frac{N_u}{A_g} \right) \sqrt{f'_c}$$

$$\text{BUT } V_{C_3} \leq 3.5 \sqrt{f'_c} \sqrt{1 + .002 \frac{N_u}{A_g}}$$

$$d = 25'' = 2.083'$$

$$P_w = \frac{(4.50 \cdot r^2)}{(12)(25)} = 0.0150$$

$$M_m = (275.5) - 65.8 \left( \frac{4 \cdot 25 - 2.083}{8} \right) = 210.4$$

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEET

ATTACHMENT 5  
P. 2 OF 3

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER ADI 1/22/82			
J.O. OR W.O. NO. 12210	DIVISION & GROUP ST/ST.M.	CALCULATION NO. 101.120-126	OPTIONAL TASK CODE <u>PAGE 311</u>

$$\therefore V_c = 1.9 \sqrt{3000} + 2500(.0150) \frac{(65.8)(2.083)}{210.4} \\ = 128.5 \text{ PSI}$$

$$V_{c_2} = 2 \left( 1 + .0005 \frac{65,800}{(12)(30)} \right) \sqrt{3000} \\ = 119.6 \text{ PSI}$$

$$V_{c_3} = 3.5 \sqrt{3000} \sqrt{1 + .002 \frac{65,800}{12(30)}} \\ = 224.0 \text{ PSI}$$

∴ USE  $V_c = 128.5 \text{ PSI}$

$$V_u = \frac{V_u}{\phi bd} \quad (\text{ACI 11.2.1}) \\ = \frac{21,400}{(1.65)(12)(25)} = \underline{\underline{83.9 \text{ PSI}}}$$

$V_u < V_c$  ∴ O.K.

FOR SECTIONS IN TENSION

$$V_c = 2 \left( 1 + .002 \frac{N_u}{A_g} \right) \sqrt{f'_c} \quad (\text{ACI 11.4.4})$$

CASE ②

$$V_c = 2 \left( 1 + .002 \frac{-3800}{12(30)} \right) \sqrt{3000} = \underline{\underline{107.2 \text{ PSI}}}$$

$$V_u = 21,000 / 255 = \underline{\underline{82.4 \text{ PSI}}}$$

$V_u < V_c$  ∴ O.K.

STONE & WEBSTER ENGINEERING CORPORATION  
CALCULATION SHEETATTACHMENT 5  
P. 3 OF 3

11/14	1-6-82	CALCULATION IDENTIFICATION NUMBER A/I 1/22/82	
J.O. OR W.O. NO. 12210	DIVISION & GROUP ST/ST. M	CALCULATION NO. 201-120-126	OPTIONAL TASK CODE <u>312</u>

## CASE ③

$$V_c = 99.3 \text{ PSI}$$

$$V_u = 74.6 \text{ PSI}$$

$$\underline{V_u < V_c} \therefore \text{O.K.}$$

CASE ④ - SECTION IS SUBJECT TO COMPRESSION AND SHEAR, BUT WAS GENERATED VIA SERVICE LOADS, WITHOUT LOAD FACTORS. ∴ THIS CASE WILL BE ANALYSED USING THE "ALTERNATE DESIGN METHOD" AS GIVEN IN THE 1944 ACI CODE (ACI 318-44), APPENDIX B.

$$v = \frac{V}{bd} = \frac{5,800}{(12)(25)} = \underline{19.3 \text{ PSI}} \quad (\text{B.7.1})$$

$$\begin{aligned} V_c &= 1.1 \left( 1 + 0.0006 \frac{N}{A_g} \right) \sqrt{f'_c} \quad (\text{B.7.4.5}) \\ &= 1.1 \left( 1 + 0.0006 \left( \frac{10,800}{12(20)} \right) \right) \sqrt{3000} \\ &= \underline{61.3 \text{ PSI}} \end{aligned}$$

$$\underline{V_u < V_c} \therefore \text{O.K.}$$

NOTE - IN EACH CASE ABOVE MINIMUM SHEAR REINFORCEING, AS REQ'D BY ACI 318-71 SECTION II.1.1 FOR  $V_c > V_u > V_2 V_c$ , HAS NOT BEEN PROVIDED FOR THE FOLLOWING REASON: THE SHIELD BLDG. IS A SHELL, AND NOT A "CONCRETE FLEXURAL MEMBER". HOWEVER, IF ONE CONSIDERS IT AS A WALL, SECTION II.10.6 SAYS TO DESIGN AS A SLAB. SLABS, THOUGH, ARE EXEMPT FROM THE MINIMUM REQUIRED SHEAR AREA PROVISION [SECTION II.1.1(a)].