

WOLF CREEK
NUCLEAR OPERATING CORPORATION

John A. Bailey
Vice President
Operations

August 13, 1992

NO 92-0237


U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Subject: Docket No. 50-482: July, 1992, Monthly
Operating Report

Gentlemen:

Attached is the July, 1992, Monthly Operating Report for Wolf Creek
Generating Station. This submittal is being made in accordance with the
requirements of Technical Specification 6.9.1.1.

Very truly yours,



John A. Bailey
Vice President
Operations

JAB/jra

Attachment

cc: A. T. Howell (NRC), w/a
J. L. Milhoan (NRC), w/a
G. A. Pick (NRC), w/a
W. D. Reckley (NRC), w/a

9203170099 920731
PDR ADOCK 05000482
R PDR

Box 411 / Burlington, KS 66839 / Phone: (316) 364-8831

An Equal Opportunity Employer M/F/H/VET

JE24

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

MONTHLY OPERATING REPORT

MONTH: July YEAR: 1992

Docket No.: 50-482

Facility Operating License No.: NPF-42

Report No. 89

Prepared by:

Merlin G. Williams

SUMMARY

The following report highlights the operating experience of Wolf Creek Generating Station for the month of July, 1992. This report is being provided pursuant to Technical Specification 6.9.1.8.

I. SUMMARY OF OPERATING EXPERIENCE

The unit operated at or near 100% power throughout the month of July.

II. MAJOR SAFETY RELATED MAINTENANCE ACTIVITIES

No major safety related maintenance activities were performed during the month of July.

OPERATING DATA REPORT

DOCKET NO. 50-482
 WOLF CREEK GENERATING STATION
 WOLF CREEK NUCLEAR OPERATING CORPORATION
 DATE 08-07-92
 COMPLETED BY M. Williams
 TELEPHONE 316-364-8831

OPERATING STATUS

1. Reporting Period: July, 1992 Gross Hours in Reporting Period: 744
 2. Currently Authorized Power Level (MWT): 3411 Max. Depend. Capacity (MWe-Net): 1131
 Design Electrical Rating (MWe-Net): 1170
 3. Power Level to Which Restricted (If Any) (MWe-Net): N/A
 4. Reasons for restriction (If Any): N/A
- | | This Month | Yr. to Date | Cumulative |
|---|------------------|-------------------|--------------------|
| 5. Number of Hours Reactor was Critical | <u>744.0</u> | <u>3,965.1</u> | <u>47,655.2</u> |
| 6. Reactor Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>339.8</u> |
| 7. Hours Generator on Line | <u>744.0</u> | <u>3,897.5</u> | <u>47,009.8</u> |
| 8. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>0.0</u> |
| 9. Gross Thermal Energy Generated (MWH) | <u>2,535,304</u> | <u>13,084,174</u> | <u>153,177,765</u> |
| 10. Gross Electrical Energy Generated (MWH) | <u>881,626</u> | <u>4,563,633</u> | <u>53,277,139</u> |
| 11. Net Electrical Energy Generated (MWH) | <u>847,049</u> | <u>4,342,987</u> | <u>50,798,458</u> |
| 12. Reactor Service Factor | <u>100.0</u> | <u>77.6</u> | <u>78.7</u> |
| 13. Reactor Availability Factor | <u>100.0</u> | <u>77.6</u> | <u>79.2</u> |
| 14. Unit Service Factor | <u>100.0</u> | <u>76.3</u> | <u>77.6</u> |
| 15. Unit Availability Factor | <u>100.0</u> | <u>76.3</u> | <u>77.6</u> |
| 16. Unit Capacity Factor (Using MDC) | <u>100.7</u> | <u>75.1</u> | <u>74.1</u> |
| 17. Unit Capacity Factor (Using Design MWe) | <u>97.3</u> | <u>72.6</u> | <u>71.7</u> |
| 18. Unit Forced Outage Rate | <u>0.0</u> | <u>23.7</u> | <u>6.8</u> |
19. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of each): N/A
 20. If Shut Down at End of Report Period, Estimated Date of Startup: N/A

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-482

WOLF CREEK GENERATING STATION

WOLF CREEK NUCLEAR OPERATING CORPORATION

DATE 08-07-92COMPLETED BY M. WilliamsTELEPHONE 316-364-8831MONTH July, 1992

| DAY AVERAGE DAILY (MWe-Net) | LEVEL | DAY AVERAGE DAILY POWER LEVEL (MWe-Net) | |
|--------------------------------|-------|--|------|
| 1 | 1139 | 17 | 1140 |
| 2 | 1137 | 18 | 1138 |
| 3 | 1141 | 19 | 1138 |
| 4 | 1141 | 20 | 1137 |
| 5 | 1142 | 21 | 1138 |
| 6 | 1140 | 22 | 1137 |
| 7 | 1140 | 23 | 1140 |
| 8 | 1140 | 24 | 1140 |
| 9 | 1138 | 25 | 1138 |
| 10 | 1138 | 26 | 1138 |
| 11 | 1139 | 27 | 1137 |
| 12 | 1139 | 28 | 1136 |
| 13 | 1136 | 29 | 1135 |
| 14 | 1139 | 30 | 1137 |
| 15 | 1137 | 31 | 1139 |
| 16 | 1138 | | |

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO. 50-482
 WOLF CREEK GENERATING STATION
 WOLF CREEK NUCLEAR OPERATING CORPORATION
 DATE 08-07-92
 COMPLETED BY M. Williams
 TELEPHONE 316-364-8871

REPORT MONTH July, 1992

| No | Date | TYPE F: FORCED S: SCHEDULED | DURATION (HOURS) | REASON (1) | METHODS SHUTTING DOWN THE REACTOR OR REDUCING POWER (2) | CORRECTIVE ACTIONS/COMMENTS |
|----|------|-----------------------------------|---------------------|---------------|---|-----------------------------|
| | | | | | | |

SUMMARY: The unit operated at or near 100% power throughout the month.

1) REASON: A: EQUIPMENT FAILURE (EXPLAIN) E: OPERATOR TRAINING AND LICENSE EXAMINATION (2) METHOD: 1. MANUAL
 B: MAINTENANCE OR TEST F: ADMINISTRATIVE 2. MANUAL SCRAM
 C: REFUELING G: OPERATIONAL ERROR (EXPLAIN) 3. AUTOMATIC SCRAM
 D: REGULATORY RESTRICTION H: OTHER (EXPLAIN) 4. CONTINUED
 5. REDUCED LOAD
 9. OTHER

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

UNIT NO. 1

MONTH July, 1992

SUMMARY OF OPERATING EXPERIENCE

Listed below in chronological sequence is a summary of operating experiences for this month which required load reduction or resulted in significant non-load related incidents.

| <u>DATE</u> | <u>TIME</u> | <u>EVENT</u> |
|---------------|-------------|---------------------|
| July 1, 1992 | 0000 hours | Unit at 100% power. |
| July 31, 1992 | 2400 hours | Unit at 100% power. |