

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-285  
 UNIT NAME Fort Calhoun St.  
 DATE July 8, 1992  
 COMPLETED BY G. R. Cavanaugh  
 TELEPHONE (402) 636-2474

REPORT MONTH June 1992

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
92-04	920531 /	F	30.3	A	1	92-019	RB	CONROD	On May 31, 1992, Control Element Assembly (CEA) No. 35 dropped into the reactor core. Reactor power was reduced to 70% within one hour per Technical Specifications. Attempts to recover the CEA while at 70% power were unsuccessful. The generator was taken off-line early in the morning on June 1, 1992.

9208170141 920814  
 PDR ADOCK 05000285  
 PDR

1  
 F: Forced  
 S: Scheduled

2  
 Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

3  
 Method:  
 1-Manual  
 2-Manual Scram  
 3-Automatic Scram  
 4-Other (Explain)

4  
 Exhibit G - Instructions  
 for Preparation of Data  
 Entry Sheets for Licensee  
 Event Report (LER) File (NUREG-0161)

5  
 Exhibit I - Same Source