

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) LaSalle County Station Unit 1	DOCKET NUMBER (2) 0 5 0 0 0 3 7 3 1	PAGE (3) OF 0 2
--	--	--------------------

TITLE (4)
Unsecured High Radiation Door

EVENT DATE (6)			LER NUMBER (8)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
0 2	0 8	8 5	8 5	0 1 6	0 0	0 3	0 7	8 5	NA		0 5 0 0 0
											0 5 0 0 0

OPERATING MODE (9) 3	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)									
POWER LEVEL (10) 0 1 0 0	<input type="checkbox"/> 20.402(b)	<input type="checkbox"/> 20.406(c)	<input type="checkbox"/> 60.73(a)(2)(iv)	<input type="checkbox"/> 73.71(b)						
	<input type="checkbox"/> 20.406(a)(1)(i)	<input type="checkbox"/> 60.36(c)(1)	<input type="checkbox"/> 60.73(a)(2)(v)	<input type="checkbox"/> 73.71(c)						
	<input type="checkbox"/> 20.406(a)(1)(ii)	<input type="checkbox"/> 60.36(c)(2)	<input type="checkbox"/> 60.73(a)(2)(vi)	OTHER (Specify in Abstract below and in Text, NRC Form 365A)						
	<input type="checkbox"/> 20.406(a)(1)(iii)	<input checked="" type="checkbox"/> 60.73(a)(2)(i)	<input type="checkbox"/> 60.73(a)(2)(vii)(A)							
	<input type="checkbox"/> 20.406(a)(1)(iv)	<input type="checkbox"/> 60.73(a)(2)(ii)	<input type="checkbox"/> 60.73(a)(2)(vii)(B)							
<input type="checkbox"/> 20.406(a)(1)(v)	<input type="checkbox"/> 60.73(a)(2)(iii)	<input type="checkbox"/> 60.73(a)(2)(ix)								

LICENSEE CONTACT FOR THIS LER (12)

NAME L. R. Aldrich, extension 238	TELEPHONE NUMBER AREA CODE: 8 1 1 5 3 1 5 1 7 - 1 6 1 7 1 6 1 1
--------------------------------------	---

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS
A	Z1Z	Z191919	Z1919 9	N					

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)

MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

At 1510 on 2/8/85 with Unit 1 in Hot Shutdown, door #426, entrance to the Unit 1 Reactor Water Cleanup B Heat Exchanger Room, was found to be unsecured and unattended. This is contrary to Technical Specification 6.1.1. An individual leaving the area failed to properly secure the door. Upon discovery of the open door, a Radiation Chemistry Technician closed and secured the door. The door was verified closed and secured at 1515 on 2/8/85. The individual responsible was counseled as to the responsibility of insuring that high radiation doors remain secured.

8503150132 850307
PDR ADOCK 05000373
S PDR

IC22
11

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1): LaSalle County Station Unit 1	DOCKET NUMBER (2): 0 5 0 0 0 3 7 3 8 5 - 0 1 6 - 0 0	LER NUMBER (6):			PAGE (3):	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
					0 2	OF 0 2

TEXT (If more space is required, use additional NRC Form 206A's) (17)

I. EVENT DESCRIPTION

At 1510 on February 8, 1985, door #426, entrance to the Unit 1 Reactor Water Cleanup (CE) B Heat Exchanger Room, was found to be unsecured and unattended. This is contrary to Technical Specification 6.1.1. At the time of the event the Unit was in Hot Shutdown.

II. CAUSE

An individual leaving the area failed to secure the door.

III. PROBABLE CONSEQUENCES OF THE OCCURRENCE

Review of the dosimetry data for the period in question indicates that no unauthorized radiation exposure greater than 50 mrem occurred.

IV. CORRECTIVE ACTION

Upon finding the door open, a Radiation Chemistry Technician closed and secured the door. The door was verified closed and secured at 1515 on February 8, 1985. The individual involved was counseled as to his responsibility of ensuring that high radiation area access doors are properly secured at all times.

V. PREVIOUS OCCURRENCES

There have been five occurrences of a similar nature as follows:

- LER 373/84-034
- LER 374/84-022
- LER 374/84-038
- LER 374/84-070
- LER 373/85-004

VI. NAME AND TELEPHONE NUMBER OF PREPARER

L. R. Aldrich, 815/357-6761, extension 238.



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

March 7, 1985

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Dear Sir:

Reportable Occurrence Report #85-016-00, Docket #050-373 is being submitted to your office in accordance with 10CFR 50.73.

for R.D. Bulys
G. J. Diederich
Superintendent
LaSalle County Station

GJD/MLD/kg

Enclosure

xc: NRC, Regional Director
INPO- Records Center
File/NRC

ZE22
//