

NOV 13 1984

Docket Nos.: 50-440
and 50-441

Mr. Murray R. Edelman
Vice President - Nuclear Group
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Dear Mr. Edelman:

Subject: Acceptability of Revised Test Method for Pre-Operational Testing
of the Control Room Ventilation System at the Perry Nuclear Power
Plant (Units 1 and 2)

Your letter to me dated June 29, 1984 requested approval to change the pre-operational testing of the control room HVAC from a positive pressure test for the emergency recirculation mode (as stated in the FSAR), to the use of a tracer gas dilution method. The proposed change is based on the system design which is not positive pressure in the recirculation mode and therefore the FSAR stated test method is not representative of system performance. The staff has reviewed the justification provided for this change and finds it acceptable. This approved change should be appropriately reflected in a future FSAR amendment.

Sincerely,

121
B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

cc: See next page

CONCURRENCES:

DL:LB#1

DL:LB#1

JStefano:es

BJYoungblood

11/13/84

11/13/84

DIST:

Docket File

NRC PDR

PRC System

NSIC

Local PDR

LB#1 Rdg

MRushbrook

JStefano

ACRS (16)

EJordan

RHeischman

OELD, Attorney

8411270530 841113
PDR ADOCK 05000440
A PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

NOV 13 1984

Docket Nos.: 50-440
and 50-441

Mr. Murray R. Edelman
Vice President - Nuclear Group
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Dear Mr. Edelman:

Subject: Acceptability of Revised Test Method for Pre-Operational Testing
of the Control Room Ventilation System at the Perry Nuclear Power
Plant (Units 1 and 2)

Your letter to me dated June 29, 1984 requested approval to change the pre-operational testing of the control room HVAC from a positive pressure test for the emergency recirculation mode (as stated in the FSAR), to the use of a tracer gas dilution method. The proposed change is based on the system design which is not positive pressure in the recirculation mode and therefore the FSAR stated test method is not representative of system performance. The staff has reviewed the justification provided for this change and finds it acceptable. This approved change should be appropriately reflected in a future FSAR amendment.

Sincerely,

A handwritten signature in cursive script that reads "B. J. Youngblood".

B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

cc: See next page

PERRY

Mr. Murray R. Edelman
Vice President, Nuclear Group
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

cc: Jay Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20006

Donald H. Hauser, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
Parmly at Center Road
Perry, Ohio 44081

U. S. Nuclear Regulatory Commission
Mr. James G. Keppler, Regional
Administrator, Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Donald T. Ezzone, Esq.
Assistant Prosecuting Attorney
105 Main Street
Lake County Administration Center
Painesville, Ohio 44077

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Terry J. Lodge, Esq.
618 N. Michigan Street
Suite 105
Toledo, Ohio 43624

John G. Cardinal, Esq.
Prosecuting Attorney
Ashtabula County Courthouse
Jefferson, Ohio 44047