



Log # TXX-92377
File # 10110
908.3
Ref. # 10CFR50.55(e)

August 14, 1992

William J. Cahill, Jr.
Group Vice President

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555


SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES) - UNIT 2
DOCKET NO. 50-446
FERRO-RESONANT TRANSFORMERS
SDAR CP-92-12 (INTERIM REPORT)

Gentlemen:

On June 18, 1992, TU Electric discovered a deviation in several spare ferro-resonant transformers drawn from the warehouse that could cause an unacceptable total harmonic distortion in the output of the Westinghouse 7.5 kva inverters. The evaluation of this identified deviation, potentially associated with a substantial safety hazard, will be completed by October 30, 1992.

Sincerely,

William J. Cahill, Jr.

By: 
D. R. Woodlan
Docket Licensing Manager

VPC/tg

c - Mr. J. L. Milhoan, Region IV
Mr. B. E. Holian, NRR
Resident Inspectors, CPSES (2)

170130
9208180206 920814
PDR ADDCK 05000446
S PDR

400 N. Olive Street L.B. 81 Dallas, Texas 75201

9237-1/0