

ENCLOSURE 2

NOTICE OF DEVIATION

Duke Power Company  
McGuire Units 1 and 2

Docket Nos. 50-369 and 50-370  
License Nos. NPF-9 and NPF-17

The following deviation was identified during an inspection conducted on July 30 - August 3, and August 9, 1984.

McGuire Nuclear Station Safety Evaluation Report, Units 1 and 2, Supplement 4, dated January 1981 states, in part, that Operation logs have been developed and both logs and checklists will be used by the Shift Supervisor or Assistant Shift Supervisors, Nuclear Control Operators, and Nuclear Equipment Operators to assure an adequate transfer of information. The relieving Shift Supervisor or Assistant Shift Supervisor reviews the turnover checklists and routes them to the Duty Engineer. The Duty Engineer or designee shall review these checklists daily and place them in a Master File for a minimum of six years. In addition, by procedure, an Assistant Nuclear Control Operator daily inspects essential valve and pump motor control/indicator stations to verify the effectiveness of shift turnover procedures.

Contrary to the above, turnover checklists are not being maintained in the Master File for a minimum of six years, in that they are routinely discarded.

Date: NDV 01 1984

8503190357 841228  
PDR ADOCK 05000369  
G PDR