



Ralph E. Beedle
Executive Vice President
Nuclear Generation

August 10, 1992
JPN-92-044

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

SUBJECT: James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
Proposed Changes to the Technical Specifications
Offgas System Steam Dilution Flow Setpoints (JPTS-92-018)

Dear Sir:

This application for an amendment to the James A. FitzPatrick Radiological Effluent Technical Specifications proposes changes to the offgas system steam dilution flow isolation setpoints. The proposed changes will increase the offgas dilution steam low flow and high flow isolation setpoints to 6300 pounds per hour and 7900 pounds per hour respectively. The bases are also revised to describe more accurately the offgas steam dilution function.

The signed original of the Application for Amendment to Operating License is enclosed for filing. Attachments I, II, and III to this application contain the current Technical Specification pages, the proposed changes to the Technical Specifications, and the associated Safety Evaluation.

A copy of this application and the associated attachments are being provided to the designated New York State official in accordance with 10 CFR 50.91.

If you have any questions, please contact J. A. Gray, Jr.

Very truly yours,

Ralph E. Beedle
Executive Vice President
Nuclear Generation

180034

att: as stated

cc: Next page

9208190061 920810
PDR ADOCK 05000333
P PDR

Acc: 11
Add: NRR/DREP/PRPB 41 End 11

cc: Regional Administrator
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Office of the Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 136
Lycoming, NY 13093

Mr. Brian C. McCabe
Project Directorate I-1
Division of Reactor Projects - I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14 B2
Washington, DC 20555

Ms. Donna Rose
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, NY 12223