

NUREG/CR-3814 ORNL/TM-9166

OAK RIDGE NATIONAL LABORATORY



Determination of Damage Exposure Parameter Values in the PSF Metallurgical Irradiation Experiment

F. W. Stailman

Prepared for the U.S. Nuclear Regulatory Commission Office of Nuclear Regulatory Research Under Interagency Agreements DOE 40-551-75 and 40-552-75

8411280229 841031 PDR NUREG CR-3814 R PDR

OPERATED BY MARTIN MARIETTA ENERGY SYSTEMS, INC. FOR THE UNITED STATES DEPARTMENT OF ENERGY

NOTICE

Availability of Reference Materials Cited in NRC Publications

Most documents cited in NRC publications will be available from one of the following sources.

- 1. The NRC Public Document Room, 1717 H Street, N.W., Washington, DC 20555
- The NRC/GPO Sales Program, U.S. Nuclear Regulatory Commission, Washington, DC 20555
- 3. The National Technical Information Service, Springfield, VA 22161

Although the listing that follows represents the majority of documents cited in NHC publications, it is not intended to be exhaustive.

Referenced documents available for inspection and copying for a fee from the NRC Public Decument Room include NRC correspondence and internal NRC memoranda; NRC Office of inspection and Enforcement bulletins, circulars, information notices, inspection and investigation notices; Licensee Event Reports; vendor reports and correspondence; Commission papers; and applicant and licensee documents and correspondence.

The following documents in the NUREG series are available for purchase from the NRC/GPO Sales Program formal NRC staff and contractor reports, NRC sponsored conference proceedings, and NRC booklets and brochures. Also available are Regulatory Guides, NRC regulations in the Code of Federal Regulations, and Nuclear Regulatory Commission Issuances.

Documents available from the National Technical Information Service include NUREG series reports and technical reports prepared by other federal agencies and reports prepared by the Atomic Energy Commission, forerunner agency to the Nuclear Regulatory Commission.

Documents available from public and special technical libraries include all open literature items, such as books, journal and periodical articles, and transactions. *Federal Register* notices, federal and state legislation, and congressional reports can usually be obtained from these libraries.

Documents such as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings are available for purchase from the organization sponsoring the publication cited.

Single copies of NRC draft reports are available free, to the extent of supply, upon written request to the Division of Technical Information and Document Control, U.S. Nuclear Regulatory Commission, Washington, DC 20555.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at the NRC Library, 7920 Norfolk Avenue, Bethesda, Maryland, and are available there for reference use by the public. Codes rind standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from the American National Standards Institute, 1430 Broadway, New York, NY 10018

Notice

P

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily coment or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

NUREG/CR-3814 ORNL/TM-9166 Dist. Category R5

Operations Division

DETERMINATION OF DAMAGE EXPOSURE PARAMETER VALUES IN THE PSF METALLURGICAL IRRADIATION EXPERIMENT*

F. W. Stallmann

Manuscript Completed - May 10, 1984

Date Published - October 1984

*Prepared for the U.S. Nuclear Regulatory Commission Office of Nuclear Regulatory Research Washington, D.C. 20555 under Interagency Agreements DOE 40-551-75 and 40-552-75

NRC FIN No. B0415

Prepared by the Oak Ridge National Laboratory Oak Ridge, Tennessee 37831 operated by Martin Marietta Energy Systems, Inc. for the U.S. DEPARTMENT OF ENERGY under Contract No. DE-AC05-840R21400

ACKNOWLEDGEMENTS

The author wishes to express appreciation to R. E. Maerker for providing the transport calculation including variance-covariance matrices and to L. S. Kellogg and E. P. Lippincott from HEDL for the dosimetry data. C. A. Baldwin made the cosine fits and prepared the resulting graphs and tables. Last, but not least, thanks to Brenda Taylor for doing a tremendous job in relieving me of all the tedious and unrewarding details, starting from the preparation of input files for the computer to the final assembly of the manuscript.

TABLE OF CONTENTS

Page

CKNOWLEDGEMENTS
IGURE LIST
ABLE LIST \ldots \ldots \cdots vii
NTRODUCTION
ATA AND PROCEDURES
Determination of Gradients
Determination of Uncertainties
ONCLUSIONS
EFERENCES
PPENDIX

FIGURE LIST

Ś

.

		Page
1.	View of the PSF facility	. 7
2.	Illustration of dosimeter and metallurgical specimen locations in the irradiation capsule	. 8
3.	Coordinate system for the ORR-PSF metallurgical experiment	. 9
4.	Methodology for the determination of exposure parameter values and uncertainties	. 10
5.	Cosine fit of the ⁵⁴ Fe(n,p) reaction along the gradient wire positioned at the left rear row of Charpy specimens in the 1/4 T capsule	. 11
6.	Cosine fit of dpa determined from the gradient sets H-16 to H-20 at the axial centerline of the 1/4 T capsule	. 12
7.	Cosine fit of dpa in the lateral direction long the centerline of the 1/4 T capsule	. 13

.

9.1

14

8

υ

TABLE LIST

1.	Encrgy groups used for the LSL-M2 adjustment procedure in the ORR-PSF metallurgical irradiation
	experiment
2.	Fluence perturbation due to water in the void box 15
3.	Fluences and dpa at capsule centers
4.	Cosine fit to the gradient wires
5.	Fitting parameters for formula (1)
6.	Coordinates of the locations of the metallurgical specimens relative to the capsule center
7.	Damage parameter values at the locations of metallurgical specimens - capsule SSC1
8.	Damage parameter values at the locations of metallurgical specimens - capsule SSC2
9.	Damage parameter values at the locations of metallurgical specimens - SPV-capsule 0-T
10.	Damage parameter values at the locations of metallurgical specimens - SPV-capsule 1/4 T
11.	Damage parameter values at the locations of metallurgical specimens - SPV-capsule 1/2 T
12.	Average and extreme values of damage parameters for different sets of Charpy specimen
A.1	Reaction probabilities estimated with LSL-M2
A.2	Irradiation time-history correction terms for ²³⁹ Pu burn-in
A.3	Correction terms for Pu burn-in at different locations in the PSF

DETERMINATION OF DAMAGE EXPOSURE PARAMETER VALUES IN THE PSF METALLURGICAL IRRADIATION EXPERIMENT

INTRODUCTION

This report describes the neutron spectral characterization of the metallurgical experiment in the Oak Ridge Research Reactor (ORR) Poolside Facility (PSF) pressure vessel simulation (PVS) configuration (Figs. 1 and 2).

Values for the damage exposure parameters $\phi t (\phi t = fluence) > 1.0$ MeV, $\phi t > 0.1$ MeV, and displacements per atom (dpa) were estimated with uncertainties for all locations of metallurgical specimens in the test assembly in the ORR-PSF irradiation experiment. In addition, maps of reaction probabilities were determined for all major threshold dosimetry reactions in order to test consistency of this evaluation with dosimetry measurements which were not included. The fluence maps can be expressed as cosine functions in the axial (z) and lateral (x) direction and by an exponential attenuation perpendicular to the core (y) of the form:

$$P(x, y, z) = P_0 \cdot \cos B_x (x - x_0) \cos B_z (z - z_0) e^{-\lambda (y - y_0)}$$
(1)

where P(x,y,z) is the integral response in question (see Table 5). The coordinates are adapted from the system described in the ORR-PSF Blind Test (see Fig. 3). The LSL-M2 adjustment procedure¹ was used followed by cosine fits of the adjusted integral parameters. The method is similar to the one described in NUREG/CR3333;¹⁰ for details see the flow diagram (Fig. 4).

DATA AND PROCEDURES

The spectral fluence calculations by R. E. Maerker and B. A. Worley²,³ were used as the input spectra for the adjustment procedure. These spectra are obtained as a three-dimensional synthesis of two-dimensional transport calculations. Special attention was paid to the changing core configurations during the two-year irradiation. This calculation contained only evergy groups above 0.1 MeV. The spectrum was extended to the epithermal range (>0.4 eV) using the results of a one-dimensional ANISN calculation of the same configuration fitted smoothly to the three-dimensional calculation. Two more thermal groups were added by extrapolating with a 20°C Maxwellian spectrum. One high-energy group (17.33-18 MeV) was also added extrapolating with a Watt fission spectrum. These extrapolations are needed to obtain correct calculated reaction rates from the ENDF/B-V dosimetry cross-section file, which extends from 10^{-4} eV to 18 MeV.

The calculated spectra with extensions were condensed to 37 energy groups as input for the LSL-M2 adjustment procedure. The energy boundaries are listed in Table 1. The one-dimensional ANISN calculation was also used to determine the amount of fluence perturbation resulting from a water leak which filled the void box capsule with water instead of gas. The ratios of fluences water/void for 11 energy groups are listed in Table 2. No significant perturbations are found in the capsules for energies above 0.1 MeV. The ANISN calculation for water was used for the input fluences at lower energies.

Variances and covariances for the calulated spectra were based on calculations by R. E. Maerker⁴ with some modifications reflecting the different energy-group structures. Simplified and somewhat more conservative variance-covariance data were tried before Maerker's results became available. The resulting damage parameter values differ by less than 2%, indicating that the input variances are not critical.

The dosimetry data were taken from the tables in the Blind Test package, which was distributed February 17, 1984.² The "gradient" (GS) dosimetry sets H-1 to H-25, the "backbone" (BB) dosimetry sets HB1 to H10, the HEDL surveillance non-fission sets (HSNF) in SSC1, and the gradient wires along the Charpy specimens were used as input for the LSL procedure (see Fig. 2). No other dosimeters were considered; the remaining dosimetry sensors either duplicated the above data or were widely scattered across the metallurgical capsules, at locations where no spectrum calculations are available. Thus, the additional dosimetry is not likely to improve the results of the adjustment procedure. However, the fluence map obtained from the adjustment procedure can be used to test the remaining dosimetry for consistency.

The H-1 to H-25 capsules each contained a set of non-fission sensors consisting of $63_{Cu(n,\alpha)}60_{Co}$, $46_{Ti(r,p)}46_{Sc}$, $58_{Ni(n,p)}58_{Co}$, $54_{Fe(n,p)}54_{Mn}$, $59_{Co(n,\gamma)}60_{Co}$, $58_{Fe(n,\gamma)}59_{Fe}$, $45_{Sc(n,\gamma)}46_{Sc,and}$ $109_{Ag(n,\gamma)}110_{Ag}$. The $109_{Ag}(n, \gamma)$ reaction was excluded because its cross section is not listed in the ENDF/B-V dosimetry file, and three other non-threshold reactions are available. The HBl to HBlO capsules contained, in addition, the three fission sensors ²³⁸U(n,f), ²³⁷Np(n,f), and ²³⁵U(n,f), with all sensors encapsulated in gadolinium. The count rates published in Ref. 2 for all sensors were converted to reaction probabilities time integrated reaction rates on the basis of the time power history of the irradiation taking into account the difference in core leakage for the different core configurations.² Nuclear data were obtained from Ref. 5 and fission yields from Ref. 6. There are slight differences between our evaluation of reaction probabilities and Ref. 2 due to differences in nuclear data, none of them significantly affecting the results of the adjustment procedure. The reaction rate uncertainties were estimated to be 4% for non-fission and 8% for fission reactions (one standard deviation). Averages were calculated whenever more than one reaction was measured at the same location or more than one fission product for the same fission sensor. No photo-fission corrections were made since the measurements and calculations for an identical configuration in the Pool Critical Assembly (PCA) reactor shows negligible effect of photo-fission.

Group cross sections and covariances were obtained from the ENDF/B-V dosimetry file as presented in the IRDF-83 file8 through the PUFF9 processing code. The first adjustment runs showed strong inconsistencies which were traced to the $238_{U(n,f)}$ reaction. Its uncertainties were then increased to 500%, resulting in ajustments of the 238U(n,f) reaction rates in the order of 30 to 50% in the SSC2 and 0-T positions. [Relative changes are given as the natural logarithm of quotients of the two quantities, e.g., 50% adjustment means | ln $(x_{adj}/x_{orig.})$ = 0.5; the same definition applies to relative variances.] There were also large differences in reaction probabilities when calculated for the same sensor based on different fission products. These discrepancies can be explained as a consequence of 239pu "burn-in," that is the production of plutonium by neutron capture of 238U. A detailed investigation of the effects is given in the Appendix. Correction terms can be determined, but the uncertainties in these corrections are very large so that no useful spectral information can be obtained from the 238 U(n,f) reaction at the SSC2 and O-T locations.

The LSL-M2 method allows both absolute and relative adjustments. In the latter, only the shape of the calulated spectrum is used with an unrestricted scale factor determined from the differences in magnitude between dosimetry and calculation. Both were tried and no significant difference in the results were found. This means that calculation agrees with the dosimetry equally well in terms of absolute fluences, as in terms of the shape of the fluence spectrum. All results, which are reported here, are based on absolute values of the fluence calculation. Values of Chi-square per degree of freedom are in the order of 0.8, which indicates a good consistency within the input data, and uncertainties that are somewhat on the conservative side. Values of the damage parameters at the center gradient capsules with uncertainties are listed in Table 3. The values of the total and thermal fluences are also included for completeness.

Determination of Gradients

It is possible, in theory, to determine damage parameter values or any other integral responses at any point through a suitable adjustment procedure, such as LSL-M2, even if no dosimeters are located at that position. However, there are practical limitations to the number of spectra and dosimeter measurements which can be processed simultaneously. The direct determination of damage parameters was, therefore, restricted to relatively few points, completing the map through suitable interpolation and extrapolation procedures. Experience has shown that a cosine curve describes fairly accurately the fluences along lines parallel to the core, provided regions of boundary reflection are avoided and the peripheral core loading is sufficiently uniform. It is also reasonable to assume that there is an exponential attenuation of fluences in directions perpendicular to the reactor, at least for sufficiently small distances and not too close to boundaries between different materials. Experience from this and other experiments with similar configurations (Refs. 10 and 11) have shown that a combined cosine-exponential fit describes accurately the fluence distributions if the interpolation/extrapolation is confined within the boundaries of each metallurgical capsule. A more detailed discussion of the uncertainties is given below.

The first step in the fitting procedure was to fit the ⁵⁴Fe(n,p) reaction probabilities of the gradient wires to a cosine function

$$P(z) = P_C \cos B_z(z-z_0) \quad .$$

The measurements fit the cosine curve very well, as expected. The residuals are consistent with measuring and positioning errors and appear to be random. A typical example is given in Fig. 5. The two exceptions are the right front of the 1/4T capsule and the right rear of the 1/2T capsule. The data for these two wires are incomplete and appear to be mislabelled since the parallel wire does not show any irregularity. The fitting parameters with standard deviations are listed in Table 4. Fits at the center, which are explained below, are included for comparison.

Ratios of the peak values of parallel gradient wires determine the attenuation of 54 Fe(n,p) reaction rates along lines perpendicular to the core. There are no significant differences between the left and the right sides but definite changes from capsule to capsule. It was, therefore, assumed that one attenuation coefficient can be applied to all positions within the same capsule but that each capsule has a different coefficient (for experimental confirmation of exponential attenuation, see Ref. 11). The attenuation coefficients for several other integral parameters (damage parameters and threshold reaction rates) were determined by applying the adjustment procedure to positions of the gradient wires and taking the ratios of the adjusted parameter values (see Table 5).

The final lateral (x) and axial (z) cosine fits were made using adjusted values at dosimeter locations along the centerlines, including gradient wires for the x-direction. Typical fits are shown in Figs. 6 and 7. Typical uncertainties for these fits can be found in Table 4 for the center 54 Fe(n,p) fits. All other fitting parameters, both axial and lateral, have standard deviations of the same size, which are somewhat larger than the standard deviations for the gradient wire fits since there are fewer data points. There are no significant differences in the B_z and z₀ values between center and gradient wire fits within the same capsule, but again, there are significant capsule-to-capsule variations. Thus, one set of fitting parameters can be used within each capsule for a particular integral parameter. Peak values P₀ are also consistent for lateral and axial fits. A complete list of fitting parameters is given in Table 5.

Formula (1) with the parameters from Table 5 provides a complete map of integral parameters, where each set of coefficients is valid within a given metallurgical capsule. Tables 7-11 list the damage parameter values at the crack tips of every metallurgical specimen. These values were calculated for the specimen coordinates in Table 6. Using the values in Tables 7-11, average, maximum, and minimum values are determined for each set of Charpy specimens from the same material and listed in Table 12.

(2)

Determination of Uncertainties

The LSL-M2 adjustment procedure provides variances and covariances for all values of adjusted integral parameters. Typical values are found in Table 3. These values are based on the uncertainties for the input data, i.e., transport calculation, dosimetry measurements, and cross sections. For the specimen values in Tables 7-12, however, additional uncertainties are introduced through the use of the fitting-interpolation formula (1). These uncertainties are not the same for all locations but depend on the distance of the specimen from the center. The uncertainties for the attenuation coefficient λ can to calculated directly to be about 3%/cm. Typical uncertainties for the coefficients of the cosine fits are given in Table 4. This translates to additional uncertainties ranging from zero at the center to about 5% at the corners of the capsule. All these uncertainties are in themselves rather uncertain, and a more detailed assignment of uncertainties to individual specimens is, therefore, rather pointless. It suffices to say that none of the estimated standard deviation for damage parameters exceeds 10%. This should be sufficiently accurate for damage correlation studies considering the large variability in metallurgical test results.

CONCLUSIONS

Damage fluences received by the metallurgical specimens in the PSF-PVS experiment can be determined to an accuracy of better than 10%. This is accomplished by combining neutron physics calculations with dosimetry measurement in the multiple spectrum adjustment method LSL-M2. The spatial fluence distribution can be approximated by a cosine-exponential fit which is accurate to better than 5% within each capsule. The same procedure can be used to test the consistency of dosimetry measurements. The accuracy of the spectral characterization is sufficient to establish the PSF-PVS experiment as a benchmark as intended.

REFERENCES

- F. W. Stallmann, "LSL-M1 and LSL-M2: Two Extensions of the LSL Adjustment Procedure for Including Multiple Spectrum Locations," to be presented at the 5th ASTM-EURATOM Symposium on Reactor Dosimetry, Geesthacht, FRG, September 24-28, 1984.
- W. N. McElroy and F. B. K. Kam, eds., PSF Blind Test SSC, SPVC Physics, Dosimetry, and Metallurgy Data packages, distributed to Blind Test participants, February 17, 1984.
- R. E. Maerker and B. A. Worley, "Calculated Spectral Fluences and Dosimeter Activities for the Metallurgical Blind Test Irradiations at the ORR-PSF," to be presented at the 5th ASTM-EURATOM Symposium on Reactor Dosimetry, Geesthacht, FRG, September 24-28, 1984.

- R. E. Maerker, M. L. Williams, B. L. Broadhead, J. J. Wagschal, and C. V. Fu, "Revision and Extension of the Data Base in the LEPRICON Dosimetry Methodology," EPRI Report, (in press), 1984.
- W. L. Zijp and J. H. Baard, Nuclear Data Guide for Reactor Neutron Metrology, Part 1 and Part 2, ECN70/71, 1979.
- B. F. Rider, et al., "Evaluation of Fission Product Yields for the U.S National Nuclear Data Files," <u>Workshop on Evaluation Methods and</u> Procedures for Applied Data, Upton, NY, September 22-26, 1980.
- E. D. McGarry, et al., "Gamma-Ray Response of Integral Neutron Dosimeters and Review of Measured ²³⁵U Fission Rates," NUREG/CR-3318, Section 4.5, U.S. Nuclear Regulatory Commission, Washington, DC, 1984.
- D. E. Cullen, N. Kocherov, and P. M. McLaughlain, <u>The International</u> Reactor Dosimetry File (IRDF-83), IAEA-NDS-41/R, 1982.
- J. D. Smith, III, and B. L. Broadhead, PUFF-2, "Determination of Multigroup Covariance Matrices from ENDF/B-V Uncertainty File," RSIC-PSR-157, Radiation Shielding Information Center, Oak Ridge, TN.
- F. W. Stallmann, C. A. Baldwin, and F. B. K. Kam, <u>Neutron Spectral</u> <u>Characterization of the Fourth Nuclear Regulatory Commission Heavy</u> <u>Section Steel Technology 1T-CT Irradiation Experiments: Dosimetry</u> <u>and Uncertainty Analysis</u>, NUREG/CR-3333, ORNL/TM-8789, U.S. Nuclear <u>Regulatory Commission</u>, Washington, DC, 1983.
- 11. C. A. Baldwin, F. B. K. Kam, and F. W. Stallmann, <u>Neutron Spectral</u> <u>Characterization for the Fifth Nuclear Regulatory Commission Heavy</u> <u>Section Steel Technology Program, Part 1. Simulator Experiments,</u> (in publication).



Fig. 1. View of the PSF facility.

ORNL DWG. 84-9122



Illustration of dosimeter and metallurgical specimen locations in the irradiation capsules. Fig. 2.

4

· 1980



Fig. 3. Coordinate system for the ORR-PSF metallurgical experiment.

ORNL DWG 83-12862

.

.



Fig. 4. Methodology for the determination of exposure parameter values and uncertainties.



4.



.

.



*

Group no.	Upper energy boundary (eV)
1	1.800 E+7
2	1.733 E+7
3	1.221 E+7
4	1.000 E+7
5	7.408 E+6
6	6.065 E+6
7	4.066 E+6
8	2.725 E+6
9	2.466 E+6
10	2.123 E+6
11	1.827 E+6
12	1.496 E+6
13	1.353 E+6
14	1.003 E+6
15	8.209 E+5
16	6.081 E+5
17	3.020 E+5
18	1.832 E+5
19	9.804 E+4
20	8.652 E+4
21	6.738 E+4
22	4.087 E+4
23	3.431 E+4
24	2.606 E+4
25	2.418 E+4
26	2.188 E+4
27	1.503 E+4
28	1.171 E+4
29	7.102 E+3
30	5.531 E+3
31	3.355 E+3
32	2.612 E+3
33	1.585 E+3
34	1.023 E+2
35	1.068 E+1
36	4.140 E-1
37	1.265 E-1
lowest energy	1.000 E-4

Table 1. Energy groups used for the LSL-M2 adjustment procedure in the ORR-PSF metallurgical irradiation experiment

Upper energy		Fluence ratio water/void							
(eV)	SSC	0-T	1/4T	1/2T	3/4T	Void box			
1.7333 E+7	1.00	1.00	1.00	1.00	1.00	0.59			
8.6071 E+6	1.00	1.00	1.00	1.00	1.00	0.53			
4.9659 E+6	1.00	1.00	1.00	1.00	0.99	0.33			
2.5924 E+6	1.00	1.00	1.00	1.00	0.98	0.23			
2.1225 E+6	1.00	1.00	1.00	1.00	0.97	0.14			
1.3534 E+6	1.00	1.00	1.00	0.99	0.95	0.06			
7.4274 E+5	1.00	0.98	0.96	0.93	0.86	0.03			
2.1280 E+5	1.00	0.97	0.94	0.89	0.80	0.03			
6.7379 E+4	1.00	0.96	0.93	0.88	0.80	0.04			
2.1875 E+4	1.00	0.97	0.94	0.88	0.79	0.06			
3.3546 E+3	1.00	0.99	0.98	0.95	0.93	0.17			

Table 2. Fluence perturbation due to water in the void box

		Std		Std.		Std.		Std.		Std.
	φ>1.0 MeV 10 ¹⁹ n/cm ² *	dev.	$\phi > 0.1 \text{ MeV}$ 10^{19} n/cm^2	dev. (%)	φ<0.4 eV 10 ¹⁹ n/cm ²	dev. (%)	[¢] total 10 ¹⁹ n/cm ²	dev. (%)	dpa (10-2)	dev. (%)
SSC1										
H-4	2.56	5.1%	7.74	5.8%	1.26	7.4%	14.20	5.8%	4.07	4.9%
SSC2										
H-9	5.50	5.1%	16.84	5.8%	2.79	7.4%	30.55	5.5%	8.80	4.9%
<u>0-T</u>										
H-14	4.10	5.1%	12.26	5.8%	6.29	7.6%	27.66	5.8%	6.56	4.9%
1/4T										
H-19	2.21	5.2%	8.98	6.0%	0.84	7.9%	14.75	5.5%	4.13	5.2%
1/2T										
H-24	1.05	5.4%	5.83	6.0%	0.27	8.3%	9.17	5.6%	2.39	5.4%

Table 3. Fluences and dpa at capsule centers

 $\star 10^{19} \text{ n/cm}^2$ is $10^{19} \text{ neutrons/cm}^2$, which was shortened for the table heading.

	Position	P0*	Bz	Std. dev.	z ₀	Std. dev.
			(cm ⁻¹)	(cm ⁻¹)	(cm)	(cm)
SSC1	left front	1,90E-6	0.0424	+0.0009	0.43	+0.15
	left rear	1.11E-6	0.0420	+0.0009	1.49	+0.11
	right front	1.84E-6	0.0429	+0.0006	1.13	+0.11
	right rear	1.13E-6	0.0449	+0.0010	1.10	+0.15
	center	1.62E-6	0.0419	+0.0150	1.47	+0.03
0-T	left front	3.08E-6	0.0377	+0.0026	1.29	+0.47
	left rear	2.06E-6	0.0379	+0.0011	1.93	+0.20
	right front	2.94E-6	0.0382	+0.0009	1.53	+0.16
	right rear	1.96E-6	0.0374	+0.0010	1.80	+0.19
	center	2.8	0.0363	+0.0084	0.91	+0.02
1/4T	left front	1.39E-6	0.0357	+0.0009	2.87	+0.20
	left rear	9.10E-7	0.0354	+0.0016	2.85	+0.38
	right front	1.31E-6	0.0242	+0.0080	-0.75	+2.40**
	right rear	8.68E-7	0.0339	+0.0016	3.03	+0.38
	center	1.24E-6	0.0331	+0.0144	1.88	+0.04
1/2T	left front	5.47E-7	0.0318	+0.0010	4.34	+0.29
	left rear	3.55E-7	0.0315	+0.0011	4.61	+0.34
	right front	5.21E-7	0.0332	+0.0008	2.93	+0.20
	right rear	3.39E-7	0.0203	+0.0079	1.30	+2.00**
	center	4.78E-7	0.0307	+0.0169	4.27	+0.06

÷

Table 4. Cosine fit to the gradient wires

*P₀ = peak value of the reaction probability of the ⁵⁴Fe(n,p)⁵⁴Mn reaction. Standard deviation is less than 2% in all cases. **Incomplete and irregular data, possible mislabelling.

	D.			в	20	λ	No
	r0	D _X	~0		20	(1)	30
		(cm ⁻¹)	(cm)	(cm-1)	(cm)	(cm ⁻¹)	(cm)
SSC1							
¢t>1.0 MeV*	2.500E+19	0.0499	0.41	0.0436	0.97	0.176	13.29
	7.607E+19	0.0507	0.37	0.0464	0.80	0.134	13.29
dpa	3.995E-02	0.0502	0.38	0.0449	0.90	0.156	13.29
237Np(n,f)	6.679E-05	0.0504	0.38	0.0449	0.89	0.152	13.29
93ND(n,n')	5.598E-06	0.0497	0.41	0.0437	0.97	0.174	13.29
238U(n,f)	8.763E-06	0.0493	0.41	0.0428	1.04	0.191	13.29
58Ni(a,p)	2.212E-06	0,0471	0.41	0.0417	1.18	0.205	13.29
54Fe(n,p)	1.622E-06	0.0467	0.42	0.0419	1.47	0.20	13.29
46Ti(n,p)	2.077E-07	0.0439	0.40	0.0406	1.31	0.209	13.29
63 Cu(n, α)	1.091E-08	0.0417	0.38	0.0402	1.38	0.202	13.29
SSC2							
¢t>1.0 MeV*	5.341E+19	0.0528	-0.95	0.0457	0.03	0.176	13.29
¢t>0.1 MeV*	1.648E+20	0.0539	-0.88	0.0484	-0.02	0.134	13.29
dpa	8.580E-02	0.0533	-0.91	0.0470	0.02	0.156	13.29
237 _{Np(n,f)}	1.437E-04	0.0536	-0.90	0.0470	0.02	0.152	13.29
93Nb(n,n')	1.196E-05	0.0526	-0.94	0.0458	0.03	0.174	13.29
238U(n,f)	1.862E-05	0.0521	-0.97	0.0449	0.06	0.191	13.29
58Ni(n,p)	4.644E-06	0.0497	-1.08	0.0437	0.12	0.205	13.29
54Fe(n,p)	3.407E-06	0.0483	-1.15	0.0415	0.63	0.207	13.29
46Ti(n,p)	4.309E-07	0.0467	-1.24	0.0426	0.20	0.209	13.29
$63Cu(n,\alpha)$	2.252E-08	0.0449	-1.33	0.0421	0.24	0.202	13.29
<u>0-T</u>							
¢t>1.0 MeV*	3.924E+19	0.0517	-0.69	0.0395	0.72	0.107	24.05
φ≤>0.1 MeV*	1.214E+20	0.0522	-0.64	0.0432	0.71	0.042	24.05
dpa	6.452E-02	0.0516	-0.67	0.0414	0.71	0.079	24.05
237 _{Np(n,f)}	1.055E-04	0.0523	-0.66	0.0416	0.69	0.071	24.05
93Nb(n,n')	8.897E-06	0.0514	-0.69	0.0397	0.73	0.107	24.05
238U(n,f)	1.4326-05	0.0509	-0.72	0.0386	0.76	0.133	24.05
58 _{Ni(n,p)}	3.796E-06	0.0488	-0.80	0.0366	0.89	0.169	24.05
54Fe(n,p)	2.805E-06	0.0482	-0.83	0.0363	0.91	0.174	24.05
46Ti(n,p)	3.987E-07	0.0467	-0.92	0.0354	0.97	0.186	24.05
63cu(n, a)	2.304E-08	0.0458	-0.96	0.0354	0.92	0.183	24.05

isting.

Table 5. Fitting parameters for formula (1)

- 0

.

.

4

4

Table 5. Continued

	Po	B _x	×0	Bz	z ₀	λ	УО
		(cm ⁻¹)	(cm)	(cm ⁻¹)	(cm)	(cm ⁻¹)	(cm)
1/4T							
<pre>\$\$\$1.0 MeV*</pre>	2.143E+19	0.0478	-0.96	0.0378	1.30	0.134	28.56
¢t>0.1 MeV*	8.823E+19	0.0486	-0.86	0.0425	1.14	0.070	28.56
dpa	4.037E-02	0.0481	-0.91	0.0407	1.21	0.097	28.56
237 _{Np(n,f)}	6.650E-05	0.0483	-0.92	0.0407	1.16	0.098	28.56
93Nb(n,n')	4.957E-06	0.0478	-0.95	0.0385	1.27	0.127	28.56
238U(n,f)	7.137E-06	0.0479	-0.97	0.0366	1.41	0.153	28.56
58 _{Ni(n,p)}	1.697E-06	0.0468	-1.06	0.0336	1.80	0.177	28.56
54Fe(n,p)	1.237E-06	0.0460	-1.10	0.0331	1.88	0.181	28.56
46Ti(n,p)	1.714E-07	0.0462	-1.11	0.0318	2.08	0.187	28.56
$63Cu(n, \alpha)$	1.018E-08	0.0463	-1.12	0.0321	2.01	0.181	28.56
<u>1/2T</u>							
<pre> \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$</pre>	1.016E+19	0.0441	-0.94	0.0349	1.94	0.146	33.70
¢t>0.1 MeV*	5.727E+19	0.0452	-0.79	0.0413	1.48	0.089	33.70
dpa	2.333E-02	0.0450	-0.83	0.0395	1.59	0.107	33.70
237 _{Np(n,f)}	3.773E-05	0.0450	-0.84	0.0393	1.54	0.111	33.70
93Nb(n,n')	2.468E-06	0.0443	-0.91	0.0365	1.80	0.135	33.70
238U(n,f)	3.085E-06	0.0436	-1.00	0.0330	2.20	0.163	33.70
58Ni(n,p)	6.588E-07	0.0423	-1.10	0.0281	3.38	0.183	33.70
54Fe(n,p)	4.777E-07	0.0448	-0.98	0.0307	4.27	0.186	33.70
46Ti(n,p)	6.389E-08	0.0419	-1.20	0.0246	4.74	0.190	33.70
$63Cu(n,\alpha)$	3.924E-09	0.0428	-1.16	0.0255	4.36	0.182	33.70

-

*Neutrons/cm².

6

-

.

-- 8

.

.

i.

	z	x	x	(y-y_)b	(y-y_)b	
No. ⁴		(left)	(right)	(front)	(rear)	
		Cha	arpy Specimens			
1	12.20	-10.37	+10.37	-1.07	+1.07	
2	11.20	-10.37	+10.37	-1.07	+1.07	
3	10.20	-10.37	+10.37	-1.07	+1.07	
4	9.20	-10.37	+10.37	-1.07	+1.07	
5	8.20	-10.37	+10.37	-1.07	+1.07	
6	7.19	-10.37	+10.37	-1.07	+1.07	
7	6.19	-10.37	+10.37	-1.07	+1.07	
8	5.19	-10.37	+10.37	-1.07	+1.07	
9	4.19	-10.37	+10.37	-1.07	+1.07	
10	3.19	-10.37	+10.37	-1.07	+1.07	
11	2.19	-10.37	+10.37	-1.07	+1.07	
12	1.19	-10.37	+10.37	-1.07	+1.07	
13	0.19	-10.37	+10.37	-1.07	+1.07	
14	-0.81	-10.37	+10.37	-1.07	+1.07	
15	-1.81	-10.37	+10.37	-1.07	+1.07	
16	-2.82	-10.37	+10.37	-1.07	+1.07	
17	-3.82	-10.37	+10.37	-1.07	+1.07	
18	-4.82	-10.37	+10.37	-1.07	+1.07	
19	-5.82	-10.37	+10.37	-1.07	+1.07	
20	-6.82	-10.37	+10.37	-1.07	+1.07	
21	-7.82	-10.37	+10.37	-1.07	+1.07	
22	-8.82	-10.37	+10.37	-1.07	+1.07	
23	-9.82	-10.37	+10.37	-1.07	+1.07	
24	-10.82	-10.37	+10.37	-1.07	+1.07	
25	-11.82	-10.37	+10.37	-1.07	+1.07	
		1/:	2 CT Specimens			
29	11.39	0.0		-0.64	+0.64	
31TC	8.22	0.0		-0.64	+0.64	
31 B ^C	4.48	0.0		-0.64	+0.64	
32T	1.87	0.0		-0.64	+0.64	
32B	-1.87	0.0		-0.64	+0.64	
33T	-4.48	0.0		-0.64	+0.64	
33B	-8.22	0.0		-0.64	+0.64	
30	-11.39	0.0		-0.64	+0.64	

Table 6. Coordinates of the locations of the metallurgical specimens relative to the capsule center (all coordinates in cm)

No.c	z	x (left)	x (right)	(y-y ₀) ^b (front)	(y-y _o) ^b (rear)
		1	CT Specimens		
34	10.05	-4.57		0.0	
38T	3.70	-4.57		0.0	
38B	-3.70	-4.57		0.0	
36	-10.05	-4.57		0.0	
35	10.05		4.57	0.0	
39T	3.70		4.57	0.0	
39B	-3.70		4.57	0.0	
37	-10.05		4.57	0.0	

...

Table 6. Continued

aFor numbers of specimens, refer to Fig. 2.

bFor values of y_o for different capsules, see Table 2.

c3lT = specimen on top of hole 31.

0

8

* *

...

31B = specimen below hole 31, etc.

Spec. No.	Fluence >1 MeV 10 ¹⁹ s/cm ² *	Fluence >.1 MeV 10 ¹⁹ n/cm ²	dpa (ASTM) (10 ⁻²)	Spec. No.	Fluence >1 MeV 10 ¹⁹ n/cm ²	Fluence > 1 MeV 10 ¹⁹ a/cm ²	dpa (ASTN) (10 ⁻²)	Spec. No.	Fluence >1 MeV 10 ¹⁹ n/cm ²	Fluence >.1 MeV 10 ¹⁹ n/cm ²	dpa (ASTM) (10 ⁻²)	Spec. No.	Fluence >1 MeV 10 ¹⁹ n/cm ²	Fluence >.1 NeV 10 ¹⁹ s/cm ²	dpa (ASTM) (10 ⁻²)
				1.21			Charpy 1	Specimen					1.2.9		
	Left F	ront			Right	Front			Left R	lear			Right	Rear	
1.	2.287	6.483	3.539	1	2.341	6.626	3.617	1.1	1.570	4.868	2.535	1	1.607	4.975	2.597
2	2.338	6.652	3.674	2	2 393	6 798	3 704	2	1 605	4.005	2 596	2	1.643	5 105	2 654
3	2.384	6.805	3,702	1	2.441	6 956	3 783		1.637	5.111	2 652	1	1 675	5 223	2 710
4	2.426	6.946	3.772	4	2.484	7.099	3.855	4	1.666	5 216	2 707		1 705	5 331	2 76.2
5	2.464	7.071	3.834	5	2.522	7.227	3,919	5	1.691	5.310	2.747	5	1.731	5.427	2.807
6	2.497	7.181	3.889	6	2.555	7 339	3 975	6	1 714	5 302	2 786		1.754	5 511	2 847
7	2.524	7.275	3.935	7	2.584	7.435	6 022	7	1.733	5 463	2.819	7	1 774	5 583	2 882
8	2.548	7.354	3.974		2.608	7.515	4.062	8	1.749	5.522	2.867		1.790	5.643	2.910
9	2.566	7,416	4.005	9	2.626	7.579	4.094	9	1.761	5.569	2.869	9	1.803	5.691	2.933
10	2.579	7.463	4.028	10	2.640	7.627	4.117	10	1.770	5.604	2.885	10	1.812	5.727	2.949
11	2.588	7.493	4.042	11	2.649	7.658	4.132	11	1.776	5.627	2.896	11	1.618	5.751	2.960
12	2,591	7,508	4.049	12	2.652	7.673	4.138	12	1.779	5.638	2,901	12	1.821	5.762	2.965
13	2,590	7.506	4.047	13	2.651	7.671	4-137	13	1.778	5.636	2.899	13	1.820	5.760	2.963
14	2.584	7.488	4.037	14	2.644	7.653	4.127	14	1.773	5.623	2.892	14	1.815	5 766	2.956
15	2.572	7.454	4.019	15	2.633	7.618	4,108	15	1.766	5.597	2.879	15	1.807	5 720	2 941
16	2.556	7.404	3,993	16	2.616	7,567	4.081	16	1.755	5,559	2.861	16	1.796	5 682	2.026
17	2.535	7.337	3,959	17	2.595	7.499	4.046	17	1.740	5,510	2.836	17	1.781	5 631	2 800
18	2.509	7.255	3,917	18	2.568	7-415	4.003	18	1.722	5.448	2.806	18	1.763	5 568	2 868
19	2.479	7,158	3,866	19	2.537	7.315	3,952	19	1.701	5.375	2.770	19	1.741	5 493	2.851
20	2.443	7.045	3,808	20	2,501	7.200	3.893	20	1.677	5,290	2.728	20	1.717	5.406	2 789
21	2,403	6.916	3.743	21	2,460	7.069	3,826	21	1.650	5,193	2,681	21	1.689	5 308	2 7/1
22	2.359	6.773	3.670	22	2.414	6.922	3,751	22	1.619	5,086	2.629	22	1.657	5.198	2 6.7
23	2.310	6.615	3.589	23	2.364	6,761	3.668	23	1.585	4.967	2.571	23	1.623	5.077	2 678
24	2.256	6.443	3,501	24	2.309	6.585	3.579	24	1.549	4.838	2.508	24	1.585	4 945	2 564
25	2.199	6.257	3 406	25	2.250	6.395	3.482	25	1.509	4.698	2.440	25	1.545	4.802	2.494
			1/2 CT Sp	ecimen		7.5	-				1 CT Spe	cimen			
	From	t			Rea	r			Left				Righ	t	
F 23-10P	2 511	7.301	3 030	#23-40#	1 008	6 158	3 336	821-58	2 226	6 701	2 550				

Table 7. Damage parameter values at the locations of metallurgical specimens - capsule SSC1

			1/2 CT 51	pecimen				1.00			1 CT Spe	cimen			
	Fro	at			Rea	ir .		L 93	Left				Righ	t	
F23-10R F23-15R F23-208 F23-258 F23-258 F23-30R 38%-1 32%-9 3PU-13	2.511 2.657 2.762 2.793 2.774 2.716 2.574 2.399	7.301 7.796 8.161 8.271 8.218 8.034 7.567 6.991	3.930 4.174 4.353 4.406 4.376 4.282 4.046 3.755	F23-40R F23-42R F23-52R F23-63R F23-66R 3PU-21 3PU-29 3PU-33	1.008 2.125 2.209 2.233 2.218 2.172 2.058 1.918	6.158 6.576 6.884 6.977 6.932 6.776 6.383 5.897	3,224 3,424 3,571 3,614 3,590 3,512 3,319 3,080	F23-5R F23-9R F23-13R 3PS-11	2.236 2.406 2.373 2.149	6.701 7.303 7.210 6.455	3.550 3.842 3.790 3.414	F23-17R F23-21R 3PS-12 3PS-14	2.257 2.429 2.396 2.169	6.761 7.368 7.274 6.513	3.582 3.876 3.824 3.444

.

1

Spec. No.	Fluence >1 MeV 10 ¹⁹ n/cm ² *	Fluence >1 MeV 10 ¹⁹ n/cm ²	dpa (ASTM) (10 ⁻²)	Spec. No.	Fluence >1 MeV 10 ¹⁹ n/cm ²	Fluence >.1 MeV 10 ¹⁹ n/cm ²	dpa (ASTM) (10 ⁻²)	Spec. No.	Fluence >1 MeV 10 ¹⁹ n/cm ²	Fluence >11 MeV 10 ¹⁹ n/cm ²	dps (ASTM) (10 ⁻²)	Spec. No.	Fluence >1 MeV 10 ¹⁹ n/cm ²	Fluence >.1 MeV 10 ¹⁹ n/cm ²	dpa (ASTM) (10 ⁻²)
		1.00					Charpy	Specimen							
	Left F	ront			Right	Front			Left R	tear			Right	Rear	
								1.1	3 303	10 116	5 345		3,107	9.742	5.034
1	4.812	13.767	7.461	1	4.526	12.973	7.027	2	3,303	10.662	5.501	2	3.192	10.047	5.181
2	4.944	14.199	7.679	2	4.650	13.380	7 4 21	3	3 477	10,961	5.645	3	3.270	10.329	5.317
3	5.065	14.597	7.879	3	4.764	13,733	7 594	4	3.555	11.234	5.770	4	3.342	10.586	5.440
4	5.176	14.901	8.063		4,000	14.608	7 750	5	3.621	11.481	*	5	3.406	10.819	5.552
5	5.276	15.290	8.228	2	4.902	14.405	7 889	6	3,682	11.701	6.000	6	3.464	11.027	5.651
6	5.365	15.583	0.3/0	0	5,119	14.926	8.010	7	3,736	11.894	6.093	7	3.514	11.208	5.738
1	5,442	15.040	8 615		5.181	15,133	8.114	8	3.781	12.059	6.171	8	3.557	11.363	5.813
8	5,509	16.261	8 706	9	5.233	15.304	8,199	9	3.819	12.195	6.237	9	3.592	11.492	5.874
9	5,503	16 384	8,777	10	5.274	15.439	8.267	10	3.848	12.303	6.288	10	3.620	11.593	5.922
10	5.638	16.489	8.829	11	5,303	15.538	8.316	11	3.870	12.382	6.325	11	3.640	11.668	5.958
12	5.658	16.556	8,862	12	5.322	15.601	8.347	12	3.883	12.431	6.349	12	3.653	11.715	5,980
13	5.665	16.583	8.875	13	5.329	15.627	8,359	13	3.889	12.452	6.358	13	3.658	11.734	5.988
14	5.661	16.572	8.869	14	5.325	15.616	8.353	14	3.886	12.444	6.353	14	3.655	11.726	3.984
15	5.645	16.521	8.843	15	5.310	15.569	8.328	15	3.875	12.406	6.335	15	3.645	11.690	5.900
16	5,618	16.432	8.797	16	5.284	15.485	8.285	16	3.856	12.339	6.302	16	3.627	11.62/	5,930
17	5.578	16.305	8.732	17	5.247	15.365	8.224	17	3.829	12.243	6.255	17	3.001	11.537	5 835
18	5.527	16.139	8.647	18	5.199	15.208	8.144	18	3.794	12.119	0.195	10	3.300	11.420	5 765
19	5.464	15.935	8.544	19	5.140	15.016	8.047	19	3.751	11.900	6.121	19	3,520	11 105	5.682
20	5.390	15.694	8.421	20	5.070	14.789	7.931	20	3.700	11.783	5.033	20	3.400	10 908	5.587
21	5.305	15.416	8.280	21	4.990	14.527	7.798	21	3.041	11,370	5 817	22	3 363	10.686	5.479
22	5.208	15.102	8.120	22	4.899	14.231	7,648	22	3.5/5	11.340	5 690	22	3 293	10.439	5.359
23	5.101	14.752	7.943	23	4.798	13.902	7.481	23	3.501	10 789	5.550	24	3,217	10,167	5.228
24 25	4.983 4.854	14.368	7.748	24	4.566	13.146	7.097	25	3.332	10.475	5.398	25	3.134	9.871	5.084
			1/2 CT S	pecimen						1	CT Specin	men			
					Rea			1000	Left				Righ	ht	
	From	ic .			ac.			Sec. 1.2							
F23-78	5,179	15.258	8.143	F23-38R	4.141	12.871	6.679	F23-2R	4.704	14.274	7.459	F23-24R	4.589	13.938	7.321
F23-17	8 5,552	16.518	8.769	F23-46R	4.440	13.933	7.193	F23-6R	5.170	15.394	8.292	F23-28R	5.044	15.519	8.094
¥23-19	8 5.842	17.499	9.255	F23-54R	4.672	14.761	7.592	F23-20R	5.168	15.899	8.289	3PS-7	3.042	15.524	8.091
F23-27	R 5.944	17.849	9.427	F23-58R	4.753	15.056	7.732	3PS-6	4.697	14.289	1.492	362-9	4.283	13.952	7.313
F23-29	R 5.943	17.852	9.425	F23-62R	4.752	15.058	7.731								
3PU-8	5.839	17.507	9.251	3PU-30	4.669	14.757	7.588	10.10							
3PU-16	5.546	16.531	8.762	3PU-32	4.435	13.944	7,187								
3PU-17	5.171	15.276	8.134	3PU-37	4.135	12.886	0.0/2	1.							

Table 8. Damage parameter values at the locations of metallurgical specimens - capsule SSC2

*Hectrons per cm2.

Spec. No.	Fluence >1 MeV 10 ¹⁹ n/cm ² *	Fluence > 1 MeV 10 ¹⁹ n/cm ²	dpa (ASTM) (10 ⁻²)	Spec. No.	Fluence >1 MeV 10 ¹⁹ n/cm ²	Fluence >.1 MeV 10 ¹⁹ n/cm ²	dpa (ASTM) (10 ⁻²)	Spec. No.	Fluence >1 MeV 10 ¹⁹ n/cm ²	Fluence >,1 MeV 10 ¹⁹ u/cm ²	dpa (ASTM) (10 ⁻²)	Spec. No.	Fluence >1 MeV 10 ¹⁹ n/cm ²	Fluence >,1 MeV 10 ¹⁹ n/cm ²	dpa (ASTM (10 ⁻²
			-				Charpy S	pecimen							
	Left F	ront			Right	Front			Left F	lear			Right	Rear	
									2.760		4.675	1. 1.	2.646	8.567	4.43
1	3.470	9.756	5.476	1	3.326	9.372	5.256	1.1	2.700	0,910	4.027		2.695	8.759	4.53
2	3.534	9.975	5.588	2	3.387	9.582	5.363		2,011	9,119	4 806	3	2.739	8,935	4.61
3	3.593	10,176	5.690	3	3.443	9.775	5.462	1.1	2.000	9.302	4.000	4	2 780	9.095	4.68
4	3.646	10.357	5.783	4	3.494	9.949	3.331		2.900	9,400	4.004		2.816	9.237	4.75
5	3.693	10.520	5.866	5	3.540	10,105	2.630	2	2.930	9.010	5 016		2.847	9.363	4.81
6	3.734	10.662	5.939	6	3.579	10.242	5,700	0	2.9/1	9.141	5.069	7	2.875	9.470	4.86
7	3.770	10.785	6.001	7	3.614	10.360	5.760	0	2.999	9.039	5 113		2.897	9.560	4.90
8	3,800	10.887	6.054	8	3.642	10,458	5.810	0	3.023	10 027	5 148	9	2.916	9.632	4.94
9	3.824	10.969	6.096	9	3.665	10.537	5,851		3.042	10.02/	5 175	10	2 929	9.686	4.96
10	3.842	11.031	6.127	10	3.682	10.596	5,881	10	3.056	10,004	5 102	11	2 918	9.722	4.98
11	3.853	11.072	6.148	11	3.693	10.030	5.901	11	3.065	10.121	5 201	12	2 943	9.740	4.99
12	3.859	11.092	6.158	12	3.699	16.655	5,911	12	3.070	10,140	5.201	12	2 943	9 740	4.99
13	3.859	11,092	6,158	13	3.699	10.655	5.910	13	3.070	10.139	5 102	16	2 938	9.721	4.98
14	3.853	11.071	6.147	14	3.693	10.634	5.900	19	3.065	10.120	5.192	16	2.930	9 684	4 96
15	3.841	11,029	6.126	15	3.681	10.594	5.880	15	3.055	10.082	2.1/4	15	2.920	9.630	A 96
16	3.822	10.966	6.094	16	3.664	10.534	5.849	16	3,041	10.024	5.147	10	2.914	9.030	4.74
17	3.798	10.883	6.052	17	3.640	10.454	5.808	17	3.022	9.949	5,111	17	2.090	9.337	4.90
18	3.768	10.780	5.999	18	3.612	10.355	5.758	18	2.998	9.834	5.007	10	2.0/3	9.400	4.00
19	3.732	10.656	5.936	19	3.577	10.237	5.697	19	2.969	9.741	5.013	19	2.040	9.357	4.01
20	3.690	10.511	5.863	20	3.537	10.099	5.627	20	2.936	9.610	4.951	20	2.814	9.231	4.15
21	3.642	10.350	5.779	21	3.491	9.942	5.547	21	2.898	9.461	4,881	21	2.777	9.088	4.68
22	3.589	10.167	5.686	22	3.440	9.767	5.458	22	2.855	9.294	4.802	2.	2.737	8.928	4,60
23	3.530	9.966	5.583	23	3.384	9.573	5.359	23	2.808	9.110	4.715	23	2.692	8,751	4.52
24	3,466	9.746	5.471	24	3.322	9.362	5.251	24	2.757	8.909	4.620	24	2.64.	8.558	4.43
25	3.396	9.508	5.349	25	3.255	9.133	5.134	25	2.701	8.691	4.517	25	2.589	8.349	4.33
			1/2 CT Se	ecimen							1 CT Spe	cimen			

Table 9. Damage parameter values at the locations of metallurgical specimens - SPV-capsule 0-T

			1/2 CT S	pecimen							1 CT Spe	cimen			
	From	at			Rei	ar .			Left				Righ	it	
F23-1R F23-5R F23-11R F23-21R F23-31R 3PU-2 3PU-10 3PU-26	2 830 4.015 4.151 4.193 4.175 4.109 3.938 3.726	11.158 11.812 12.296 12.446 12.384 12.149 11.546 10.797	6.128 6.455 6.697 6.772 6.741 6.624 6.322 5.947	F23-39R F23-43R F23-51R F23-59R F23-67R 3PU-18 3PU-14 3FU-34	3.343 3.504 3.624 3.660 3.645 3.587 3.438 3.253	10.578 11.198 11.657 11.799 11.741 11.518 10.946 10.236	5.543 5.839 6.058 6.126 6.090 5.991 5.719 5.379	F23-15R 723-19R F23-23R 3PS-9	3,587 3,619 3,787 3,503	10.931 11.786 11.670 10.625	5.855 6.273 6.217 5.705	F23-27R F23-1R 3PS-10 3PS-15	3.526 3.754 3.722 3.443	10.755 11.596 11.482 10.453	5.759 6.170 6.114 5.611

*Neutrons per cm².

.

Spec. No.	Fluence >1 MeV 10 ¹⁹ n/cm ² *	Fluence >.1 MeV 10 ¹⁹ n/cm ²	dpa (ASTN) (10 ⁻²)	Spec. No.	Fluence >1 MeV 10 ¹⁹ a/cm ²	Fluence >1 MeV 10 ¹⁹ n/cm ²	dpa (ASTM) (10 ⁻²)	Spec. No.	Fluence >1 MeV 10 ¹⁹ n/cm ²	Fluence > 1 MeV 10 ¹⁹ n/cm ²	dpa (ASTM) (10 ⁻²)	Spec. No.	Fluence >1 MeV 10 ¹⁹ n/cm ²	Fluence >11 MeV 10 ¹⁹ n/cm ²	dpa (ASTM) (10 ⁻²)
						1.00	Charpy	Specimen							
	Left F	ront			Right	Front			Left #	lear			Right	Ren.	
1	2.041	7.588	3.627		1.942	7.246	3,458	1	1.532	6.533	2.948	1	1.458	6.239	3.712
2	2.073	7.745	3.695	2	1,973	7.396	3.522	2	1.557	6,669	3,003	2	1.481	5.368	2.863
3	2.102	7.888	3.756	3	2,000	7.533	3.581	3	1.579	6.792	3.053	3	1.502	6.485	2.911
4	2.129	8.017	3.812	4	2.025	7.655	3,634	4	1.598	6.903	3.098	4	1.521	6.591	2.954
5	2.152	8.131	3.861	5	2.048	7.765	3.681	5	1.616	7.001	3-138	5	1.538	6.685	2.992
6	2.172	8.231	3.904	6	2.067	7.860	3.722	6	1,631	7.087	3.173	6	1.552	6.767	3.025
7	2.189	8.315	3.940	7	2.083	7.940	3.756	7.	1.644	7.160	3.202	7	1.564	6.837	3.053
8	2.203	8.385	3.970	8	2.096	8.007	3.785	8	1.654	7.220	3.226	8	1.574	6.894	3.076
9	2.214	8.439	3.993	9	2.107	8.059	3.807	9	1.662	7.266	3.245	9	1.582	6.939	3.094
10	2.221	8.479	4.009	10	2.114	8.096	3.823	10	1.668	7.300	3.258	10	1.587	6.97:	3.107
11	2.226	8.502	4.019	11	2.118	8.119	3.832	11	1.671	7.321	3.266	11	1.590	6.991	3.114
12	2.227	8.511	4.022	12	2.119	8.127	3.815	12	1.672	7.328	3.269	12	1.591	6.997	3.117
13	2.225	8.504	4.019	13	2.117	8.121	3.832	13	1.671	7.322	3.266	13	1.590	6.992	3.114
14	2.220	8.482	4.009	14	2.112	8.099	3.822	14	1.667	7.303	3.258	14	1.586	6.973	3.106
15	2.212	8.444	3.992	15	2.104	8.063	3.806	15	1.661	7.270	3.244	15	1.580	6.942	3.093
16	2.200	8.391	3.969	16	2.094	8.013	3.784	16	1.652	7.225	3.225	16	1.572	6.899	3.075
17	2.186	8.323	3.939	17	2.080	7.948	3.755	17	1.641	7.166	3.201	17	1.562	6.843	3.052
18	2.168	8.240	3.902	18	2.063	7.868	3.720	18	1.628	7.094	3.171	18	1.549	6.774	3.023
19	2.147	8.141	3.859	19	2,043	7.774	3.679	19	1.612	7.010	3.136	19	1.534	6.694	2.990
20	2.123	8.029	3.810	20	2.020	7.667	3.632	20	1.594	6.913	3.096	20	1.517	6.601	2.952
21	2.096	7.901	3.754	21	1.994	7.545	3.579	21	1.574	6.803	3.051	21	1.498	6.496	2.909
22	2.066	7.760	3.692	22	1.966	7.410	3.520	22	1.351	6.681	3.000	22	1.476	6.380	2.861
23	2.033	7.604	3.624	23	1.935	7.251	3.455	23	1.527	0.547	2,945	23	1.453	6.252	2,808
24	1.959	7.434	3.550	24	1.864	6.925	3.308	25	1.471	6.244	2.885	24 25	1.427	6.112 5.962	2.750 2.688
	1.24		1/2 CT 5	pecimen							1 CT Spe	cimen			
	From	12			Rea	r		1.1	Left				Righ	NE.	
		0.355	2.022		1 975	2 444			1.001						1.
F23-38	2.163	8.355	3.926	F23-45R	1,825	7.644	3.471	F23-48	1.997	8.065	3.720	23-168	1.956	7.914	3.648
F23-8R	2.252	8.802	4.110	#23-47R	1.899	8.034	3.039	F23-5R	2.102	8.629	3.954	F23-309	2.060	8.467	3.878
F23-138	2.314	9.123	4.201	P23-338	1.952	9.347	3.759	23-12R	2.074	8.497	3.896	3PS-16	2.032	8.338	3.820
F23-188	2.330	9.212	4.280	#23-35K	1.900	0.420	3.791	385-13	1.920	1.111	3.000	3PT-1	1.881	7.572	3.495
F23-238	2.314	9,141	4.230	301-27	1.992	8 102	3.703								
3PU-3	2.275	8.407	4.175	300-27	1.919	7 774	3.691	0.000							
3PU-11	2.182	7 979	3.978	300-15	1.040	7.766	3.316	1. S. S. S.							
380-19	2.000	1.939	3.131	310-35	1	1.204	3.30	1							

Table 10. Damage parameter values at the locations of metallurgical specimens - SPV-capsule 1/4 T

*Neutrons per cm².

. .

Autron State Autron State Autron State Autron State Autron State Autron State Autron State Autron State Autron State <th colspa="</th"><th>Fluence >1 MeV 19 n/cm2e</th><th>Fluence >1 MeV 1019 n/cm2</th><th>dpa (ASTH) (10⁻²)</th><th>Spec.</th><th>Fluence >1 MeV 1019 n/cm2</th><th>Fluence >,1 MeV 1019 n/cm²</th><th>dpa (ASTM) (10⁻²)</th><th>Spec. No.</th><th>Fluence >1 MeV 1019 n/cm²</th><th>Fluence >.1 MeV 1019 n/cm2</th><th>dpa (ASTH) (10⁻²)</th><th>Spec. No.</th><th>Fluence >1 MeV 1019 n/cm2</th><th>Fluence >.1 MeV 1019 n/cm2</th><th>dpa (ASTN) (10-2)</th></th>	<th>Fluence >1 MeV 19 n/cm2e</th> <th>Fluence >1 MeV 1019 n/cm2</th> <th>dpa (ASTH) (10⁻²)</th> <th>Spec.</th> <th>Fluence >1 MeV 1019 n/cm2</th> <th>Fluence >,1 MeV 1019 n/cm²</th> <th>dpa (ASTM) (10⁻²)</th> <th>Spec. No.</th> <th>Fluence >1 MeV 1019 n/cm²</th> <th>Fluence >.1 MeV 1019 n/cm2</th> <th>dpa (ASTH) (10⁻²)</th> <th>Spec. No.</th> <th>Fluence >1 MeV 1019 n/cm2</th> <th>Fluence >.1 MeV 1019 n/cm2</th> <th>dpa (ASTN) (10-2)</th>	Fluence >1 MeV 19 n/cm2e	Fluence >1 MeV 1019 n/cm2	dpa (ASTH) (10 ⁻²)	Spec.	Fluence >1 MeV 1019 n/cm2	Fluence >,1 MeV 1019 n/cm ²	dpa (ASTM) (10 ⁻²)	Spec. No.	Fluence >1 MeV 1019 n/cm ²	Fluence >.1 MeV 1019 n/cm2	dpa (ASTH) (10 ⁻²)	Spec. No.	Fluence >1 MeV 1019 n/cm2	Fluence >.1 MeV 1019 n/cm2	dpa (ASTN) (10-2)
Left Point Left Point <thleft point<="" th=""> Left Point Left Po</thleft>							Charpy S	pecimen								
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	Left	Front			Right	Front			Left 8	ear			Right	Rear		
$ \begin{array}{ $. 440		0 715	4 110	1.664	
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	1.017	5.166	2.173	-	0.977	4.983	2.092		0.745	4.271	27/ 1		762 0	4 106	1.692	
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	1.030	5.263	2.209	2	0.989	5.076	2.127		0.154	102.4	101.1		0 737	4.766	1.718	
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	1.042	5.351	2.242	3	1.000	5.161	2.159		0.762	878.8	1.104		0 730	4.320	1.740	
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	1.052	5.429	2.272	4	1.010	5.237	2.188	4	0.770	4.489	1001		0.715	195. 1	1 740	
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	1.061	5.499	2.298	5	1.018	5.303	2.213	5	0.776	4.546	1.628	~	0.140	4.304	1 776	
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	1.068	5.559	2.320	9	1.025	5.361	2.235	0	0.782	4.596	1.845		0.120	4.432	1.110	
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	1.074	5.609	2.339		1.031	5.410	2.253	1	0.786	4.637	1.861		0.755	4.473	1.192	
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	1 079	6.450	3.354	00	1.036	5.449	2.267	80	0.790	4.671	1.873	80	0.758	4.505	1.804	
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	1 0.07	187 5	3 36.6		070	5.480	2.278	6	0.793	4.697	1.882	6	0.761	4.530	1.812	
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	1 0.00	2012 3	712 6	01	1 04.2	5.500	2.286	10	0.794	4.715	1.888	10	0.763	4.547	1.818	
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	- 00-1	2110	975 6	11	1 041	5.512	2.290	11	0.795	4.725	1.891	11	0.763	4.557	1.822	
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	1.000	CT1-C	are e		1 0.43	5 514	2.290	12	0.795	4.726	1.892	12	0.763	4.558	1.822	
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	1.000	111.0	0.010		170 1	5 506	2 287	11	0.794	4.720	1.889	13	0.762	4.552	1.819	
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	1.084	2.00	C10.2	71	10.0 I	5 480	2.280	14	0.791	4.705	1.884	14	0.760	4.538	1.814	
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	1901	760.0	4.300	***	720 1	1.44.2	2.270	15	0.788	4.683	1.875	15	0.757	4.517	1.806	
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	1.011	5000	100.1		*CO. 1	6 2 38	3 356	16	0.784	4.652	1.853	16	0.753	4.487	1.795	
$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$	1.071	5.628	2,342		670.1	282 3	316 6	17	0.779	4.614	1.849	17	0.748	4.450	1.781	
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	1.060	190.0	476.7		1 014	5 290	3 218		0.773	4.568	1.832	18	0.742	4.405	1.764	
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	1.056	5.525	2.303	2	1.014	2.32.7	1017 1		0 766	4 514	1 812		0.735	4.353	1.745	
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	1.047	5.460	2.277	61	C00'1	007.0	21173	106	0.758	6 46 9	1 780	20	0 728	4 794	1.723	
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	1.036	5.385	2.248	20	\$66.0	561.6	C01-7	22	071.0	192 4	1 763	16	0 710	100 4	1.698	
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	1.024	108.2	2.216	21	0.983	211.0	4.139	17	0 110	1 305	726 1		0 710	4 153	1 670	
$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$	1.011	5.208	2.180	22	0.970	5.023	2.100	27	0. 140	166 7	1 745	22	0 700	4 071	1 640	
0.980 4.995 2.098 2.098 2.093 2.095 2.095 2.095 2.095 2.095 2.095 2.095 2.095 2.095 2.095 2.095 2.095 2.095 2.095 2.095 2.095 2.097 3.868 1.572 Pront 1/2 CT Speciaen kear 1	0.996	5.106	2.141	52	0.956	576.5	160 6	57	0 718	4.129	1.669	34	0.689	3.983	1.607	
0.963 4.876 2.052 25 0.925 4.703 1.976 25 0.003 4.001 1.003 4.001 1.003 4.001 1.003 4.001 1.003 4.001 1.003 4.001 2.017 4.001 2.011 1.003 4.001 2.011 1.001 5.201 2.118 0.001 5.215 2.119 5.215 2.113 81ght 5.215 2.113 812-258 0.947 5.215 2.113 1.004 5.423 2.410 723-418 0.903 5.201 2.104 723-38 0.947 5.215 2.139 1.004 5.429 723-418 0.903 5.201 2.104 723-38 0.947 5.315 2.139 1.109 5.443 723-418 0.903 2.118 0.944 5.515 2.213 2.431 2.213 2.431 2.213 1.109 5.913 2.446 5.118 0.944 5.515 2.213 2.431 2.213 2.431 2.213	0.980	4.995	2.098	24	0.941	110.4	170.7	4	011*0	100 7			0 677	2 880	1 673	
I/2 CT Speciaen Left Left Left Left State Kight #roat \$ 5.356 2.111 \$ 723-378 0.875 4.962 2.017 \$ 723-38 0.947 5.215 2.119 1.005 5.823 2.410 \$ 723-418 0.903 5.201 2.104 \$ 723-78 0.947 5.215 2.119 1.006 5.010 2.479 \$ 723-418 0.903 5.201 2.104 \$ 723-78 0.947 5.515 2.113 \$ 723-28 0.947 5.536 2.139 1.109 6.010 2.479 \$ 723-58 0.947 5.536 2.215 2.139 2.1	0.963	4.876	2.052	25	0.925	4.703	1.976	52	co/ .0	4.031	560.1	G	110.0	000.6		
Front Left Left Right 1.054 5.556 2.311 F23-378 0.875 4.962 2.017 F23-38 0.963 5.294 2.173 F23-258 0.947 5.215 2.139 1.087 5.823 2.410 F23-418 0.903 5.204 2.173 F23-258 0.947 5.215 2.139 1.0087 5.823 2.410 F23-418 0.903 5.204 2.173 F23-258 0.947 5.215 2.139 1.109 6.010 2.479 F23-578 0.922 5.104 F23-118 0.984 5.515 2.220 3.730 2.139 2.2135 2.139 2.2135 2.139 2.2135 2.139 2.2135 2.139 2.2135 2.139 2.2135 2.2135 2.2135 2.2135 2.2135 2.2135 2.2135 2.139 2.2135 2.139 2.2135 2.2135 2.2135 2.2135 2.2135 2.2135 2.2135 2.2135 2.2135 2.2135 <td< td=""><td></td><td></td><td>1/2 CT SP</td><td>ec imen</td><td></td><td></td><td></td><td></td><td></td><td></td><td>I CT Spe</td><td>cimen</td><td></td><td></td><td></td></td<>			1/2 CT SP	ec imen							I CT Spe	cimen				
Front Lett Lett Lett Lett 1.054 5.556 2.311 F23-378 0.815 4.962 2.017 F23-38 0.943 5.215 2.139 1.054 5.825 2.311 F23-418 0.903 5.201 2.104 F23-78 1.001 5.620 2.173 F23-258 0.947 5.215 2.139 1.087 5.823 2.410 F23-48 0.903 5.201 2.104 F23-78 1.001 5.620 2.173 F23-258 0.947 5.215 2.139 1.109 6.010 2.479 F23-578 0.925 5.408 2.178 9.72 0.916 5.016 2.061 5.433 2.215 2.215 1.114 6.035 2.424 91-24 0.925 5.408 2.118 9.750 2.215 2.215 2.215 2.215 2.215 2.215 2.215 2.215 2.215 2.215 2.215 2.215 2.215 2.215 2.215 2.215																
1.054 5.556 2.311 Y23-378 0.875 4.962 2.017 Y23-38 0.963 5.294 2.173 Y23-258 0.947 5.215 2.139 1.087 5.823 2.410 Y23-418 0.903 5.201 2.104 Y23-78 1.001 5.620 2.173 Y23-298 0.947 5.215 2.135 1.109 6.010 2.479 Y23-498 0.922 5.408 2.178 1.001 5.620 2.236 3743 5.235 2.433 2.215 2.135 2.135 2.135 2.135 2.215	Fre	ant			Re				Tel				RIN			
1.007 5.823 2.410 F23-418 0.903 5.201 2.104 F23-78 1.001 5.620 2.298 0.994 5.536 2.253 1.109 6.010 2.479 F23-418 0.903 5.204 F23-118 0.994 5.515 2.230 397-3 0.967 5.433 2.215 1.114 6.058 2.427 F23-578 0.917 5.194 F23-118 397-3 0.967 5.433 2.215 1.114 5.958 2.472 F23-578 0.917 5.158 377-4 0.901 4.941 2.029 1.114 5.958 2.472 F23-578 0.917 5.156 377-4 0.901 4.941 2.029 1.104 5.873 2.472 F21-578 0.917 5.156 2.118 377-4 0.901 4.941 2.029 1.006 5.873 2.424 370-24 0.902 5.2156 2.116 1.064 5.016 2.061 4.941 2.029 <t< td=""><td>1 054</td><td>5.556</td><td>2.311</td><td>F23-376</td><td>a 0.875</td><td>4.962</td><td>2.017</td><td>F23-38</td><td>0.963</td><td>5.294</td><td>2.173</td><td>F23-251</td><td>R 0.947</td><td>5.215</td><td>2.139</td></t<>	1 054	5.556	2.311	F23-376	a 0.875	4.962	2.017	F23-38	0.963	5.294	2.173	F23-251	R 0.947	5.215	2.139	
1.109 6.010 2.479 F23-498 0.922 5.367 2.164 F23-118 0.984 5.515 2.250 377-3 0.967 5.433 2.215 1.114 6.055 2.495 F23-578 0.917 5.316 377-3 0.967 5.433 2.215 1.114 5.958 2.495 7.215 5.118 377-2 0.916 5.016 2.061 377-4 0.901 4.941 2.029 1.044 5.373 2.426 2.116 377-2 0.916 5.016 2.061 377-4 0.901 4.941 2.029 1.064 5.373 2.426 2.116 0.916 5.016 2.061 377-4 0.901 4.941 2.029 1.064 5.577 2.310 370-4 0.902 5.246 2.116 1.064 5.511 1.064 5.016 2.061 377-4 0.901 4.941 2.029 1.044 5.577 2.310 370-4 0.902 5.017	1.087	5.823	2.410	F23-418	0.903	5.201	2.104	F23-78	1,001	5.620	2.292	P23-291	R 0.984	5.536	2.257	
1.114 6.035 2.495 F23-57R 0.925 5.408 2.178 3PT-2 0.916 5.016 2.061 3PT-4 0.901 4.941 2.029 1.104 5.998 2.472 F23-65R 0.917 5.357 2.118 3PT-2 0.916 2.061 3PT-4 0.901 4.941 2.029 1.004 5.873 2.424 3PU-24 0.902 5.246 2.116 1.086 5.873 2.310 3PT-4 0.901 4.941 2.029 1.004 5.577 2.310 3PU-24 0.902 5.246 2.116 1.086 4.981 2.017 1.004 5.577 2.310 3PU-31 0.868 4.981 2.017 1.004 5.577 2.310 3PU-4 0.877 4.981 2.017	1 100	6 010	2.474	\$23-49k	a 0.922	5.367	2.164	F23-118	0.984	5.515	2.250	3PT-3	0.967	5.433	2.215	
1.104 5.498 2.472 F23-658 0.917 5.357 2.158 1.086 5.873 2.424 3PU-24 0.902 5.246 2.116 1.044 5.577 2.310 3PU-24 0.868 4.981 2.017	1 114	\$ 055	2.495	#23-578	0.925	5.408	2.178	3PT-2	0.916	5.016	2.061	3PT-4	0.901	4.941	2.029	
1.046 5.873 2.424 3PU-24 0.902 5.246 2.116 1.044 5.577 2.310 3PU-24 0.968 4.981 2.017 1.044 5.577 2.310 3PU-31 0.868 4.981 2.017	101	108	2 477	\$23-651	110.0	5.357	2.158									
1.044 5.577 2.310 3PU-31 0.868 4.981 2.017	1 0.84	5 873	2 474	3011-24	0.902	5.246	2.116									
	1.000	2.012	015 6	1011-31	0.868	4.981	2.017									
	1.044	110.0	21210	10-010	0 837	1 463	1 808									

Table 11. Damage parameter values at the locations of metallurgical specimens - SPV-capsule 1/2 T

26

"Neutrons per cm2.

	Fluend (10	ce > 1.0)19 n/cr	0 MeV ∎²)	Fluen (1	ce > 0. 0 ¹⁹ n/c	1 MeV m ²)		dpa (10-2)	
	Min.	Avg.	Max.	Min.	Avg.	Max.	Min.	Avg.	Max,
A302-B P1	ate								
SSC1	2.51	2.59	2.65	7.25	7.48	7.67	3.92	4.04	4.14
SSC2	5.14	5.41	5.66	15.02	15.82	16.57	8.05	8.47	8.87
0-T	3.58	3.73	3.86	10.24	10.72	11.09	5.70	5.96	6.16
1/4T	2.04	2.15	2.23	7.77	8.21	8.51	3.68	3.88	4.02
1/2T	1.00	1.05	1.09	5.27	5.53	5.72	2.19	2.30	2.38
A533-B P1	ate								
SSC1	2.20	2.35	2.50	6.26	6.73	7.20	3.41	3.65	3.89
SSC2	4.57	4.97	5.39	13.15	14.41	15.69	7.10	7.75	8.42
0-T	3.25	3.47	3.69	9.13	9.82	10.51	5.13	5.50	5.86
1/4T	1.86	1.99	2.12	6.93	7.47	8.03	3.31	3.56	3.81
1/2T	0.92	0.98	1.04	4.70	5.04	5.38	1.98	2.11	2.25
22NiMoCr3	7 Forging								
SSC1	1.51	1.64	1.76	4.70	5.14	5.57	2.44	2.66	2.87
SSC2	3.13	3.44	3.79	9.87	10.93	12.12	5.08	5.61	6.19
0-T	2.59	2.80	3.00	8.35	9.12	9.85	4.34	4.71	5.07
1/4T	1.40	1.51	1.63	5.96	6.51	7.09	2.69	2.92	3.17
1/2T	0.68	0.73	0.77	3.89	4.23	4.57	1.57	1.70	1.83
A508-3 Fo	rging								
SSC1	1.74	1.79	1.82	5.51	5.67	5.76	2.84	2.92	2.97
SSC2	3.60	3.72	3.89	11.54	11.92	12.45	5.89	6.09	6.36
0-T	2.90	2.97	3.07	9.56	9.82	10.14	4.91	5.04	5.20
1/4T	1.56	1.61	1.67	6.84	7.06	7.30	3.05	3.15	3.26
1/2T	0.75	0.77	0.79	4.45	4.58	4.72	1.78	1.83	1.89
Submerged	Arc Weld	(EC)							
SSC1	1.64	1.73	1.80	5.11	5.44	5.69	2.65	2.81	2.93
SSC2	3.27	3.57	3.82	10.33	11.34	12.20	5.32	5.81	6.24
0-T	2.74	2.90	3.04	8.93	9.53	10.03	4.61	4.91	5.15
1/4T	1.50	1.59	1.66	6.49	6.91	7.27	2.91	3.09	3.25
1/2T	0.73	0.76	0.79	4.27	4.50	4.70	1.72	1.81	1.88
Submerged	Arc Weld	(R)							
SSC1	2.34	2.47	2.58	6.65	7.07	7.44	3.62	3.83	4.02
SSC2	4.65	5.06	5.44	13.38	14.64	15.84	7.23	7.89	8.50
0-T	3.39	3.59	3.77	9.58	10,21	10.78	5.36	5.69	6.00
1/4T	1.97	2.08	2.19	7.40	7.87	8.32	3.52	3.74	3.94
1/2T	0.99	1.03	1.07	5.08	5.33	5.61	2.13	2.23	2.34

Table 12. Average and extreme values of damage parameters for different sets of Charpy specimens

10^m

APPENDIX:

CALCULATION OF CORRECTIONS FOR 239Pu "BURN-IN" IN THE 238U(n,f) FISSION RATE

Neutron fluence determination through measurement of fission products of ²³⁸U detectors becomes unreliable for high fluences at low neutron energies due to the production and subsequent fission of ²³⁹Pu. The pluton:um is produced through disintegration of

$$239_{\text{U}} \xrightarrow{23.54 \text{ min}} 239_{\text{Np}} \xrightarrow{2.355 \text{ d}} 239_{\text{Pu}}$$

of the 239 U generated by the 238 U(n, $_{\gamma}$) 239 U reaction. The process can be described by a system of differential equations for the quantities q_x, which are the number of nuclides of isotope x with time t as the independent variable. The parameters of the differential equations are the reaction rates r_x and the decay constants, which govern the transmutation from one nuclide to another. The reaction rates describe the rate of transmutation in a given neutron field

$$r_x = p \int \phi(E) \sigma_x(E) dE$$
 (A.1)

where p is the power level of the reactor, $\phi(E)$ the fluence rate per unit power at energy E, and $\sigma_{\mathbf{x}}(E)$ the reaction cross section at thi energy. Specifically, we define

$$r_{1} = reaction rate \frac{238}{U(n,\gamma)} r_{2}$$

$$r_{2} = reaction rate \frac{238}{U(n,\gamma)} r_{3}$$

$$r_{3} = reaction rate \frac{239}{Pu(n,f)} r_{P}.$$
(A.2)

Further, let λ be the decay rate of the given fission product (F.P.) and μ be the rate of transmutation from 239 U to 239 Pu. To simplify matters, we disregard the conversion to 239 Np considering it as instanteneous. We also disregar' burnout; the total burnout is not more than 1% for 239 Pu fission and much less for all other reactions.

The quantities qx are defined as follows:

$$q_1 = \text{amount of } 238_U$$

$$q_2 = \text{amount of } 239_U \text{ (or } 239_{Np}\text{)}$$

$$q_3 = \text{amount of } 239_{Pu}$$

$$q_4 = \text{amount of fission product (F.P.)} \quad . \qquad (A.3)$$

With these definitions and simplifications, we have the following system of differential equations:

 $q_1 = 0 (-r_1q_1 - r_2q_2)$ $\dot{q}_2 = -\mu q_2 + r_2q_1$ $\dot{q}_3 = \mu q_2 (-r_3q_3)$ $\dot{q}_4 = -\lambda q_4 + r_1q_1 + r_3q_3$

The dot means, as usual, the time derivative; the neglected burnout terms are added in parentheses.

We consider a time interval from t to t + Δt . The (constant) power level during this interval is p_t , so that $r_x = p_t \rho_x$, with ρ_x the reaction rate per unit power, i.e., the integral in formula (A.1). Thus, $p_t = 0$ during reactor shutdown.

Assuming $q_1(t) = 1$, the solution of the differential equation yields $q_1(t + \Delta t) = q_1(t) = 1$ (= constant) $q_2(t + \Delta t) = q_2(t)e^{-\Delta t} + \rho_2 p_t \Delta t \frac{1 - e^{-\mu\Delta t}}{\mu\Delta t}$ $q_3(t + \Delta t) = q_3(t) + q_2(t)$ (1 - $e^{-\mu\Delta t}$) + $\rho_2 p_t \Delta t$ $\left(1 - \frac{1 - e^{-\mu\Delta t}}{\mu\Delta t}\right)$ $q_4(t + \Delta t) = q_4(t)e^{-\lambda\Delta t} + \rho_1 p_t \Delta t \frac{1 - e^{-\lambda\Delta t}}{\lambda\Delta t}$ + $\rho_3 p_t \Delta t \left[q_3(t) \frac{1 - e^{-\lambda\Delta t}}{\lambda\Delta t} + q_2(t) \left(\frac{1 - e^{-\lambda\Delta t}}{\lambda\Delta t} - \frac{e^{-\mu\Delta t} - e^{-\lambda\Delta t}}{(\lambda - \mu)\Delta t}\right)$ + $\rho_2 p_t \Delta t \left[\frac{e^{-\lambda\Delta t} + \lambda\Delta t - 1}{(\lambda\Delta t)^2} - \frac{1}{\mu\Delta t} \left(\frac{1 - e^{-\lambda\Delta t}}{\lambda\Delta t} - \frac{e^{-\mu\Delta t} - e^{-\lambda\Delta t}}{(\lambda - \mu)\Delta t}\right)\right]\right]$ (A.5)

Repeated application of this formula leads to the determination of the amount of fission product q_4 at the end of an irradiation experiment, $t = t_{end}$, that extends over several periods of reactor operation at different power levels separated by reactor shutdowns.

Starting with $q_2(0) = q_3(0) = q_4(0) = 0$, the final amount at $t = t_{end}$, $q_4(t_{end})$, consists of two independent components, one from the fission of 238U that is proportional to ρ_1 , and the other from the fission of 239_{Fu} , proportional to the product $\rho_2 \cdot \rho_3$. Defining the total reaction probability of the reaction as

 $R_{x} = \rho_{x} \Sigma P_{t} \Delta t , \qquad (A.6)$

we can express the final amount q4 as

.

2.

 $q_4(t_{end}) = R_1C_1 + R_2R_3C_2$ (A.7)

A-2

(A.4)

L

where the factors C_1 and C_2 depend only on the power-time history of the irradiation experiment and can be calculated from formula (A.5).

$$q_4(t_{end}) = R_1 C_1 \left(1 + \frac{R_2 R_3}{R_1} \frac{C_2}{C_1} \right)$$
 (A.8)

so that

$$C_{Pu} = \frac{R_2 R_3}{R_1} \frac{C_2}{C_1}$$
(A.9)

represents the correction term which must be applied to the fission rate determination based on 238U fission alone. Table A.1 lists the values of R₂R₃/R₁ for different locations estimated from the adjustment procedure, and Table A.2 lists the ratios, C2/C1, for the different irradiation histories of SSC1, SSC2, and SPVC and different fission products. Uncertainties for R_2R_3/R_1 are about 22%; the uncertainties for C_2/C_1 are primarily due to fission yield uncertainties in the order of 2-3%. Table A.3 compares the correction terms determined from the differences between measurements of fission products in the ²³⁸U detectors and the LSL-M2 estimates of the ²³⁸U fission probability with the correction terms calculated from formula (9). The corrections from formula (A.9) do not contain corrections for self-shielding and are, therefore, consistently too large. Inspection of the ratios "(1)/(2)" in Table A.3, for the SSC2 and O-T positions, suggest a self-shielding factor of about 30%. The remaining discrepancies, including correction terms in the SSC1, 1/4T, and 1/2T positions, are less than 10% relative to the measurements and are in line with the measurement uncertainties of the other fission detectors.

Thus, Pu burn-in explains, at least qualitatively, the 238 U fission product measurement, including apparent discrepancies between measurements for different fission products. However, there are large uncertainties connected with the correction terms so that the 18 U(n,f) detectors are of questionable value for high-fluence applications (epithermal fluence > 10^{19} neutrons/cm² per unit lethargy).

				238 _{U(n,Y)*239_{Pu(n,f)}}
	238 _{U(n,f)}	238 _{U(n,Y)}	239 _{Pu(n,f)}	238 _{U(n,f)}
SSC1				
HB3	8.49 E-6	8.18 E-4	4.64 E-3	0.45
HB4	8.62 E-6	7.97 E-4	4.53 E-3	0.42
SSC2				
HB5	1.84 E-5	1.69 E-3	1.08 E-2	0.99
нвб	1.80 E-5	1.64 E-3	1.04 E-2	0.94
<u>0-T</u>				
HB1	1.42 E-5	1.62 E-3	1.02 E-2	1.16
HB2	1.40 E-5	1.59 E-3	1.00 E-2	1.14
1/4T				
HB7	7.05 E-6	7.10 E-4	4.70 E-3	0.47
HB8	6.97 E-6	6.69 E-4	4.44 E-3	0.43
1/2T				
HB9	3.06 E-6	3.38 E-4	1.94 E-3	0.21
HB10	3.04 E-6	3.42 E-4	1.96 E-3	0.22

Table A.1. Reaction probabilities estimated with LSL-M2

Table A.2. Irradiation time-history correction terms for 239pu burn-in

Piccica	F	ission yiel	d	Time (includ	-history t ing fissio	erms n yield)
product	238 _U (%)	239 _{Pu} (%)	Pu/U	SSC1	SSC2	SPVC
95 _{Zr}	5.17	4.72	0.91	0.45	0.52	0.80
103 _{Ru}	6.33	6.87	1.09	0.56	0.69	1.00
137 _{Cs}	5.97	6.50	1.09	0.48	0.51	0.54
140 _{Ba}	5.04	5.29	0.89	0.59	0.72	0.87

50

\$. .

			Fission	n produc	t	LSL-M2
		95 _{Zr}	102 _{Ru}	137 _{Cs}	140 _{Ba}	estimate
SSC1						
нвз	Measurements*	9.06	9.48	9.34	9.09	8.49
	Correction terms:					
	(1) Measurements vs. LSL-M2	0.067	0.117	0.099	0.071	
	(2) ²³⁹ Pu burn-in	0.203	0.252	0.216	0.266	
	Ratio (1)/(2)	0.33	0.46	0.46	0.27	
HB4	Measurements*	8.85	9.27	9.16	8.80	8.62
	Correction terms:					
	(1) Measurements vs. LSL-M2	0.027	0.075	0.062	0.021	
	(2) 239Pu burn-in	0.189	0.235	0.202	0.248	
	Ratio (1)/(2)	0.14	0.32	0.31	0.08	
SSC2						
HB5	Measurements*	25.38	28.02	26.33		18.42
	Correction terms:					
	(1) Measurements vs. LSL-M2	0.378	0.521	0.429		
	(2) ²³⁹ Pu burn-in	0.515	0.683	0.505		
	Ratio (1)/(2)	0.73	0.76	0.85		
HB6	Measurements*	23.56	25.36	24.50		17.96
	Correction terms:					
	(1) Measurements vs. LSL-M2	0.312	0.412	0.364		
	(2) ²³⁹ Fu burn-in	0.519	0.649	0.479		
	Ratio (1)/(2)	0.62	0.63	0.76		
<u>0-T</u>						
HB1	Measurements*	23.05	26.29	22.13		14.18
	Correction terms:					
	(1) Measurements vs. LSL-M2	0.626	0.854	0.561		
	(2) 239pu burn-in	0.928	1.160	0.627		
	Ratio $(1)/(2)$	0.67	0.74	0.89		

. * *

٠

Table A.3. Correction terms for Pu burn-in at different locations is the PSF

Table A.3. Continued

			Fission	produc	t	LSL-M2
		95 _{Zr}	102 _{Ru}	137 _{Cs}	140 _{Ba}	estimate
нв 2	Measurements*	21.77	24.56	20.84		14.03
	Correction terms:					
	(1) Measurements vs. LSL-M2	0.552	0.751	0.485		
	(2) ²³⁹ Pu burn-in	0.912	1.140	0.616		
	Ratio (1)/(2)	0.61	0.66	0.79		
<u>1/4T</u>						
нв7	Measurements*	8.05	8.77	8.90		7.05
	Correction terms:					
	(1) Measurements vs. LSL-M2	0.142	0.244	0.262		
	(2) 239pu burn-in	0.376	0.470	0.254		
	Ratio (1)/(2)	0.38	0.52	1.03		
HB8	Measurements*	7.35	8.20	7.77		6.97
	Correction terms:					
	(1) Measurements vs. LSL-M2	0.054	0.176	0.115		
	(2) ²³⁹ Pu burn-in	0.344	0.430	0.232		
	Ratio (1)/(2)	0.16	0.41	0.50		
<u>1/2T</u>						
HB9	Measurements*	3.23	3.27	3.38		3.06
	Correction terms:					
	(1) Measurements vs. LSL-M2	0.056	0.068	0.104		
	(2) 239pu burn-in	0.168	1.210	0.113		
	Ratio (1)/(2)	0.13	0.32	0.92		
HB10	Measurements*	3.00	3.24	3.35		3.04
	Correction terms:					
	(1) Measurements vs. LSL-M2	-0.013	0.066	0.102		
	(2) ²³⁹ Pu burn-in	0.176	1.220	0.119		
	Ratio (1)/(2)		0.30	0.86		

 $*^{238}$ U fission probability determined from fission product counting but not corrected for Pu burn-in (*10⁻⁶).

.

-

NUREG/CR-3814 ORNL/TM-9166 Dist. Category R5

INTERNAL DISTRIBUTION

1.	C. /	A. Baldwin	17.	C. E. Pugh
2.	R. (G. Berggren	18.	J. A. Setaro
3.	D. 1	M. Eissenberg	19-25.	F. W. Stallmann
4.	R. 1	W. Hobbs	26.	J. H. Swanks
5.	S. 5	S. Hurt	27.	G. Whitman
6-12.	F. 1	B. K. Kam	28.	Document Reference Section
13.	R. 1	E. Maerker	29-30.	Central Research Library
14.	A. 1	P. Malinauskas	31-32.	Laboratory Records Department
15.	L. 1	F. Miller	33.	Laboratory Records - ORNL R.C.
16.	R. 1	K. Nanstad	34.	ORNL Patent Office

EXTERNAL DISTRIBUTION

- 35. Assistant Manager for Energy Research and Development, U.S. Department of Energy, Oak Ridge Operations Office, Oak Ridge TN 37830
- 36-37. Technical Information Center, U.S. Department of Energy, Oak Ridge TN 37830
- 38-387. Given distribution under category R5 (10 copies NTIS)

a

BIBLIOGRAPHIC DATA SHEET	1. REPORT NUMBER (Assigned by DDC) NUREG/CR-3814
TITLE AND SUBTITLE (Add Volume No (angrogram)	ORNL/TM-9166
DETERMINATION OF DAMAGE EXPOSURE PARAMETER VALUES IN TH PSF METALLURGICAL IRKADIATION EXPERIMENT	E 3. RECIPIENT SACCESSION NO.
F. W. Stallmann	S. DATE REPORT COMPLETED MONTH May YEAR 1984
PERFORMIN 3 ORGANIZATION NAME AND MAILING ADDRESS (nelude Zip Code)	DATE REPORT ISSUED
Oak Ridge National Laboratory	NONTH YEAR
P.O. Box X	(Leave blank)
Oak Ridge, Tennessee 37831	1
	8. (Leave blank)
2. SPONSORING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code) Division of Engineering Technology	10. PROJECT/TASK/WORK UNIT NO.
Office of Nuclear Regulatory Research	
U.S. Nuclear Regulatory Commission	11. FIN NO.
Washington, D.C. 20555	B0415
3. TYPE OF REPORT	OVERED (Inclusive dates)
Topical	y 1984
5. SUPPLEMENTARY NOTES	14. (Leave blank)
Values for the damage exposure parameters fluence > 1.0 were determined for all locations of metallurgical spec ORR-PSF irradiation experiment. Determination is based HEDL and the fluence calculations by R. E. Maerker and	MeV, fluence > 0.1 MeV, and dpa imens in the test assembly of the on dosimetry measurements by B A Worley at OPNL The ISL-M
6 ABSTRACT (200 words or less) Values for the damage exposure parameters fluence > 1.0 were determined for all locations of metallurgical spec ORR-PSF irradiation experiment. Determination is based HEDL and the fluence calculations by R. E. Marker and adjustment procedure was used. The space dependency of be presented as a cosine-exponential function. Uncerta	MeV, fluence > 0.1 MeV, and dpa imens in the test assembly of the on dosimetry measurements by B. A. Worley at ORNL. The LSL-M2 the damage parameter values can inties are between 5 and 10%.
6. ABSTRACT (200 words or less) Values for the damage exposure parameters fluence > 1.0 were determined for all locations of metallurgical spec ORR-PSF irradiation experiment. Determination is based HEDL and the fluence calculations by R. E. Marker and adjustment procedure was used. The space dependency of be presented as a cosine-exponential function. Uncerta	MeV, fluence > 0.1 MeV, and dpa imens in the test assembly of the on dosimetry measurements by B. A. Worley at ORNL. The LSL-M2 the damage parameter values can inties are between 5 and 10%.
5. ABSTRACT (200 words or less) Values for the damage exposure parameters fluence > 1.0 were determined for all locations of metallurgical spec ORR-PSF irradiation experiment. Determination is based HEDL and the fluence calculations by R. E. Maerker and adjustment procedure was used. The space dependency of be presented as a cosine-exponential function. Uncerta	MeV, fluence > 0.1 MeV, and dpa imens in the test assembly of the on dosimetry measurements by B. A. Worley at ORNL. The LSL-M2 the damage parameter values can inties are between 5 and 10%.
6. ABSTRACT (200 words or less) Values for the damage exposure parameters fluence > 1.0 were determined for all locations of metallurgical spectors (ORR-PSF irradiation experiment. Determination is based HEDL and the fluence calculations by R. E. Marker and adjustment procedure was used. The space dependency of be presented as a cosine-exponential function. Uncertained be presented as a cosine-exponential function.	MeV, fluence > 0.1 MeV, and dpa imens in the test assembly of the on dosimetry measurements by B. A. Worley at ORNL. The LSL-Mi the damage parameter values can inties are between 5 and 10%.
 ABSTRACT (200 words or less) Values for the damage exposure parameters fluence > 1.0 were determined for all locations of metallurgical spec ORR-PSF irradiation experiment. Determination is based HEDL and the fluence calculations by R. E. Marker and adjustment procedure was used. The space dependency of be presented as a cosine-exponential function. Uncertained be presented as a cosine-exponential function. 	MeV, fluence > 0.1 MeV, and dpa imens in the test assembly of the on dosimetry measurements by B. A. Worley at ORNL. The LSL-M2 the damage parameter values can inties are between 5 and 10%.
6. ABSTRACT (200 words or less) Values for the damage exposure parameters fluence > 1.0 were determined for all locations of metallurgical spec ORR-PSF irradiation experiment. Determination is based HEDL and the fluence calculations by R. E. Marker and adjustment procedure was used. The space dependency of be presented as a cosine-exponential function. Uncertain 17. KEY WORDS AND DOCUMENT ANALYSIS 17. DESCRIP Dosimetry Neutron Transport Calculations Uncertainties	MeV, fluence > 0.1 MeV, and dpa imens in the test assembly of the on dosimetry measurements by B. A. Worley at ORNL. The LSL-Mi the damage parameter values can inties are between 5 and 10%.
6. ABSTRACT (200 words or less) Values for the damage exposure parameters fluence > 1.0 were determined for all locations of metallurgical spec ORR-PSF irradiation experiment. Determination is based HEDL and the fluence calculations by R. E. Marker and adjustment procedure was used. The space dependency of be presented as a cosine-exponential function. Uncertain the presented as a cosine-exponential function. Uncertaint Dosimetry Neutron Transport Calculations Uncertainties Damage Correlation	MeV, fluence > 0.1 MeV, and dpa imens in the test assembly of the on dosimetry measurements by B. A. Worley at ORNL. The LSL-Mi the damage parameter values can inties are between 5 and 10%.
 ABSTRACT (200 words or less) Values for the damage exposure parameters fluence > 1.0 were determined for all locations of metallurgical spector (ORR-PSF irradiation experiment. Determination is based HEDL and the fluence calculations by R. E. Marker and adjustment procedure was used. The space dependency of be presented as a cosine-exponential function. Uncertainties Dosimetry Neutron Transport Calculations Uncertainties Damage Correlation The IDENTIFIERS.OPEN-ENDED TERMS 	MeV, fluence > 0.1 MeV, and dpa imens in the test assembly of the on dosimetry measurements by B. A. Worley at ORNL. The LSL-M2 the damage parameter values can inties are between 5 and 10%.
 ABSTRACT (200 words or less) Values for the damage exposure parameters fluence > 1.0 were determined for all locations of metallurgical spect ORR-PSF irradiation experiment. Determination is based HEDL and the fluence calculations by R. E. Marker and adjustment procedure was used. The space dependency of be presented as a cosine-exponential function. Uncertainties presented as a cosine-exponential function. Uncertainties Damage Correlation 17. KEY WORDS AND DOCUMENT ANALYSIS 17. DESCRIPTION TRANSPORT Calculations 17. DENTIFIERS.OPEN-ENDED TERMS 18. AVAILABILITY STATEMENT 19. SECTION 	MeV, fluence > 0.1 MeV, and dpa imens in the test assembly of the on dosimetry measurements by B. A. Worley at ORNL. The LSL-M2 the damage parameter values can inties are between 5 and 10%.
 ABSTRACT (200 words or less) Values for the damage exposure parameters fluence > 1.0 were determined for all locations of metallurgical spec ORR-PSF irradiation experiment. Determination is based HEDL and the fluence calculations by R. E. Marker and adjustment procedure was used. The space dependency of be presented as a cosine-exponential function. Uncertain be presented as a cosine-exponential function. Uncertain Dosimetry Neutron Transport Calculations Uncertainties Damage Correlation IP IDENTIFIERS.OPEN-ENDED TERMS 18 AVAILABILITY STATEMENT 19.560 Unlimited 	MeV, fluence > 0.1 MeV, and dpa imens in the test assembly of the on dosimetry measurements by B. A. Worley at ORNL. The LSL-MA the damage parameter values can inties are between 5 and 10%.

120555078877 1 IANIR5 US NRC ADM-DIV OF TIDC POLICY & PUB MGT BR-PDR NUREG W-501 WA SHINGTON DC 20555

ð

Å

1

k

*

.

*