



Wayne H. Jens  
Vice President  
Nuclear Operations

Fermi-2  
6400 North Dixie Highway  
Newport, Michigan 48166  
(313) 586-4150

November 20, 1984  
EF2-71997

Director of Nuclear Reactor Regulation  
Attention: Mr. B. J. Youngblood, Chief  
Licensing Branch No. 1  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

- Reference: 1) Fermi 2  
NRC Docket No. 50-341
- 2) Detroit Edison Letter to NRC, "Submittal of  
SQRT List Update and Responses to Open  
Items", EF2-68287, dated June 22, 1984.
- 3) NUREG-0798, Safety Evaluation Report -  
Supplement No. 4, dated September, 1984.

Subject: Seismic Qualification of Equipment

Dear Mr. Youngblood:

Section 3.10 of Reference 3 indicated that as a result of the NRC's review of Reference 2, only Item (2) (c) [as identified in Section 3.10 of Supplement 3 to the SER] remained open. Edison has reviewed the status of valve V11-2006 and confirms the required modification has been completed, and the valve now meets the applicable seismic qualification criteria. This should resolve this remaining issue identified in SSER 4.

In addition, in accordance with SSER 3, item 3.10 (2) (d), and SSER 4, item 3.10.2 (b), attached are additional SQRT forms for equipment installed and qualified after the SQRT audit. These forms constitute the last set of SQRT forms to be submitted prior to fuel load. Edison, therefore, confirms that all safety-related equipment currently identified to be installed at time of fuel load is seismically qualified. As you are aware, Detroit Edison has a seismic qualification program to address future design changes with related Seismic Category I equipment. Edison will notify you of design changes identified subsequent to this letter and before fuel load, which require the qualification of additional equipment or structures not currently encompassed in Fermi 2 seismic qualification submittals to date.


8411280241 841120  
PDR ADOCK 05000341  
E PDR

A048  
1/38

Mr. B. J. Youngblood  
EF2-71997  
November 20, 1984  
Page 2

If you have any further questions on this matter, please contact  
Mr. O. K. Earle (313) 586-4211.

Sincerely,

A handwritten signature in cursive script, appearing to read "Wayne A. Jones". The signature is written in dark ink and is positioned to the right of the typed name "Wayne A. Jones".

cc: Mr. P. M. Byron  
Mr. M. D. Lynch  
Mr. A. Lee  
USNRC, Document Control Desk  
Washington, DC 20555

Mr. B. J. Youngblood  
EF2-71997  
November 20, 1984  
Page 3

bcc: F. E. Agosti  
Y. A. Anand\*  
L. P. Bregni  
R. A. Bryer  
W. F. Colbert  
O. K. Earle\*  
W. R. Holland  
W. H. Jens (2)  
R. S. Lenart  
E. Lusic  
P. A. Marquardt  
T. D. Phillips  
M. S. Rager  
G. M. Trahey  
R. A. Vance  
A. E. Wegele  
NOC Approval Control - ARMS Coding\*  
O. K. Earle (Bethesda Office)  
Secretary's Office (2412 WCB)  
NRR Chron File

\* With attachment

Qualification Summary of EquipmentI. Plant Name: Enrico Fermi Atomic Power Plant - Unit 2 Type:1. Utility: Detroit Edison Company PWR  
2. NSSS: GE 3. A/E: DECo BWR XII. Component Name Annubar Flow Element1. Scope: ( ) NSSS (X) BOP2. Model Number: ANR 763. Vendor: Dieterich Standard Corp.4. If the component is a cabinet or panel, name and model No. of the devices included: (See Section VIII)5. Physical Descriptiona. Appearance (See Section IX)b. Dimensions 21.37" long, probe 0.813" x 0.813" square (approx.)c. Weight 10.5 lbs. (approx.)6. Location: Building: AuxiliaryElevation: 691'-3"7. Field Mounting Condition ( ) Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)  
(X) Weld (Length 5.7")  
( ) \_\_\_\_\_8. a. System in which located: T-46b. Functional Description Measures flowc. Is the equipment required for ( ) Hot Standby ( ) Cold Shutdown  
(X) Both ( ) Neither9. Pertinent Referenced Design Specifications IEEE 344-1975

III. Is Equipment Available for Inspection in the Plant? (X) Yes ( ) No  
 However it is inaccessible.

IV. Equipment Qualification Method:

( ) Test (X) Analysis ( ) Combination of Test  
 and Analysis

Qualification Report\*: ER-5109, Rev. A, "Seismic Analysis Qualification  
 Annubar Flow Element Model ANR 76, Jan. 25, 1984  
 DECo File No. R3-865

Company that Prepared Report: Dieterich Standard Corp.

Company that Reviewed Report: DECo

V. Vibration Input

1. Loads considered: a. (X) Seismic only

b. ( ) Hydrodynamic only

c. ( ) Combination of (a) and (b)

2. Method of Combining RRS: ( ) Absolute Sum ( ) SRSS

(X) N/A

other, specify

3. Required Response Spectra (attach the graphs): N/A

4. Damping Corresponding to RRS: OBE N/A SSE N/A

5. Required Acceleration in Each Direction: ( ) ZPA

(X) 5g horizontal

3g vertical

other, specify

6. Were fatigue effects or other vibration loads considered?

(X) Yes

( ) No

If yes, describe loads considered and how they were treated in  
overall qualification program: The strouhal frequency of the fluid  
 probe system was calculated and was compared with the natural fre-  
 quency of the probe to ensure that the fluid forcing function would  
 not cause the probe to resonate.

\*NOTE: If more than one report complete items IV through VII for each report.

VI. If Qualification by Test then Complete\*: N/A

1. ( ) Single Frequency ( ) Multi-Frequency ( ) random  
( ) sine beat ( ) \_\_\_\_\_  
other, specify

2. ( ) Single Axis ( ) Multi-Axis

3. No. of Qualification Tests: OBE \_\_\_\_\_ SSE \_\_\_\_\_  
Other \_\_\_\_\_

4. Frequency Range: \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back,  
Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies \_\_\_\_\_

( ) Lab Test ( ) In-Situ Test ( ) Analysis

7. TRS enveloping RRS using Multi-Frequency Test ( ) Yes (Attach TRS & RRS  
Graphs)  
( ) No

8. Input g-level Test: OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_  
SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

1. ( ) Bolt (No. \_\_\_\_, Size \_\_\_\_ ) ( ) Weld (Length \_\_\_\_ ) ( ) \_\_\_\_\_

10. Functional operability verified: ( ) Yes ( ) No ( ) Not Applicable

11. Test Results including modifications made: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including  
results): \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\*NOTE: If qualification by a combination of test and analysis also complete  
Item VII.

VII. If Qualification by Analysis, then Complete:

1. Method of Analysis:

- Static Analysis       Equivalent Static Analysis  
 Dynamic Analysis       Time-History     Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = Not determined F/B = 299 HZ V = 299 HZ

3. Model Type:  3D       2D     1D  
 Finite Element     Beam     Closed Form Solution

4.  Computer Codes: \_\_\_\_\_

Frequency Range and No. of modes considered: \_\_\_\_\_

Hand Calculations

5. Method of Combining Dynamic Responses:  Absolute Sum     SRSS

Other: N/A  
 (specify)

6. Damping: OBE - SSE - Basis for the damping used: N/A

7. Support Considerations in the model: Fixed

8. Critical Structural Elements: Exterior probe and internal tubes

A. Identification	Location	Governing Load	Seismic Stress	Total Stress	Stress Allowable
		or Response Combination			
Probe	Static Port		1795	2282	18,800 psig
Inner Tubes	Welds		3208	4210	18,800 psig

B. Max. Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
$1.02 \times 10^{-3}$ in	Static port of probe	5° or 0.715 in.

VIII. List of Subcomponents    N/A

<u>Name</u>	<u>Model No. - *Weight - *Location - If subcom- ponent was actually present</u>	<u>Was Component present or mass simulated?</u>	<u>Was subcomponent operability veri- fied (Y or N or U **)</u>
-------------	---	---	---

\* If Available

\*\* Yes = Yes, N = No, U = Unknown



# ANNUBAR Flow Measurement

## IX. Sketch or drawing installed

How it has been installed

OR

How it will be installed

Industrial Line

Dieterich Standard Corporation

Regular models  
General purpose flow applications

DS-1000 (5/79)  
Section B



ITEM NO	SERIAL NO	TAG NO	FLUID	DESIGN			APPROX WEIGHT (LBS)	REVISION	
				PRESS (PSIA)	TEMP (°F)	FLOW (CFH)		NO	DESCRIPTION
01	10004 01 1	T48ND12A	AIR	16.7	250	240000	10.5	A	ISSUE
01	10004 01 2	T48ND12B	AIR	16.7	250	240000	10.5	B	ECR R1294

**PRODUCTION NOTES FOR DUCT FLANGE**

1. MAT IS TO BE 187
2. PIECE IS TO HAVE A 8.375" RADIUS BEND

**DECO FILE NO. R3-870**

**NOTES**

1. PERMANENT RUSTPROOF METAL TAG SHOWING MODEL NUMBER, LINE SIZE, SERIAL NUMBER AND INFORMATION AS SUPPLIED BY CUSTOMER (A TAG NUMBER, DESIGN FLOW/METER READINGS)
2. ANNUBAR TO BE DESIGNED AND MANUFACTURED IN ACCORDANCE WITH ASME B89V CODE SECTION III, CLASS 3, LESS A1 AND STAMP
3. WELDING OF ALL PRESSURE RETAINING AND WETTED PARTS TO BE PER EP-4885, PARAGRAPH 3.8
4. VISUAL WELD EXAMINATION PER ES-1818
5. ASSEMBLY TO BE HYDROSTATICALLY TESTED PER EP-4817
6. DYE PENETRANT INSPECTION TO BE PER ES-1812
7. ASSEMBLY TO BE CLEANED PER ES-1888
8. SPECIAL HANDLING PER EP-4823
9. PACKING, SHIPPING AND STORAGE OF ASSEMBLY TO BE PER EP-4827

DETROIT EDISON CO  
P O NO 1450785  
DUCT CONTROL NO P-0884

**ANR 76 DUCT ANNUBAR**

SU-273 8

Qualification Summary of Equipment

I. Plant Name: Enrico Fermi Atomic Power Plant - Unit 2 Type:

1. Utility: Detroit Edison Company PWR  
 2. NSSS: GE 3. A/E: DECo BWR X

II. Component Name Presure Transmitter

1. Scope: ( )NSSS (X)BOP
2. Model Number: 1153GB7
3. Vendor: Rosemount
4. If the component is a cabinet or panel, name and model No. of the devices included: (See Section VIII)
5. Physical Description
  - a. Appearance (See Section IX)
  - b. Dimensions 4-1/2" x 4-1/2" x 9" H
  - c. Weight 13 lbs.
6. Location: Building: Reactor  
Elevation: Varies
7. Field Mounting Condition ( )Bolt (No. 4, Size 5/16")  
 ( )Weld (Length )  
 ( )
8. a. System in which located: T-49  
 b. Functional Description Measurement of Gage Pressure  
 c. Is the equipment required for ( )Hot Standby ( )Cold Shutdown  
 (X)Both ( )Neither
9. Pertinent Referenced Design Specifications IEEE-344-1975

III. Is Equipment Available for Inspection in the Plant?(X)Yes( )No

IV. Equipment Qualification Method:

(X)Test ( )Analysis ( )Combination of Test and Analysis

Qualification Report\*: Rosemount Report 108025, Rev. B, 2/22/83:  
Qualification report for pressure transmitters  
(No., Title and Date) Rosemount Model 1153 Series B (DECo #C1-1689)

Company that Prepared Report: Rosemount

Company that Reviewed Report: DECo

V. Vibration Input

- 1. Loads considered: a.(X)Seismic only  
b.( )Hydrodynamic only  
c.( )Combination of (a) and (b)

2. Method of Combining RRS:( )Absolute Sum ( )SRSS  
( ) N/A  
other, specify \_\_\_\_\_

3. Required Response Spectra (attach the graphs):See Attachment "A"  
(Generic Requirement by the vendor)

4. Damping Corresponding to RRS: OBE 5% SSE 5%

5. Required Acceleration in Each Direction:( )ZPA  
( ) \_\_\_\_\_  
other, specify \_\_\_\_\_

6. Were fatigue effects or other vibration loads considered?

(X)Yes ( )No

If yes, describe loads considered and how they were treated in overall qualification program: Sine vibration sweep in a limited frequency range to simulate semi-rigid mounting at field.

\*NOTE: If more than one report complete items IV through VII for each report.

VI. If Qualification by Test then Complete\*:

1. ( ) Single Frequency (X) Multi-Frequency ( ) random  
 ( ) sine beat ( ) \_\_\_\_\_  
 other, specify

2. ( ) Single Axis (X) Multi-Axis

3. No. of Qualification Tests: OBE 5 SSE 1  
 Other \_\_\_\_\_

4. Frequency Range: 1-33

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): RIGID. See note 1 below.

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies See note 1 below

( ) Lab Test ( ) In-Situ Test ( ) Analysis

7. TRS enveloping RRS using Multi-Frequency Test (X) Yes (Attach TRS & RRS Graphs)  
 ( ) No See Attachment "A"

8. Input g-level Test: OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_  
 N/A SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

1. (X) Bolt (No. 4, Size 5/16) ( ) Weld (Length \_\_\_\_\_) ( ) \_\_\_\_\_

10. Functional operability verified: (X) Yes ( ) No ( ) Not Applicable

11. Test Results including modifications made: Satisfactory

12. Other tests performed (such as aging or fragility test, including results): Aging: Thermal, Functional, Radiation, Seismic.  
Results: Satisfactory

\*NOTE: If qualification by a combination of test and analysis also complete Item VII.

Item VII. Note 1. Resonance search was conducted by a low level (approx. 0.2g single axis sine sweep from 1 to 60 Hz, in each of three orthogonal axes. The sweep rate was one octave per minute. The test results are given in Table 16, Page 44 of the O.T.R. (Type Test Report, Vol. 1, Test Results).

VII. If Qualification by Analysis, then Complete: N/A

1. Method of Analysis:

- Static Analysis                       Equivalent Static Analysis
- Dynamic Analysis                       Time-History    Response Spectra

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

3. Model Type:  3D                       2D    1D  
 Finite Element  Beam  Closed Form Solution

4.  Computer Codes: \_\_\_\_\_

Frequency Range and No. of modes considered: \_\_\_\_\_

Hand Calculations

5. Method of Combining Dynamic Responses:  Absolute Sum    SRSS

Other: \_\_\_\_\_  
(specify)

6. Damping: OBE \_\_\_ SSE \_\_\_ Basis for the damping used: \_\_\_\_\_

7. Support Considerations in the model: \_\_\_\_\_

8. Critical Structural Elements: \_\_\_\_\_

A. Identification	Location	Governing Load	Seismic	Total	Stress
		or Response Combination			

B. Max. Critical Deflection	Location	Maximum Allowable Deflection to
		Assure Functional Operability

VIII. List of Subcomponents

TABLE

Model No. - \*Weight -  
\*Location - If subcom-  
ponent was actually  
present

Was Component  
present or mass  
simulated?

Was subcomponent  
operability veri-  
fied (Y or N or  
U \*\*)

\* If Available

\*\* Yes = Yes, N = No, U = Unknown

SQRT FORM

IX. Sketch or drawing installed

How it has been installed

or


How it will be installed

From  
Rosemount Inc. 1978  
Product Data Sheet  
2302




# Rosemount PRESSURE TRANSMITTERS

## DIMENSIONAL DRAWINGS MODEL 1153AB AND 1153GB



### TYPICAL MOUNTING CONFIGURATION




Page No. 60  
Report No. 45353-1

FULL SCALE SHOCK SPECTRUM (g Peak)

1.0  10  100  1000

DAMPING  5%



SPECIMEN 345

LOCATION NO H2

AXIS Long/V

TEST RUN NO 22



Qualification Summary of Equipment

I. Plant Name: Enrico Fermi Atomic Power Plant - Unit 2 Type:

1. Utility: Detroit Edison Company PWR  
 2. BSSS: GE 3. A/E: DECo BWR X

II. Component Name Differential Pressure Transmitter

1. Scope: ( ) NSSS (X) BOP  
 2. Model Number: Veltron/4 - BEJPV  
 3. Vendor: Air Monitor Corporation  
 4. If the component is a cabinet or panel, name and model No. of the devices included: (See Section VIII)

5. Physical Description  
 a. Appearance (See Section IX)  
 b. Dimensions  
 c. Weight 55 lbs (approximately)

6. Location: Building: Auxiliary  
Elevation: 3rd Floor

7. Field Mounting Condition (X) Bolt (No. 2, Size 0.281)  
( ) Weld (Length )  
(X) Additional silicon adhesive  
GE RTV-108

8. a. System in which located: T-41  
Monitor differential pressure for room  
 b. Functional Description: pressurization (Ref. NUREG 75/087)

c. Is the equipment required for ( ) Hot Standby ( ) Cold Shutdown  
(X) Both ( ) Neither

9. Pertinent Referenced Design Specifications IEEE 344-1975

III. Is Equipment Available for Inspection in the Plant?  Yes  No

IV. Equipment Qualification Method:

- Test
- Analysis
- Combination of Test and Analysis

Qualification Report\*: 1A-57815, IEEE-323 & IEEE-344 Qualification  
 (No., Title and Date) Summary. 1/25/84. DECo File No. C1-2529. This report is to be used in conjunction with C1-2530 and C1-2531.  
 Company that Prepared Report: Wyle Laboratories for Air Monitor Corp.  
Test Report No. 58800 and 58619  
 Company that Reviewed Report: DECo

V. Vibration Input

1. Loads considered:
  - a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Combination of (a) and (b)
2. Method of Combining RRS:  Absolute Sum  SRSS  
 \_\_\_\_\_  
 other, specify
3. Required Response Spectra (attach the graphs): See Attachments "A" and "B"
4. Damping Corresponding to RRS: OBE \_\_\_\_\_ SSE 3%
5. Required Acceleration in Each Direction:  ZPA  
 See Attachment "C"  
 other, specify
6. Were fatigue effects or other vibration loads considered?  
 Yes  No

If yes, describe loads considered and how they were treated in overall qualification program: See page 22, Wyle Lab Qualification Plan 57612-1, DECo File C1-2531. Operational Cycling Effects. Aging effects of mechanical cycling were found to be insignificant.

\*NOTE: If more than one report complete items IV through VII for each report.

**VI. If Qualification by Test then Complete\*:**

1. ( ) Single Frequency (X) Multi-Frequency (X) random  
 ( ) sine beat ( ) \_\_\_\_\_  
 other, specify \_\_\_\_\_

2. ( ) Single Axis (X) Multi-Axis

3. No. of Qualification Tests: OBE 5 SSE 1  
 Other \_\_\_\_\_

4. Frequency Range: 1 1/2 to 40 HZ

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): 30 HZ combined. See Attachment "D", Transmissibility curve.

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies Resonance search

(X) Lab Test ( ) In-Situ Test ( ) Analysis

7. TRS enveloping RRS using Multi-Frequency Test (X) Yes (Attach TRS & RRS Graphs)  
 ( ) No

8. Input g-level Test: OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_ N/A

SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting: See Page 23, Wyle Qualification Plan 57612-1, Rev. A, DECo C1-2531. Mounting hole pattern of equipment is simulated in the test fixture.  
 1. (X) Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_) ( ) Weld (Length \_\_\_\_\_) ( ) \_\_\_\_\_

10. Functional operability verified: (X) Yes ( ) No ( ) Not Applicable

11. Test Results including modifications made: Satisfactory  
 \_\_\_\_\_  
 \_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including results): Baseline functional, radiation, aging, time-temperature effect, operational cycling effect.  
 \_\_\_\_\_  
 \_\_\_\_\_

\*NOTE: If qualification by a combination of test and analysis also complete Item VII.

VII. If Qualification by Analysis, then Complete: N/A

1. Method of Analysis:

- Static Analysis             Equivalent Static Analysis
- Dynamic Analysis            Time-History    Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

3. Model Type:  3D                     2D    1D  
 Finite Element  Beam  Closed Form Solution

4.  Computer Codes: \_\_\_\_\_

Frequency Range and No. of modes considered: \_\_\_\_\_

Hand Calculations

5. Method of Combining Dynamic Responses:  Absolute Sum    SRSS

Other: \_\_\_\_\_  
(specify)

6. Damping: OBE \_\_\_ SSE \_\_\_ Basis for the damping used: \_\_\_\_\_

7. Support Considerations in the model: \_\_\_\_\_

8. Critical Structural Elements: \_\_\_\_\_

A. Identification	Location	Governing Load	Seismic Stress	Total Stress	Stress Allowable
		or Response Combination			

B. Max. Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
-----------------------------	----------	---

VIII. List of Subcomponents

<u>Name</u>	<u>Model No. - *Weight - *Location - If subcom- ponent was actually present</u>	<u>Was Component present or mass simulated?</u>	<u>Was subcomponent operability veri- fied (Y or N or U **)</u>
-------------	---	---	---

IEEE-323 & 344 QUALIFICATION SUMMARY  
Document No. 1A-57815

1-25-1984

page 3 of 19

2.0 IEEE-323 QUALIFICATION (WYLE Report No. 58800)

2.1 DESCRIPTION OF COMPONENTS


- a) Electronic Differential Pressure Transducer  
Manufacturer / Model: Air Monitor Corp., Veltron Series 2000
- b) Electronic Signal Conditioner/Scaling Multiplier  
Manufacturer / Model: Air Monitor Corp., Factron Series 1500  
Note: Two different models of the Factron Series (1000 & 1750) were qualified in the following test. Together these models contain all of the components and systems incorporated in any other single model in the Factron line. Therefore, their qualification will qualify all Factron models, due to their similarity of construction and components. The Factron 1000 contains all of the components and systems in the Factron 1500, plus the most sensitive system tested, a square rooting circuit, which is not incorporated in the 1500. Since the Factron 1000 is qualified, the Factron 1500 is considered to be also.
- c) Fuse  
Manufacturer / Model: Bussman/Fusetron FRN-R-1
- d) Fuse Block  
Manufacturer / Model: Allen Bradley, 1491-N122
- e) Terminal Strip  
Manufacturer / Model: General Electric, CR151A2
- f) Pneumatic Tubing, Polyurethane  
Manufacturer / Model: J.P. Stevens, MP1880
- g) Electrical Wiring  
Manufacturer / Model: Carol, 18 ga. MTW
- h) Wire Connectors  
Manufacturer / Model: Molex, series 22
- i) Bulkhead Connectors  
Manufacturer / Model: Parker, 01600-7002
- j) 20" x 20" NEMA Type 4 Enclosure  
Manufacturer / Model: Hoffman, A20H20BLP

**IX. Sketch or drawing installed**


How it has been installed

or





How it will be installed



**FRONT VIEW**




**BOTTOM VIEW**





PD1-1  
(-2.5 TO +2.5 W.C.)

NEMA 4 ENCLOSURE  
A20H20 BLP  
WITH A20P20 BACK PANEL

IDENTIFICATION  
LABEL




BILL OF MATERIALS		
ITEM	QTY	DESCRIPTION



**INFORMATION ONLY**

**PROJECT**  
ENRICO FERMI POWER PLANT, UNIT 2  
PURCHASER: DETROIT EDISON COMPANY  
P.O. NO. 1A-57815  
INSTRUMENT TAG NO'S:  
PDX-T41-N022A  
PDX-T41-N022B  
PDX-T41-N024A  
PDX-T41-N024B

QA. LEVEL I  
SEISMIC CLASS I  
CLASS 1E



**C1-2347**

**NOTES**

- ES<sub>2</sub> = 24VDC
- ES<sub>3</sub> = 5VDC
- ⚠ INSTRUMENT TAGGING PER SPEC. 3071-315, APPENDIX C
- ⚠ MAX OUTPUT LOAD IMPEDANCE - 1K OHMS
- ⚠ TOTAL PANEL WEIGHT 35 LBS
- ⚠ NO SHIELD WIRE TERMINATIONS

REV	DATE	DESCRIPTION	DR	CR	DR	AUTH
A	7/28/83	ECD 637				

**Air Monitor Corporation**  
P.O. BOX 6380 SANTA ROSA, CA 95406  
TELEPHONE (707) 544-1700

TITLE: SYSTEM DIAGRAMMATIC B WIRING DIAGRAM  
VELTRON/4-BEJPV (TYPICAL OF 4 CENTERS)

DESIGNED BY: DATE: 6-13-83  
DRAWN BY: DATE: 6-14-83  
CHECKED BY: DATE: 6-14-83  
SCALE: NTS  
SHEET: 1 OF 1  
SIZE: OR NUMBER NO: C  
REV: SNC-106-100 A

FIG. 1 - HORIZONTAL ACCELERATIONS

WYLE LABORATORIES SCIENTIFIC SERVICES & SYSTEMS GROUP

IEEE-323 & 344 QUALIFICATION SUMMARY Document No. 1A-57815

1-25-1984

page 15 of 19

CUSTOMER AIR MONITOR Job No. 58800 Date 3-1-83  
 Specimen DIFF. PRESSURE TRANSDUCER CENTER Axis of Test X-Y  
 Accel. No. 1 Axis HORIZ Control (  ) Response ( ) OBE ( ) SSE (  ) DBE ( )  
 Full Scale 100 g Damping 3 % Run No. 6  
 Operator GRETERMAN Engineer Ron

RESPONSE SPECTRUM




FIG. 2 - VERTICAL ACCELERATIONS

IEEE-323 & 344 QUALIFICATION SUMMARY  
Document No. 1A-57815


**WYLE**  
LABORATORIES SCIENTIFIC SERVICES & SYSTEMS GROUP

1-25-1984

page 16 of 19

CUSTOMER AIR MONITOR Job No. 58800 Date 3-1-83  
 Specimen DIFF. PRESSURE TRANSDUCER CENTER Axis of Test X-Y  
 Accel. No. 2 Axis VERT Control (  ) Response ( ) OBE ( ) SSE (  ) DBE ( )  
 Full Scale 100 g Damping 3 % Run No. 6  
 Operator GRETERMAN Engineer Roman

RESPONSE SPECTRUM



ACCELERATION g's PEAK

vm Approval








FIG. 3 - COMBINED ACCELERATIONS  
FREQUENCY HZ



**Air Monitor Corporation**

SANTA ROSA • CALIFORNIA




IEEE-323 & 344 QUALIFICATION SUMMARY  
Document No. 1A-57815

1-25-1984

page 18 of 19

FIG. 4 - TRANSMISSIBILITY (DOOR-MOUNTED EQUIPMENT)



Qualification Summary of Equipment

I. Plant Name: Enrico Fermi Atomic Power Plant - Unit 2 Type:

- 1. Utility: Detroit Edison Company PWR \_\_\_\_\_
- 2. NSSS: GE 3. A/E: DECo BWR X

II. Component Name Pressure Regulator

- 1. Scope: ( ) NSSS (X) BOP
- 2. Model Number: Circle Seal NP20-2
- 3. Vendor: Circle Seal Controls
- 4. If the component is a cabinet or panel, name and model No. of the devices included: (See Section VIII)
- 5. Physical Description
  - a. Appearance (See Section IX)
  - b. Dimensions See page 6
  - c. Weight 5 lbs. approximately
- 6. Location: Building: Reactor  
Elevation: 2nd and 3rd Floor
- 7. Field Mounting Condition ( ) Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)  
( ) Weld (Length \_\_\_\_\_)  
(X) Male/Female Connector
- 8. a. System in which located: T50  
b. Functional Description Pressure Regulator for Primary Containment H<sub>2</sub>-O<sub>2</sub> Monitoring System  
c. Is the equipment required for ( ) Hot Standby ( ) Cold Shutdown  
(X) Both ( ) Neither
- 9. Pertinent Referenced Design Specifications IEEE-344-1975

III. Is Equipment Available for Inspection in the Plant?  Yes  No

IV. Equipment Qualification Method:

- Test
- Analysis
- Combination of Test and Analysis

Qualification Report\*: Seismic Test Report of Circle Seal Controls  
Part No. NP20-2 including Test Report #16262 of  
 (No., Title and Date) Environmental Action Testing Corp. DECo File No.  
CI-2585

Company that Prepared Report: Circle Seal Controls

Company that Reviewed Report: DECo

V. Vibration Input

- 1. Loads considered: a.  Seismic only
- b.  Hydrodynamic only
- c.  Combination of (a) and (b)

2. Method of Combining RRS:  Absolute Sum  SRSS  
 \_\_\_\_\_  
 other, specify

3. Required Response Spectra (attach the graphs): Attachment "A"  
 Generic by Vendor

4. Damping Corresponding to RRS: OBE 1% SSE 1%

5. Required Acceleration in Each Direction:  ZPA  
 N/A  
 other, specify

6. Were fatigue effects or other vibration loads considered?

- Yes
- No
- NOT MENTIONED IN TEST REPORT

If yes, describe loads considered and how they were treated in overall qualification program: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

\*NOTE: If more than one report complete items IV through VII for each report.

VI. If Qualification by Test then Complete\*:

1. ( ) Single Frequency (X) Multi-Frequency (X) random  
( ) sine beat ( ) \_\_\_\_\_  
other, specify

2. ( ) Single Axis (X) Multi-Axis

3. No. of Qualification Tests: OBE 5 SSE 1  
Other \_\_\_\_\_

4. Frequency Range: 1 - 35 HZ

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): None below 35 HZ, Reference Page 8 of Report

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies Resonance Search  
( ) Lab Test ( ) In-Situ Test ( ) Analysis

7. TRS enveloping RRS using Multi-Frequency Test (X) Yes (Attach TRS & RRS Attachment "A" Graphs)  
( ) No

8. Input g-level Test: OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_ N/A  
SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

1. ( ) Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_) ( ) Weld (Length \_\_\_\_\_) (X) Bulkhead type fixture

10. Functional operability verified: (X) Yes ( ) No ( ) Not Applicable

11. Test Results including modifications made: Satisfactory  
\_\_\_\_\_  
\_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including results): N/A  
\_\_\_\_\_  
\_\_\_\_\_

\*NOTE: If qualification by a combination of test and analysis also complete Item VII.

VII. If Qualification by Analysis, then Complete:

1. Method of Analysis:

- Static Analysis                       Equivalent Static Analysis  
 Dynamic Analysis                       Time-History     Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

3. Model Type:  3D                       2D     1D  
 Finite Element  Beam  Closed Form Solution

4.  Computer Codes: \_\_\_\_\_

Frequency Range and No. of modes considered: \_\_\_\_\_

- Hand Calculations

5. Method of Combining Dynamic Responses:  Absolute Sum     SRSS

Other: \_\_\_\_\_  
 (specify)

6. Damping: OBE \_\_\_ SSE \_\_\_ Basis for the damping used: \_\_\_\_\_

7. Support Considerations in the model: \_\_\_\_\_

8. Critical Structural Elements: \_\_\_\_\_

A. Identification	Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable

B. Max. Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability

VIII. List of Subcomponents

<u>Name</u>	<u>Model No. - *Weight - *Location - If subcom- ponent was actually present</u>	<u>Was Component present or mass simulated?</u>	<u>Was subcomponent operability veri- fied (Y or N or U **)</u>
-------------	---	---	---

\* If Available

\*\* Yes = Yes, N = No, U = Unknown

IX. Sketch or drawing installed




How it has been installed

OR

How it will be installed

CRR 20-22

CENTRAL  
BLUEPRINT  
FILE



SECTION A-A  
SCALE: 2/1

<b>CONTROLS DIVISION</b> CIRCLE SEAL CORPORATION AMYUN, W. CALIFORNIA		
<b>REGULATOR, CORROSION &amp; DIFFUSION RESISTANT</b> (HIGH PURITY GASES & CORROSIVE FLUIDS)		
C 31816	31816	CRR 20 THRU 22
WRE/12/1/	WT N7780	101 SHEET 1 OF 1



NO. 31,288 LOGARITHMIC SCALE BY THREE ENGINEERING

ENVIRONMENTAL TESTING CORPORATION


NO. 31,288 LOGARITHMIC SCALE BY THREE ENGINEERING

FIGURE 2  
FRRS  
OBE + SSE  
0r 50, 1/4 DAMPING



Test No. \_\_\_\_\_  
 Date \_\_\_\_\_  
 Customer \_\_\_\_\_  
 Test Item P/N \_\_\_\_\_  
 Test Item S/N \_\_\_\_\_  
 Type of Test \_\_\_\_\_  
 Spec. No. \_\_\_\_\_  
 Para. No. \_\_\_\_\_  
 Conditions \_\_\_\_\_  
 Temperature \_\_\_\_\_  
 Period of Test \_\_\_\_\_  
 Control Axis \_\_\_\_\_  
 Pump No. \_\_\_\_\_  
 CA-30 Axis \_\_\_\_\_

Test ENGT. \_\_\_\_\_  
 GRMS \_\_\_\_\_



10.0

10.0

1.0

1.0

NO. 31,288

Qualification Summary of Equipment

I. Plant Name: Enrico Fermi Atomic Power Plant - Unit 2 Type:

1. Utility: Detroit Edison Company PWR \_\_\_\_\_  
 2. NSSS: GE 3. A/E: DECo BWR X

II. Component Name Differential Pressure Switch

1. Scope:  NSSS ( ) BOP

2. Model Number: 580A-0

3. Vendor: ITT Barton

4. If the component is a cabinet or panel, name and model No. of the devices included: (See Section VIII)

5. Physical Description

a. Appearance (See Section IX)

b. Dimensions See page 6

c. Weight 15 lbs. approximately

6. Location: Building: Reactor Building sub-basement

Elevation: 548'-0"

7. Field Mounting Condition  Bolt (No. 4, Size 3/8)  
 ( ) Weld (Length \_\_\_\_\_)  
 ( ) \_\_\_\_\_

8. a. System in which located: T-23

b. Functional Description Differential Pressure Switch for Primary Containment Vent System

c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither

9. Pertinent Referenced Design Specifications IEEE - 344 -1975

III. Is Equipment Available for Inspection in the Plant? (X) Yes ( ) No

IV. Equipment Qualification Method:

(X) Test ( ) Analysis ( ) Combination of Test and Analysis

Qualification Report\*: R3-580A-9, ITT Barton Qualification Test Report;  
580A Series Differential Pressure Switch; 12/83;  
(No., Title and Date) DECo File No. CI-2586 (4 Volumes)

Company that Prepared Report: ITT Barton

Company that Reviewed Report: Seismic Review by DECo

V. Vibration Input

1. Loads considered: a. (X) Seismic only

b. ( ) Hydrodynamic only

c. ( ) Combination of (a) and (b)

2. Method of Combining RRS: ( ) Absolute Sum ( ) SRSS  
( ) N/A  
other, specify \_\_\_\_\_

3. Required Response Spectra (attach the graphs): See Attachments "A" and "B"

4. Damping Corresponding to RRS: OBE 5% SSE 5%

5. Required Acceleration in Each Direction: ( ) ZPA  
( ) N/A  
other, specify \_\_\_\_\_

6. Were fatigue effects or other vibration loads considered?

(X) Yes ( ) No

If yes, describe loads considered and how they were treated in overall qualification program: Accelerated aging.  
Result: Satisfactory

\*NOTE: If more than one report complete items IV through VII for each report.

VI. If Qualification by Test then Complete\*:

1. ( ) Single Frequency (X) Multi-Frequency ( ) random  
( ) sine beat ( ) \_\_\_\_\_  
other, specify

2. ( ) Single Axis (X) Multi-Axis

3. No. of Qualification Tests: OBE 5 SSE 1  
Other \_\_\_\_\_

4. Frequency Range: 1 to 100 HZ \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): Resonance search indicated resonance above 40HZ in all directions (Page IV-17, Volume 2 of Report)

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies Resonance Search

(X) Lab Test ( ) In-Situ Test ( ) Analysis

7. TRS enveloping RRS using Multi-Frequency Test ( ) Yes (Attach TRS & RRS Graphs)  
( ) No

8. Input g-level Test: OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_  
SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

1. ( ) Bolt (No. \_\_, Size \_\_) ( ) Weld (Length \_\_) (X) Simulation of Actual Mounting

10. Functional operability verified: (X) Yes ( ) No ( ) Not Applicable

11. Test Results including modifications made: Satisfactory

12. Other tests performed (such as aging or fragility test, including results): Aging, Radiation, LOCA. Results satisfactory.  
Section 4.13, pages 29 and 30. Volume 1 of Report.

\*NOTE: If qualification by a combination of test and analysis also complete Item VII.

VII. If Qualification by Analysis, then Complete:

1. Method of Analysis:

- Static Analysis                       Equivalent Static Analysis
- Dynamic Analysis                       Time-History    Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

3. Model Type:  3D                       2D    1D  
 Finite Element  Beam  Closed Form Solution

4.  Computer Codes: \_\_\_\_\_

Frequency Range and No. of modes considered: \_\_\_\_\_

Hand Calculations

5. Method of Combining Dynamic Responses:  Absolute Sum    SRSS

Other: \_\_\_\_\_  
(specify)

6. Damping: OBE \_\_\_ SSE \_\_\_ Basis for the damping used: \_\_\_\_\_

7. Support Considerations in the model: \_\_\_\_\_

8. Critical Structural Elements: \_\_\_\_\_

A. Identification	Location	Governing Load	Seismic Stress	Total Stress	Stress Allowable
		or Response Combination			

B. Max. Critical Deflection	Location	Maximum Allowable Deflection to
		Assure Functional Operability

VIII. List of Subcomponents

<u>Name</u>	<u>Model No. - *Weight - *Location - If subcom- ponent was actually present</u>	<u>Was Component present or mass simulated?</u>	<u>Was subcomponent operability veri- fied (Y or N or U **)</u>
-------------	---	---	---

\* If Available

\*\* Yes = Yes, N = No, U = Unknown

IX. Sketch or drawing installed

How it has been installed

or

How it will be installed




Figure 5-3. Outline Dimension Drawing Model 58DA-C

-35-

REF: Qualification Report  
Volume




Figure 11.1

RUN OBEYZ1

A4




Figure 11.2

RUN OBEYZ1

A4






Figure 11.11 RUN SSEYZ1 AH





Figure 11.12 RUN SSEYZ1 AV



Qualification Summary of Equipment

I. Plant Name: Enrico Fermi Atomic Power Plant - Unit 2 Type:

1. Utility: Detroit Edison Company PWR \_\_\_\_\_  
 2. NSSS: GE 3. A/E: DECo BWR X

II. Component Name See attached table A-C

1. Scope:  NSSS  BOP
2. Model Number: See attached table A-C
3. Vendor: See attached table A-C
4. If the component is a cabinet or panel, name and model No. of the devices included: (See Section VIII)
5. Physical Description
  - a. Appearance (See Section IX)
  - b. Dimensions Largest component is 8" x 6" x 4". All other instruments are smaller.
  - c. Weight All each less than 15 lbs.
6. Location: Building: Auxiliary, Reactor, RHR  
 Elevation: All elevations
7. Field Mounting Condition  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)  
 Weld (Length \_\_\_\_\_)  
 \_\_\_\_\_ See Attachment D & E
8. a. System in which located: T41-00, T41-02, X41-03, T47  
 b. Functional Description Various  
 c. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither
9. Pertinent Referenced Design Specifications 3071-150

III. Is Equipment Available for Inspection in the Plant? (X)Yes ( )No

IV. Equipment Qualification Method:

(X)Test

( )Analysis

( )Combination of Test

and Analysis

Qualification Report\*: Nuclear Environmental Qualification Report of Safety Related  
HVAC Equipment for Enrico Fermi Atomic Power Plant, Unit 2

(No., Title and Date) CCL Report #A-610-83, November 15, 1983

Company that Prepared Report: Corporate Consulting and Development Company, LTD.

Company that Reviewed Report: DECo

V. Vibration Input

1. Loads considered: a. (X)Seismic only

b. ( )Hydrodynamic only

c. ( )Combination of (a) and (b)

2. Method of Combining RRS: ( )Absolute Sum ( )SRSS

(X) N.A.

other, specify

3. Required Response Spectra (attach the graphs): Figures 3.3 - 3.6 from  
Report - Attachment F-I

4. Damping Corresponding to RRS: OBE 2% SSE 5%

5. Required Acceleration in Each Direction: ( )ZPA

(X) N.A.

other, specify

6. Were fatigue effects or other vibration loads considered?

( )Yes

(X)No

If yes, describe loads considered and how they were treated in  
overall qualification program: \_\_\_\_\_

\*NOTE: If more than one report complete items IV through VII for each report.

VI. If Qualification by Test then Complete\*:

1. ( ) Single Frequency (X) Multi-Frequency (X) random  
( ) sine beat ( ) \_\_\_\_\_  
other, specify

2. ( ) Single Axis (X) Multi-Axis

3. No. of Qualification Tests: OBE 5 SSE 1  
Other \_\_\_\_\_

4. Frequency Range: 1 to 50 HZ

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): (See Attached Sheets J-L)

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies Low level sine sweep  
(X) Lab Test ( ) In-Situ Test ( ) Analysis

7. TMS enveloping RRS using Multi-Frequency Test (X) Yes (Attach TRS & RRS Graphs)  
( ) No\*\*ROA 001 (See #11 below)

8. Input g-level Test: OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_  
N.A. SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting: See attachment D & E

1. ( ) Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_) ( ) Weld (Length \_\_\_\_\_) ( ) \_\_\_\_\_

10. Functional operability verified: (X) Yes ( ) No ( ) Not Applicable

11. Test Results including modifications made: Test levels did not meet required levels due to limitations of the shake table. Refer to ROA 001. The RRS peak is 33.6 compared to shake table maximum 33.4.

12. Other tests performed (such as aging or fragility test, including results): NUREG 0588 analysis for potential aging. A recommended schedule for periodic maintenance is to be supplied by MCC panels.

\*NOTE: If qualification by a combination of test and analysis also complete Item VII.

VII. If Qualification by Analysis, then Complete: N.A.

1. Method of Analysis:

- Static Analysis                       Equivalent Static Analysis
- Dynamic Analysis                       Time-History  Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

3. Model Type:  3D                       2D     1D  
 Finite Element  Beam  Closed Form Solution

4.  Computer Codes: \_\_\_\_\_

Frequency Range and No. of modes considered: \_\_\_\_\_

Hand Calculations

5. Method of Combining Dynamic Responses:  Absolute Sum  SRSS

Other: \_\_\_\_\_  
(specify)

6. Damping: OBE \_\_\_ SSE \_\_\_ Basis for the damping used: \_\_\_\_\_

7. Support Considerations in the model: \_\_\_\_\_

8. Critical Structural Elements: \_\_\_\_\_

A. Identification	Location	Governing Load	Seismic Stress	Total Stress	Stress Allowable
		or Response Combination			

B. Max. Critical Deflection	Location	Maximum Allowable Deflection to
		Assure Functional Operability

VIII. List of Subcomponents N.A.

<u>Name</u>	<u>Model No. - *Weight - *Location - If subcom- ponent was actually present</u>	<u>Was Component present or mass simulated?</u>	<u>Was subcomponent operability veri- fied (Y or N or U **)</u>
-------------	---	---	---

\* If Available

\*\* Yes = Yes, N = No, U = Unknown

IX. Sketch or drawing installed

How it has been installed

or

How it will be installed

Table 2.1 Safety-Related Instruments, Seismic I, QA Level I, Class IE

CCL SAMPLE NO. 1794-	DESCRIPTION AND RANGE/RATING	MANUFACTURER	MANUFACTURER PART NUMBER	ENVIRONMENTAL CRITERIA
001	Terminal Block, 600 V	Allen Bradley	1492-CA1	Table 3.1
002	Dual Element Fuse/Fuseblock	Fusetron Fuse Buchanan Fuseblock	FMM 358	Table 3.1
003	Control Relay, 120 VAC, 10 A, 8 Pole	General Electric	CR120A08022AA	Table 3.1
004	Control Relay, 125 VDC, 10 A, 8 Pole	General Electric	CR120AD08041AA	Table 3.1
005	Control Relay, Latched, 120 VAC, 10 A, 8 Pole	General Electric	CR120C08022AA	Table 3.1
006	Control Relay, 120 VAC, 10 A, 8 Pole	General Electric	CR120B08022	Table 3.1
007	Control Relay, 125 VDC, 10 A, 9 Pole	General Electric	CR120B009041	Table 3.1
008	DC Milliammeter, 4-20 maDC	General Electric	DB-40 50-103191HE	Table 3.2
009	E/P Transducer, 4-20 maDC	Moore Products	GC 77-16	Table 3.2
010	Alarm Module, 4-20 maDC	Rochester Instruments	ET-1215	Table 3.2
011	Isolated Signal Transmitter, 4-20 maDC	Rochester Instruments	SC-1302	Table 3.2
024 *	Pushbutton Switch, 120 VAC	General Electric	CR2940UN221A2	Table 3.2
025 *	Current Transformer, 10 VA, 40 A	Osborne	12207	Table 3.1

\* SUPPLIED BY ACTUAL MANUFACTURER, ALL OTHERS SUPPLIED BY NCC POWERS.



Table 2.2 Safety-Related Instruments, Seismic I, QA Level I

CCL SAMPLE NO. 1794-	DESCRIPTION AND RANGE/RATING	MANUFACTURER	MANUFACTURER PART NUMBER	ENVIRONMENTAL CRITERIA
012	Pilot Valve, 3-30 psig	ASCO	F316D44K	Table 3.2
013	Receiver Controller, 3-15 psig	MCC Powers	RC185-0125	Table 3.2
014	Multi-Purpose Relay, 20 psi Input	MCC Powers	243-0009	Table 3.2
015	Room Thermostat, 20 psig Input	MCC Powers	TH-180D	Table 3.3
016	Pressure Gauge, 3-15 psig Input	Ashcroft	35-1009-AXPR-02B-XUC	Table 3.2
017	Receiver-Controller, 3-15 psig Input	MCC Powers	RC 195-0001	Table 3.2
018	Temperature Transmitter, 3-15 psig	MCC Powers	163-3110	Table 3.2

ATTACH. 13

Table 2.3 Safety-Related Instruments, Seismic II/I, QA Level II

CCL SAMPLE NO. 1794-	DESCRIPTION AND RANGE/RATING	MANUFACTURER	MANUFACTURER PART NUMBER	ENVIRONMENTAL CRITERIA
019	Light, 120 VAC	Dialight	51-091-0231-303 Lens 656-125V Lamp	N/A
020	Enclosure, 8" x 6" x 4"	Hoffman	Type SC	N/A
021	Transformer, 120 VAC/24 VAC	Jefferson Electric	216-1121	N/A
022	Switching Relay, 3-20 psig	MCC Powers	243-0001	N/A
023	Current Alarm, 115 VAC, 0-5 A	Rochester Instruments	ET-1200 L/U	N/A

Table 4.1 Mounting Details

The mounting of the specimen simulated the actual in-service mounting as closely as practical.

CCL SAMPLE NO. 1794-	DESCRIPTION	MOUNTED IN	MOUNTING HARDWARE	SOURCE OF HARDWARE	
				MFR	COMM'L
001	Terminal Block	12 ga	8-32 screws every 18". Drill and tap subpanel.		X
002	Fuse/Fuseblock	12 ga	(1) 8-32 screw each end. Drill and tap subpanel.		X
003	AC Relay	12 ga	(2) 8-32 self tapping screws, top left and bottom right.	X	
004	DC Relay	12 ga	(2) 8-32 self tapping screws, top left and bottom right.	X	
005	Latched AC Relay	12 ga	(2) 8-32 self tapping screws, top left and bottom right.	X	
006	AC Relay	12 ga	(2) 8-32 self tapping screws, top left and bottom right.	X	
007	DC Relay	12 ga	(2) 8-32 self tapping screws, top left and bottom right.	X	
008	DC Milliammeter	12 ga	(4) 1/4-28 studs & nut.	X	
009	E/P Transducer	12 ga	(4) 1/4-20 bolts. Drill and tap subpanel.		X
010	Alarm Module	12 ga	(2) 8-32 screws. Drill and tap subpanel.		X
011	Isolated Signal Transmitter	12 ga	(2) 8-32 screws. Drill and tap subpanel.		X
012	Solenoid Valve	3/8"	(2) 3/8" bulkhead fittings.		X
013	Receiver Controller	12 ga	(4) 8-32 screws. Drill and tap subpanel.		X

(Continued)

Table 4.1 Mounting Details

LCL SAMPLE NO. 1794-	DESCRIPTION	MOUNTED IN	MOUNTING HARDWARE	SOURCE OF HARDWARE	
				MFR	COMM'L
014	Multi-Purpose Relay	12 ga	(2) 8-32 screws. Drill and tap subpanel.		X
015	Room Thermostat	1/8"	(2) 8-32 screws. Drill and tap subpanel.		X
016	Temperature Gauge	12 ga	Vendor clamps over 10-32 case studs.	X	
017	Receiver Controller	12 ga	Mount to sample 1794-020 using (4) 6-32 screws, 2 nuts.		X
018	Temperature Transmitter	1/4"	(4) 8-32 screws. Drill and tap subpanel.		X
019	Light	12 ga	Furnished lockwasher and nut.	X	
020	Enclosure	12 ga	(4) 8-32 screws. Drill and tap subpanel.		X
021	Transformer	12 ga	(4) 1/4-20 bolts. Drill and tap subpanel.		X
022	Switching Relay	12 ga	(1) 8-32 screw through vendor bracket. Drill and tap subpanel.	X	X
023	Current Alarm	12 ga	(2) 8-32 screws. Drill and tap subpanel.		X
024	Switch	1/4"	Furnished lockwasher, (1) gasket and nut. 20° from vertical.	X	X
025	Transformer	12 ga	(4) 1/4-20 screws, flat and lockwasher. Install screws from bottom, mount horizontal.		X

(Concluded)

SSE <input type="checkbox"/>	PERCENT	DIRECTION	CCL No.: 83-1794
1/2SSE <input type="checkbox"/>	DAMPING	HORIZONTAL N-S <input type="checkbox"/>	DWG. BY: SFGripin
DBE <input type="checkbox"/>	2 %	HORIZONTAL E-W <input type="checkbox"/>	CHK. BY: ANM
OBE <input checked="" type="checkbox"/>		VERTICAL <input checked="" type="checkbox"/>	DATE: 8-18-83






Figure 3.3 Vertical OBE RRS

Corporate Consulting & Development Company, Ltd.  
 consultants constructors

P.O. Box 12728, Research Triangle Park, North Carolina, 27709-9998





SSE <input checked="" type="checkbox"/>	PERCENT	DIRECTION	CCL No.: 83-1794
1/2 SSE <input type="checkbox"/>	DAMPING	HORIZONTAL N-S <input checked="" type="checkbox"/>	DWG. BY: S.F. GRIFFIN
DBE <input type="checkbox"/>	2 %	HORIZONTAL E-W <input checked="" type="checkbox"/>	CHK. BY: ANM
OBE <input type="checkbox"/>		VERTICAL <input type="checkbox"/>	DATE: 8-18-83




Figure 3.6 Horizontal SSE RRS

Corporate Consulting & Development Company, Ltd.  
 consultants  
 constructors

P.O. Box 12728, Research Triangle Park, North Carolina, 27709-2998



Accelerometer		Direction	Photo Fig. No.	Plot Fig. No.	SAMPLE NO. 1974- Description	Summary of Major Resonances (Hz)*
Location	Number					
1 1 1	X Y Z	N-S E-W Vertical	1.1	E.1 E.2 E.3	- 002 FUSE / FUSE BLOCK	None Below 50 Hz None Below 50 Hz None Below 50 Hz
2 2 2	X Y Z	N-S E-W Vertical	1.1	E.4 E.5 E.6	- 004 DC RELAY	36.9, 41.1 None Below 50 Hz None Below 50 Hz
3 3 3	X Y Z	N-S E-W Vertical	1.2	E.7 E.8 E.9	- 010 TEMPERATURE TRANSMITTER	**23.1, 39.2 None Below 50 Hz None Below 50 Hz
4 4 4	X Y Z	N-S E-W Vertical	1.3	E.10 E.11 E.12	- 005 AC RELAY	37.3, 41.1, 49.0 None Below 50 Hz None Below 50 Hz
5 5 5	X Y Z	N-S E-W Vertical	1.3	E.13 E.14 E.15	- 007 DC RELAY	**23.3, 37.3, 39.5 41.9, 49.0 39.5, 42.3 43.6, 48.6
6 6 6	X Y Z	N-S E-W Vertical	1.4	E.16 E.17 E.18	- 006 AC RELAY	**23.1, 36.6, 41.1 43.2 39.2, 44.0, 48.6 44.5
7 7 7	X Y Z	N-S E-W Vertical	1.3	E.19 E.20 E.21	- 013 RECEIVER CONTROLLER	36.9 None Below 50 Hz None Below 50 Hz
8 8 8	X Y Z	N-S E-W Vertical	1.3	E.22 E.23 E.24	- 009 E/P TRANSDUCER	37.3, 39.5, 41.9 40.3, 41.9, 48.1 41.5, 44.0

\* Note: These frequencies are cursored approximations at the equipment's resonant frequencies.

\*\*Note: This frequency represents a system resonance and is not a resonance of the fixture.

TABLE 8.1

Report No. 10139, Rev. 0  
34

ATTACH. I

Accelerometer		Direction	Photo Fig. No.	Plot Fig. No.	SAMPLE 870 1974- Description	Summary of Major Resonances (Hz)*
Location	Number					
9	X	N-S	1.5	E.25	-010 ALARM MODULE	35.9, 37.7, 48.6 30.1, 34.5, 39.5, 44.5 40.7, 49.0
9	Y	E-W		E.26		
9	Z	Vertical		E.27		
10	X	N-S	1.3	E.28	- TEST FIXTURE	**23.3, 36.9, 41.9 None Below 50 Hz None Below 50 Hz
10	Y	E-W		E.29		
10	Z	Vertical		E.30		
11	X	N-S	1.3	E.31	-022 SWITCHING RELAY	37.7, 42.3, 49.0 None Below 50 Hz 41.5
11	Y	E-W		E.32		
11	Z	Vertical		E.33		
12	X	N-S	1.6	E.34	-020 ENCLOSURE	None Below 50 Hz None Below 50 Hz Bad Cable None Below 50 Hz
12	Y	E-W		E.35		
12	Z	Vertical		E.36		
13	X	N-S	1.6	E.37	-021 TRANSFORMER	20.5 None Below 50 Hz None Below 50 Hz
13	Y	E-W		E.38		
13	Z	Vertical		E.39		
14	X	N-S	1.6	E.40	-015 ROOM THERMOSTAT	20.7 None Below 50 Hz None Below 50 Hz
14	Y	E-W		E.41		
14	Z	Vertical		E.42		
15	X	N-S	1.7	E.43	-012 PILOT VALVE	20.7 None Below 50 Hz None Below 50 Hz
15	Y	E-W		E.44		
15	Z	Vertical		E.45		
16	X	N-S	1.7	E.46	-001 TERMINAL BLOCK	20.7, 42.3 30.1, 33.8 None Below 50 Hz
16	Y	E-W		E.47		
16	Z	Vertical		E.48		

\* Note: These frequencies are cursored approximations at the equipment's resonant frequencies.

\*\*Note: This frequency represents a system resonance and is not a resonance of the fixture.

TABLE 8.1 (CONTINUED)

Report No. 10139, Rev. 0  
35

ATTACH K

Accelerometer		Direction	Photo Fig. No.	Plot Fig. No.	SAMPLE NO. 1974- Description	Summary of Major Resonances (Hz)*
Location	Number					
17	X	N-S	1.8	E.49	-024 SWITCH	20.7 Accel not mounted due to space limitations None Below 50 Hz
17	Y	E-W				
17	Z	Vertical				

TABLE 8.1 (CONTINUED)

Report No. 10139, Rev. 0  
36

ATTACH-L

\* Note: These frequencies are cursored approximations at the equipment's resonant frequencies.

Qualification Summary of EquipmentI. Plant Name: Enrico Fermi Atomic Power Plant - Unit 2 Type:1. Utility: Detroit Edison Company PWR \_\_\_\_\_  
2. NSSS: GE 3. A/E: DECo BWR XII. Component Name Bellows assemblies1. Scope:  NSSS  BOP  
2. Model Number: 1-1/2" bellows assemblies  
3. Vendor: Johnson Controls, Engineered Piping Systems Division  
4. If the component is a cabinet or panel, name and model No. of the devices included: (See Section VIII)

5. Physical Description

a. Appearance (See Section IX)

b. Dimensions \_\_\_\_\_

c. Weight \_\_\_\_\_

6. Location: Building: Reactor Building, 1st FloorElevation: 583'-6"7. Field Mounting Condition  Bolt (No. 4, Size 1/2)  
 Weld (Length \_\_\_\_\_)  
 \_\_\_\_\_8. a. System in which located: C51 (Traversing In-Core Probe System)b. Functional Description Expansion Jointc. Is the equipment required for  Hot Standby  Cold Shutdown  
 Both  Neither9. Pertinent Referenced Design Specifications IEEE-344-1975

III. Is Equipment Available for Inspection in the Plant?  Yes  No

IV. Equipment Qualification Method:

- Test
- Analysis
- Combination of Test and Analysis

Qualification Report\*: SR-10276, Stress Report, 9-20/84

(No., Title and Date) \_\_\_\_\_

Company that Prepared Report: Johnson Controls

Company that Reviewed Report: DECo

V. Vibration Input

- 1. Loads considered:
  - a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Combination of (a) and (b)

2. Method of Combining RRS:  Absolute Sum  SRSS  
 \_\_\_\_\_  
other, specify

3. Required Response Spectra (attach the graphs): N/A

4. Damping Corresponding to RRS: OBF N/A SSE N/A

5. Required Acceleration in Each Direction:  ZPA  
 N/A  
other, specify

6. Were fatigue effects or other vibration loads considered?

- Yes
- No

If yes, describe loads considered and how they were treated in overall qualification program: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\*NOTE: If more than one report complete items IV through VII for each report.

VI. If Qualification by Test then Complete\*: N/A

1. ( ) Single Frequency ( ) Multi-Frequency ( ) random  
 ( ) sine beat ( ) \_\_\_\_\_  
 other, specify

2. ( ) Single Axis ( ) Multi-Axis

3. No. of Qualification Tests: OBE \_\_\_\_\_ SSE \_\_\_\_\_  
 Other \_\_\_\_\_

4. Frequency Range: \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies \_\_\_\_\_

( ) Lab Test ( ) In-Situ Test ( ) Analysis

7. TRS enveloping RRS using Multi-Frequency Test ( ) Yes (Attach TRS & RRS Graphs)  
 ( ) No

8. Input g-level Test: OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

1. ( ) Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_) ( ) Weld (Length \_\_\_\_\_) ( ) \_\_\_\_\_

10. Functional operability verified: ( ) Yes ( ) No ( ) Not Applicable

11. Test Results including modifications made: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including results): \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

\*NOTE: If qualification by a combination of test and analysis also complete Item VII.

VII. If Qualification by Analysis, then Complete:

1. Method of Analysis:

- ( ) Static Analysis                      (X) Equivalent Static Analysis  
 ( ) Dynamic Analysis                  ( ) Time-History ( ) Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = 560 HZ              F/B = 279 HZ              V = 560 HZ

3. Model Type: (X) 3D                      ( ) 2D              ( ) 1D  
 ( ) Finite Element ( ) Beam (X) Closed Form Solution

4. ( ) Computer Codes: DESCAL-8

Frequency Range and No. of modes considered: N/A

( ) Hand Calculations

5. Method of Combining Dynamic Responses: (X) Absolute Sum ( ) SRSS

( ) Other: \_\_\_\_\_  
 (specify)

6. Damping: OBE - SSE - Basis for the damping used: N/A

7. Support Considerations in the model: Both ends rigid

8. Critical Structural Elements: Bellows

A. Identification	Location	Governing Load or Response Combination	Seismic Stress	Total Stress Range	Stress Range Allowable
Bellows	On the	Normal +(OBE/SSE)	-	153,680 PSI	375,000 PSI
	Bellows	Faulted (LOCA)	-	457,761 PSI	550,000 PSI

B. Max. Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
0.375" Axial      NORMAL + 0.125" Lateral (OBE/SSE)	On the Bellows	0.875"      (FSAR 3.8.2.3.2.2) 0.375"
1.25" Axial      FAULTED 0.125" Lateral (LOCA)	"	----- -----

VIII. List of Subcomponents    N/A

<u>Name</u>	<u>Model No. - *Weight - *Location - If subcom- ponent was actually present</u>	<u>Was Component present or mass simulated?</u>	<u>Was subcomponent operability veri- fied (Y or N or U **)</u>
-------------	---	---	---

\* If Available

\*\* Yes = Yes, N = No, U = Unknown




IX. Sketch or drawing installed

How it has been installed

or

How it will be installed



VERTICAL (UPWARD) RESTRAINTS  
 ARE TO BE ADDED TO PENETRATIONS  
 X35 B, E AND F  
 1/16" UPWARD CLEARANCE IS REQ'D

NOTE! THE BELLOW'S ARE TO BE  
 INSTALLED PER THE  
 MANUFACTURERS REQUIREMENTS.

SECTION A-A  
 BELLOW ASSEMBLIES  
 PENETRATIONS X35 B-F

(REF: DC #2937 SHT.A-2)

Qualification Summary of Equipment

I. Plant Name: Enrico Fermi Atomic Power Plant - Unit 2 Type:

1. Utility: Detroit Edison Company PWR \_\_\_\_\_  
 2. NSSS: GE 3. A/E: DECo BWR X

II. Component Name Solenoid Operated Globe Valves

1. Scope:  NSSS ( ) BOP  
 2. Model Number: 81M-002, 82M-003, 81M-004 and 84U-001  
 3. Vendor: Target Rock Corporation  
 4. If the component is a cabinet or panel, name and model No. of the devices included: (See Section VIII)

5. Physical Description  
 a. Appearance (See Section IX)  
 b. Dimensions \_\_\_\_\_  
 c. Weight \_\_\_\_\_

6. Location: Building: Reactor Building  
 Elevation: 613'-6" T2-B12

7. Field Mounting Condition ( ) Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)  
 (X) Weld (3/4" Socket)  
 (X) On line

8. a. System in which located: Radiation Monitoring System T50-01  
 b. Functional Description  Full Open or Full Closed  
 Not used for throttling  
 c. Is the equipment required for ( ) Hot Standby ( ) Cold Shutdown  
 (X) Both ( ) Neither

9. Pertinent Referenced Design Specifications \_\_\_\_\_  
DECo Spec. 3071-501, 3071-12-PUR-116, IEEE-344-1975

III. Is Equipment Available for Inspection in the Plant? ( ) Yes ( ) No

IV. Equipment Qualification Method:

( ) Test                      (X) Analysis                      ( ) Combination of Test  
and Analysis

Qualification Report\*: TRC Report No. 3477A (DECo File #Cl-2134)

(No., Title and Date) Design Report for Solenoid Operated Globe Valves, 2/17/83

Company that Prepared Report: Target Rock Corporation

Company that Reviewed Report: DECo

V. Vibration Input

1. Loads considered: a. ( ) Seismic only

b. ( ) Hydrodynamic only

c. (X) Combination of (a) and (b)

2. Method of Combining RRS: ( ) Absolute Sum (X) SRSS  
( ) \_\_\_\_\_  
other, specify

3. Required Response Spectra (attach the graphs): N/A

4. Damping Corresponding to RRS: OBE N/A SSE N/A

5. Required Acceleration in Each Direction: ( ) ZPA  
(X) 5.0g Horiz. Accel.,  
3.0g Vert. Accel.  
other, specify

6. Were fatigue effects or other vibration loads considered?

(X) Yes                      ( ) No

If yes, describe loads considered and how they were treated in overall qualification program:

Fatigue Requirements per NB-3545.3 satisfied.

\*NOTE: If more than one report complete items IV through VII for each report.

VI. If Qualification by Test then Complete\*: N/A

1. ( ) Single Frequency ( ) Multi-Frequency ( ) random  
( ) sine beat ( ) \_\_\_\_\_  
other, specify

2. ( ) Single Axis ( ) Multi-Axis

3. No. of Qualification Tests: OBE \_\_\_\_\_ SSE \_\_\_\_\_  
Other: \_\_\_\_\_

4. Frequency Range: \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back,  
Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies \_\_\_\_\_

( ) Lab Test ( ) In-Situ Test ( ) Analysis

7. TRS enveloping RRS using Multi-Frequency Test ( ) Yes (Attach TRS & RRS  
Graphs)  
( ) No

8. Input g-level Test: OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

1. ( ) Bolt (No. \_\_, Size \_\_) ( ) Weld (Length \_\_) ( ) \_\_\_\_\_

10. Functional operability verified: ( ) Yes ( ) No ( ) Not Applicable

11. Test Results including modifications made: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including  
results): \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\*NOTE: If qualification by a combination of test and analysis also complete  
Item VII.

VII. If Qualification by Analysis, then Complete:

1. Method of Analysis:

- ( ) Static Analysis                      (X) Equivalent Static Analysis  
 ( ) Dynamic Analysis                    ( ) Time-History ( ) Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = 162 HZ      F/B = --      V = 162 HZ

3. Model Type: (X) 3D                      ( ) 2D      ( ) 1D  
 ( ) Finite Element (X) Beam ( ) Closed Form Solution

4. ( ) Computer Codes: \_\_\_\_\_

Frequency Range and No. of modes considered: \_\_\_\_\_

(X) Hand Calculations

5. Method of Combining Dynamic Responses: ( ) Absolute Sum (X) SRSS

( ) Other: \_\_\_\_\_  
 (specify)

6. Damping: OBE - SSE - Basis for the damping used: N/A

7. Support Considerations in the model: Assumed simply supported by the pipes

8. Critical Structural Elements: Wall Thickness (see Table C below)

A. Identification	Location		Total Stress	Stress Allowable
81M-003	Body	} (Fatigue Factor = 0.50797)	1,927 PSI	32,700 PSI
	Bonnet		10,902 PSI	20,000 PSI
81M-004	Body	} (Fatigue Factor = 0.43172)	<1,927 PSI	42,100 PSI
	Bonnet		11,880 PSI	20,000 PSI

B. Max. Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
0.0038	81M-003	0.005
0.0038	81M-004	0.005

Model No.	Wall Thickness (inches)				Actual	Required
	Body		Neck			
	Actual	Req'd.	Actual	Req'd.		
81M-003	0.617	0.2454	0.5975	0.3924	0.0825	0.0441
81M-004	0.758	0.307	0.5975	0.510	0.0825	0.0441

VIII. List of Subcomponents      N/A

<u>Name</u>	<u>Model No. - *Weight - *Location - If subcom- ponent was actually present</u>	<u>Was Component present or mass simulated?</u>	<u>Was subcomponent operability veri- fied (Y or N or U **)</u>
-------------	---	---	---

\* If Available


\*\* Yes = Yes, N = No, U = Unknown

IX. Sketch or drawing installed N/A

How it has been installed

OR

How it will be installed



Qualification Summary of Equipment

I. Plant Name: Enrico Fermi Atomic Power Plant - Unit 2 Type:

1. Utility: Detroit Edison Company PWR  
2. NSSS: GE 3. A/E: DECo BWR X

II. Component Name PYCO Thermocouple

1. Scope: ( )NSSS (X)BOP
  2. Model Number: 102-9039-08-6/102-3171-20
  3. Vendor: PYCO
  4. If the component is a cabinet or panel, name and model No. of the devices included: (See Section VIII)
  5. Physical Description
    - a. Appearance (See Section IX)
    - b. Dimensions 6" long x 1/4" O.D.
    - c. Weight less than 1 lb. each
  6. Location: Building: Reactor  
Elevation: Various
  7. Field Mounting Condition ( ) Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)  
( ) Weld (Length \_\_\_\_\_)  
(X) Pipe mounted or local
  8. a. System in which located: P44 and G33  
b. Functional Description Measure Area Temperature  
c. Is the equipment required for ( ) Hot Standby ( ) Cold Shutdown  
(X) Both ( ) Neither
  9. Pertinent Referenced Design Specifications IEEE-344-1975
-



III. Is Equipment Available for Inspection in the Plant?  Yes  No

IV. Equipment Qualification Method:

- Test
- Analysis
- Combination of Test and Analysis

Qualification Report\*: Nuclear Qualification Testing of Temperature Measurement Devices per IEEE Std. 323-1974 and IEEE Std. 344-1975

(No., Title and Date) 16436-82N Rev. 3 1/31/84

Company that Prepared Report: Acton Environmental Testing Corp.

Company that Reviewed Report: DECo

V. Vibration Input

1. Loads considered:
  - a.  Seismic only
  - b.  Hydrodynamic only
  - c.  Combination of (a) and (b)
2. Method of Combining RRS:  Absolute Sum  SRSS  
 N.A.  
 other, specify \_\_\_\_\_
3. Required Response Spectra (attach the graphs): \_\_\_\_\_
4. Damping Corresponding to RRS: OBE 5% SSE 5%
5. Required Acceleration in Each Direction:  ZPA  
 N.A.  
 other, specify \_\_\_\_\_

6. Were fatigue effects or other vibration loads considered?

- Yes
- No

If yes, describe loads considered and how they were treated in overall qualification program: \_\_\_\_\_  
 \_\_\_\_\_

\*NOTE: If more than one report complete items IV through VII for each report.

VI. If Qualification by Test then Complete\*:

1. ( ) Single Frequency (X) Multi-Frequency ( ) random  
 ( ) sine beat ( ) \_\_\_\_\_  
 other, specify

2. ( ) Single Axis (X) Multi-Axis

3. No. of Qualification Tests: OBE 5 SSE 1  
 Other \_\_\_\_\_

4. Frequency Range: 1 to 50 HZ

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): No Resonance found from 1 to 50 to 1 HZ

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies Low level sine sweep  
 (X) Lab Test ( ) In-Situ Test ( ) Analysis

7. TRS enveloping RRS using Multi-Frequency Test (X) Yes (Attach TRS & RRS  
SAMPLE: Graphs)  
 ( ) No

8. Input g-level Test: OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_  
 N/A SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

1. ( ) Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_) ( ) Weld (Length \_\_\_\_\_) (X) To simulate actual field mtg.

10. Functional operability verified: (X) Yes ( ) No ( ) Not Applicable

11. Test Results including modifications made: No anomalies to report during multi-frequency testing

12. Other tests performed (such as aging or fragility test, including results): Thermal aging performed with no anomalies

\*NOTE: If qualification by a combination of test and analysis also complete Item VII.

VII. If Qualification by Analysis, then Complete: N/A

1. Method of Analysis:

- Static Analysis                       Equivalent Static Analysis
- Dynamic Analysis                       Time-History    Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

3. Model Type:  3D                       2D    1D  
 Finite Element  Beam  Closed Form Solution

4.  Computer Codes: \_\_\_\_\_

Frequency Range and No. of modes considered: \_\_\_\_\_

- Hand Calculations

5. Method of Combining Dynamic Responses:  Absolute Sum    SRSS

Other: \_\_\_\_\_  
(specify)

6. Damping: OBE - SSE - Basis for the damping used: \_\_\_\_\_

7. Support Considerations in the model: \_\_\_\_\_

8. Critical Structural Elements: \_\_\_\_\_

A. Identification	Location	Governing Load	Seismic Stress	Total Stress	Stress Allowable
		or Response Combination			

B. Max. Critical Deflection	Location	Maximum Allowable Deflection to
		Assure Functional Operability

VIII. List of Subcomponents      N.A.

<u>Name</u>	<u>Model No. - *Weight - *Location - If subcom- ponent was actually present</u>	<u>Was Component present or mass simulated?</u>	<u>Was subcomponent operability veri- fied (Y or N or U **)</u>
-------------	---	---	---

\* If Available

\*\* Yes = Yes, N = No, U = Unknown

**IX. Sketch or drawing installed**

How it has been installed


or

How it will be installed



$\alpha = 10$  5% Damping

Test No. 3A  
Date 2/11/83  
Customer PYCO  
Test Item P/N  
Test Item S/N  
Type of Test ORF  
Spec No.  
Para. No.  
Conditions OPER 150° F  
Temperature 10°  
Period of Test 30 Sec  
Control Axis ORIENTATION #2  
Pick-up No. 9  
Pick-up Axis Horiz  
Operator W. BOLUAR  
Program  
Co-Ordinator D. MICHAUD  
ORMS Controls of Bottom OF FUTURE





Q = 10 5% DAMPING

TEST No. \_\_\_\_\_  
 Date 2/11/83  
 Customer PYCC  
 Test Item 274  
 Test Item S/N \_\_\_\_\_  
 Type of Test 550  
 Spec. No. \_\_\_\_\_  
 Para. No. \_\_\_\_\_  
 Conditions VERT 150°F  
 Temperature 100  
 Period of Test 80.366  
 Control Axis ORIENTATION #3  
 Pick-up No. 10  
 Pick-up Axis VERT  
 Operator W. BOLUAR  
 Program \_\_\_\_\_  
 Co-Ordinator D. MICHARD  
 GRMS CENTRAL ON  
BOTTOM OF FUTURE



Qualification Summary of Equipment

I. Plant Name: Enrico Fermi Atomic Power Plant - Unit 2 Type:

1. Utility: Detroit Edison Company PWR \_\_\_\_\_  
 2. NSSS: GE 3. A/E: DECo BWR X

II. Component Name Liquid filled pressure gauges

1. Scope:  NSSS                      ( ) BOP
2. Model Number: Ashcroft Model #1279, 316 SS Bourdon Tube
3. Vendor: Dresser Instrument Division
4. If the component is a cabinet or panel, name and model No. of the devices included: (See Section VIII)
5. Physical Description
  - a. Appearance (See Section IX)
  - b. Dimensions Dial Size 4-1/2" dia. See page 6
  - c. Weight 3-1/2 lbs. (approximately)
6. Location: Building: RX Building. Sub-basement  
 Elevation: 545'-0"
7. Field Mounting Condition ( ) Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)  
 ( ) Weld (Length \_\_\_\_\_)  
 (X) Threaded mounting
8. a. System in which located: E11 and E21  
 b. Functional Description To measure suction pressure for RHR pumps and core spray pumps  
 c. Is the equipment required for ( ) Hot Standby ( ) Cold Shutdown  
 ( ) Both (X) Neither
9. Pertinent Referenced Design Specifications None -  
Pur. Specification 3071-ROO-PUR-113



III. Is Equipment Available for Inspection in the Plant? (X)Yes ( )No

IV. Equipment Qualification Method:

(X)Test ( )Analysis ( )Combination of Test and Analysis

Qualification Report\*: DTB04R74-0892, Dayton T. Brown, Inc. Job No. 400524-00.000 Instrument Seismic Vibration Test Program, 7/23/74

(No., Title and Date) DECo File No. Cl-2795

Company that Prepared Report: Dayton T. Brown, Inc. for Dresser Industrial Valve and Instrument Division

Company that Reviewed Report: \_\_\_\_\_

V. Vibration Input

- 1. Loads considered: a.(X)Seismic only  
b.( )Hydrodynamic only  
c.( )Combination of (a) and (b)

2. Method of Combining RRS: ( )Absolute Sum ( )SRSS  
( ) N/A  
other, specify \_\_\_\_\_

3. Required Response Spectra (attach the graphs): N/A

4. Damping Corresponding to RRS: OBE \_\_\_\_\_ SSE N/A

5. Required Acceleration in Each Direction: ( )ZPA  
(X) 3G. - Vendor Specified  
other, specify \_\_\_\_\_

6. Were fatigue effects or other vibration loads considered?

( )Yes (X)No

If yes, describe loads considered and how they were treated in overall qualification program: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\*NOTE: If more than one report complete items IV through VII for each report.

VI. If Qualification by Test then Complete\*:

1.  Single Frequency ( ) Multi-Frequency ( ) random  
( ) sine beat (X) Dwell Test \_\_\_\_\_  
other, specify \_\_\_\_\_

2.  Single Axis ( ) Multi-Axis

3. No. of Qualification Tests: OBE \_\_\_\_\_ SSE \_\_\_\_\_ N/A  
Other \_\_\_\_\_

4. Frequency Range: \_\_\_\_\_ 1 to 35 HZ \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): Resonance at 7, 11 and 16 HZ. Page 15 of Report.

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies \_\_\_\_\_ Resonance Search \_\_\_\_\_

(X) Lab Test ( ) In-Situ Test ( ) Analysis

7. TRS enveloping RRS using Multi-Frequency Test ( ) Yes (Attach TRS & RRS Graphs)  
( ) No N/A

8. Input g-level Test: OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_  
Up to 7.5g  
Combined SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting: Standard mounting simulating field mounting condition  
1. ( ) Bolt (No. \_\_\_\_, Size \_\_\_\_ ) ( ) Weld (Length \_\_\_\_ ) ( ) \_\_\_\_\_

10. Functional operability verified: (X) Yes ( ) No ( ) Not Applicable

11. Test Results including modifications made: \_\_\_\_\_ Satisfactory \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including results): \_\_\_\_\_ N/A \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\*NOTE: If qualification by a combination of test and analysis also complete Item VII.

VII. If Qualification by Analysis, then Complete: N/A

1. Method of Analysis:

- Static Analysis             Equivalent Static Analysis
- Dynamic Analysis            Time-History    Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

3. Model Type:  3D                     2D    1D  
 Finite Element  Beam  Closed Form Solution

4.  Computer Codes: \_\_\_\_\_

Frequency Range and No. of modes considered: \_\_\_\_\_

Hand Calculations

5. Method of Combining Dynamic Responses:  Absolute Sum    SRSS

Other: \_\_\_\_\_  
(specify)

6. Damping: OBE - SSE - Basis for the damping used: \_\_\_\_\_

7. Support Considerations in the model: \_\_\_\_\_

8. Critical Structural Elements: \_\_\_\_\_

A. Identification	Location	Governing Load	Seismic	Total	Stress
		or Response Combination			

B. Max. Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
--------------------------------	----------	--

VIII. List of Subcomponents

<u>Name</u>	<u>Model No. - *Weight - *Location - If subcom- ponent was actually present</u>	<u>Was Component present or mass simulated?</u>	<u>Was subcomponent operability veri- fied (Y or N or U **)</u>
-------------	---	---	---

\* If Available

\*\* Yes = Yes, N = No, U = Unknown

**IX. Sketch or drawing installed**

How it has been installed


OR

How it will be installed



**Specifications 1279 :**

**ASHCROFT® 1279**  
Liquid Filled Gauge



Type 1279  
 Dial Size ..... 4 1/8"  
 Case ..... Phenol Turb. Blk. Solid Front  
 Ring ..... Glass Filled Polypropylene, Threaded  
 Connection ..... 1/8" NPT Lower  
 Mounting ..... Sash, Surface, or Flush  
 Window ..... Acrylic Plastic  
 Dial ..... White Aluminum  
 Pointer ..... Micrometer Adjustable, Black Aluminum  
 Bourdon Tube ..... Bronze, Steel, Stainless  
 Movement ..... Steel, Monel  
 Accuracy ..... ±0.5% of Full Scale\*  
 "O" Ring (Window and Socket) ..... Buna-N  
 Rear Elastomeric Diaphragm ..... EPDM  
 Ranges ..... Vacuum to 20,000 psi  
 \*ANSI BAC 1 Grade 2A


NOTE: Throttle screws are supplied as standard on all liquid filled gauges.

All gauges are temperature compensated. The Type 1279 utilizes a flexible elastomeric back and the Type 1320 a thin, flexible plastic window. The action of each is to minimize the error created by changes in ambient temperature.


Three-way convertible, Type 1279 is a 4 1/8" solid front phenolic glass gauge which may be ordered in any one of three versions: liquid filled, hermetically sealed or weatherproof. Should the gauge be ordered in the weatherproof version, all examples and service conditions warrant other hermetically sealing for ambient corrosion protection or liquid filling for applications where severe vibration or pulsation are encountered, a kit is available for field conversion.

A unique feature of this Ashcroft gauge is the absence of a case vent or fill hole normally required on a conventional non-liquid filled gauge. A specially designed rear elastomeric diaphragm seal, compressed for internal case pressure changes due to changes in ambient temperature. Protection for the diaphragm is provided by a stainless steel rear cover. If a Bourdon tube leak occurs, the resultant case pressure will push the diaphragm out of its seat and release the rear cover allowing the pressure to be dissipated towards the rear.



All case horns and threads are milled into the rugged phenolic case front seal. No further machining is required, thus eliminating the possibility of cracking or leaking caused by machining of the phenolic material. The integrally milled threads the front and rear of the case provide an leak-tight seal with the use of threaded rings. Identical rings are used in both location. Only three seals are required: front, rear, and socket. A-leads will bronze case, stainless steel and flange Bourdon tubes for sash, surface, or flush mounting. Ranges: Vacuum to 20,000 p.



**12 Dimensions 1279**



Lower Connection



Flush Mounting Ring

Dial Size Inches	A	B	C	D	I	P	B		J	L	Y	V	Wgt. (Oz.)	C-1	LL		M	S	RR	QQ
							1/8"	1/4"							1/8"	1/4"				
4 1/8	5 1/16	3 1/2	5 1/16	1 1/2	5 1/2	1 1/2	3 1/2	4 1/2	1	1 1/2	3/8	3/8	3 1/2	8	1/8	1/4	3 1/2	1 1/2	1 1/2	2 1/2
	(148)	(88)	(128)	(41)	(137)	(41)	(97)	(153)	(27)	(5.5)	(15)	(61)	(152)	(3)	(6)	(14)	(5)	(21)	(71)	

Note: Dimensions in Brackets ( ) are millimeters

Qualification Summary of Equipment

I. Plant Name: Enrico Fermi Atomic Power Plant - Unit 2 Type:

1. Utility: Detroit Edison Company PWR \_\_\_\_\_  
 2. NSSS: GE 3. A/E: DECo BWR X

II. Component Name 20" 900# Gate Valves with Limitorque SMB-3-150 Operator

1. Scope:  NSSS ( ) BOP  
 2. Model Number: DECo Valve No. V8-4613 and V8-4614  
 3. Vendor: TVA (Anchor Darling)  
 4. If the component is a cabinet or panel, name and model No. of the devices included: (See Section VIII)

5. Physical Description  
 a. Appearance (See Section IX)  
 b. Dimensions 13-1/2" dia x 50" long x 79" ht (Approx) See page 6  
 c. Weight 7349 lbs (Approx)

6. Location: Building: Reactor - Torus Room  
 Elevation: 567', 570'

7. Field Mounting Condition ( ) Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)  
 (X) Weld (Length \_\_\_\_\_)  
 ( ) \_\_\_\_\_

8. a. System in which located: RHR (E11)  
 b. Functional Description Isolate bypasses around F017A/B  
 c. Is the equipment required for ( ) Hot Standby ( ) Cold Shutdown  
 ( ) Both (X) Neither

9. Pertinent Referenced Design Specifications \_\_\_\_\_

III. Is Equipment Available for Inspection in the Plant? (X) Yes ( ) No

IV. Equipment Qualification Method:

( ) Test (X) Analysis ( ) Combination of Test  
and Analysis

Qualification Report\*: 1077.524, Seismic Category I Analysis of 20  
inch-900 lb. Carbon Steel Flex Wedge Gate Valves,  
3/28/78

(No., Title and Date) (DECo File No. Pl-11045)

Company that Prepared Report: Anamet Lab. Inc. for Anchor/Darling Valve Co.

Company that Reviewed Report: Hopper and Associates (HA-4/84-283)

V. Vibration Input

1. Loads considered: a. (X) Seismic only

b. ( ) Hydrodynamic only

c. ( ) Combination of (a) and (b)

2. Method of Combining RRS: ( ) Absolute Sum ( ) SRSS

( ) N/A

other, specify

3. Required Response Spectra (attach the graphs): N/A

4. Damping Corresponding to RRS: OBE \_\_\_\_\_ SSE \_\_\_\_\_ N/A

5. Required Acceleration in Each Direction: ( ) ZPA

(X) \_\_\_\_\_

other, specify

$S_{H1} = 4.5g$ ,  $S_{H2} = 4.5g$ ,  $S_V = 3.0g$   
 $S_{MAX} = 7.52g$ . Reference Page 8 of Report

6. Were fatigue effects or other vibration loads considered?

(X) Yes

( ) No

If yes, describe loads considered and how they were treated in  
overall qualification program: Valve Body is analyzed for the  
maximum combination of seismic, operating and pipe reaction loads.  
Reference page 34 of report.

\*NOTE: If more than one report complete items IV through VII for each report.

VI. If Qualification by Test then Complete\*: N/A

1. ( ) Single Frequency ( ) Multi-Frequency ( ) random  
 ( ) sine beat ( ) \_\_\_\_\_  
 other, specify

2. ( ) Single Axis ( ) Multi-Axis

3. No. of Qualification Tests: OBE \_\_\_\_\_ SSE \_\_\_\_\_  
 Other \_\_\_\_\_

4. Frequency Range: \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies \_\_\_\_\_

( ) Lab Test ( ) In-Situ Test ( ) Analysis

7. TRS enveloping RRS using Multi-Frequency Test ( ) Yes (Attach TRS & RRS Graphs)  
 ( ) No

8. Input g-level Test: OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_  
 SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

1. ( ) Bolt (No. \_\_, Size \_\_) ( ) Weld (Length \_\_) ( ) \_\_\_\_\_

10. Functional operability verified: ( ) Yes ( ) No ( ) Not Applicable

11. Test Results including modifications made: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including results): \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

\*NOTE: If qualification by a combination of test and analysis also complete Item VII.



**VII. If Qualification by Analysis, then Complete:**

**1. Method of Analysis:**

- Static Analysis                       Equivalent Static Analysis  
 Dynamic Analysis                       Time-History     Response Spectrum

**2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):** 79.52 HZ. Minimum. Reference page 59 of Report.

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

**3. Model Type:**  3D                       2D     1D  
 Finite Element  Beam  Closed Form Solution

**4.  Computer Codes:** \_\_\_\_\_

**Frequency Range and No. of modes considered:** \_\_\_\_\_

Hand Calculations

**5. Method of Combining Dynamic Responses:**  Absolute Sum     SRSS

Other: \_\_\_\_\_ N/A  
 (specify)

**6. Damping:** OBE - SSE - Basis for the damping used: \_\_\_\_\_ N/A

**7. Support Considerations in the model:** Hinged on both ends of valve body  
 (Page 58 of Report)

**8. Critical Structural Elements:** Valve Body and Bonnet

A. Identification	Location	Governing Load or Response Combination	Seismic	Total	Stress
			Stress	Stress	Allowable
			KSI	KSI	KSI
Valve Body	(Material SA216 WCB)			14.62	17.5
Bonnet	(Material SA105)			6.23	17.5

B. Max. Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
0.008"	Maximum Lateral Deflection of Operator	>0.008"

VIII. List of Subcomponents

<u>Name</u>	<u>Model No. - *Weight - *Location - If subcom- ponent was actually present</u>	<u>Was Component present or mass simulated?</u>	<u>Was subcomponent operability veri- fied (Y or N or U **)</u>
-------------	---	---	---

\* If Available

\*\* Yes = Yes, N = No, U = Unknown

IX. Sketch or drawing

How it has been installed


OR

How it will be installed

**ANAMET** LABORATORIES, INC.  
BERKELEY, CALIF. • SAN CARLOS, CALIF.

**ANAMET** LABORATORIES, INC.  
BERKELEY, CALIF. • SAN CARLOS, CALIF.

TABLE III-1  
COMPONENT WEIGHTS AND DIMENSIONS



Component Weights	
Operator ( $w_1$ , lbs.)	= 1200.0
Yoke & Stem ( $w_2$ , lbs.)	= 400.0
Bonnet ( $w_3$ , lbs.)	= 507.0
Valve Body ( $w_4$ , lbs.)	= 4250.0
Disc ( $w_5$ , lbs.)	= 512.0
Total Wts. ( $W_T$ , lbs.)	= 7549.0
Dimensions	
$y_1$ (in.)	= 70.00
$y_2$ (in.)	= 50.00
$y_3$ (in.)	= 30.00
$y_4$ (in.)	= 4.85
$y_5$ (in.)	= 30.00
$y_6$ (in.)	= 13.50
$y_7$ (in.)	= 62.70
$y_8$ (in.)	= 30.00
$x_1$ (in.)	= 25.00
$x_2$ (in.)	= 12.00
$x_3$ (in.)	= 0.00
$x_4$ (in.)	= 7.34
$x_5$ (in.)	= 0.00

Figure III-1 Schematic of Valve Assembly

Qualification Summary of Equipment

I. Plant Name: Enrico Fermi Atomic Power Plant - Unit 2 Type:

1. Utility: Detroit Edison Company PWR  
 2. NSSS: GE 3. A/E: DECo BWR X

II. Component Name Battery Charger Area Cooling Units

1. Scope: ( )NSSS (X)BOP  
 2. Model Number:  
 3. Vendor: CVI Inc.  
 4. If the component is a cabinet or panel, name and model No. of the devices included: (See Section VIII)

5. Preliminary Physical Description:  
 a. Appearance (See Section IX)

b. Dimensions T4100B043 66" x 48" x 36" High T4100B044 57" x 39" x 33" High

c. Weight 1050 lb. 850 lb.

6. Location: Building: Auxiliary  
Elevation: T4100B043 - 651'-0"+  
T4100B044 - 652'-0"+

7. Field Mounting Condition (X)Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)  
 Mounting bolts are used to anchor the platform to the ceiling.  
 ( )Weld (Length \_\_\_\_\_)  
 ( ) \_\_\_\_\_

8. a. System in which located: Battery Charger Area Ventilation

b. Functional Description

c. Is the equipment required for ( )Hot Standby ( )Cold Shutdown  
 (X)Both ( )Neither

9. Pertinent Referenced Design Specifications 3071-533 Rev. A

III. Is Equipment Available for Inspection in the Plant? ( ) Yes ( ) No

IV. Equipment Qualification Method:

( ) Test (X) Analysis ( ) Combination of Test and Analysis

Qualification Report\*: B9-2463, B9-2477, B9-2479, B9-2478 & B9-2476

(No., Title and Date) Response Spectrum Analysis of Fan/Coil Units  
No. T4100B043 and T4100B044

Company that Prepared Report: CVI Incorporated

Company that Reviewed Report: DECo

V. Vibration Input

- 1. Loads considered: a.(X) Seismic only
  - b.( ) Hydrodynamic only
  - c.( ) Combination of (a) and (b)

2. Method of Combining RRS:( ) Absolute Sum (X) SRSS  
( ) \_\_\_\_\_  
other, specify

3. Required Response Spectra (attach the graphs): Attached

4. Damping Corresponding to RRS: OBE .5% SSE 2%

5. Required Acceleration in Each Direction:( ) ZPA  
( ) \_\_\_\_\_  
other, specify

6. Were fatigue effects or other vibration loads considered?

( ) Yes (X) No

If yes, describe loads considered and how they were treated in overall qualification program: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\*NOTE: If more than one report complete items IV through VII for each report.

VI. If Qualification by Test then Complete\*:

1. ( ) Single Frequency ( ) Multi-Frequency ( ) random  
( ) sine beat ( ) \_\_\_\_\_  
other, specify

2. ( ) Single Axis ( ) Multi-Axis

3. No. of Qualification Tests: OBE \_\_\_\_\_ SSE \_\_\_\_\_  
Other \_\_\_\_\_

4. Frequency Range: \_\_\_\_\_

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies \_\_\_\_\_

( ) Lab Test ( ) In-Situ Test ( ) Analysis

7. TRS enveloping RRS using Multi-Frequency Test ( ) Yes (Attach TRS & RRS Graphs)  
( ) No

8. Input g-level Test: OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting:

1. ( ) Bolt (No. \_\_\_\_, Size \_\_\_\_ ) ( ) Weld (Length \_\_\_\_ ) ( ) \_\_\_\_\_

10. Functional operability verified: ( ) Yes ( ) No ( ) Not Applicable

11. Test Results including modifications made: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

12. Other tests performed (such as aging or fragility test, including results): \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\*NOTE: If qualification by a combination of test and analysis also complete Item VII.

VII. If Qualification by Analysis, then Complete:

1. Method of Analysis:

- Static Analysis                       Equivalent Static Analysis  
 Dynamic Analysis                       Time-History  Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = 13.3 HZ      F/B = 17.4 HZ      V = 23.7 HZ

3. Model Type:  3D                       2D       1D  
 Finite Element  Beam  Closed Form Solution

4.  Computer Codes: Stardyne

Frequency Range and No. of modes considered: 1-50 HZ      No. of modes = 13

Hand Calculations

5. Method of Combining Dynamic Responses:  Absolute Sum  SRSS

Other: \_\_\_\_\_  
 (specify)

6. Damping: OBE .5 SSE 2 Basis for the damping used: % of Critical Damping (REG. GUIDE 1.61) & FSAR

7. Support Considerations in the model: (HINGED)

8. Critical Structural Elements: Tombstone and Fan Housing

A. Identification	Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable	
Element 970 (Fan/Coil Unit No. T4100B043)	Tombstone	SRSS		6045 psi	13500	OBE
Element 970 (Fan/Coil Unit No. T4100B043)	Tombstone	SRSS		15033	18900	SSE

B. Max. Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
0.187 in. (Global X1 Direction) OBE	Bottom of Backplate Near outlet	
0.203 in. (Global X1 Direction) SSE	Bottom of Backplate Near outlet	

VIII. List of Subcomponents

<u>Name</u>	<u>Model No. - *Weight - *Location - If subcom- ponent was actually present</u>	<u>Was Component present or mass simulated?</u>	<u>Was subcomponent operability veri- fied (Y or N or U **)</u>
-------------	---	---	---

\* If Available

\*\* Yes = Yes, N = No, U = Unknown



SQRT FORM

IX. Sketch or drawing installed

How it has been installed

or


How it will be installed

(SEE ATTACHED SKETCH)

OUTLET

INLET

RAIN PIPE




FULL MODEL CONNECTING I/O AND DRAIN PIPES

FIGURE 4: Full Model w/Connection I/O And Drain Pipes

ENRICO FERMI UNIT 2  
ATTACHMENT TO SPECIFICATION 3071-337

Revision A  
Revision Date: May 1983

APPENDIX "C"



BOTTOM ELEVATION:  
R.I.S. N<sup>o</sup> T4100B043 650'-10"  
R.I.S. N<sup>o</sup> T4100B044 651'-10"

ARRANGEMENT OF CEILING  
SUSPENDED FAN COIL UNITS

Dynamic Seismic Re-evaluation of Fan/coil Unit  
 computed by: Rahim Falsafi

PREPARED BY: *R. Falsafi* 11/5/51  
 A. KROLIKOWSKI DATE  
 SYSTEM ENGR: *Y.O. / ASK* 11/11/51  
 V. SHANK DATE




FIGURE NO B-11

ACTUAL LOCATION SPECTRA  
 T4100B043 UNIT IS HUNG FROM 4TH  
 FLOOR AUX. BLDG. SLAB

ENRICO FERMI ATOMIC POWER PLANT  
 UNIT 2

HORIZONTAL FLOOR RESPONSE SPECTRA  
 OPERATING BASIS EARTHQUAKE ELEVATION -  
 850'-0" (SLAB NO. 4) REACTOR/AUXILIARY  
 BUILDING NORTH - SOUTH COMPONENT

BARGENT & LUNDY REPORT NO. BL-2882




FIGURE NO B-12

ACTUAL LOCATION  
 SPECTRA  
 FOR T4100B043 UNIT

ENRICO FERMI ATOMIC POWER PLANT  
 UNIT 2

HORIZONTAL FLOOR RESPONSE SPECTRA  
 OPERATING BASIS EARTHQUAKE  
 ELEVATION - 659'-0" (SLAB NO. 4) REACTOR/  
 AUXILIARY BUILDING EAST-WEST COMPONENT




FIGURE NO C-8

ACTUAL LOCATION  
 SPECTRA  
 FOR T4100B043 UNIT

ENRICO FERMI ATOMIC POWER PLANT  
 UNIT 2.

VERTICAL RESPONSE SPECTRA OPERATING  
 BASIS EARTHQUAKE AUXILIARY BUILDING  
 SLAB EL. 583'-6", 613'-6" & 659'-6"


# UNIT 2

SYSTEM ENGR. *Y. Anand* ..... *4/4* .....  
Y. ANAND DATE

## SITE SPECIFIC EARTHQUAKE 5% SITE DAMPING

Computed by: Rahim Falsafi

Page 17 of 29



Actual Location Spectra  
For T4100B043 Unit  
FIGURE NO.

REACTOR AUXILLARY BUILDING: RESPONSE SPECTRUM

SPECTRUM	NODE	ELEV	DIRECT	LOCATION	SLAB
SE5-B-35	4	659-0	NS	REA-AUX BLDG	SLAB 4

**SE5-B-35**

# UNIT 2


SYSTEM ENGR: *ya/ak*

DATE: *4/11/82*  
*G. ANAND*

## SITE SPECIFIC EARTHQUAKE 5% SITE DAMPING

Computed by: *Rahim Falsafi*

Page 18 of 29



Actual Location Spectra  
 For T4100B043 Unit

REACTOR AUXILLARY BUILDING: RESPONSE SPECTRUM

FIGURE NO.

SPECTRUM	NODE	ELEV	DIRECT	LOCATION	SLAB
SE5-B-36	4	659-0	EW	REA-AUX BLDG	4

**SE5-B-36**


# ENRICO FERMI UNIT 2

A. KROLIKOWSKI DATE  
 SYSTEM ENGR: *Y. Anand* DATE *2/14/81*  
 Y. ANAND DATE

## SITE SPECIFIC EARTHQUAKE 5% SITE DAMPING

Page 19 of 29

Computed by: *Rahim Falsafi*



Actual Location Spectra

REACTOR-AUXILLIARY BUILDING: RESPONSE SPECTRUM For T4100 B043 Unit

SPECTRUM	NODE	ELEV	DIRECT	LOCATION	FIGURE NO.
SES-C-18		583-6 613-6 650-6	VERT	AUXILLIARY BUILDING SLAB	SE5-C-18



Qualification Summary of Equipment

I. Plant Name: Enrico Fermi Atomic Power Plant - Unit 2 Type:

1. Utility: Detroit Edison Company PWR  
 2. NSSS: GE 3. A/E: DECo BWR X

II. Component Name Various pneumatic control devices. See Attachment 'A'

1. Scope: ( ) NSSS (X) BOP

2. Model Number: See Attachment 'A'

3. Vendor: See Attachment 'A'

4. If the component is a cabinet or panel, name and model No. of the devices included: (See Section VIII)

5. Physical Description

a. Appearance (See Section IX)

b. Dimensions See Attachment 'A'

c. Weight See Attachment 'A'

6. Location: Building: Auxiliary Building

Elevation: 577'-6"

7. Field Mounting Condition ( ) Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)  
 ( ) Weld (Length \_\_\_\_\_)  
 ( ) \_\_\_\_\_ See Attachment 'A'

8. a. System in which located: T41-02

b. Functional Description Pneumatic controls for operation of damper and its air seal

c. Is the equipment required for ( ) Hot Standby ( ) Cold Shutdown  
 (X) Both ( ) Neither

9. Pertinent Referenced Design Specifications IEEE 344-1975 and

DECo 3071-296

III. Is Equipment Available for Inspection in the Plant? (X) Yes ( ) No

IV. Equipment Qualification Method:

- (X) Test
- ( ) Analysis
- ( ) Combination of Test and Analysis

Qualification Report\*: 10258, Rev. 0, Seismic Qualification Report on Twelve pneumatic control devices, November 5, 1984  
(No., Title and Date)

Company that Prepared Report: Farwell and Hendricks, Inc.

Company that Reviewed Report: DECo

V. Vibration Input

- 1. Loads considered: a. (X) Seismic only
- b. ( ) Hydrodynamic only
- c. ( ) Combination of (a) and (b)

2. Method of Combining RRS: ( ) Absolute Sum ( ) SRSS  
( ) N/A  
other, specify

3. Required Response Spectra (attach the graphs): Attachment C and D

4. Damping Corresponding to RRS: OBE 5% SSE 5%

5. Required Acceleration in Each Direction: ( ) ZPA  
(X) 5.0 G for SSE ZPA  
other, specify

6. Were fatigue effects or other vibration loads considered?

- (X) Yes
- ( ) No

If yes, describe loads considered and how they were treated in overall qualification program: Operational cycling (1500 cycles) with monitoring.

\*NOTE: If more than one report complete items IV through VII for each report.

**VI. If Qualification by Test then Complete\*:**

1.  Single Frequency  Multi-Frequency  random  
 sine burst  \_\_\_\_\_  
 other, specify \_\_\_\_\_

2.  Single Axis  Multi-Axis

3. No. of Qualification Tests: OBE 5 SSE 1  
 Other \_\_\_\_\_

4. Frequency Range: 1 to 50 HZ

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): Not required for the test program

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

6. Method of Determining Natural Frequencies N/A

Lab Test  In-Situ Test  Analysis

7. TRS enveloping RRS using Multi-Frequency Test  Yes (Attach TRS & RRS Graphs)  
 Attachment 'C' and 'D'  No

8. Input g-level Test: OBE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = N/A

SSE S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

9. Laboratory Mounting: See Attachment 'B'

1.  Bolt (No. \_\_\_\_\_, Size \_\_\_\_\_)  Weld (Length \_\_\_\_\_)  \_\_\_\_\_

10. Functional operability verified:  Yes  No  Not Applicable

11. Test Results including modifications made: Satisfactory.

12. Other tests performed (such as aging or fragility test, including results): Baseline functional, operational cycling prior to seismic test, operational cycling after seismic test, post seismic functional.

\*NOTE: If qualification by a combination of test and analysis also complete Item VII.

VII. If Qualification by Analysis, then Complete: N/A

1. Method of Analysis:

- Static Analysis                       Equivalent Static Analysis
- Dynamic Analysis                       Time-History    Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = \_\_\_\_\_ F/B = \_\_\_\_\_ V = \_\_\_\_\_

3. Model Type:  3D                       2D    1D  
 Finite Element  Beam  Closed Form Solution

4.  Computer Codes: \_\_\_\_\_

Frequency Range and No. of modes considered: \_\_\_\_\_

- Hand Calculations

5. Method of Combining Dynamic Responses:  Absolute Sum    SRSS

Other: \_\_\_\_\_  
(specify)

6. Damping: OBE - SSE - Basis for the damping used: \_\_\_\_\_

7. Support Considerations in the model: \_\_\_\_\_

8. Critical Structural Elements: \_\_\_\_\_

A. Identification	Location	Governing Load			
		or Response Combination	Seismic Stress	Total Stress	Stress Allowable

B. Max. Critical Deflection	Location	Maximum Allowable Deflection to	
		Assure Functional Operability	

VIII. List of Subcomponents

<u>Name</u>	<u>Model No. - *Weight - *Location - If subcom- ponent was actually present</u>	<u>Was Component present or mass simulated?</u>	<u>Was subcomponent operability veri- fied (Y or N or U **)</u>
-------------	---	---	---

\* If Available

\*\* Yes = Yes, N = No, U = Unknown

ATTACHMENT 'A'  
to SQR Form #65

COMPONENT	VENDOR MODEL	DIMENSION INCH (APPROXIMATE)	WT LBS. (APPROX)	FIELD MOUNTING
1. Check Valve	Parker Hannifin C-400-B-10	0.81 x 0.81 x 2.62 long.	0.4	In line, Brass Fittings to 1/4" Soft Copper
2. Filter Regulator	Fisher Controls Co. 67F-203 (in- stalled) 67AF-237 (tested)	3.19 x 3.19 x 9.0 Ht. 3.19 x 3.19 x 7.94 Ht.	1.5	(2) 5/16" dia. bolts;
3. 3-Way Switching Valve (3-15PSIG) & (40-100PSIG)	Fisher Controls Co. 164A	4.12 dia. x 9.19 ht.	4.0	L shaped bracket
4. Pressure Gauge (0-60PSIG) 1-1/2" dia.	Fisher Controls Co. J512	2.0 dia.		Brass tee to 1/4" soft copper
5. Actuator	G.H. Bettis CB-525-SR CB-725-SR	8-3/4 dia. x 27-11/16 lg. 8-3/4 dia. x 27-3/4 lg.	60.0 92.0	(4) 7/16"-14THD bolts
6. 3-Way Valve Manual with- out lugs	WABCO 2MA-1A and 2CA-1A (without roller)	2-1/2 w x 2-7/16 ht x 1-1/2 th.	0.5	(2) 1/4" thru bolts

TABLE 1.1


## DESCRIPTION OF TEST SPECIMEN(S) AND MOUNTING

Test Specimen I.D.	Device	Mounting	Orientation
CV-1	Parker Hannifin Check Valve C-400-8-10	In Line Connection - Brass Fittings to 1/4" Soft Copper	Horizontal
CV-2	Same as CV-1	In Line Connection - Brass Fittings to 1/4" Soft Copper	Vertical
PVC-1	Fisher 67AF-237 Filter Regulator	2-5/16" Diameter Bolts - Side of Regulator to Fixture	Horizontal
PCV-2	Same as PCV-1	2-5/16" Diameter Bolts - Side of Regulator to Fixture	Vertical
SWV-1	Fisher 164A-47(40-100 psig Spring Range) 3 Way Switching Valve	L-Shaped Bracket (Supplied with Unit) to Fixture	Horizontal
SWV-2	Fisher 164A-17 (3-15 psig Spring) 3 Way Switching Valve	L-Shaped Bracket (Supplied with Unit) to Fixture	Vertical
PI-2	Fisher J512 Pressure Gauge 0-60 psig 1 1/2" Dia. Back Mounted	Connect to Stainless Steel Tee Stainless Steel Tee 1/4" Soft Copper	Horizontal
PI-4	Fisher J512 Pressure Gauge 0-60 psig 1 1/2" Dia. Back Mounted	Connect to Stainless Steel Tee Stainless Steel Tee to 1/4" Soft Copper	Vertical
ACT-1	Bettis CB-725-SR-80 Actuator	Bolt to Fixture with 4-1/2"-13 THD. SAE Grade 5 Bolts	Vertical
ACT-2	Bettis CB-525-SR-80 Actuator	Bolt to Fixture with 4-7/16" 14 THD SAE Grade 5 Bolts	Horizontal
*SWV-3	WABCO 2 CA-1A(P58721) Manual 3 Way Valve with CAM Roller Removed	2-1/4" Thru Bolts to Fixture	Vertical
*SWV-4	WABCO 2 MA-1A(P58719)	2-1/4" Thru Bolts to Fixture	Horizontal

\* Functionally the same: Refer to Appendix D, the P58719 is functionally the same as the P58718 but is supplied with lugs for various operating kits. The P58721 is a P58719 supplied with a two-director cam roller operator kit.

Test items were purchased by Farwell & Hendricks, Inc. as commercial grade components.

Model numbers are corrected from list provided by Detroit Edison and verified with Larry Raisanen on 10-15-84.



	A	D	E	G
OBE #1	.63 g's 1 Hz	6.25 g's 4 Hz	6.25 g's 16 Hz	2.5 g's 33 Hz
OBE #2 - #5 will be increased to the following approximate flat.				


Portion (D-E) Levels

OBE #2	7.50 g's			
OBE #3	8.75 g's			
OBE #4	10.00 g's			
OBE #5	11.25 g's			
SSE	1.25 g's 1 Hz	12.5 g's 4 Hz	12.5 g's 16 Hz	5.0 g's 33 Hz

REQUIRED RESPONSE SPECTRA



CHANNEL - A ZPA= 4.00 Gpk



01-NOV-84  
12:14:40  
?

SHOCK RESPONSE  
10258 D.E. 2ND 50%OBE @ Y,Z 5.0 % Damp Abs Acc  
1/3 Octave Maxi-Max

Free	Ampl	Free	Ampl	Free	Ampl
0.63	0.11	3.16	5.23	15.85	6.53
0.79	0.25	3.98	8.94	19.95	5.69
1.00	0.60	5.01	8.32	25.12	5.27
1.26	1.01	6.31	7.87	31.62	5.00
1.58	1.62	7.94	8.04	39.81	4.27
2.00	2.27	10.00	7.86	50.12	4.18
2.51	3.19	12.59	7.50		

FIGURE 6.2

TEST RESPONSE SPECTRA

**IX. Sketch or drawing installed**

How it has been installed

or

How it will be installed

Parker Hannifin Corporation  
Hydraulic Valve Division  
520 Ternes Avenue  
Elyria, Ohio 44035  
Phone: (216) 322-4631


# Manatrol Control Valves

Catalog 3000-2 884 10M AP

## Check Valves Series C and CS


Dimensions  
Check Valve,  
Inline-mounted

Models C200 through C3200



Subplate-mounted Series CS  
check valve

Inline-mounted Series C  
check valve



Model Number	Part Size, inches A	Dimensions, inch (mm)		Weight Lb. (Kg)
		B	D	
C200	1/8-27 NPTF	0.62 (15.7)	2.00 (50.8)	0.1 (0.05)
C400	1/4-18 NPTF	0.81 (20.6)	2.62 (66.5)	0.4 (0.2)
C620	9/16-18 UNF 2B (SAE 6)	0.86 (22.3)	3.12 (79.2)	0.5 (0.2)
C670	3/8-18 NPTF	1.00 (25.4)	2.75 (69.9)	0.5 (0.2)
C820	3/4-16 UNF 2B (SAE 8)	1.12 (28.4)	3.50 (88.9)	1.3 (0.6)
C800	1/2-14 NPTF	1.25 (31.8)	3.44 (87.4)	1.3 (0.6)
C1020	7/8-14 UNF 2B (SAE 10)	1.25 (31.8)	4.00 (101.6)	2.0 (0.9)
C1200	3/4-14 NPTF	1.50 (38.1)	3.86 (98.6)	2.0 (0.9)
C1220	1-1/16-12 UNF 2B (SAE 12)	1.50 (38.1)	4.62 (117.3)	2.0 (0.9)
C1420	1-3/16-12 UN (SAE 14)	2.00 (50.8)	5.00 (127.0)	3.3 (1.5)
C1800	1-11-1/2 NPTF	1.75 (44.5)	5.00 (127.0)	3.3 (1.5)
C1620	1-5/16-12 UN (SAE 16)	2.25 (57.2)	5.62 (142.7)	3.3 (1.5)
C2000	1-1/4-11-1/2 NPTF	2.25 (57.2)	5.62 (142.7)	6.2 (2.9)
C2020	1-5/8-12 UN (SAE 20)	2.75 (69.9)	6.50 (165.1)	6.2 (2.9)
C2400	1-1/2-11-12 NPTF	2.75 (69.9)	5.62 (142.7)	8.4 (3.9)
C2420	1-7/8-12 UN (SAE 24)	3.00 (76.2)	7.25 (184.2)	8.4 (3.9)
C3200	2-11-1/2 NPTF	3.50 (83.7)	6.50 (165.1)	15.4 (7.1)
C3220	2-1/2-12 UN (SAE 32)	4.00 (101.6)	9.00 (228.6)	15.4 (7.1)

IX. Sketch or drawing installed

How it has been installed




67 Series Small-Volume Pressure Regulators

November 1973 | Bulletin 71.1.6

Old Catalog Number C-67

Specifications	
AVAILABLE CONFIGURATIONS	See table 1 for type number variations and construction features available with each type
BODY SIZE AND END CONNECTION STYLE	1/4" 18 Dryseal NPTF screwed pipe threads
ALUMINUM INLET PRESSURE	Types 67H, 67HR, 67S, 67U, and 67UR: 400 psig All Other Types: 250 psig
ALUMINUM OUTLET PRESSURE	Types 67FY, 67FYR, 67Y, and 67YR: 20 psig All Other Types: 100 psig
INLET SET POINTS OR PRESSURE RANGES	See table 2
PRESSURE REGISTRATION	Internal
CONSTRUCTION MATERIALS	Only materials common to most or all types are shown below; see table 3 for additional materials for individual types Body Plug Gasket (Band/Filter Type Only): Asbestos Regulator Spring Seat: Zinc-plated steel Regulator Spring: See table 2 Valve Stem: Brass or stainless steel Valve Plug One-Piece Construction: Same material as valve stem Band/Filter Construction: Standard composition material or Viton <sup>®</sup> bonded to valve stem
TEMPERATURE CAPABILITIES	-20°F to +150°F
FLOW CAPABILITIES	See table 4 and figure 6
FLOW COEFFICIENTS	Regulating C <sub>v</sub> : 6.2 Wide-Open C <sub>v</sub> (w/ Relief Valve Setting): 8.5 Representative C <sub>v</sub> : 30.4 Maximum C <sub>v</sub> : 0.28
BORE DIAMETER	0.125"
FILTER CAPABILITIES	Free Area: 12 times pipe area Micron Rating Brass and Stainless Steel: 50μ Cellulose: 40μ
OPTIONAL PRESSURE GAUGES	See table 5
SPRING CASE VENT	Standard: 1/8" drilled hole Optional: 1/4" 18 Dryseal NPTF tapped connection



NOTE:

Model 67F-203 has been installed. However, this model is now discontinued by the manufacturer. Model 67AF has been tested for similarity. Besides Model 67FR-224 was previously qualified per MCC Powers Report No. 44870-1, December 17, 1979, DECo File No. B9-2455 as part of a Control Relay panel with components. See Page 6 B.




Figure 8. Bottom Dimensions Common Only to Those 67 Series Regulators with Filters

Figure 10. Dimensions for Types 67F and 67FR

IX. Sketch or drawing installed

Fisher Controls

**67 Series Small-Volume Pressure Regulators**

How it has been installed

September 1980

Bulletin 71.1:6

**Specifications**

<b>AVAILABLE CONFIGURATIONS</b>	See table 1 for type numbers and available configurations. Also, see "Construction Features."	<b>MATERIAL TEMPERATURE CAPABILITIES</b>	With Nitro Diaphragm: -20 to 150°F (-28 to 66°C) With Viton Diaphragm: 0 to 300°F (-18 to 149°C)
<b>BODY SIZE AND END CONNECTION STYLE</b>	1/8 in. NPT screwed	<b>PRESSURE SETTING ADJUSTMENT</b>	Type 67AFY, 67AFYR, 67Y, and 67YR Regulators: Not adjustable All Other Types: Adjustable throughout each spring range by turning setscrew; see handle, hand-wheel, or cap on calibrated spring case
<b>MAXIMUM ALLOWABLE INLET PRESSURE</b>	Types 67H, 67HR, 67S, 67U, and 67UR: 400 psig (27.2 bar) All Other Types: 250 psig (17.2 bar)	<b>PRESSURE REGISTRATION</b>	Internal
<b>OUTLET PRESSURE RANGES</b>	See table 2	<b>SPRING CASE VENT</b>	1/8 in. (3.2 mm) drilled hole
<b>MAXIMUM OPERATING OUTLET PRESSURE</b>	Types 67AFY, 67AFYR, 67Y, and 67YR: 30 psig (1.4 bar) All Other Types: 100 psig (6.9 bar)	<b>FILTER CAPABILITIES</b>	Free Area: 12 times pipe area Micron Rating: 40 µ
<b>MAXIMUM PRESSURE DROP OUTLET PRESSURE</b>	50 psi (3.4 bar) over outlet pressure setting, or 110 psig (7.6 bar), whichever is greater	<b>APPROXIMATE WEIGHT</b>	Up to 1-1/2 lb (0.7 kg) depending on configuration
<b>PORT DIAMETER</b>	1/8 in. (3.2 mm)	<b>OPTIONS</b>	■ See table 1 ■ Pressure gauges are available for regulators with second tapped outlet. Information on the gauges is provided in a separate bulletin.
<b>FLOW CAPACITIES</b>	See table 4		
<b>RELIEF RATING COEFFICIENTS</b>	Wide-Open C <sub>v</sub> : 8.5 Representative C <sub>v</sub> : 30.4 Maximum C <sub>v</sub> : 0.28		
<b>CONSTRUCTION MATERIALS</b>	See table 3		



TYPE 67AF OR TYPE 67AFR WITH FILTER AND OUTLET PRESSURE GAUGE

**Construction Features**

All standard and optional constructions available in the 67 Series regulators are shown in table 1 which cross-references type numbers and construction features.

The 67 Series regulators with fitting action employ two ways of retaining the filter. A regulator type number that includes the letters "AF" indicates that the filter cap retains the filter. A regulator type number that includes the letter "F" and not the letter "A" indicates that the filter post retains the filter. The performance and specifications are the same regardless of how the filter is retained. The same amount of moisture, or other impurities from the process fluid, can be contained in the filter cap regardless of the way the filter is retained. In addition, the recommended spare parts are interchangeable from a regulator with one filter retention method to a regulator with the other. For a regulator with fitting action, the filter retention method supplied depends on the location at which that regulator was manufactured.



Some standard construction features designated by a letter suffix in the type number are described in the following paragraphs.

**Internal Relief**

An internal relief valve (indicated by "R" in the type number as shown in table 1) increases controllability in low-flow situations. Although not designed to provide full over-pressure protection, the 67 Series internal relief valve (figures 2, 3, 4, and 5) will allow partial reduction of downstream pressure without the necessity of an external relief valve being opened.

**Filtering Action**

A filter (indicated by "F" in the type number as shown in table 1) of either stainless steel or resin-impregnated cellulose is available with the 67 Series regulators. The filter has a free area of 12 times the pipe area.



TYPE 67AF (OPTIONAL)

TYPE 67AFR (OPTIONAL)

NOTE: PERFORMANCE AND SPECIFICATIONS OF THE REGULATORS ARE IDENTICAL.





Fig. 2. Sectional Views of Filter Regulators Showing Details of Filter Retention and Internal Relief!

NOTE:

Model 67AF-237 has been tested to qualify the installed Model 67F-203 by similarity. 67F series has been discontinued by the manufacturer.

IX. Sketch or drawing installed

How it has been installed



① DIMENSION SHOWN IS FOR TYPE 164A SWITCHING VALVE FOR TYPE 164 SWITCHING VALVE THIS DIMENSION IS 3.28 INCHES (83 mm)  
 ② 1.59 INCHES (40 mm) FOR TYPE 164 SWITCHING VALVE

INCH (mm)

Figure 4. Dimensions

Specifications

<b>AVAILABLE CONFIGURATIONS</b>	Type 164. Two-way switching valve Type 164A. Three-way switching valve	<b>CONNECTIONS</b>	Type 164. Ports A and C— $\text{1/4}$ -inch NPT or $\text{1/2}$ -inch NPT. Vent and control pressure connection (Port D)— $\text{1/4}$ -inch NPT Type 164A. Ports A, B, and C— $\text{1/4}$ -inch NPT or $\text{1/2}$ -inch NPT. Vent and control pressure connection (Port D)— $\text{1/4}$ -inch NPT														
<b>MAXIMUM VALVE INLET PRESSURE</b>	350 psig (12.3 bar)	<b>CONSTRUCTION MATERIALS</b>	<table border="1"> <thead> <tr> <th>Part</th> <th>Material</th> </tr> </thead> <tbody> <tr> <td>Spring Case</td> <td>St. Aluminum or St. Cast iron (Accepts optional closing stop)</td> </tr> <tr> <td>Valve Body</td> <td>Aluminum</td> </tr> <tr> <td>Valve Disc</td> <td>Brass and synthetic rubber</td> </tr> <tr> <td>Stem/rod and O-rings</td> <td>Stainless</td> </tr> <tr> <td>Spring</td> <td>Steel</td> </tr> <tr> <td>Closing Cap (Optional)</td> <td>Steel</td> </tr> </tbody> </table>	Part	Material	Spring Case	St. Aluminum or St. Cast iron (Accepts optional closing stop)	Valve Body	Aluminum	Valve Disc	Brass and synthetic rubber	Stem/rod and O-rings	Stainless	Spring	Steel	Closing Cap (Optional)	Steel
Part	Material																
Spring Case	St. Aluminum or St. Cast iron (Accepts optional closing stop)																
Valve Body	Aluminum																
Valve Disc	Brass and synthetic rubber																
Stem/rod and O-rings	Stainless																
Spring	Steel																
Closing Cap (Optional)	Steel																
<b>ACTUATOR PRESSURE RANGE</b>	See table 1	<b>APPROXIMATE WEIGHT</b>	4 lbs (1.8 kg)														
<b>MAXIMUM OPERATING PRESSURE RANGE</b>	100 psig (6.9 bar)	<b>OPTIONS</b>	Closing stop														
<b>OPERATIVE TEMPERATURE LIMITS*</b>	-30 to 150°F (-28 to 66°C)																
<b>FLOW COEFFICIENTS (Cv)</b>	Depends on construction and flow path (see figure 2) as follows: Type 164. 28.5 (Port A to Port C) Type 164A. 15.0 (Port A to Port B) or 26.5 (Port A to Port C)																

**IX. Sketch or drawing installed**

How it has been installed

or

How it will be installed



**Fisher Gauges**

December 1972 | Bulletin 71.8:50

Old Catalog Number PI-50

*FINISH SPECIFICATION  
3071-246-NR-MS SHEET 12 OF 15*

**Series J500 Gauges**

Series J500 to J508 and J510 to J519 gauges are furnished in 2" diameter, black steel case. The Type J509 gauge is supplied in 2 1/2" diameter, black steel case. All types are furnished with 1/4" NPT connections and with black letters on a white background. The following tables give the connection locations and the pressure ranges available.

**Bottom Connection**

Type	Part Number	Calibration-Range
J500	1.8780 99012	0 to 15
J501	1.8781 99012	0 to 30
J502	1.8782 99012	0 to 60
J503	1.8783 99012	0 to 100
J504	1.8784 99012	0 to 150
J505	1.8785 99012	0 to 200
J506	1.8786 99012	0 to 300
J507	1.8787 99012	0 to 500
J508	1.8788 99012	0 to 1000
J509	1.8789 99012	0 to 2000

**Back Connection**

Type	Part Number	Calibration-Range
J510	1.8757 99012	0 to 15
J511	1.8940 99012	0 to 30
J512	1.8752 99012	0 to 60
J513	1.8753 99012	0 to 100
J514	1.8754 99012	0 to 150
J515	1.8755 99012	0 to 200
J516	1.8755 99012	0 to 300
Type	Part Number	Special Calibration-Range, Cn
J518	1.8758 99012	0 to 2
J519	1.8759 99012	0 to 4




Figure 3. Type J500 Gauge Calibrated 0 to 15 Psi With Bottom Connection





Figure 4. Type J510 Gauge With Back Connector



NOTE: ALL FITTINGS ARE STAINLESS STEEL

FIGURE 5 - FISHER J512 MOUNT

**IX. Sketch or drawing installed**


How it has been installed

or


How it will be installed

**GIBETTIS**  
A GIBETTIS COMPANY

**CB-Series:  
Pneumatic Actuators** Catalog #20.00-1A



**Dimensions**



Actuator Model	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	Y	Z
CB 312	120	4 1/2																								
CB 315 SR	20 1/2	4 1/2	2 1/2	1 1/2	3 1/2	1 1/2	2 1/2	1 1/2	3 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2
CB 415	13 1/2	4 1/2																								
CB 415 SR	20 1/2	4 1/2	2 1/2	1 1/2	3 1/2	1 1/2	2 1/2	1 1/2	3 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	
CB 425	17 1/2	5 1/2																								
CB 425 SR	24 1/2	5 1/2	2 1/2	1 1/2	3 1/2	1 1/2	2 1/2	1 1/2	3 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	
CB 525	18 1/2	5 1/2																								
CB 525 SR	27 1/2	5 1/2	2 1/2	1 1/2	3 1/2	1 1/2	2 1/2	1 1/2	3 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	
CB 725	18 1/2	6 1/2																								
CB 725 SR	27 1/2	6 1/2	2 1/2	1 1/2	3 1/2	1 1/2	2 1/2	1 1/2	3 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	1 1/2	

All dimensions are in inches. Contact Gibettis for drawings and details. Contact Gibettis for correct model designation and stock number.

**Spring-Return Actuators**

Actuator Model	Displacement per Stroke		Actuator Spring Size				Max Allowable Operating Pressure** (psig)	Approximate Weight (lbs)
			40	60	80	100		
	in <sup>3</sup>	ft <sup>3</sup>	Max Operating Pressure* (psig)					
CB 315 SR	41	0.24	90	100	115	130	160	25
CB 415 SR	41	0.24	90	100	115	130	160	25
CB 525 SR	76	0.44	100	110	125	135	160	42
CB 725 SR	190	1.10	95	105	120	135	160	92

IX. Sketch or drawing installed

How it has been installed

OR

How it will be installed

**WABCO BLOCK-TYPE VALVES**


**OPERATION**

In release position, as shown, the valve disc seats on the inlet valve seat and seals the passage from the inlet to the outlet port. The outlet port is vented to atmosphere through the center of the plunger. As the plunger is forced downward by an external force, it seats on the valve disc. This seals the passage between the outlet port and atmosphere.


Further downward travel of the plunger unseats the valve disc from the inlet valve seat and allows inlet air pressure to flow to the outlet port.

Release of the external force releases the plunger and valve and plunger return to the original position.

Install the valve to ensure operation within the travel limits shown on the outline drawings. Travel beyond these limits can cause damage to the valve.




**2-MA-1A PILOTAIR VALVE, NORMALLY CLOSED**



The 2-MA-1A PILOTAIR VALVE is a mechanically (straight push) operated, 3-way directional valve with a variety of mounting styles. The outlet port is exhausted in release position. This valve is the basic valve shown below, without legs.

WT. = 1/2 LB. (APPROX.)



**ORDERING REFERENCE**

2MA1A PILOTAIR Valve (Lins Legs) for direct push operation.  
Flare Number P2226

**WABCO**  
fluid power



II. Sketch or drawing installed


How it has been installed

OR



**WABCO BLOCK-TYPE VALVES**

SWU-3

2-CA-1A PILOTAIR VALVE WITH TWO-DIRECTION CAM ROLLER, NORMALLY CLOSED



The Two-Direction Cam Roller Operator Kit assembled to the 2-MA-1A PILOTAIR Valve is designated the 2-CA-1A PILOTAIR Valve with Two-Direction Cam Roller.



Model 2-CA-1A is same as Model 2-MA-1A except for the additional cam roller, which was removed for the test.

ORDERING REFERENCE

2-CA-1A PILOTAIR Valve, with Two-Direction Cam Roller complete.

Part Number FM271

CAM ROLLER OPERATOR KIT

Contains a cam lever, a roller, two roll pins and 7 washers.

Part Number FM274

**WABCO**  
fluid power