



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUQUESNE LIGHT COMPANY

OHIO EDISON COMPANY

PENNSYLVANIA POWER COMPANY

DOCKET NO. 50-334

BEAVER VALLEY POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No.82
License No. DPR-66

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Duquesne Light Company, Ohio Edison Company, and Pennsylvania Power Company (the licensees) dated July 14, 1983 and May 7, 1984 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-66 is hereby amended to read as follows:


8411280262 841108
PDR ADOCK 05000334
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 82, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This amendment is effective on issuance, to be implemented no later than 30 days after issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance:

November 8, 1984

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 82 TO FACILITY OPERATING LICENSE NO. DPR-66

DOCKET NO. 50-334

Revise Appendix A as follows:

Remove Pages

Insert Pages

3/4 6-5

3/4 6-5

• --

3/4 6-5a

3/4 6-10

3/4 6-10

CONTAINMENT SYSTEMS

CONTAINMENT AIR LOCKS

LIMITING CONDITION FOR OPERATION

- 3.6.1.3 Each containment air lock shall be OPERABLE with:
- a. Both doors closed except when the air lock is being used for normal transit entry and exit through the containment, then at least one air lock door shall be closed, and
 - b. An overall air lock leakage rate of less than or equal to $0.05 L_a$ at P_a (38.3 psig).

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

- a. With one containment air lock door inoperable:
 1. Maintain the associated OPERABLE air lock door closed and either restore the associated inoperable air lock door to OPERABLE status within 24 hours or lock the associated OPERABLE air lock door closed.
 2. Operation may then continue until performance of the next required overall air lock leakage test provided that the associated OPERABLE air lock door is verified to be locked closed at least once per 31 days.
 3. Otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
 4. The provisions of Specification 3.0.4 are not applicable.
- b. With a containment air lock inoperable, except as the result of an inoperable air lock door, maintain at least one air lock door closed; restore the inoperable air lock to OPERABLE status within 24 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS

- 4.6.1.3 Each containment air lock shall be demonstrated OPERABLE:
- a. Within 72 hours following each containment entry, except when the air lock is being used for multiple entries, then at least once per 72 hours, by verifying no detectable seal leakage when the gap between the door seals is pressurized for at least 2 minutes to:
 1. Personnel airlock ≥ 38.3 psig
 2. Emergency air lock ≥ 10.0 psigor, by quantifying the total air lock leakage to insure the requirements of 3.6.1.3.b are met.
 - b. At least once per 6 months by conducting an overall air lock leakage test at P₀ (38.3 psig) and by verifying that the overall air lock leakage rate is within its limit, and
 1. Only one door in each air lock can be opened at a time, and
 2. No detectable seal leakage when the volume between the emergency air lock shaft seals is pressurized to greater than or equal to 38.3 psig for at least 2 minutes.
 - c. At least once per 18 months during shutdown by verifying:
 1. Only one door in each air lock can be opened at a time, and
 2. No detectable seal leakage when the volume between the emergency air lock shaft seals is pressurized to greater than or equal to 38.3 psig for at least 2 minutes.

* The provisions of Specification 4.0.2 are not applicable.

CONTAINMENT SYSTEMS

CONTAINMENT STRUCTURAL INTEGRITY

LIMITING CONDITIONS FOR OPERATION

3.6.1.6 The structural integrity of the containment shall be maintained at a level consistent with the acceptance criteria in Specification 4.6.1.6.1.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With the structural integrity of the containment not conforming to the above requirements, restore the structural integrity to within the limits prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

4.6.1.6.1 Liner Plate and Concrete The structural integrity of the containment liner plate and concrete shall be determined during the shutdown for each Type A containment leakage rate test (reference Specification 4.6.1.2) by:

- a. a visual inspection of the accessible surfaces and verifying no apparent changes in appearance or other abnormal degradation.
- b. a visual inspection of accessible containment liner test channels prior to each Type A containment leakage rate test. Any containment liner test channel which is found to be damaged to the extent that channel integrity is impaired or which is discovered with a vent plug removed, shall be removed and a protective coating shall be applied to the liner in that area.
- c. a visual inspection of the dome area prior to each Type A containment leakage rate test to insure the integrity of the protective coating. If a loss of integrity of the protective coating is observed, any vent plug to a test channel which may be in the area where the protective coating has failed shall be seal welded and then the protective coating shall be repaired.

4.6.1.6.2 Reports An initial report of any abnormal degradation of the containment structure detected during the above required tests and inspections shall be made within 10 days after completion of the surveillance requirements of this specification, and the detailed report shall be submitted pursuant to Specification 6.9.1 within 90 days after completion. This report shall include a description of the condition of the liner plate and concrete, the inspection procedure, the tolerances on cracking and the corrective actions taken.